



Log # TXX-93173
File # 10130
IR-93-08

William J. Cahill, Jr.
Group Vice President

April 15, 1993

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
SUPPLEMENT INFORMATION TO NRC
INSPECTION REPORT NO. 50-445/93-08; 50-446/93-08

REF: TU Electric letter logged TXX-93135 from
Mr. William J. Cahill, Jr. to the USNRC
dated March 24, 1993

Gentlemen:

During a telephone conversation on April 5, 1993, with your Region IV staff, TU Electric agreed to supplement and clarify the response to the Notice of Violation which was submitted via the above referenced letter.

TU Electric has reviewed the reasons for the violation, and concurs with your staff that; one of the principal causes for the violation was that TU Electric did not invoke the operations procedural requirements for the work performed. Since the system had been turned over to Operations, and was not under the custody of Startup, a work order in accordance with Station Administration procedure STA-606 "Work Requests And Work Orders" should have been issued.


190173

9304190232 930415
PDR ADOCK 05000445
G PDR

JED 1/0


Should you require a copy of our root cause analysis or need additional information, please contact Obaid Bhatti at (817)897-5839.

Sincerely,



William J. Cahill, Jr.

By:



Roger D. Walker
Manager of Regulatory
Affairs for NEO

OB/bm

c - Mr. J. L. Milhoan, Region IV
Mr. L. A. Yandell, Region IV
Resident Inspectors, CPSES (2)