

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the matter of)
NEW YORK POWER AUTHORITY) Docket No. 50-333
James A. FitzPatrick Nuclear Power Plant)


APPLICATION FOR AMENDMENT TO OPERATING LICENSE

The New York Power Authority requests an amendment to the Technical Specifications contained in Appendix A to Facility Operating License DPR-59 for the James A. FitzPatrick Nuclear Power Plant. This application is filed in accordance with Section 10 CFR 50.90 of the Nuclear Regulatory Commission's regulation.

This application for an amendment to the James A. FitzPatrick Technical Specifications makes four changes to Table 4.7-2, "Exception to Type C Tests." The first adds system numbers to the valve identification numbers for seven control rod drive containment isolation valves to be consistent with valve identifiers in the Technical Specifications, and clarifies the penetration arrangements. There is no change to the valves themselves or to the penetrations. The second change removes valves 10MOV-57 and 10MOV-67 from the table because they are not containment isolation valves as defined by the current FitzPatrick licensing basis. The third change adds valves 10RHR-729A and 10RHR-729B to the table to exempt them from Type C testing based on the current FitzPatrick licensing basis. Fourthly, three errors introduced in Amendment 143 are corrected.

The proposed change to the Technical Specifications is Attachment I to this Application for Amendment to the Operating License. The Safety Evaluation for the proposed change is included as Attachment II.


New York Power Authority



Ralph E. Beedle
Executive Vice President
Nuclear Generation

STATE OF NEW YORK
COUNTY OF WESTCHESTER

Subscribed and sworn to before me
this 15th day of April, 1993.


Notary Public

GERALDINE STRAND
Notary Public, State of New York
No. 4991272
Qualified in Westchester County
Commission Expires Jan. 27, 1994

9304210280 930415
PDR ADOCK 05000333
P PDR