



General Electric Company  
175 Cortner Avenue, San Jose, CA 95125

April 26, 1993

Docket No. STN 52-001

Chet Poslusny, Senior Project Manager  
Standardization Project Directorate  
Associate Directorate for Advanced Reactors  
and License Renewal  
Office of the Nuclear Reactor Regulation

Subject: Submittal Supporting Accelerated ABWR Review Schedule - DFSER  
**Outstanding Items for Chapters 3 and 6**

Dear Chet:

Enclosed are SSAR markups addressing Open items 3.8.4-2 and 6.2.6-8, and COL Action Item 3.8.4-1.

In addition to the outstanding items above, GE has addressed Open Item 6.2.6-7 by reviewing systems that interface with the primary containment. It was determined there are two closed loop systems that provide an extension to containment. These are the containment atmosphere monitoring and fuel pool cooling systems. Both of these systems are leak tested by opening their lines to containment atmosphere during the Type A ILRT. Both systems already have notes describing this method of leak testing.

Please provide a copy of this transmittal to Tom Cheng, Dave Terao and Butch Burton.

Sincerely,

Jack Fox  
Advanced Reactor Programs

cc: Gary Ehlert (GE)  
Norman Fletcher (DOE)

High strength structural steel plates	ASTM A572 or A441
Bolts, studs, and nuts (dia. $\geq$ 3/4")	ASTM A325 or A490
Bolts, studs, and nuts (dia. $\leq$ 3/4")	ASTM A307

### 3.8.3.6.5 Other Internal Structures

The materials conform to all applicable requirements of ANSI/AISC N690 and comply with the following:

Item	Specification
Miscellaneous platforms	Same as Section 3.8.3.6.4
Lower drywell equipment tunnel	ASTM A516 Grade 70 SA-240 Type 304 L
Lower drywell personnel tunnel	ASTM A516 Grade 70 SA-240 Type 304 L
Reactor shield wall stabilizer	
--tube sections	ASTM A501
--plates	ASTM A36
Lower drywell floor fill material	A material other than limestone concrete

### 3.8.3.7 Testing and Inservice Inspection Requirements

A formal program of testing and inservice inspection is not planned for the internal structures except the diaphragm floor, reactor pedestal, and lower drywell access tunnels. The other internal structures are not directly related to the functioning of the containment system; therefore, no testing or inspection is performed.

Testing and inservice inspection of the diaphragm floor, reactor pedestal and lower drywell access tunnels are discussed in Subsection 3.8.1.7.

## 3.8.4 OTHER SEISMIC CATEGORY I STRUCTURES

Other Seismic Category I structures which constitute the ABWR Standard Plant are the reactor building, control building and radwaste building substructure. Figure 1.2-1 shows the spatial relationship of these buildings. The only other structure in close proximity to these structures is the turbine building. They are structurally separated from the other ABWR Standard Plant buildings.

The Seismic Category I structure within the ABWR Standard Plant, other than the containment structures, that contains high-energy pipes is the reactor Building. The steam tunnel walls protect the reactor building from potential impact by rupture of the high-energy pipes. This building is designed to accommodate the guard pipe support forces.

The reactor building, steam tunnel, residual heat removal (RHR) system, reactor water cleanup (RWCU) system, and reactor core isolation cooling (RCIC) system rooms are designed to handle the consequences of high energy pipe breaks. The RHR, RCIC, and RWCU rooms are designed for differential compartment pressures, with the associated temperature rise and jet force. Steam generated in the RHR compartment from the postulated pipe break exits to the steam tunnel through blowout panels. The steam tunnel is vented to the turbine building through the seismic interface restraint structure (SIRS). The steam tunnel, which contains several pipelines (e.g., main steam, feedwater, RHR), is also designed for a compartment differential pressure with the associated temperature changes and jet force.

Seismic Category I masonry walls are not used in the design. The ABWR Standard Plant does not contain seismic Category I pipelines buried in soil.

### 3.8.4.1 Description of the Structures

#### 3.8.4.1.1 Reactor Building Structure

The reactor building (RB) is constructed of reinforced concrete with a steel frame roof. The RB has four stories above the ground level and three stories below. Its shape is a rectangle of 59 meters in the E-W direction, 56 meters in the N-S direction, and a height of about 57.9 meters from the top of the basement.

The COL applicant will identify all Seismic Category I structures. See Subsection 3.8.6.4 for COL license information.

# ABWR

## Standard Plant

interaction of the substructure with the underlying foundation medium. For a mat foundation supported on soil or rock, the pertinent aspects in the design are to maintain the bearing pressures within allowable limits, particularly due to overturning forces, and to ensure that there is adequate frictional and passive resistance to prevent sliding of the structure when subjected to lateral loads.

The design loads considered in analysis of the foundations are the worst resulting forces from the superstructures and loads directly applied to the foundation mat due to static and dynamic load combinations.

The capability of the foundation to transfer shear with waterproofing will be evaluated. See Subsection 3.8.6.1 for COL license information requirements.

The standard ABWR design is developed using a range of soil conditions as detailed in Appendix 3A. The variations of physical properties of the site-specific subgrade materials will be determined (see Subsection 3.8.6.2). Settlement of the foundations, differential settlement between foundations for the site-specific foundations medium will be calculated and safety-related systems (i.e., piping, conduit, etc.) will be designed for the calculated settlement of the foundations. The effect of the site-specific subgrade stiffness and calculated settlement on the design of the seismic Category I structures and foundations will be evaluated. See Subsection 3.8.6.2 for COL license information requirements.

A detailed description of the analytical and design methods for the reactor building foundation mat including the containment foundation, is included in Section 3.8.1.4.

### **3.8.5.5 Structural Acceptance Criteria**

The main structural criteria for the containment portion of the foundation are adequate strength to resist loads and sufficient stiffness to protect the containment liner from excessive strain. The acceptance criteria for the containment portion of the foundation mat are presented in Subsection 3.8.1.5. The structural acceptance criteria for the reactor building foundations are described in Subsection 3.8.4.5.

The calculated and allowable factors of safety of the ABWR structures for overturning, sliding, and flotation are shown in Sections 3H.1 and 3H.2.

### **3.8.5.6 Materials, Quality Control, and Special Construction Techniques**

The foundations of seismic Category I structures are constructed of reinforced concrete using proven methods common to heavy industrial construction. For further discussion see Subsections 3.8.1.6 and 3.8.4.6.

### **3.8.5.7 Testing and Inservice Inspection Requirements**

A formal program of testing and inservice inspection is not planned and is not required for the seismic Category I structures of the ABWR.

## **3.8.6 COL License Information**

### **3.8.6.1 Foundation Waterproofing**

The capability of foundations to transfer shear loads where foundation waterproofing is used will be evaluated (see Subsection 3.8.5.4).

### **3.8.6.2 Site Specific Physical Properties and Foundation Settlement**

Physical properties of the site specific subgrade medium shall be determined and the settlement of foundations and structures including seismic Category I will be evaluated see Subsection 3.8.5.4).

### **3.8.6.3 Structural Integrity Pressure Result**

Each COL applicant will perform the structural integrity test (SIT) of the ABWR containment in accordance with Subsection 3.8.1.7.1. Additionally, the first ABWR containment is considered as a prototype and its SIT performed accordingly. The details of the test and the instrumentation as required for such a test will be provided by the first COL applicant for NRC review and approval.

**3.8.6.4 Identification of Seismic Category I Structures**  
**The COL applicant will identify all Seismic Category I structures. (See Sub-** 3.8-28  
**section 3.8.4)**

Table 6.2-10 Potential Bypass Leakage Paths<sup>1</sup>

Item	Name	Diameter (mm)	Termination Region <sup>(3)</sup>	Leakage Barriers <sup>(2)</sup>	Potential Bypass Path
X-1	U/D Equipment Hatch	2600	S		No
X-2	U/D Personnel Hatch	2600	S		No
X-3	ISI Hatch	200	S		No
X-4	Wetwell Access Hatch	2000	S		No
X-5	L/D Personnel Hatch	2400	S		No
X-6	L/D Equipment Hatch	2400	S		No
X-10A	Mainsteam Line	1100	E	<del>L</del> D, G	<del>No</del> Yes
X-10B	Mainsteam Line	1100	E	<del>L</del> D, G	<del>No</del> Yes
X-10C	Mainsteam Line	1100	E	<del>L</del> D, G	<del>No</del> Yes
X-10D	Mainsteam Line	1100	E	<del>L</del> D, G	<del>No</del> Yes
X-11	Mainsteam Drain	600	E	<del>L</del> D, G	<del>No</del> Yes
X-12A	Feedwater Line	950	E	<del>L</del> D, F	<del>No</del> Yes
X-12B	Feedwater Line	950	E	<del>L</del> D, F	<del>No</del> Yes
X-22	Borated Water INjection	40	S		No
X-30A	Drywell Spray	200	S		No
X-30B	Drywell Spary	200	S		No
X-31A	HPCF (B)	600	S		No
X-31B	HPCF (C)	600	S		No
X-32A	LPFL (B)	650	S		No
X-32B	LPFL (C)	650	S		No
X-33A	RHR Suction (A)	750	S		No
X-33B	RHR Suction (B)	750	S		No
X-33C	RHR Suction (C)	750	S		No
X-37	RCIC Turbine Steam	550	S		No
X-38	RPV Head Spray	550	S		No
X-50	CUW Pump Feed	600	S		No
X-60	MUWP Suction	50	S		No
X-61	RCW Suction (A)	200	E	C	No
X-62	RCW Return (A)	200	E	C	No
X-63	RCW Suction (B)	200	E	C	No
X-64	RCW Return (B)	200	E	C	No
X-65	HNCW Suction	150	E	C	No
X-66	HNCW Return	150	E	C	No
X-69	SA	25	E	C	No
X-70	IA	50	E	C	No
X-71A	ADS Accumulator (A)	50	S		No
X-71B	ADS Accumulator (B)	50	S		No
X-72	RElief Valve Accum.	150	S		No
X-80	Drywell Purge Suction	550	E	C	No
X-81	Drywell Purge Exhaust	550	E	C	No
X-82	FCS Suction	100	S		No
X-90	Spare	400	P	A	No
X-91	Spare	400	P	A	No
X-92	Spare	400	P	A	No
X-93	Spare	400	P	A	No
X-100A	IP Power	450	S		No
X-100B	IP Power	450	S		No
X-100C	IP Power	450	S		No

Table 6.2-10 Potential Bypass Leakage Paths<sup>1</sup> (Continued)

Item	Name	Diameter (mm)	Termination Region <sup>(3)</sup>	Leakage Barriers <sup>(2)</sup>	Potential Bypass Path
X-143A	C & I	100	S		No
X-143B	C & I	100	S		No
X-143C	C & I	100	S		No
X-143D	C & I	100	S		No
X-144A	C & I	100	S		No
X-144B	C & I	100	S		No
X-144C	C & I	100	S		No
X-144D	C & I	100	S		No
X-146A	C & I	300	S		No

Notes:

1. This Table provided in response to Question 430.52b.
2. A) Penetration is capped  
B) Terminates at Primary Containment Wall  
C) Terminates inside Secondary Containment  
D) Terminates outside Secondary Containment  
E) Redundant Containment Isolation Valves

3. E - Environment  
P - Primary containment  
S - Secondary containment

F) Water seal plus third stop check valve.  
G) Leakage handled and accounted for  
alternate leakage control system (condenser).

## APPENDIX 3G

## RESPONSE OF STRUCTURES DUE TO CONTAINMENT LOADS

## TABLE OF CONTENTS

1. Scope
2. Dynamic Response
  - 2.1 Classification and Analytical Procedure
  - 2.2 Analysis Model
  - 2.3 Load Application
  - 2.4 Analysis Method
3. Hydrodynamic Load For Design

## 1. Scope

This appendix specifies the design for safety-related structures, systems, and components as applicable due to dynamic excitations originating in the primary containment in the event of operational transients and LOCA. The input containment loads are described in appendix 3B. The containment loads considered for structural dynamic response analysis are Condensation Oscillation (CO), Pool Chugging (CH), Horizontal Vent Chugging (HV), Safety/Relief Valve discharge (SRV), and Annulus Pressurization (AP).

## 2. Dynamic Response

### 2.1 Classification Of Analytical Procedure

Analytical procedure of hydrodynamic loads classified into following three groups:

- a. Pipe nozzle break loads,
- b. Symmetric loads, and
- c. Asymmetric loads.


## 2.2 Analysis Models

### (1) Analysis Model

The structural models used in the analyses represent a synthesis of the reactor building model and the RPV & Internals model. The beam model used in the pipe break load analysis is illustrated in figure 2.2-1. The analysis model used for symmetric load and asymmetric load are illustrated in figure 2.2-2 and figure 2.2-3 respectively.

### (2) Structural Damping

Regulatory Guide 1.61 OBE and SSE damping values were used for SRV and LOCA loads respectively.



See Fig. 3.2-7 for elevations of the RPV and internals nodes.

Fig. 8-2-1 Horizontal Beam Model for AP Load  
2.2-1





Fig.3.2-4 Nodal Point No (R/B Horizontal/Vertical Shell Model)  
Z Z - Z



The number inside ( ) means  
the node in the building model  
shown in Fig.3.2-4.  
Elevations are with respect to  
RPV bottom head.

Fig.3.2-6 Nodal Point No. (RPV / Internal Vertical Shell Model)  
Z Z-3

## 2.3 Load Application

### (1) Pipe break nozzle load

The AP pressures were converted to horizontal forces to the following formula.

For RSW side:

$$F_j(t) = 2 \sum_{i=1}^{\theta} P_{ij}(t) \int_{\theta=a_i}^{\theta=b_i} R \cos(\theta) d\theta$$

For RPV side:

$$F_j(t) = -2 \sum_{i=1}^{\theta} P_{ij}(t) \int_{\theta=a_i}^{\theta=b_i} r \cos(\theta) d\theta$$

$F_j(t)$  : Force per unit height each level

$P_{ij}(t)$  : Pressure each level and angle

$i$  : Cell No.

$j$  : Level No.

$R$  : RSW Inner Radius

$r$  : RPV Outer Radius

$\theta$  : angle ( $\leq 180^\circ$ )

Jet reaction, jet impingement, and pipe whip reaction forces were considered as steady state loads whose rise time for initial pulse was set as one millisecond.

### (2) SRV Load

Symmetric SRV (all) response analysis is covered by  $n=0$  harmonic. Asymmetric case of SRV (all) actuation is to be covered by  $n=1$  harmonic that corresponds to overturning moment. SRV (1) is also in this category. The SRV air bubble frequencies are expected to be within a range of 5 to 12hz. Ways of selecting minimum number of bubble frequencies for dynamic analysis are as follows.

Frequency range of SRV Loads :  $f_1 \leq f \leq f_2$  ( $f_1 = 5\text{hz}$ ,  $f_2 = 12\text{hz}$ )

For vertical structural frequencies ( $n=0$ )

(1) If  $(f_s)_v > f_2$  then use  $f_2$

(2) If  $f_1 < (f_s)_V < f_2$  then use  $(f_s)_V$

For horizontal structural frequencies ( $n=1$ )

(1) If  $(f_s)_H < f_1$  then use  $f_1$

(2) If  $f_1 < (f_s)_H < f_2$  then use  $(f_s)_H$

(3) If  $f_2 < (f_s)_H$  then use  $f_2$

In symmetric load case, 12hz was adopted as bubble frequency, because the vertical frequencies of the structure were higher than 12hz. In asymmetric load case, 3 horizontal beam frequencies of the structure within the above range 7.73hz, 9.59hz, and 11.58hz were adopted as bubble frequencies.

(3) HV Load

Both symmetric and non-symmetric upward loads on pedestal due to chugging in the top horizontal vents was considered.

(4) Chugging, Condensation Oscillation Loads

According to the study of the natural frequencies of the structure and the frequencies of the input motion, 4 critical pressure time histories out of 8 for CH and 2 out of 4 for CO, were selected for dynamic analysis. Furthermore, 1 local spike load was added in CO response study.

## 2.4 Analysis Method

### (1) Pipe Nozzle Break Load Analysis

For pipe nozzle break cases, multi-input excitation time history analyses were performed by using mode superposition method. Strain energy damping was used for this analyses.

### (2) Symmetric Load Analysis

For symmetric load cases, frequency response method for  $n=0$  harmonic was used. Hysteresis damping was considered.

### (3) Asymmetric Load Analysis

For asymmetric load cases, frequency response method for  $n=1$  harmonic was used. Hysteresis damping was considered.

### (4) Analysis Parameters

The analysis parameters in terms of time/frequency steps in analysis are shown in Table 2.4-1.

Tables 3 - 4 - 1. Analysis Parameters Estimates in Terms of Frequency Step

Load	Analysis Case	Domain Time/Freq.	Input Time Pitch At (sec)	Given Time Step $n_i$	Duration Time $t_i (n_i \cdot \Delta t) (\text{sec})$	Trailing zero Step $n_s$	Analysis Time Step $N(n_i + n_s)$	Analysis Duration Time $\tau (n_i + n_s) (\text{sec})$	Frequency Resolution $1/\tau (\text{Hz})$	Transfer Function Interpolation Method	
										Interval	Method
	Definition of AP		$1.0 \times 10^{-8}$	2000	2.0	—	—	—	—	—	—
	Definition of $F_1 \sim F_6$		$1.0 \times 10^{-8}$	2000	2.0	—	—	—	—	—	—
Pipe	AP A1, AP A2	Time	$1.0 \times 10^{-8}$	2000	2.0	—	—	—	—	—	—
Break	AP B1, AP B2			—	—	2000	2,0	—	—	—	—
	AP C1, AP C2			—	—	—	—	—	—	—	—
	Definition			—	—	—	—	—	—	—	—
	SRVY			150	0.50	1898	2048	6.83	0.1449	Every Step	—
1	SRVH	Freq.		150	0.625	1898	2048	8.54	0.1170	Every 2 Step Reciprocal	—
	SRVHZ			150	0.518	1898	2048	7.074	0.14136	Every Step	—
25	SRVY3			150	0.776	1898	2048	10.598	0.09436	Every 2 Step Reciprocal	—
	Definition			—	—	—	—	—	—	—	—
	RV			2	0.032	—	—	—	—	—	—
	RVH	Freq.		2	0.002	4094	4096	4.096	0.24414	Every Step	—
	Definition			1 $\times 10^{-8}$	1000	1.0	—	—	—	—	—
	CH1, CHH1			1 $\times 10^{-8}$	1000	1.0	3096	4096	4.096	0.24414	Every Step
	CH2, CHH2			—	—	—	—	—	—	—	—
	CH3, CHH3			—	—	—	—	—	—	—	—
	CH4, CHH4			—	—	—	—	—	—	—	—
CR	COV1	Definition		$1 \times 10^{-8}$	2000	2.0	—	—	—	—	—
	COV3	Analysis		$1 \times 10^{-8}$	2000	2.0	2096	4096	4.096	0.24414	Every Step
CO	COV2	Definition		$1 \times 10^{-8}$	3000	3.0	—	—	—	—	—
		Analysis		$1 \times 10^{-8}$	3000	3.0	1096	4096	4.096	0.24414	Every Step

### 3. Hydrodynamic Load Analysis Results

The acceleration response spectra at a few select locations for each loading event are presented in figure 3-1 through 3-40. The maximum displacements, acceleration at a few select locations for each loading event are presented table 3-1 and 3-2.

The input excitation of suppression pool boundary horizontal loads (SRV, Chugging, and HV) was considered unidirectional which can be set at any direction in the horizontal plane, and the AP analysis was performed assuming that pipe break can be associated with any one of the vessel nozzles for each of the postulated line breaks.

The resulting response of structures considered in the analyses is thus unidirectional applicable to any azimuth angle for suppression pool loads and to the horizontal direction corresponding to the break direction for AP loads.

For subsystem analyses using floor response spectra and ,if applicable, building displacement data, the input direction of the horizontal load shall be selected to result in worst subsystem response.

As an alternate approach, the horizontal input to subsystem may be taken to be the same in the two orthogonal horizontal directions.

The SRV(one) loads can be obtained by multiplying the SRV(all) loads by 0.4 and 0.3 in the horizontal and vertical directions respectively.

Maximum Accelerations For AP Loadings (g)

Location	Node	MSLB	FDW	RHR
Top Of RPV	28	0.727	0.523	0.897
Top Of Pedestal	86	0.11	0.063	0.085
Top Of RSW	80	3.89	0.504	0.759
D/F Slab	85	0.02	0.009	0.014

Maximum Accelerations For Hydrdynamics Loads (g)

Location	Direction	Node	SRV	HV	CH	CO
Top Of RPV	Horizontal	1	0.173	0.029	0.116	0.400
	Vertical		0.273	0.008	0.057	
Top Of Pedestal	Horizontal	42	0.116	0.006	0.051	0.171
	Vertical		0.216	0.003	0.020	
Top Of RSW	Horizontal	165	0.119	0.016	0.063	0.378
	Vertical		0.220	0.008	0.065	
D/F Slab	Horizontal	157	0.031	0.002	0.018	0.069
	Vertical		0.045	0.001	0.008	

Table 3-2 Sheet

## Maximum Displacements For AP Loadings (mm)

Location	Node	MSLB	FDW	RHR
Top Of RPV	28	1.94	0.74	1.01
Top Of Pedestal	86	0.11	0.04	0.06
Top Of RSW	80	1.43	0.36	0.56
D/F Slab	85	0.15	0.05	0.07

## Maximum Displacements For Hydrdynamics Loads (mm)

Location	Direction	Node	SRV	HV	CH	CO
Top Of RPV	Horizontal	28	0.110	0.013	0.029	
	Vertical	1	0.470	0.006	0.016	0.674
Top Of Pedestal	Horizontal	71	0.069	0.003	0.012	
	Vertical	42	0.420	0.003	0.011	0.636
Top Of RSW	Horizontal	165	0.065	0.006	0.001	
	Vertical	165	0.398	0.003	0.013	0.624
D/F Slab	Horizontal	153	0.039	0.002	0.006	
	Vertical	157	0.155	0.001	0.009	0.436

AP LOAD(MS NOZZLE BREAK)

CASE: APA1 , NODE: 33 , HORIZONTAL




FIG.A-11 FLOOR RESPONSE SPECTRUM

AP LOAD(MS NOZZLE BREAK)

CASE: APA1 , NODE: 81 , HORIZONTAL




FIG.A-26 FLOOR RESPONSE SPECTRUM




FIG. A-29 FLOOR RESPONSE SPECTRUM

AP LOAD(MS NOZZLE BREAK)

CASE: APA2 , NODE: 33 , HORIZONTAL




FIG. A-48      FLOOR RESPONSE SPECTRUM

AP LOAD(MS NOZZLE BREAK)

CASE: APA2 , NODE: 81 , HORIZONTAL




FIG. A-63 FLOOR RESPONSE SPECTRUM




FIG.A-66 FLOOR RESPONSE SPECTRUM

AP LOAD(FWD NOZZLE BREAK)

CASE: APB1 , NODE: 33 , HORIZONTAL




FIG. A-85 FLoor Response Spectrum

AP LOAD(FDW NOZZLE BREAK)

CASE: APB1 , NODE: 81 , HORIZONTAL




FIG. A-100 FLOOR RESPONSE SPECTRUM

AP LOAD(FWD NOZZLE BREAK)

CASE: APB1 , NODE: 85 , HORIZONTAL




FIG. A-103 FLLOOR RESPONSE SPECTRUM

AP LOAD(FWD NOZZLE BREAK)

CASE:APB2 , NODE:33 , HORIZONTAL




FIG.A-122 FLOOR RESPONSE SPECTRUM




FIG. A-137 FLOOR RESPONSE SPECTRUM

AP LOAD(FDW NOZZLE BREAK)

CASE: APB2 , NODE: 85 , HORIZONTAL




FIG. A-140 FLOOR RESPONSE SPECTRUM

AP LOAD/RHR NOZZLE BREAK)

CASE: APC1 , NODE: 33 , HORIZONTAL




FIG.A-159 FLOOR RESPONSE SPECTRUM

AP LOAD(RHR NOZZLE BREAK)

CASE: APC1 , NODE: 81 , HORIZONTAL




FIG. A-174 FLOOR RESPONSE SPECTRUM

AP LOAD(RHR NOZZLE BREAK)

CASE:APC1 ,NODE:85 ,HORIZONTAL




FIG. A-177 FLOOR RESPONSE SPECTRUM

AP LOAD(RHR NOZZLE BREAK)

CASE: APC2 , NODE: 33 , HORIZONTAL




FIG.A-196 FLOOR RESPONSE SPECTRUM

AP LOAD(RHR NOZZLE BREAK)

CASE: APC2 , NODE: 81 , HORIZONTAL




FIG.A-211 FLLOOR RESPONSE SPECTRUM

AP LOAD(RHR NOZZLE BREAK)

CASE: APC2 , NODE: 85 , HORIZONTAL




FIG.A-214 FLOOR RESPONSE SPECTRUM

SRV LOAD (F=12.0HZ, AXISYM)

CASE: SRVV , NODE: 7 • VERTICAL




FIG. A-225 FLOOR RESPONSE SPECTRUM

SRV LOAD (F=12.0HZ, AX15YM)

CASE: SKVV , NODE: 125 , VERTICAL




FIG. A-238 FLLOOR RESPONSE SPECTRUM

SRV LOAD (12.0 Hz, AX1SYM)

CASE: SRVV , NODE: 148 , VERTICAL




FIG. A-244 FLLOOR RESPONSE SPECTRUM

SRV LOAD ( $F = 12$ , OHZ, AXISYM)

CASE : SRVV , NODE : 157 , VERTICAL




FIG. A-247 FLOOR RESPONSE SPECTRUM

SKV 1 LOAD (F=3.0017, NUM AX1514)

CASE: SKVH1, NODE: 33, HORIZONTAL




FIG. A-272 FLLOOR RESPONSE SPECTRUM

SRV LOAD ( $F = 9.59\text{Hz}$ , NON-AXISYM)

CASE : SRVH1 , NODE : 71 , HORIZONTAL




FIG. A-289 FLOOR RESPONSE SPECTRUM

SRV LOAD (F=9.59HZ, NON-AXISYM)

CASE : SRVH1 , NODE : 80 , HORIZONTAL




FIG. A-291 FLOOR RESPONSE SPECTRUM

A-292




FIG. A-292 FLOOR RESPONSE SPECTRUM

SRV LOAD (F=9.59HZ, NON-AXISYM)

CASE: SRVH1 , NODE: 157 , HORIZONTAL




FIG. A-300 FLOOR RESPONSE SPECTRUM

SRV LOAD (F=9.59HZ, NON-AXISYM)

CASE: SRVH1 , NODE: 165 , HORIZONTAL




FIG. A-308 FLOOR RESPONSE SPECTRUM

SRV LOAD(F=11.58HZ, NON-AXISYM)

CASE: SRVH2 , NODE: 33 , HORIZONTAL




FIG. A-325 FLOOR RESPONSE SPECTRUM

SRV LOAD (F=11.58HZ, NON-AXISYM)

CASE: SRVH2 , NODE: 71 , HORIZONTAL




FIG. A-342 FLOOR RESPONSE SPECTRUM

SRV LOAD(F=11.58HZ, NON-AXISYM)

CASE: SRVH2 , NODE: 80 , HORIZONTAL




FIG. A-344 FLOOR RESPONSE SPECTRUM




FIG. A-345 FLOOR RESPONSE SPECTRUM

SRV LOAD(F=11.58HZ, NON-AXISYM)

CASE: SRVH2 , NODE: 157 , HORIZONTAL




FIG. A-353 FLOOR RESPONSE SPECTRUM

SRV LOAD(F=11.58HZ, NON-AXISYM)

CASE: SRVH2 , NODE: 165 , HORIZONTAL




FIG. A-361 FLOOR RESPONSE SPECTRUM




FIG. A-378 FLOOR RESPONSE SPECTRUM

SRV LOAD(F=7.73HZ, NON-AXISYM)

CASE: SRVH3 , NODE: 71 , HORIZONTAL




FIG. A-395 FLOOR RESPONSE SPECTRUM

SRV LOAD (F=7.73HZ, NON-AXISYM)

CASE: SRVH3 , NODE: 80 , HORIZONTAL




FIG. A-397 FLOOR RESPONSE SPECTRUM

SRV LOAD ( $F=7.73\text{Hz}$ , NON-AXISYM)

CASE: SRVH3 , NODE: 125 , HORIZONTAL




FIG. A-398 FLOOR RESPONSE SPECTRUM

SRV LOAD(F=7.73HZ, NON-AXISYM)

CASE: SRVH3 , NODE: 157 , HORIZONTAL




FIG. A-406 FLOOR RESPONSE SPECTRUM

SRV LOAD (F=7.73HZ, NON-AXISYM)

CASE: SRVH3 , NODE: 165 , HORIZONTAL




FIG. A-414 FLOOR RESPONSE SPECTRUM

HV LOAD(AXISYM)

CASE: HVV , NODE: 7 , VERTICAL




FIG. A-424 FLOOR RESPONSE SPECTRUM

HV LOAD(AXISYM)  
CASE: HVV , NODE: 125 , VERTICAL




FIG. A-437 FLOOR RESPONSE SPECTRUM

HV LOAD(AXISYM)  
CASE: HVV , NODE: 148 , VERTICAL




FIG. A-443 FLLOOR RESPONSE SPECTRUM




FIG. A-446 FLOOR RESPONSE SPECTRUM

HV LOAD (AXISYM)

CASE : HVV , NODE : 165 , VERTICAL




FIG. A-454 FLOOR RESPONSE SPECTRUM

HV LOAD (NON-AXISYM)  
CASE: HVH , NODE: 33 , HORIZONTAL




FIG. A-471 FLLOOR RESPONSE SPECTRUM

HV LOAD(NON-AXISYM)

CASE:Hvh , NODE:42 , HORIZONTAL




FIG. A-476 FLOOR RESPONSE SPECTRUM





FIG. A-491 FLOOR RESPONSE SPECTRUM

HV LOAD(NON-AXISYM)  
CASE: HVH , NODE: 157 , HORIZONTAL



A-499

FIG. A-499 FL00R RESPONSE SPECTRUM

HV LOAD(NON-AXISYM)  
CASE: HVH , NODE: 165 , HORIZONTAL




FIG. A-507 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH3,AXISYM)  
CASE:CHV1 ,NODE:7 ,VERTICAL




FIG. A-517 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH3,AXISYM)

CASE:CHV1 ,NODE:125 ,VERTICAL




FIG. A-530 FLOOR RESPONSE SPECTRUM




FIG. A-536 FLOOR RESPONSE SPECTRUM

A-539

CHUGGING LOAD(CH3,AXISYM)

CASE:CHV1 ,NODE:157 ,VERTICAL




FIG. A-539 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH3,AXISYM)

CASE:CHV1 ,NODE:165 ,VERTICAL




FIG. A-547 FLOOR RESPONSE SPECTRUM




FIG. A-557 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH4,AXISYM)

CASE:CHV2 ,NODE:125 ,VERTICAL




FIG. A-570 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH4,AXISYM)

CASE:CHV2 ,NODE:148 ,VERTICAL




FIG. A-576 FLOOR RESPONSE SPECTRUM




FIG. A-579 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH4,AXISYM)

CASE:CHV2 ,NODE:165 ,VERTICAL




FIG. A-587 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH5,AXISYM)

CASE:CHV3 , NODE:7 , VERTICAL




FIG. A-597 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH5,AXISYM)

CASE:CHV3 ,NODE:125 ,VERTICAL




FIG. A-610 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH5,AXISYM)

CASE:CHV3 , NODE: 148 , VERTICAL




FIG.A-616 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH5,AXISYM)

CASE:CHV3 ,NODE:157 ,VERTICAL




FIG.A-619 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH5,AXISYM)

CASE:CHV3 ,NODE:165 ,VERTICAL




FIG. A-627 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH7,AXISYM)

CASE:CHV4 ,NODE:7 ,VERTICAL




FIG. A-637 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH7,AXISYM)

CASE:CHV4 ,NODE:125 ,VERTICAL




FIG.A-650 FLOOR RESPONSE SPECTRUM

999-4




FIG. A-656 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH7,AXISYM)

CASE:CHV4 ,NODE:157 ,VERTICAL




FIG. A-659 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH7,AXISYM)

CASE:CHV4 , NODE:165 , VERTICAL




FIG. A-667 FLOOR RESPONSE SPECTRUM

b89-4




FIG. A-684 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH3, NON-AXISYM)

CASE: CHH1 , NODE: 71 , HORIZONTAL




FIG. A-701 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH3, NON-AXISYM)

CASE: CHH1 , NODE: 125 , HORIZONTAL




FIG. A-704 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH3, NON-AXISYM)

CASE: CHH1 , NODE: 157 , HORIZONTAL




FIG. A-712 FLOOR RESPONSE SPECTRUM




FIG. A-720 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH4, NON-AXISYM)

CASE: CHH2 , NODE: 33 , HORIZONTAL




FIG. A-737 FLOOR RESPONSE SPECTRUM




FIG. A-757 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH4, NON-AXISYM)

CASE: CHH2 , NODE: 71 , HORIZONTAL




FIG. A-754 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH4, NON-AXISYM)  
CASE: CHH2 , NODE: 157 , HORIZONTAL




FIG. A-765 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH4, NON-AXISYM)

CASE: CHH2 , NODE: 165 , HORIZONTAL




FIG. A-773 FLOOR RESPONSE SPECTRUM




FIG. A-790 FLØR RESPONSE SPECTRUM

CHUGGING LOAD (CH5, NON-AXISYM)

CASE: CHH3 , NODE: 71 , HORIZONTAL




FIG. A-807 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH5, NON-AXISYM)

CASE: CHH3 , NODE: 125 , HORIZONTAL




FIG. A-810 FLOOR RESPONSE SPECTRUM




FIG. A-818 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD (CH5, NON-AXISYM)

CASE: CHH3 , NODE: 165 , HORIZONTAL




FIG. A-826 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH7, NON-AXISYM)

CASE: CHH4 , NODE: 33 , HORIZONTAL




FIG. A-843 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH7, NON-AXISYM)

CASE: CHH4 , NODE: 71 , HORIZONTAL




FIG. A-860 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH7, NON-AXISYM)

CASE: CHH4 , NODE: 125 , HORIZONTAL




FIG. A-863 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH7, NON-AXISYM)

CASE: CHH4 , NODE: 157 , HORIZONTAL




FIG. A-871 FLOOR RESPONSE SPECTRUM

CHUGGING LOAD(CH7, NON-AXISYM)

CASE: CHH4 , NODE: 165 , HORIZONTAL




FIG. A-879 FLOOR RESPONSE SPECTRUM




FIG. A-889 FLOOR RESPONSE SPECTRUM

C0 LOAD(C0-03,AXISYM)

CASE:C0V1 ,NODE:125 ,VERTICAL




FIG. A-902.FLOOR RESPONSE SPECTRUM

CO LOAD(CO-03,AXISYM)

CASE: COV1 ,NUDE: 148 , VERTICAL




FIG. A-908 FLLOOR RESPONSE SPECTRUM

C0 LOAD(C0-03,AXISYM)

CASE:C0V1 ,NODE:157 ,VERTICAL




FIG. A-911 FLOOR RESPONSE SPECTRUM

C0 LOAD(C0-03,AXISYM)

CASE:C0V1 ,NODE:165 ,VERTICAL




FIG. A-919 FLOOR RESPONSE SPECTRUM

C0 LOAD(C0-04,AXISYM)

CASE:C0V2 ,NODE:7 ,VERTICAL




FIG. A-929 FLOOR RESPONSE SPECTRUM

CO LOAD(C0-04,AXISYM)

CASE: COV2 , NODE: 125 , VERTICAL




FIG. A-942 FLOOR RESPONSE SPECTRUM

C0 LOAD(C0-04,AXISYM)

CASE:C0V2 ,NODE:148 ,VERTICAL

346-V




FIG. A-948 FLOOR RESPONSE SPECTRUM

196-V




FIG. A-951 FLOOR RESPONSE SPECTRUM




FIG. A-959 FLOOR RESPONSE SPECTRUM

C0 LOAD(C0-SPIKE,AXISYM)

CASE:C0V3 ,NODE:7 ,VERTICAL




FIG. A-969 FLOOR RESPONSE SPECTRUM

C0 LOAD(C0-SPIKE,AXISYM)

CASE:C0V3 ,NODE:125 ,VERTICAL




FIG. A-982 FLOOR RESPONSE SPECTRUM

C0 LOAD(C0-SPIKE,AXISYM)

CASE:COV3 ,NODE:148 ,VERTICAL




FIG. A-988 FLOOR RESPONSE SPECTRUM

C0 LOAD(C0-SPIKE,AXISYM)

CASE:C0V3 ,NODE:157 ,VERTICAL




FIG. A-991 FLOOR RESPONSE SPECTRUM

CO LOAD(CO-SPIKE,AXISYM)

CASE:COV3 , NODE: 165 , VERTICAL




FIG. A-999 FLLOOR RESPONSE SPECTRUM