

DCS  
APR 23 1993

Docket Nos. 50-317  
50-318

Mr. Robert E. Denton  
Vice President - Nuclear Energy  
Baltimore Gas and Electric Company  
Calvert Cliffs Nuclear Power Plant  
1650 Calvert Cliffs Parkway  
Lusby, Maryland 20657 - 4702

Dear Mr. Denton:

SUBJECT: INSPECTION REPORT NOS. 50-317/93-07 AND 50-318/93-07

This letter refers to the inspection conducted by Mr. J. Carrasco of this office on March 1-5, 1993, at the Calvert Cliffs Nuclear Power Plant, Units 1 and 2, in Lusby, Maryland. The inspector discussed the results of the inspection with Mr. R. H. Waskey and other members of your staff at the conclusion of the inspection.

This inspection focused on activities important to the public health and safety and was directed towards engineering activities, with emphasis on the adequacy of your provisions for the analysis, design, and construction of two safety-related diesel generator buildings at the two-unit Calvert Cliffs Nuclear Power Plant. The independent spent fuel storage installation was also inspected, including the closing of an unresolved item from a previous inspection.

Details on the areas examined during the inspection are described in the NRC Region I inspection report, which is enclosed with this letter. Within these areas, the inspection consisted of selected examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of this inspection, no violations were observed. Your staff has demonstrated that the soil excavation was performed in accordance with special instructions established in their 10 CFR 50.59 safety evaluation and adequate provisions were made to prevent soil erosion and sediment throughout the duration of the yard modification.

300084

OFFICIAL RECORD COPY A:CC9307.JC

9305030117 930423  
PDR ADDCK 05000317  
G PDR

5001

APR 23 1993

Mr. Robert E. Denton

2

No reply to this letter is required. Your cooperation in this matter is appreciated.

Sincerely,

Original Signed By:

Jacque P. Durr, Chief  
Engineering Branch  
Division of Reactor Safety

Enclosure: NRC Region I Inspection Report Nos. 50-317 and 318/93-07

cc w/encl:

G. Detter, Director, Nuclear Regulatory Matters (CCNPP)  
R. McLean, Administrator, Nuclear Evaluations  
J. Walter, Engineering Division, Public Service Commission of Maryland  
K. Burger, Esquire, Maryland People's Counsel  
R. Cchs, Maryland Safe Energy Coalition  
K. Abraham, PAO (2) All Inspection Reports  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of Maryland (2)

OFFICIAL RECORD COPY A:CC9307.JC

APR 23 1993

Mr. Robert E. Denton

3

bcc w/encl:

Region I Docket Room (with concurrences)

C. Cowgill, DRP

J. Yerokun, DRP

L. Nicholson, DRP

S. Greenlee, DRP

P. Wilson, SRI - Calvert Cliffs

V. McCree, OEDO

R. Capra, NRR

D. McDonald, NRR

DRS/EB SALP Coordinator

D. Holody, EO

RI:DRS

Carrasco

*[Signature]*  
03/27/93

RI:DRS

Gray

*[Signature]*  
03/27/93

RI:DRS

Durr

*[Signature]*  
03/27/93

OFFICIAL RECORD COPY A:CC9307.JC