

BEFORE THE  
UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of the Facility Operating License)  
of )  
PUBLIC SERVICE COMPANY OF COLORADO )

Application for Amendment to  
Appendix A of Facility Operating License  
License No. DPR-34

OF THE  
PUBLIC SERVICE COMPANY OF COLORADO  
FOR THE  
FORT ST. VRAIN NUCLEAR GENERATING STATION

This application for Amendment to the Facility  
Operating License and Appendix A of the Facility  
Operating License, License No. DPR-34, is  
submitted for NRC review and approval.

Respectfully submitted,

PUBLIC SERVICE COMPANY OF COLORADO

By A. Clegg Crawford  
Vice President  
Electric Production

KELLY, STANSFIELD & O'DONNELL  
James K. Tarpey  
Mark A. Davidson  
Public Service Company Building  
Denver, Colorado 80202

Attorneys for Applicant

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of the Facility Operating License) )  
of )  
Public Service Company of Colorado Fort St. ) Docket No. 50-267  
Vrain Unit No. 1 ) )

AFFIDAVIT

A. Clegg Crawford, being first duly sworn, deposes and says: That he is Vice President, Electric Production, of Public Service Company of Colorado, the Licensee herein, that he has read the foregoing Application of Amendment to the Facility Operating License and knows the contents thereof, and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.

A. Clegg Crawford  
A. Clegg Crawford  
Vice President  
Electric Production

STATE OF Colorado )  
COUNTY OF Denver )

Subscribe and sworn to before me, a Notary Public on this  
7<sup>th</sup> day of May, 1993.

Audrey L. Kitzman  
Notary Public

My commission expires 11-29, 1995

ATTACHMENT 1

TO P-93045

SUMMARY OF PROPOSED CHANGE

## SUMMARY OF PROPOSED CHANGE

### DTS Section

### Summary of Change

Design Feature 4.3

Revise PCRV Leakage Prevention section to allow blind flanges to be removed from PCRV outlet coolant thermocouple penetrations, during use of push rod assemblies for thermocouple removal.