



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
475 ALLENDALE ROAD  
KING OF PRUSSIA, PENNSYLVANIA 19406 1415

JUL 01 1991

Docket Nos. 50-336  
File Number RI-91-A-0148

Northeast Nuclear Energy Company  
ATTN: Mr. E. J. Mroczka  
Senior Vice President - Nuclear  
Engineering and Operations Group  
P.O. Box 270  
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

The U.S. Nuclear Regulatory Commission recently received information concerning activities at the Millstone Nuclear Power Facility, Unit 2. The details are enclosed for your review and followup.

We request that the results of your review and disposition of these matters be submitted to Region I within 30 days of the date of receipt of this letter. We request that your response contain no personal privacy, proprietary, or safeguards information so it can be released to the public and placed in the NRC Public Document Room. If necessary, such information shall be contained in a separate attachment which will be withheld from public disclosure. The affidavit required by 10 CFR 2.790(b) must accompany your response if proprietary information is included. Please refer to file number RI-91-A-0148 when providing your response.

The enclosure to this letter should be controlled and distribution limited to personnel with a "need to know" until your investigation of the concern has been completed and reviewed by NRC Region I. The enclosure to this letter is considered Exempt from Public Disclosure in accordance with Title 10, Code of Federal Regulations, Part 2.790(a). However, a copy of this letter excluding the enclosure will be placed in the NRC Public Document room.


The response requested by this letter and the accompanying enclosure are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

9305180451 930216  
PDR FOIA  
HUBBARD92-162 PDR

17  
H/86

Your cooperation with us is appreciated. We will gladly discuss any questions you have concerning this information.

Sincerely,



Charles W. Helil, Director  
Division of Reactor Projects

Enclosure: (10 CFR 2.790(a) Information)

cc w/o encl:

Public Document Room (PDR)

Local Public Document Room (LPDR)

State of Connecticut

bcc w/encl:

W. Raymond, SRI, Millstone

Allegation File<sup>(3)</sup> RI-91-A-0148, C, SC, e. 49

J. Stewart

E. Kelly

T. Shedlosky

~~LIMITED DISTRIBUTION - NOT FOR PUBLIC DISCLOSURE~~

ENCLOSURE

Issue

RI-91-A-148  
RI-91-A-149

On June 14, 1991, while attempting to replace the "SealTite" flexible electrical conduit and the position indicator window for No. 1 Steam Generator Main Steam Isolation Bypass Valve motor operator (2-MS-65A), it was found that the work had been done previously under AWO M2-89-01828 on March 13, 1989. However, the prints had not been updated.

Request

Please discuss the validity of the above assertions. If deficiencies in work control or drawing control are found, please inform us of the corrective actions you have taken to prevent recurrence. Please provide us with an assessment of the significance with regard to safety of any identified deficiencies.

Issue

RI-91-A-150

On June 14, 1991, differences between a control wiring diagram and actual plant conditions was found. The wiring diagram (Drawing 25203-32020) for the No. 1 Steam Generator Main Steam Bypass Valve (2-MS-65A) Motor Operator indicates the presence of an amber light to signify when the unit has tripped on overload. This light is not installed.

Also, Contact 49, shown on Drawing 25203-32031, sht. 42 does not exist.

Request

Please discuss the validity of the above assertions. If deficiencies are found in plant drawings, please notify us of the corrective actions taken to prevent recurrence. Please provide us with an assessment of the significance with regard to safety of any identified deficiencies.

~~LIMITED DISTRIBUTION - NOT FOR PUBLIC DISCLOSURE~~

## RECORD OF ALLEGATION PANEL DECISIONS

SITE: MILLSTONE 2

ALLEGATION NO.: RT-91-A-0150

DATE: 6-19-91 (Mtg. (1) 2 3 4 5)

PRIORITY:      High      Medium      Low

SAFETY SIGNIFICANCE: Yes No Unknown

CONCURRENCE TO CLOSEOUT: DD (BC) SC

CONFIDENTIALITY GRANTED: Yes No  
(See Allegation Receipt Report)

IS THERE A DOL FINDING: ~~Yes~~ No

IS CHILLING EFFECT LETTER WARRANTED: Yes No

HAS CHILLING EFFECT LETTER BEEN SENT: Yes No

HAS LICENSEE RESPONDED TO CHILLING EFFECT LETTER: Yes No

ACTION:

- 1) T/O to licensee for action
- 2)
- 3)
- 4)
- 5)

NOTES: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



13

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
475 ALLENDALE ROAD  
KING OF PRUSSIA, PENNSYLVANIA 19406-1415

JUL 01 1991

Docket Nos. 50-336  
File Number RI-91-A-0148

Northeast Nuclear Energy Company  
ATTN: Mr. E. J. Mroczka  
Senior Vice President - Nuclear  
Engineering and Operations Group

P.O. Box 270  
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

The U.S. Nuclear Regulatory Commission recently received information concerning activities at the Millstone Nuclear Power Facility, Unit 2. The details are enclosed for your review and followup.

We request that the results of your review and disposition of these matters be submitted to Region I within 30 days of the date of receipt of this letter. We request that your response contain no personal privacy, proprietary, or safeguards information so it can be released to the public and placed in the NRC Public Document Room. If necessary, such information shall be contained in a separate attachment which will be withheld from public disclosure. The affidavit required by 10 CFR 2.790(b) must accompany your response if proprietary information is included. Please refer to file number RI-91-A-0148 when providing your response.

The enclosure to this letter should be controlled and distribution limited to personnel with a "need to know" until your investigation of the concern has been completed and reviewed by NRC Region I. The enclosure to this letter is considered Exempt from Public Disclosure in accordance with Title 10, Code of Federal Regulations, Part 2.790(a). However, a copy of this letter excluding the enclosure will be placed in the NRC Public Document room.

The response requested by this letter and the accompanying enclosure are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.


H/74

Northeast Nuclear Energy Company

2

Your cooperation with us is appreciated. We will gladly discuss any questions you have concerning this information.

Sincerely,



Charles W. Hehl, Director  
Division of Reactor Projects

Enclosure: (10 CFR 2.790(a) Information)

cc w/o encl:

Public Document Room (PDR)

Local Public Document Room (LPDR)

State of Connecticut

bcc w/encl:

W. Raymond, SRI, Millstone

Allegation File<sup>9</sup> RI-91-A-0148, CISC, e149

J. Stewart

E. Kelly

T. Shedlosky

~~LIMITED DISTRIBUTION - NOT FOR PUBLIC DISCLOSURE~~

ENCLOSURE

Issue

On June 14, 1991, while attempting to replace the "SealTite" flexible electrical conduit and the position indicator window for No. 1 Steam Generator Main Steam Isolation Bypass Valve motor operator (2-MS-65A), it was found that the work had been done previously under AWO M2-89-01828 on March 13, 1989. However, the prints had not been updated.

Request

Please discuss the validity of the above assertions. If deficiencies in work control or drawing control are found, please inform us of the corrective actions you have taken to prevent recurrence. Please provide us with an assessment of the significance with regard to safety of any identified deficiencies.

Issue

On June 14, 1991, differences between a control wiring diagram and actual plant conditions was found. The wiring diagram (Drawing 25203-32020) for the No. 1 Steam Generator Main Steam Bypass Valve (2-MS-65A) Motor Operator indicates the presence of an amber light to signify when the unit has tripped on overload. This light is not installed.

Also, Contact 49, shown on Drawing 25203-32031, sht. 42 does not exist.

Request

Please discuss the validity of the above assertions. If deficiencies are found in plant drawings, please notify us of the corrective actions taken to prevent recurrence. Please provide us with an assessment of the significance with regard to safety of any identified deficiencies.

~~LIMITED DISTRIBUTION - NOT FOR PUBLIC DISCLOSURE~~

64



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
475 ALLENDALE ROAD  
KING OF PRUSSIA, PENNSYLVANIA 19406-1415

JUL 01 1991

Docket Nos. 50-336  
File Number RI-91-A-0148

Northeast Nuclear Energy Company  
ATTN: Mr. E. J. Mroczka  
Senior Vice President - Nuclear  
Engineering and Operations Group  
P.O. Box 270  
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

The U.S. Nuclear Regulatory Commission recently received information concerning activities at the Millstone Nuclear Power Facility, Unit 2. The details are enclosed for your review and followup.

We request that the results of your review and disposition of these matters be submitted to Region I within 30 days of the date of receipt of this letter. We request that your response contain no personal privacy, proprietary, or safeguards information so it can be released to the public and placed in the NRC Public Document Room. If necessary, such information shall be contained in a separate attachment which will be withheld from public disclosure. The affidavit required by 10 CFR 2.790(b) must accompany your response if proprietary information is included. Please refer to file number RI-91-A-0148 when providing your response.

The enclosure to this letter should be controlled and distribution limited to personnel with a "need to know" until your investigation of the concern has been completed and reviewed by NRC Region I. The enclosure to this letter is considered Exempt from Public Disclosure in accordance with Title 10, Code of Federal Regulations, Part 2.790(a). However, a copy of this letter excluding the enclosure will be placed in the NRC Public Document room.

The response requested by this letter and the accompanying enclosure are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-341.

H/81




Northeast Nuclear Energy Company

2

Your cooperation with us is appreciated. We will gladly discuss any questions you have concerning this information.

Sincerely,



Charles W. Held, Director  
Division of Reactor Projects

Enclosure: (10 CFR 2.790(a) Information)

cc w/o encl:

Public Document Room (PDR)

Local Public Document Room (LPDR)

State of Connecticut

bcc w/encl:

W. Raymond, SRI, Millstone

Allegation File # RI-91-A-0148, CISC, 0149

J. Stewart

E. Kelly

T. Shedlosky

~~LIMITED DISTRIBUTION - NOT FOR PUBLIC DISCLOSURE~~

ENCLOSURE

Issue

On June 14, 1991, while attempting to replace the "SealTite" flexible electrical conduit and the position indicator window for No. 1 Steam Generator Main Steam Isolation Bypass Valve motor operator (2-MS-65A), it was found that the work had been done previously under AWO M2-89-01828 on March 13, 1989. However, the prints had not been updated.

Request

Please discuss the validity of the above assertions. If deficiencies in work control or drawing control are found, please inform us of the corrective actions you have taken to prevent recurrence. Please provide us with an assessment of the significance with regard to safety of any identified deficiencies.

Issue

On June 14, 1991, differences between a control wiring diagram and actual plant conditions was found. The wiring diagram (Drawing 25203-32020) for the No. 1 Steam Generator Main Steam Bypass Valve (2-MS-65A) Motor Operator indicates the presence of an amber light to signify when the unit has tripped on overload. This light is not installed.

Also, Contact 49, shown on Drawing 25203-32031, sht. 42 does not exist.

Request

Please discuss the validity of the above assertions. If deficiencies are found in plant drawings, please notify us of the corrective actions taken to prevent recurrence. Please provide us with an assessment of the significance with regard to safety of any identified deficiencies.

~~LIMITED DISTRIBUTION - NOT FOR PUBLIC DISCLOSURE~~

from the desk of

1/31/52  
(61)

GENE KELLY

FILE 91-A-148

Typo in close-out letter  
to allay (10/28/51). Last  
sentence of 2nd ¶ (last line)  
should read

"... are not expected to  
reflect as-built."

No need for additional correspondence  
to allay, since NC response makes  
this clear.

Joe

H/77

## RECORD OF ALLEGATION PANEL DECISIONS

SITE: MILKSTONE 2

PANEL ATTENDEES:

ALLEGATION NO.: RI-91-A-0149

Chairman - WIGGINS

DATE: 6-19-91 (Mtg. (1) 2 3 4 5)

Branch Chief -

PRIORITY:      High      Medium      Low

Section Chief (AOC) - KELLEY

SAFETY SIGNIFICANCE: Yes No Unknown

Others - MATAKIS, EASLICK

CONCURRENCE TO CLOSEOUT: DD (BC) SC

STEWART VIA PHONE: RAYMOND

CONFIDENTIALITY GRANTED: Yes No  
(See Allegation Receipt Report)

SHELOSKY, H. ABIGHORST

IS THERE A DOL FINDING: ☒ Yes ☐ No

IS CHILLING EFFECT LETTER WARRANTED: Yes No

HAS CHILLING EFFECT LETTER BEEN SENT: Yes No

HAS LICENSEE RESPONDED TO CHILLING EFFECT LETTER: Yes No

ACTION:

- 1) T/O to licensee for action.
- 2)
- 3)
- 4)
- 5)

NOTES: \_\_\_\_\_

© 2000 Blackwell Science Ltd *Journal of Internal Medicine* 247: 101–108

© 2000 Blackwell Science Ltd *Journal of Internal Medicine* 247: 395–402

4/78