



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Robert A. Stratman
VICE PRESIDENT - NUCLEAR

June 4, 1993
PY-CEI/OEPA-0181L

Nancy Meli
Ohio EPA, Northeast District Office
Division of Air Pollution Control
2110 E. Aurora Rd.
Twinsburg, Ohio 44087

RE: Additional Information for Permit to Operate Renewal Applications for
the CEI Perry Plant Auxiliary Boilers

Dear Ms. Meli,

The following information is being provided in response to questions raised
during your inspection of the Perry Plant Auxiliary Boilers on May 27, 1993.

Volume of oil used in 1992 - 274,484 gallons

Average percent sulfur content - .175% (This is the average of five analyses:
3/11 - 0.14%, 3/12 - 0.14%, 4/11 - 0.165%, 4/28 - 0.16%, and 10/23 - 0.27%.)

Justification of 75 million BTU/hr maximum input capacity - The rated input
capacity of the boiler is 124 million BTU/hr (based on 881 gal/hr at 7.2 lb/gal
and 19,600 BTU/lb). Because there are fewer loads on the boiler than
originally anticipated, 75 million BTU/hr was established by Perry engineering
as the input maximum to be used.

Please contact us if you have questions or need additional information.

Sincerely,

Robert A. Stratman

RAS:LKB:ss

cc: Thomas Rigo, OEPA Columbus
NRC Project Manager
NRC Resident Inspector Office
NRC Document Control
NRC Region III

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

9306110212 930604
PDR ADOCK 05000440
G PDR

000110