



GPU Nuclear Corporation  
One Upper Pond Road  
Parsippany, New Jersey 07054  
201-316-7000  
TELEX 136-482  
Writer's Direct Dial Number:

June 4, 1993  
5000-93-0040  
C321-93-2093

U. S. Nuclear Regulatory Commission  
Att: Document Control Desk  
Washington, DC 20555

Gentlemen:

Subject: Oyster Creek Nuclear Generating Station (OCNGS)  
Docket No. 50-219  
Completion of IEB 79-02 Requirement

- Reference: (1) GPU Nuclear letter dated September 19, 1988, "Seismic Floor Response Spectra."  
(2) NRC letter dated September 15, 1989, "Upgrade of Pipe Supports and Anchorages to Meet IEB 79-02 and IEB 79-14 Using the New Floor Response Spectra - Oyster Creek Nuclear Generating Station."

In response to your recent request, this letter provides the status of GPUN's effort in response to IEB 79-02 at OCNGS.

Our letter of September 19, 1988 (Reference 1) transmitted a "pie-chart" showing the status of IEB 79-02 anchorage inspections as of September 9, 1988. The chart indicated that 67 anchorage inspections had not been completed. The letter also indicated that all remaining anchor-bolted base plates in the IEB 79-02 scope had previously been either inspected, qualified on the bases of high calculated factors of safety (>20), determined to have adequate QA documentation or upgraded.

During refueling outage 12R which ended in May 1989, GPUN completed the remaining 67 anchorages using the methodology discussed in the September 19, 1988 letter.


9300140066 930604  
PDR ADOCK 05000219  
G PDR

JEM 1/0

Based on the anchor-bolt design criteria documents, wedge-type anchor-bolts with factors of safety between 4 and 20, and shell-type anchor-bolts with factors of safety between 5 and 20 were inspected and appropriate QA documentation was generated by recording the actual anchor-bolt installation. Factors of safety for the anchor bolts were determined from the piping analysis performed using the original design basis Housner spectrum provided in the OCNGS FSAR consistent with the NRC letter dated September 15, 1989 (Reference 2).

If you have any questions regarding the information provided in this letter, please call Mike Laggart, Manager, Corporate Nuclear Licensing, at (201) 316-7968.

Sincerely,



R. W. Keaten  
Vice President and Director  
Technical Functions

RWK\YN\plp

cc: Administrator, Region I  
Oyster Creek NRC Project Manager  
Oyster Creek Senior Resident Inspector