

200 Exelon Way Kennett Square, PA 19348

www.exeloncorp.com

10CFR50.55a

February 5, 2020

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

> R. E. Ginna Nuclear Power Plant Renewed Facility Operating License No. DPR-18 <u>NRC Docket No. 50-244</u>

Subject: Submittal of the Program Plan for the Inservice Testing (IST) Program for the Sixth 10-Year Interval

In accordance with the ASME OM Code-2012 Edition, attached for your information is a copy of the Program Plan for the Inservice Testing (IST) Program for the R. E. Ginna Nuclear Power Plant, associated with the sixth ten-year IST interval. The new interval began on January 1, 2020 and concludes on December 31, 2029.

There are no regulatory commitments contained within this submittal.

If you have any questions or require additional information, please contact David Neff (267) 533-1132.

Sincerely,

David T. Andre

David T. Gudger Sr. Manager - Licensing Exelon Generation Company, LLC

Attachment: R. E. Ginna Nuclear Power Plant, Inservice Testing Program, Program Plan for the Sixth 10-Year Interval, Revision 0

cc: Regional Administrator, Region I, USNRC NRC Senior Resident Inspector - Ginna NRC Project Manager, NRR - Ginna A. L. Peterson, NYSERDA

ATTACHMENT

R. E. Ginna Nuclear Power Plant Inservice Testing (IST) Program, Program Plan for the Sixth 10-Year Interval, Revision 0

Exelon Nuclear Generation, LLC

300 Exelon Way Kennett Square, PA 19348

R. E. Ginna Nuclear Power Plant Unit 1 NRC Docket Number:50-244 1503Lake Road Ontario, NY 14519

Commercial Service Date: September 19, 1969

Inservice Testing (IST) Program Program Plan

SIXTH 10-YEAR INTERVAL

1/1/2020- 12/31/2029

Revision 0 01/01/2020

REVISION RECORD

Revision	Effective	Revision Description		Sign & Date		
	Date		Prepared;	Reviewed	Approved;	1
			Site IST	Corporate	Engr.	
			Program	IST	Programs	
			Engineer	Engineer	Manager	
0	1/1/2020	Sixth Ten Year Interval Update	XIIA IZINI	1 2 12/19/19	M, McGran	121
				ę –		1
				N,		1

TABLE OF CONTENTS

SECTION

1.0 INTRODUCTION

1.1	Purpose	5
1.2	Scope	5
1.3	Discussion	7
1.4	IST Program Plan	11
1.5	References	13

2.0 INSERVICE TESTING PLAN FOR PUMPS

2.1	Code Compliance	14
2.2	Allowable Ranges of Test Quantities	14
2.3	Testing Intervals	14
2.4	Instrument Accuracy	14
2.5	Vertical Line Shaft Pumps	14
2.6	Pump Design Flow	15
2.7	Specific Pump Testing Requirements	17
2.8	Mandatory Appendix V "Pump Periodic Verification Test Program"	18
2.9	IST Plan Pump Table Description	20

3.0 INSERVICE TESTING PLAN FOR VALVES

Code Compliance	21
Exercise Test Requirements for OM Code Category A and B	21
Power Operated Valves	
Check Valve Testing	23
Manual Valves	27
Testing Intervals	28
Deferred Valve Testing	28
Specific Valve Definitions	29
Mandatory Appendix III	30
Position Indicator (PI) Verification	32
Category A Containment Isolation Valve (CIV) and RCS	
Pressure Isolation Valve Leak Testing	33
IST Plan Valve Table Description	34
	Code Compliance Exercise Test Requirements for OM Code Category A and B Power Operated Valves Check Valve Testing Manual Valves Testing Intervals Deferred Valve Testing Specific Valve Definitions Mandatory Appendix III Position Indicator (PI) Verification Category A Containment Isolation Valve (CIV) and RCS Pressure Isolation Valve Leak Testing IST Plan Valve Table Description

TABLE OF CONTENTS (Continued)

4.0 <u>ATTACHMENTS</u>

- 1. System and P&ID Listing
- 2. Pump Relief Request Index
- 3. Pump Relief Requests
- 4. Valve Relief Request Index
- 5. Valve Relief Requests
- 6. Relief Request RAIs and SER
- 7. Code Case Index
- 8. Cold Shutdown Justification Index
- 9. Cold Shutdown Justifications
- 10. Refueling Outage Justification Index
- 11. Refueling Outage Justifications
- 12. Technical Position Index
- 13. Technical Positions
- 14. Inservice Testing Pump Table
- 15. Inservice Testing Valve Table
- 16. Check Valve Condition Monitoring Plan Index

1.0 Introduction

This document outlines the R. E. Ginna Nuclear Station Unit 1 IST Program for the next 10-year interval based on the requirements of the American Society of Mechanical Engineers (ASME) Operations and Maintenance (OM) 2012 Code Edition. This revision of the R. E. Ginna ASME Inservice Testing (IST) Program will be in effect through the end of the 120-month (10-year) interval unless changed and re-issued for reasons other than the routine update required at the start of the next interval per 10 CFR 50.55a(f). The IST interval begins on January 1, 2020, and is scheduled to end on December 31, 2029.

1.1 Purpose

The purpose of this IST Program is to verify operational readiness of those pumps and valves whose function is required for safety. It is not intended to place the R. E. Ginna Station in a degraded safety condition for the purpose of conducting system or component tests. Therefore, as normally viewed for Code compliance, testing of a safety train will not be performed when any redundant train is out of service. Instead, equipment will be positioned to provide for safe plant operation. Pumps and valves included in this program are those in systems or portions of systems which are required to perform a specific function in shutting down the reactor to a safe shutdown condition, in maintaining the safe shutdown condition, or in mitigating the consequences of an accident, as identified within R.E. Ginna Station's licensing basis.

R. E. Ginna is licensed for a safe shutdown condition of hot shutdown. As such, OM Code required testing does not apply to those components whose only safety function relied on is for achieving and maintaining a cold shutdown condition.

1.2 Scope

ASME OM-2012 Code (hereafter referred to as 'the OM Code') requires that the owner of each nuclear power plant prepare and submit a "plan" for testing and inspection of systems and components (pumps, valves, and dynamic restraints) under the jurisdiction of the Code and in compliance with Title 10, Part 50 of the Code of Federal Regulations (Para. 50.55a).

Inservice Testing of ASME Class 1, 2, and 3, and other safety-related pumps and valves is performed in accordance with the OM Code, except as allowed by 10CFR50 or where specific written relief has been granted by the NRC pursuant to 10CFR50.55a(f)(6)(i) for examinations and tests determined to be impracticable. Provided guidance of NUREG 1482, Revision 2, is followed, the proposed alternative examinations or tests may be implemented prior to receiving written NRC approval if so stated in the guidance document.

On August 17, 2017, a revision to the Code of Federal Regulations became effective with a revision to the wording of 10CFR50.55a(f)(4). Paragraph (f)(4) now states, in part, "The inservice test requirements for pumps and valves that are within the scope of the ASME OM Code but are not classified as ASME BPV Code Class 1, Class 2, or Class 3 may be satisfied as an augmented IST program in accordance with paragraph (f)(6)(ii) of this section without requesting relief under paragraph (f)(5) of this section or alternatives under paragraph (z) of this section. This use of an augmented IST program may be acceptable provided the basis for deviations from the ASME OM Code, as incorporated by reference in this section, demonstrates an acceptable level of quality and safety, or that implementing the Code provisions would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety, where documented and available for NRC review."

1.2 Scope (Cont.)

In accordance with the OM Code and 10CFR50.55a, the following are required to be included in the testing Program:

ASME Class 1, 2, and 3, and other safety-related centrifugal and positive displacement pumps that are provided with an emergency power source and are required to perform a specific function in:

- a. Shutting down the reactor to the safe shutdown condition;
- b. Maintaining the safe shutdown condition; or Mitigating the consequences of an accident.

ASME Class 1, 2, and 3, and other safety-related active or passive valves (and their actuating and position indicating systems) which are required to perform a specific function in:

- a. Shutting down the reactor to the safe shutdown condition;
- b. Maintaining the safe shutdown condition; or
- c. Mitigating the consequences of an accident.

ASME Class 1, 2, and 3, and other safety-related pressure relief devices that protect systems or portions of systems which perform a required function in:

- a. Shutting down the reactor to the safe shutdown condition;
- b. Maintaining the safe shutdown condition; or
- c. Mitigating the consequences of an accident.

Dynamic restraints (snubbers) used in systems that perform one or more of the required functions:

- a. Shutting down the reactor to the safe shutdown condition;
- b. Maintaining the safe shutdown condition; or
- c. Mitigating the consequences of an accident.

NOTE: Dynamic restraints (snubbers) are addressed in a separate test program.

In addition to the general OM Code requirements outlined above, there are other interpretations and positions that have come about as a result of past regulatory and licensee actions including NUREG-1482.

The term "accident" refers not only to the design basis accidents analyzed in Chapter 15 of the UFSAR, but to a broad range of possible adverse events which could affect plant safety. Additional accidents and operational transients, and the equipment required to mitigate the possible consequences thereof, are identified in the UFSAR.

The R. E. Ginna safety analysis specifically requires the plant to reach a safe-shutdown condition defined as hot shutdown and not the cold shutdown condition. Per NUREG-1482, Revision 2, pumps and valves in such plants needed only to reach cold shutdown need not be included in the IST Program. However, in some instances, R. E. Ginna has decided to include cold shutdown-related components in the Program for completeness even though compliance with Code requirements may not be required.

1.2 Scope (Cont.)

In light of the foregoing, a set of rules was established by which the scope of the R. E. Ginna ASME OM Code IST Program is determined including components that are to be included and the extent and type of testing required for each component. Based on these rules, the philosophy and assumptions used in determining the test requirements for selected pumps and valves were documented.

In addition to those pumps and valves required to be tested by the Code, other "augmented" components are administratively included in the program from a good engineering and management practice standpoint. The inclusion of components designated as "augmented" within the IST program has been discussed in NUREG-1482, Rev. 2, Section 2.2, Generic Letter 89-04, NRC Staff Position II, "Scope of IST Programs", and Summary of Public Workshops Held in NRC Regions on Inspection Procedure 73756, Section 1, General Questions. These components are identified as "augmented" in the test tables and need not be tested to specific Code criteria.

1.3 Discussion

1.3.1 Commercial Operation Date and IST Intervals

As noted on the cover page, the R. E. Ginna Nuclear Station commercial service date was September 19, 1969. The fourth ten-year IST interval ended on December 31, 2009. The fifth ten-year interval began on January 1, 2010, and is scheduled to end on December 31, 2019. The sixth ten-year IST interval will begin on January 1, 2020, and is scheduled to end on December 31, 2029.

1.3.2 ASME Code for Operation and Maintenance of Nuclear Power Plants, 2012 Edition

For R. E. Ginna, the next 120-month interval begins on January 1, 2020. Therefore, the Code Edition of interest is the one endorsed by the NRC in 10CFR50.55a as of January 1, 2019. The Code Edition in effect on January 1, 2019 was the 2012 Edition of ASME OM Code, no addenda.

Subsections and Appendices of the ASME Code for Operation and Maintenance of Nuclear Power Plants, 2012 Edition are as follows:

a. ASME OM Code, Subsection ISTA, "General Requirements"

ISTA contains the requirements directly applicable to inservice testing including the Owner's Responsibility and Records Requirements.

b. ASME OM Code, Subsection ISTB, "Inservice Testing of Pumps in Light-Water Reactor Nuclear Power Plants – Pre-2000 Plants"

ISTB establishes the requirements for inservice testing of pumps in light-water reactor nuclear power plants. The pumps covered are those provided with an emergency power source, that are required in shutting down the reactor to the safe shutdown condition, in maintaining the safe shutdown condition, or in mitigation of the consequences of an accident.

1.3 Discussion (Cont.)

c. ASME OM Code, Subsection ISTC, "Inservice Testing of Valves in Light-Water Reactor Nuclear Power Plants"

ISTC establishes the requirements for inservice testing of valves in light-water reactor nuclear power plants. The valves covered include those that are required to perform a specific function, either active or passive, in shutting down a reactor to the safe shutdown condition, in maintaining the safe shutdown condition, or in mitigating the consequences of an accident. Valves that provide over-pressure protection to systems or portions of system that are required to perform any of these functions are also included.

d. ASME OM Code, Subsection ISTD, "Preservice and Inservice Examination and Testing of Dynamic Restraints (Snubbers) in Light-Water Reactor Nuclear Power Plants"

ISTD establishes the requirements for preservice and inservice testing of dynamic restraints (snubbers) in light-water reactor nuclear power plants. The snubbers covered include those in systems that perform a specific function in shutting down the reactor to the safe shutdown condition, in maintaining the safe shutdown condition, or in mitigation of the consequences of an accident.

e. ASME OM Code, Division 1, Mandatory Appendix I, "Inservice Testing of Pressure Relief Devices in Light-Water Reactor Nuclear Power Plants"

Appendix I provides the requirements for performance testing and monitoring of nuclear plant pressure relief devices. Methods, intervals, and record requirements for monitoring and testing are established, as well as requirements for the evaluation of results.

f. ASME OM Code, Division 1, Mandatory Appendix II, "Check Valve Condition Monitoring Program"

Appendix II provides an alternative to the check valve testing or examination requirements of ISTC-3510, ISTC-3520, ISTC-3530, ISTC-3550, and ISTC-5221. The purpose of this program is both to improve valve performance and to optimize testing, examination, and preventive maintenance activities in order to maintain the continued acceptable performance of a select group of check valves.

g. ASME OM Code, Division 1, Mandatory Appendix III, "Preservice and InserviceTesting of Active Electric Motor Operated Valve Assemblies in Light-Water Reactor Power Plants"

Appendix III establishes the requirements for inservice testing to assess the operational readiness of active motor-operated valves (MOVs) in light-water reactor power plants.

h. ASME OM Code, Division 1, Mandatory Appendix V, "Pump Periodic Verification Test Program"

Appendix V establishes the requirements for implementing a pump periodic verification test (PPVT). As discussed in ISTB-1400, the Owner shall establish a PPVT program for certain applicable pumps that are tested in accordance with para. ISTA-1100.

1.3 Discussion (Cont.)

1.3.3 ASME OM Code Cases

Additionally, ASME OM Code Cases (CC) that have been approved for use by the NRC per Regulatory Guide 1.192 and are adopted for use at R. E. Ginna (subject to additional NRC approval where required) are identified below. These Code Cases shall be used during the 10-Year Interval IST Program implementation with all conditions, as applicable: On August 17, 2017, a revision to the Code of Federal Regulations became effective with a new OM condition 10CFR50.55a(b)(3)(x), "ASME OM Code Case OMN-20," to allow licensees to implement OM Code Case OMN-20, "Inservice Test Frequency," with the OM Code, 2012 Edition.

CC OMN-20, "Inservice Test Frequency," Revision 0.

ASME OM CC OMN-20 allows the use of "Test Frequency Grace." The R. E. Ginna new 10-year interval IST Program will voluntarily and fully implement CC OMN-20 as written in the 2012 Edition of ASME OM Code for all applicable pumps and valves included in the IST program as follows:

Components whose test frequencies are based on elapsed time periods shall be tested at the frequencies specified in Section IST with a specified time period between tests as shown in Table 1. The specified time period between tests may be reduced or extended as follows:

(1) For periods specified as fewer than 2 years, the period may be extended by up to 25% for any given test.

(2) For periods specified as greater than or equal to 2 years, the period may be extended by up to 6 months for any given test.

(3) All periods specified may be reduced at the discretion of the owner (i.e., there is no minimum period requirement).

Period extension is to facilitate test scheduling and considers plant operating conditions that may not be suitable for performance of the required testing (e.g., performance of the test would cause an unacceptable increase in the plant risk profile due to transient conditions or other ongoing surveillance, test, or maintenance activities). Period extensions are not intended to be used repeatedly merely as an operational convenience to extend test intervals beyond those specified.

Period extensions may also be applied to accelerated test frequencies (e.g., pumps in alert range) and other fewer than 2-yr test frequencies not specified in Table 1.

Period extensions may not be applied to the test frequency requirements specified in Subsection ISTD, Preservice and Inservice Examination and Testing of Dynamic Restraints (Snubbers) in Light-Water Reactor Nuclear Power Plants, as Subsection ISTD contains its own rules for period extensions.

1.3 Discussion (Cont.)

1.3.3 ASME OM Code Cases (Cont.)

Components whose test frequencies are based on the occurrence of plant conditions or events may not have their period between tests extended except as allowed by ASME OM, Division 1, Section IST, 2009 Edition through OMa-2011 Addenda and all earlier editions and addenda.

Table 1 Specified Test Frequencies

Frequency Quarterly (or every 3 mo)	Specified Time Period Between Tests 92 days
Semiannually (or every 6 mo)	184 days
Annually (or every year)	366 days
X years	<i>x</i> calendar years where <i>x</i> is a whole number of years greater than or equal to 2 years

1.3.4 Regulatory Issue Summaries

In Regulatory Issue Summary (RIS) 2012-10, "NRC Staff Position on Applying Surveillance Requirement 3.0.2 and 3.0.3 to Administrative Controls Program Tests," and Enforcement Guidance Memorandum (EGM) 2012-001, "Dispositioning Noncompliance with Administrative Controls Technical Specifications Programmatic Requirements that Extend Test Frequencies and Allow Performance of Missed Tests," the NRC stated that items b, c, and d of the Technical Specifications (TS) IST Program were inappropriately added to the TS and may not be applied (although the EGM allows licensees to continue to apply those paragraphs pending a generic resolution of the issue).

In RIS 2012-10 and EGM 2012-001, the NRC stated that the current TS allowance to apply SR 3.0.2 and SR 3.0.3, or equivalent, to the IST Program would no longer be permitted. In response, OMN-20, which provides allowances similar to SR 3.0.2, or equivalent, was approved and is proposed to be used as an alternative to the test periods specified in the OM code. The proposed alternative substitutes an approved Code Case for the existing TS requirements that the NRC has determined are not legally acceptable as a TS allowance. This proposed alternative provides an equivalent level of safety as the existing TS allowance, while maintaining consistency with 10 CFR 50.55a and the ASME OM Code.

For pumps and valves with test periods of two years or less, the test frequency allowed by OMN-20 and the current TS IST Program (as modified by SR 3.0.2, or equivalent, and EGM 2012-001) are the same. For pumps and valves with test frequencies greater than two years, OMN-20 allows the test frequency to be extended by six months. The current TS IST Program does not allow extension of test frequencies that are greater than two years.

- 1.3 Discussion (Cont.)
- 1.3.4 Regulatory Issue Summaries (Cont.)

As stated in EGM 2012-001, if an Inservice Test is not performed within its frequency, SR 3.0.3, or equivalent, will not be applied. The effect of a missed Inservice Test on the Operability of TS equipment will be assessed under the R. E. Ginna Operability Determination Program.

1.3.5 Generic Letter 89-04 and NUREG-1482

Generic Letter 89-04 provided mandatory guidance for several areas of IST Program Plan scoping and content that the NRC staff had determined to be an industry generic weakness. Subsequent to the Generic Letter, NUREG-1482 was issued and the Generic Letter was included as an appendix in the NUREG. The NUREG expands on the guidance provided by the Generic Letter. To keep the guidance in the NUREG current, the NRC issued Revision 2 in October 2013. Revision 2 incorporates regulatory changes up to and including the 2004 Edition including 2005 and 2006 addendas of Title 10, Part 50, of the Code of Federal Regulations. The "Code-of-Record" for this revision of the NUREG is the ASME OM Code, 2004 Edition through the 2006 Addenda.

NUREG-1482, while voluntary, incorporates the "non-voluntary" guidance in Generic Letter 89-04. In addition, NUREG-1482 provides discussion of some issues that are relevant to IST programs and their implementation.

This IST Program Plan is based on the recommendations of NUREG 1482, Revision 2. This Program Plan describes the testing requirements and R. E. Ginna Station commitments for testing those ASME Code Class 1, 2, and 3, and other safety-related active or passive components that meet the criteria for inclusion in the IST Program.

1.4 IST Program Plan

This document is the Pump and Valve Inservice Testing Program Plan for R. E. Ginna in compliance with the requirements of 10CFR50.55a(f) and Technical Specifications. This Program Plan was prepared in accordance with the rules of the ASME OM-2012 Code. Appendix I is used for safety and relief valves; Subsection ISTB and Appendix V for pump testing; and Subsection ISTC for most valve testing along with Mandatory Appendix II for check valves and Mandatory Appendix III for active motor operated valve testing.

In accordance with ASME OM Code, ISTA-1320, some systems are ASME classified as an optional upgrade. The upgrade directs that the repair, replacement, and maintenance activities will be performed to ASME rules. It does not require the owner to conduct periodic inservice, functional, or hydrostatic testing. For optionally upgraded systems, ISTA-1320 states that the application of the rules (ASME Code) is at the option of the owner and not a requirement.

A summary listing of all the pumps and valves that are tested in accordance with the IST Program is provided in the IST Pump and IST Valve Tables contained in Attachments 14 and 15. The Pump and Valve Tables also identify each test that is performed on each component, the frequency at which the test is performed, and any Relief Request or Technical Position applicable to the test. For valves, the Valve Table also identifies any Cold Shutdown Justification or Refueling Outage Justification that is applicable to the required exercise tests. Additional information is provided for both pumps and valves.

All data fields included in the IST Pump and Valve Tables are listed and described in Sections 2 and 3 of this document.

Following Sections 2 and 3 are Attachments which provide information referenced in the Pump and Valve Tables.

- Attachment 1 includes a listing of P&IDs on which a depiction of the pump or valve may be located.
- Attachment 2 provides an index of the Pump Relief Requests that apply to any of the pumps in the IST Program for this ten-year interval.
- Attachment 3 includes a copy of each of those Relief Requests.
- Attachment 4 provides an index of the Valve Relief Requests that apply to any of the valves in the IST Program for this ten-year interval.
- Attachment 5 includes a copy of each of those Relief Requests.
- Attachment 6 contains the Safety Evaluation Report(s) (SER) that document approval of the Relief Requests contained in Attachments 3 and 5. It also includes Requests for Additional Information (RAIs) received from the NRC regarding the Relief Requests and the responses provided by Exelon.
- Attachment 7 includes a list of the ASME OM Code Cases that are being invoked for this tenyear interval.
- Attachment 8 provides an index of Cold Shutdown Justifications that apply to the exercise testing of any valves in the IST Program for this ten-year interval.
- Attachment 9 includes a copy of each of those Cold Shutdown Justifications.
- Attachment 10 provides an index of Refueling Outage Justifications that apply to the exercise testing of any valves in the IST Program for this ten-year interval.
- Attachment 11 includes a copy of each of those Refueling Outage Justifications.
- Attachment 12 provides an index of Technical Positions that apply to the IST Program for this ten-year interval. Technical Positions provide detailed information regarding how Exelon satisfies certain ASME OM Code requirements, particularly when the Code requirement may be ambiguous or when multiple options for implementation may be available. Technical Positions do not take exception to or provide alternatives to Code requirements.
- Attachment 13 includes a copy of each Technical Position listed in Attachment 12.
- As described previously, Attachments 14 and 15 include the IST Pump and Valve Tables.
- Attachment 16 provides a listing of Check Valve Condition Monitoring (CVCM) Program Plans.

This IST Program Plan is a quality-related document and is controlled and maintained in accordance with approved Exelon Corporate Engineering and Records Management procedures.

1.5 References

This Program Plan was developed per the requirements and guidance provided by the following documents:

General References:

- a. Title 10, Code of Federal Regulations, Part 50, Section 55a(f), Inservice Testing Requirements
- b. Regulatory Guide 1.192, "Operations and Maintenance Code Case Acceptability, ASME OM Code", Revision 2, dated March 2017
- c. NUREG/CR-6396, Examples, Clarifications, and Guidance on Preparing Requests for Relief from Pump and Valve Inservice Testing Requirements
- d. NUREG-0800, Standard Review Plan Section 3.9.6, "Inservice Testing of Pumps and Valves"
- e. NUREG-0821, Systematic Evaluation Program (SEP) topics
- f. ASME OM-2012, "Code for Operation and Maintenance of Nuclear Power Plants"
- g. NUREG 1482, Revision 2, "Guidelines for Inservice Testing at Nuclear Power Plants"
- Summary of Public Workshops Held in NRC Regions on Inspection Procedure 73756, "Inservice Testing of Pumps and Valves and Answers to Panel Questions on Inservice Testing Issues," dated 7/18/97
- NRC Regulatory Guide 1.26, "Quality Group Classification and Standards for Water-, Steam, and Radioactive-Waste-Containing Components of Nuclear Power Plants", dated March 23, 1972
- j. Exelon Corporation Administrative Procedure ER-AA-321, Administrative Requirements for Inservice Testing

Unit Specific References:

- k. R. E. Ginna Station Updated Final Safety Analysis Report (UFSAR)
- I. R. E. Ginna Station Technical Specifications
- m. Interface Procedure IP-IIT-2, Inservice Testing Program for Pumps and Valves
- n. Interface Procedure IP-IIT-3, Containment Leakage Rate Testing Program

2.0 INSERVICE TESTING PROGRAM FOR PUMPS

2.1 Code Compliance

The R. E. Ginna Station IST Program for pumps meets the requirements of Subsections ISTA, ISTB, and Mandatory Appendix V of the OM Code and any applicable interpretations or clarifications of existing requirements. Paragraph and table references in this section refer to specific paragraphs and tables in the OM Code. Where these requirements have been determined to be impractical, an alternative test provides an acceptable level of quality and safety, or conformance would cause unreasonable hardship without any compensating increase in safety, relief from Code requirements is/was requested pursuant to the requirements of 10CFR 50.55a(f)(5)(iii), 10CFR50.55a(z)(1), or 10CFR50.55a(z)(2).

2.2 Allowable Ranges of Test Quantities

The allowable ranges for test parameters as specified in the OM Code, Tables ISTB-5121-1, ISTB-5221-1, and ISTB-5321-1 will be used for all measurements of pressure, flow, and vibration except as provided for in specific relief requests.

2.3 Testing Intervals

The test frequency for pumps included in the Program will be as set forth in OM Code, paragraph ISTB-3400 and related relief requests. An allowable extension, not to exceed +25 percent of the surveillance interval may be applied to a test schedule as allowed by the R. E. Ginna Technical Specifications or OM Code Case OMN-20 to provide for operational flexibility.

The frequencies used for scheduling pump tests are defined as:

- a. Quarterly (Q) 92 days
- b. Biennial (2Y) 730 days
- c. Refueling 546 days
- d. Cold Shutdown Per the applicable Relief Request consistent with the cold shutdown testing requirements for valves in the OM Code. When all cold shutdown testing will not be completed, priorities for testing will be established per approved R. E. Ginna procedures.

2.4 Instrument Accuracy

Instruments will meet the requirements specified in the OM Code, paragraph ISTB-3500, and amplified in NUREG 1482, Revision 2, Section 5, except where specific relief is granted.

2.5 Vertical Line Shaft Pumps

Paragraph ISTB-2000 of the OM Code defines a Vertical Line Shaft pump as "a vertically suspended pump where the pump driver and the pump element are connected by a line shaft within an enclosed column." In a vertical line shaft pump configuration, the pump bearings would be submerged in the pumped fluid and inaccessible.

2.6 Pump Function and Design Flow

2.6.1 Group A Pumps

The OM Code defines Group A pumps as those pumps that are operated continuously or routinely during normal operation, cold shutdown, or refueling operations. Ginna considers the following pumps as being categorized as Group A. The justification does not necessarily consider all safety related functions.

- Component Cooling Water (CCW) Pumps, [PAC02A, 02B] The component cooling water pumps perform the safety-related function of providing cooling water flow to certain essential equipment during post-accident conditions. A large break loss-of-coolant accident (LOCA) in conjunction with a loss of offsite power places the most severe demands on the CCW system. Under these conditions, the CCW pumps are capable of supplying the required accident cooling flow to those safety-related components dependent upon CCW for continued operability. During normal plant operation the CCW pumps provide cooling water to various nonessential heat loads.
- Charging Pumps, [PCH01A, 01B, 01C] The charging pumps together with the charging system perform the following process functions during normal plant operation; 1) control reactor coolant inventory, chemistry conditions, activity level, and boron concentrations, 2) provide seal water injection flow to the reactor coolant pumps, 3) process reactor coolant effluent for reuse of boric acid and makeup water.

Safety significant functions of the charging pumps together with the charging system are to provide makeup and boration to the RCS via two credited flowpaths. During the safety significant function of makeup and boration the borated water supply source would be provided from the RWST. One charging pump alone can provide cold shutdown boration requirements immediately following reactor shutdown.

The charging pumps will be included in the IST Program scope as Augmented components since their only credited function is achieving coldshutdown. Ginna Station's safe shutdown condition is the Hot Shutdown condition; therefore, they do not meet the scoping/selection criteria specified in paragraph ISTA-1100 of the OM Code. The basis for the testing requriements applied to the charging pumps is documented in Alternative Relief Evaluation, PRE-01.

- Motor Driven Auxiliary Feedwater Pumps (MDAFW), [PAF01A, 01B] For worst case UFSAR Chapter 15 events the MDAFW pumps are required to be capable of supplying AFW flow to the steam generators during a loss of normal feedwater flow or a steam line break (SLB) in conjunction with a loss of offsite power. During plant operation, the MDAFW pumps are briefly utilized during startup to maintain steam generator water level.
- **Residual Heat Removal (RHR) Pumps, [PAC01A, 01B]** The RHR pumps perform the safetyrelated function of providing low head safety injection and recirculation flow to the RCS, and long term shutdown cooling during post-accident conditions. During the recirculation phase of a small break LOCA, the RHR pumps have the capability of providing suction to the high head safety injection pumps via the RHR heat exchangers. During normal shutdown activities the RHR pumps, in conjunction with the RHR heat exchangers are utilized for decay heat removal from the RCS.

2.6 Pump Design Flow (Cont.)

2.6.1 Group A Pumps (Cont.)

• Spent Fuel Pool (SFP) Recirculation Pumps, [PAC07A, 07B] - SFP recirculation pump A performs the safety significant function of providing heat removal from the spent fuel pool by circulating fuel pool inventory through SFP heat exchanger A, allowing the residual heat to be transferred to the service water system. This function is required to limit the pool temperature during maximum normal heat load conditions associated with a refueling outage. SFP pump A is included in the IST Program scope as an Augmented component. The basis for the testing requirements applied to SFP pump A is documented in Alternative Relief Evaluation, PRE-02.

SFP recirculation pump B performs the safety-related function of providing heat removal from the spent fuel pool by circulating fuel pool inventory through SFP heat exchanger B, allowing the residual heat to betransferred to the service water system. The maximum safety basis or abnormal heat load assumed by design is that resulting from offloading a complete core.

• Service Water (SW) Pumps, [PSW01A, 01B, 01C, 01D] - The SW pumps perform the safetyrelated function of heat removal from essential safety-related equipment during accident conditions and serve as a suction supply source for the SAFW pumps. During normal plant operation the SW pumps provide cooling water flow to numerous nonessential heat loads.

2.6.2 Group B Pumps

The OM Code defines Group B pumps as those pumps in standby systems that are not operated routinely except for testing. Ginna considers the following pumps as being categorized as Group B. The justification does not necessarily consider all safety related functions.

- Containment Spray Pumps, [PSI02A, 02B] The containment spray pumps perform the safetyrelated function of providing a means for containment heat removal and pressure suppression in the event of a LOCA or steam line break inside containment. The CS system serves to limit peak containment pressure. This function is accomplished by spraying relatively cool borated water from the RWST to inside the containment via the spray nozzles. Suction supply to the containment spray pumps can also be provided from the RHR heat exchanger discharge when operating in the recirculation mode. The containment spray pumps also perform the safety-related function of removing fission products released into the containment atmosphere during a LOCA. This is accomplished by the addition of sodium hydroxide (NaOH) to the borated spray stream at the suction of the pumps. The pumps are not operated except during testing.
- **Diesel Generator Fuel Oil Transfer Pumps, [PDG02A, 02B]** The diesel generator fuel oil transfer pumps perform the safety-related function of transferring fuel oil from the storage tank to the day tank. This function ensures a continuous fuel supply in support of long term operation of the engine during accident conditions. The pumps are operated only during testing.
- **Turbine Driven Auxiliary Feedwater Pump, [PAF03]** For worst case UFSAR Chapter 15 events the TDAFW pump is required to be capable of supplying AFW flow to the affected unit. Pump controls and associated valves receive their power from the vital 125 VDC supply source to ensure short term operability independent of normal or emergency AC power satisfying beyond design basis station blackout requirements. The pump is operated only during testing.

2.6 Pump Design Flow (Cont.)

2.6.2 Group B Pumps (Cont.)

- Standby Auxiliary Feedwater (SAFW) Pumps, [PSF01A, 01B] The SAFW pumps are required to be capable of supplying AFW flow to the steam generators in the event that the preferred AFW system has failed due to a high energy line break (HELB) in the intermediate building, a seismic event, or fire. The SAFW pumps have the same features as the MDAFW pumps with regard to functional capability and power supply separation. The pumps are started manually and will only start provided that the breaker for the associated MDAFW pump is open. The suction supply source is service water and the service water supply valve must be in the open position before the pumps will start. The pumps are operated only during testing.
- Safety Injection (SI) Pumps, [PSI01A, 01B, 01C] The SI pumps perform the safety-related function of providing high head safety injection and recirculation flow to the RCS, and long term shutdown cooling during post-LOCA conditions. In addition, the system accomplishes the safety related function of bringing the plant to a safe shutdown condition subsequent to a steam line break. During the recirculation phase, the RHR pumps circulate containment sump inventory through the RHR heat exchangers to the SI pumps supply for return to the core. SI recirculation would be required only if RCS pressure remained above the shutdown head of the RHR pumps. The pumps operate only during testing.
- 2.7 Specific Pump Testing Requirements
- a. Surveillance Test Procedures shall be written for testing those pumps in the IST Program. These procedures shall provide for measurement of the required parameters at the stated frequency.
- b. Reference values

Reference values shall be obtained as follows:

- Established only when the pump is known to be operating acceptably.
- Established at a point(s) of operation (reference point) readily duplicated during subsequent tests.
- Established in a region(s) of relatively stable pump flow.

Reference values shall be established at the comprehensive pump test flow rate for the comprehensive test.

Reference values shall be established at the comprehensive pump test flow rate for the Group A and Group B tests, if practicable. If not practicable, the reference point flow rate shall be established at the highest practical flow rate.

- 2.7 Specific Pump Testing Requirements (Cont.)
- c. Allowable Variance from Fixed Reference Points

The OM Code allows for variance from a fixed reference value, stating that "the resistance of the system shall be varied until the flow rate is as close as practical to the reference point with the variance not to exceed +2% or -1% of the reference point. The differential pressure shall then be determined and compared to its reference value. Alternatively, the flow rate shall be varied until the differential pressure is as close as practical to the reference point with the variance not to exceed +1% or -2% of the reference point and the flow rate determined and compared with the reference flow rate. Where it is not practical to vary system resistance, flow rate and pressure shall be determined and compared to their respective reference values."

- d. Pump Monitoring, Analysis, and Evaluation
 - 1. Applicable pump test parameters, except for fixed values, shall be trended [ISTB-6100].
 - 2. If measured test parameter values fall within the OM Code alert range, the frequency of testing specified in paragraph ISTB-3400 shall be doubled until the cause of the deviation is determined and the condition is corrected, or an analysis of the pump is performed.
 - 3. If the measured test parameter values fall within the required action range, the pump shall be declared inoperable until either the cause of the deviation has been determined and the condition is corrected, or an analysis of the pump is performed.
 - 4. In cases where the pump's test parameters are within either the alert or required action ranges, an analysis may be performed that supports the pump's continued use at the changed values. This analysis shall include verification of the pump's operational readiness. The analysis shall include both a pump level and a system level evaluation of operational readiness, the cause of the change in pump performance, and an evaluation of all trends indicated by available data. The analysis shall also consider whether new reference values should be established and shall justify the adequacy of the new reference values, if applicable.
- 2.8 Mandatory Appendix V "Pump Periodic Verification Test Program"

This Mandatory Appendix contains requirements to augment the rules of Subsection ISTB, Inservice Testing of Pumps in Light Water Reactor Nuclear Power Plants. The Owner is not required to perform a pump periodic verification test, if the design basis accident flow rate (DBAFR) in the Owner's safety analysis is bounded by the Comprehensive Pump Test (CPT) or Group A Test.

A pump periodic verification test (PPVT) verifies a pump can meet the required (differential or discharge) pressure, as applicable, at its highest design basis accident flowrate.

- 2.8.1 Mandatory Appendix V General Requirements
 - a. Identify those certain applicable pumps with specific design basis accident flow rates in the credited safety analysis (e.g., technical specifications, technical requirements program, or updated safety analysis report) for inclusion in this program.
 - b. Perform the pump periodic verification test atleast once every 2 years.

- 2.8.1 Mandatory Appendix V General Requirements (Cont.)
 - c. Determine whether the pump periodic verification test is required before declaring the pump operable following replacement, repair, or maintenance on the pump.
 - d. Declare the pump inoperable if the pump periodic verification test flow rate and associated differential pressure (or discharge pressure for positive displacement pumps) cannot be achieved.
 - e. Maintain the necessary records for the pump periodic verification tests, including the applicable test parameters (e.g., flow rate and associated differential pressure, or flow rate and associated discharge pressure, and speed for variable speed pumps) and their basis.
 - f. Account for the pump periodic verification test instrument accuracies in the test acceptance criteria.

2.9 IST Plan Pump Table Description

The pumps included in the R. E. Ginna Station IST Program are listed inAttachment 14. The information contained in that table identifies those pumps required to be tested to the requirements of the ASME OM Code, the parameters measured, associated relief requests and comments, and other applicable information. The column headings for the Pump Table are listed below with an explanation of the content of each column.

<u>Pump ID</u> or Pump EIN	The unique identification number for the pump, as designated on the System P&ID or Flow Diagram	
Description	The descriptive name for the pump [use PIMS, Passport, FCMS, etc. names for consistency]	
<u>Pump Type</u>	An abbr C PDN PDR VLS	eviation used to designate the type of pump: Centrifugal Positive Displacement - Non-Reciprocating Positive Displacement - Reciprocating Vertical Line Shaft
<u>P&ID</u>	The Pipi	ing and Instrumentation Diagram or Flow Drawing on which the pump is shown
<u>Sheet</u>	The She	eet Number of the P&ID identified in the previous column
(Coord)	Coordin	ates of the P&ID where the pump is located
Code Class	The ASME Safety Class (i.e., 1, 2 or 3) of the pump. Non-ASME Safety Class pumps are designated "N/A".	
<u>Group</u>	A or B, a	as defined in Reference 1.5.f.
<u>Test</u> Parameters	Lists each of the test parameters which are required to be measured for the sp pump. These include:	
	N dP DIS-P Q Vd Vv SKID	Speed (for variable speed pumps, only) Differential Pressure Discharge Pressure (positive displacementpumps) Flow Rate Vibration (displacement) Vibration (velocity) Skid mounted
Procedure	Test Pro	ocedure which implements the testing identified in the previous column.
<u>Freq</u>	An abbreviation which designates the frequency at which the associated test is performed:	
	Q Y2	Quarterly Once every 2 years
	NOTE: docume	All tests are performed at the frequencies specified by Code unless specifically nted by a Relief Request.
<u>Code</u> Deviation	Identifie applicab	s the number of the Relief Request or Technical Position identification number le to the pump or specified test.
<u>Comments</u>	Any app	propriate reference or explanatory information (e.g., technical positions, etc.)

3.0 INSERVICE TESTING PROGRAM FOR VALVES

3.1 Code Compliance

The R. E. Ginna Station IST Program for valves meets the requirements of Subsections ISTA, ISTC, and Appendices I, II, and III of the OM Code and any applicable interpretations or clarifications of existing requirements provided by NUREG 1482, Revision 2. Paragraph and table references in this section refer to specific paragraphs and tables in the OM Code. Where these requirements have been determined to be impractical, an alternative test provides an acceptable level of quality and safety, or conformance would cause unreasonable hardship without any compensating increase in safety, relief from Code requirements is/was requested pursuant to the requirements of 10CFR 50.55a(z)(1) or 10CFR50.55a(z)(2).

3.1.1 Exemptions

The following components are excluded from the testing requirements of this section, provided that the components are not required to perform a specific function as previously described in section 1.0:

- a. valves used only for operating convenience such as vent, drain, instrument, and test valves.
- b. valves used only for system control, such aspressure-regulating valves.
- c. valves used only for system or component maintenance

Skid-mounted valves are excluded from Subsection ISTC, provided they are tested as part of the major component and are justified by the Owner to be adequately tested.

External control and protection systems responsible for sensing plant conditions and providing signals for valve operation are excluded from the requirements of Subsection ISTC.

Category A and Category B safety and relief valves are excluded from the requirements of paragraph ISTC-3700, Valve Position Verification and paragraph ISTC-3500, ValveTesting Requirements.

- 3.2 Power Operated Valves (POV) Test Requirements
- 3.2.1 Category A and B POVs, except motor-operated valves (MOV)
 - a. The exercise test shall consist of exercising the valve full open and/or full close and measuring stroke time(s) in the safety direction(s) as required.
 - b. When measuring valve stroke time, stroke time will commence upon movement of the valve control switch and end when the desired position indication is the only light that is illuminated (control switch to light) indicating full open/full close.
 - c. When a valve has no indicating lights in its designed electrical circuit, alternate acceptable means may be used to measure time from initiation of actuating signal to end of activating cycle (e.g., local timing by acoustic or visual observation).
 - d. For fail-safe valves, whereby placing the control switch in the OPEN position for fail-open valves, and the CLOSED position for fail-closed valves, results in a loss of actuator power; the fail-safe testing requirements are satisfied by the exercise test.

3.2.2 POV Failures and Corrective Action

Power Operated Valves (POV's) which fail to operate or exceed the limiting (maximum) stroke time acceptance criteria contained in the Surveillance Test Procedure, shall be declared inoperable. The Technical Specifications shall be reviewed for any applicable LCO Conditions. Valves declared inoperable may be repaired, replaced, or the data may be analyzed to determine the cause of the deviation and the valve shown to be operating acceptably. Valve operability based upon analysis shall have the results of the analysis recorded in the record of tests.

3.2.3 Stroke-Time Testing of Multiple Valves Operated From A Single Switch

Some power-operated valves are grouped together on a common control switch. Valves tested as a group will be identified in the valve test tables. When individual valve position indication is available for multiple valves stroked from a single switch, and the ability exists to measure stroke time, the time shall be recorded. Such valves shall be stroke timed using sufficient stopwatches and resources to ensure that all valves are timed on the same switch movement. This satisfies the Code requirement for stroke-timing each valve individually and prevents inadvertent pre-conditioning that could be caused by multiple switch manipulations and multiple valve strokes.

3.2.4 Reactor Coolant System Pressure Isolation Valves

Reactor Coolant System Pressure Isolation Valves (PIVs) are Category A valves. ISTC-3630(f), requires that a valve with leakage rates exceeding the value specified by the Owner per ISTC-3630(e) shall be declared inoperable and either repaired or replaced. An ASME Code Interpretation (Interpretation 95-5) states, "It is up to the Owner to define what activities constitute maintenance, replacement, or a repair." These definitions are drawn from existing definitions in ASME Section XI and from R. E. Ginna Station procedures. Activities undertaken to correct or prevent unsatisfactory or abnormal conditions shall fulfill the requirement for Corrective Action in ISTC-3630(f).

There are 12 PIVs listed in the R. E. Ginna Technical Specifications Bases.

Valve Number	Valve Type
853A	Check Valve
853B	Check Valve
867A	Check Valve
867B	Check Valve
877A	Check Valve
877B	Check Valve
878A	Motor Operated Valve
878C	Motor Operated Valve
878F	Check Valve
878G	Check Valve
878H	Check Valve
878J	Check Valve

Primary Coolant System Pressure Isolation Valves

3.2.4 Reactor Coolant System Pressure Isolation Valves (Cont.)

There are 9 additional PIVs not listed in the R. E. Ginna Technical Specifications Bases.

Valve Number	Valve Type
123	Air Operated Valve
700	Motor Operated Valve
701	Motor Operated Valve
720	Motor Operated Valve
721	Motor Operated Valve
842A	Check Valve
842B	Check Valve
852A	Motor Operated Valve
852B	Motor Operated Valve

Primary Coolant System Pressure Isolation Valves

3.3 Check Valve Testing

3.3.1 Test Methods

Check valves are full-stroke exercised in the open direction using the following methods:

- a. Using system flow equal to, or greater than, the required accident flow rate (plus allowance for analytical and instrument uncertainties).
- b. Non-intrusive monitoring, or other positive means, that verifies the valve disk reaches the fullyopen position (recording flow rate is not necessary).
- c. Mechanical exercising.
- d. Other methods that satisfy the requirements of GL 89-04, Position 1 or as specified in an approved relief request.

Check valves are full-stroke exercised in the closed direction using the following methods:

- a. Verifying system flow equal to, or greater than, the required accident flow rate (plus allowance for analytical and instrument uncertainties) is achievable in a parallel flow path when the check valve being tested forms a boundary for that flow path.
- b. Measuring check valve gross leakage or performing a gross pressure drop test to verify the valve disk is in the closed position.
- c. Non-intrusive monitoring, or other positive means, that verifies the valve disk opens and then returns to the fully-closed position (recording leakage is not necessary unless required for Category A valves).
- d. Mechanical exercising.
- e. Other methods that satisfy the requirements of GL 89-04, Position 1 or as specified in an approved relief request.

3.3.2 Non-Intrusive Check Valve Testing

As discussed in NUREG-1482, Revision 2, Section 4.1.2, the NRC determined that the use of nonintrusive techniques is acceptable to verify the full stroke of a check valve. The licensee may use nonintrusive techniques to verify the capability to open, close, and fully stroke in accord with quality assurance program requirements. These techniques are considered "other positive means" in accordance with paragraph ISTC-5221(a), and relief is not required except as would be necessary for the testing frequency if the test interval extends beyond each refueling outage as allowed by the OM Code.

During the initial test of each valve, non-intrusive techniques will be used to verify that the system pressures and flow conditions specified in the test procedures cause the valves to fully stroke. Initial testing of check valves using non-intrusive techniques shall only be performed when the valve is known to be operating acceptably. During subsequent testing, if the system conditions are repeatable, each valve would typically be stroked and monitored using non-intrusive techniques.

Another alternative that may be employed is radiography. The position of the disk and the general condition of the internals may be determined using the radiographic method. This methodology is normally used for verification of valve closure only.

3.3.3 Check Valves Verified Closed by Leak Testing

The OM Code requires that check valves performing a safety function in the closed position be exercised to that position. Certain of these valves cannot be verified in the closed position quarterly because they do not have remote position indication and are generally located inside reactor containment or at other inaccessible locations. These valves may lack design provisions for system testing to verify closure capability at any plant condition. The only practical means of verifying valve closure may be by performing a seat leakage test. Many of these valves are Category AC valves that are Type C leak-rate tested during each refueling outage as specified in Appendix J to 10 CFR Part 50.

If no other practical means is available, it is acceptable to verify that check valves are capable of closing by performing leak-rate testing, such as local leak rate testing in accordance with Appendix J to 10 CFR Part 50, at each reactor refueling outage. Recognizing that the setup and performance limitations may render leak testing impractical during power operation and cold shutdown outages, the NRC has determined that implementation of an extension of the test frequency for such valves is acceptable in accordance with 10 CFR 50.55a(f).

In accordance with paragraph ISTC-5222, and as discussed in NUREG-1482, Revision 2, Section 4.4.7, as an alternative to check valve closure verification by Type C seat leakage testing at refueling, the Appendix II Check Valve Condition Monitoring Program (CVCMP) could justify extending the exercise test interval to the leak test frequencies specified in Option B of Appendix J based on the valve's performance and operating condition.

3.3.4 Check Valve Disassembly and Inspection

When using check valve disassembly in a sampling plan, the IST Program may implement testing such that similar valves in the same service are grouped for testing purposes, not to exceed four valves in a single group (for valve groups of greater than four, the grouping and test schedule must be justified in the description of the testing plan). The sample examination program shall group check valves of similar design, application, and service condition and require a periodic examination of one valve from each group. Grouping of check valves shall be technically justified and shall consider, as a minimum, valve manufacturer, design, service, size, materials of construction, and orientation. Maintenance and modification history should be considered in the grouping process. The details and bases of the sampling program shall be documented and recorded. (paragraph ISTC-5221(c))

During the disassembly process, the full-stroke motion of the obturator shall be verified. Full-motion of the obturator shall be re-verified immediately prior to completing reassembly. Check valves that have their obturator disturbed before full-stroke motion is verified shall be examined to determine if a condition exists that could prevent full opening or closure of the obturator.

At least one valve from each group shall be disassembled and examined at each refueling outage; all valves in each group shall be disassembled and examined at least once every 8 years. If problems are found with the sample valve that are determined to affect the operational readiness of the valve, all valves in the group must be tested during the same outage.

Before return to service, valves that were disassembled for examination or that received maintenance that could affect their performance; shall be exercised, full or part stroke if practicable, with flow in accordance with paragraph ISTC-3520. Those valves shall also be tested for other applicable requirements (e.g., closure verification or leak rate testing) before returning them to service.

As an alternative to the aforementioned disassembly and inspection frequency, the Appendix II CVCMP could justify extending the disassembly and inspection interval to reduce the burden of unnecessary IST based on previous disassembly and inspection results.

3.3.5 Check Valve Condition Monitoring

As an alternative to the testing or examination requirements of paragraphs ISTC-3510, ISTC-3520, ISTC-3530, ISTC-3550, and ISTC-5221, R. E. Ginna Station has established a check valve condition monitoring program per paragraph ISTC-5222 and implements the program in accordance with Appendix II "Check Valve Condition Monitoring Program" and 10CFR50.55a(b)(3)(iv), OM Condition: Check Valves (Appendix II).

The purpose of this program is to both (a) improve check valve performance and to (b) optimize testing, examination, and preventive maintenance activities in order to maintain the continued acceptable performance of a select group of check valves.

Examples of candidates for (a) improved valve performance are check valves that: (1) have an unusually high failure rate during inservice testing or operations; (2) cannot be exercised under normal operating conditions or during shutdown; (3) exhibit unusual, abnormal, or unexpected behavior during exercising or operation, or (4) R. E. Ginna elects to monitor for improved valve performance.

Examples of candidates for (b) optimization of testing, examination, and preventive maintenance activities are check valves with documented acceptable performance that: (1) have had their performance improved under the Condition Monitoring Program; (2) cannot be exercised or are not readily exercised during normal operating conditions or during shutdowns; (3) can only be disassembled and examined, or (4) R. E. Ginna elects to optimize all the associated activities of the valve or valve group in a consolidated program.

If the Appendix II Condition Monitoring Program for a valve or valve group is discontinued then the requirements of paragraphs ISTC-3510, ISTC-3520, ISTC-3530, ISTC-3550, and ISTC-5221 must be implemented.

Valves included in the CVCMP will be annotated with "CM" in the "Frequency" column of the Valve Tables. The Code testing specified in the Tables is replaced by the activities/tests identified in the specific CMP Plan.

3.3.5 Check Valve Condition Monitoring (Cont.)

Trending and evaluation shall support the determination that the valve or group of valves is capable of performing its intended function(s) over the entire interval. At least one of the Appendix II condition monitoring activities for a valve group shall be performed on each valve of the group at approximate equal intervals not to exceed the maximum interval shown in the following table and as specified in NRC condition 10CFR50.55a(b)(3)(iv).

Group size	Maximum interval between activities of member valves in the groups (years)	Maximum interval between activities of each valve in the group (years)
≥4	4.5	16
3	4.5	12
2	6	12
1	Not applicable	10

3.3.6 Check Valves Serving as Vacuum Relief Valves (Appendix I)

If a check valve is capacity-certified, then it shall be classified as a vacuum relief device and tested in accordance with Appendix I. If a check valve is not capacity-certified, it shall be classified as a check valve and tested in accordance with ISTC. (Reference: Summary of Public Workshops, dated July 18, 1997 - Questions 2.3.15 and 2.4.11)

3.4 Manual Valves

Manual valves within the scope of the IST Program that perform an active safety function shall be exercised at least once every 2 years, except where adverse conditions may require the valve to be exercised more frequently to ensure operational readiness (ISTC-3540).

3.5 Testing Intervals

The test frequency for valves included in the Program will be as set forth in the OM Code, paragraph ISTC-3510 and related relief requests. An allowable extension, not to exceed +25 percent of the surveillance interval, may be applied to the test schedule as allowed by the R. E. Ginna Station Technical Specifications or OM Code Case OMN-20 to provide for operational flexibility.

The frequencies used for scheduling valve tests are defined as:

- a. Quarterly 92 days
- b. Refueling 546days
- c. 2 Year 730 days
- d. Per App. J Leak Rate Testing frequency determined by Appendix J requirements.
- e. Sampling For safety/relief valves, set-point testing per the applicable population sampling requirements specified in OM Code, Appendix I.
- f. Sampling For check valves, disassembly and inspection per the applicable population sampling requirements specified in Subsection ISTC-5221(c).
- g. Cold Shutdown Consistent with the cold shutdown testing requirements for valves of the OM Code, paragraphs ISTC-3521(f), (g), & (h) and ISTC-3522(d), (e), & (f), and NUREG 1482, Revision 2, Sections 3.1.1, 3.1.1.1 and 3.1.1.2. When all cold shutdown testing will not be completed, priorities for testing will be established per approved Exelon/Ginna procedures.
- h. CM Valves included in the CVCMP will be annotated with "CM" in the "Frequency" column of the Valve Tables. The Code testing specified in the Tables is replaced by the activities/tests identified in the specific CMP Plan.

Per the OM Code, paragraphs ISTC-3550 and ISTC-3610, valves in regular use and valves which demonstrate functionally adequate seat tightness during normal operation are not required to be additionally tested as long as the required observations and analyses are performed and documented at the otherwise required test frequency. The frequency indicated in the valve table for such valves is the applicable required test frequency.

3.6 Deferred Valve Testing

Where quarterly testing of valves is impractical or otherwise undesirable, testing will be deferred and performed during cold shutdown or refueling periods as permitted by the OM Code and NUREG 1482, Revision 2. The valve program tables identify those valves to which deferred testing applies and the respective technical justification for each is provided in an associated cold shutdown or refueling outage justification. The criteria for determining appropriate justification is based on NUREG 1482, Revision 2, Paragraphs 2.4.5, 3.1.1, and 4.1.6 as well as OM Code, paragraphs ISTC-3521(b), (c), (d),& (e) and ISTC-3522(b) & (c). The schedule and extent of testing valves during cold shutdown periods will be based on the requirements of OM Code, paragraphs ISTC-3521(f), (g), & (h) and ISTC-3522(d), (e), & (f), and NUREG 1482, Revision 2, Sections 3.1.1.1 & 3.1.1.2. When all cold shutdown testing will not be completed, priorities for testing will be established per approved Exelon/Ginna procedures.

OM Code, paragraphs ISTC-3521(h) and ISTC-3522(f) require that for valves tested during refueling outages, all testing must be completed prior to returning the plant to operation. For those cases where valves can be tested during power ascension and where the Technical Specification requirements for the valves or system determine when the valves are required to be operable, tests may be performed during power ascension. This position conforms to that stated in NUREG 1482, Revision 2, Section 3.1.1.2.

3.6 Testing Intervals (Cont.)

The majority of R. E. Ginna'sTest Deferral Justifications have been written for cold shutdown periods, vice only refueling outages. Many of these cold shutdown tests require very specific and unique plant conditions that may not be common during an "average" cold shutdown period. This limits R. E. Ginna's ability to perform these tests. However, they are classified as cold shutdown tests, vice refueling tests, because if the appropriate plant conditions exist during a cold shutdown period and the opportunity presents itself, the appropriate tests can be performed.

3.7 Specific Valve Definitions

3.7.1 Active Valves

Per the OM Code, valves and pressure relief devices that perform a mechanical motion during the course of accomplishing a safety function are active components. If a valve is capable of being moved out of its safety position during either normal operation, and/or accident response and it must be capable of returning to that safety position, then the valve is considered to be active for that safety function.

NUREG 1482, Revision 2, Section 2.4.2, states that valves need not be considered active if they are only temporarily removed from their safety position for a short period of time and would be considered active only if the valve is routinely repositioned during power operation.

3.7.2 Passive Valves

Per the OM Code, a valve is considered passive for a given safety function if, to perform that safety function, it is not required to move or be capable of moving (i.e. not even part-stroke or fail-safe) at any time. This means the valve must remain in that position any time the safety function might be required. This includes normal operation, as well as post-accident response until the safety function would no longer be required. If a valve does not meet this general criterion, then it should be considered to be active for that safety function. Passive valves include those valves required to perform a nuclear safety function by maintaining their position.

3.7.3 Normal Position

Some valves may be moved to an alternate position during plant operations that is different from their normal position, such as to support surveillance testing. If the valve is still relied on while in its alternate position to accomplish its safety function in its normal position, then the ability to return to its normal position from its alternate position must be considered to be an active valve function that is subject to IST requirements, even if the valve is only in the alternate position for a short period of time. In this case, the alternate position is also listed in the "Normal Position" column in the Valve Tables to ensure this test requirement is captured. (The only other alternative is to consider the valve inoperable while it is out of its normal position.)

3.7.4 Valve Categories

- a. Category A Valves for which seat leakage is limited to a specific maximum amount in the closed position for fulfillment of their required function(s). Category A applies to valves for which a specific maximum valve leakage limit exists.
- b. Category B Valves for which seat leakage in the closed position is inconsequential for fulfillment of the required function(s). Inconsequential implies a leakage limit does not exist relative to the valve's ability to perform its safety function. However, leakage past a closed valve above some level indicates the valve may be degrading and its ability to close at all (e.g., gross closure capability) may become threatened at some point.
- c. Category C Valves which are self-actuated in response to some system characteristic, such as pressure (relief valves) or flow direction (check valves) for fulfillment of the required function(s). If seat leakage in the closed position is consequential for a Category C valve, then it is categorized as "AC". If seat leakage in the closed position is not consequential for a Category C valve, then it may be categorized "BC". However, such valves are merely categorized as "C" and the "B" is considered to be implied. "Gross" leakage past a closed category C valve may still be used as the desired test parameter to detect when the valve may be degrading and its ability to close at all (e.g., "gross" closure capability) may become threatened, without implying the valve should be categorized AC.
- d. Category D Valves that are actuated by an energy source capable of only one operation, such as rupture disks or explosively actuated valves.
- 3.8 Division 1, Mandatory Appendix III
- 3.8.1 Exercise Requirements

ASME OM Code Mandatory Appendix III, "Preservice and Inservice Testing of Active Electric Motor Operated Valve Assemblies in Light-Water Reactor Power Plants," establishes the requirements for preservice and inservice testing to assess the operational readiness of active motor-operated valves (MOVs) in light-water reactor (LWR) power plants.

Appendix III, paragraph III-3610 "Normal Exercising Requirements" requires that all MOVs, within the scope of this Mandatory Appendix, shall be full cycle exercised at least once per refueling cycle with the maximum time between exercises to be not greater than 24 months. Full cycle operation of an MOV, as a result of normal plant operations or Code requirements, may be considered an exercise of the MOV, if documented. If full stroke exercising of an MOV is not practical during plant operation or cold shutdown, full stroke exercising shall be performed during the plant's refueling outage.

Appendix III, paragraph III-3620 "Additional Exercising Requirements" requires that the Owner shall consider more frequent exercising requirements for MOVs in any of the following categories:

- (a) MOVs with high risk significance
- (b) MOVs with adverse or harsh environmental conditions
- or
- (c) MOVs with any abnormal characteristics

- 3.8 Division 1, Mandatory Appendix III (Cont.)
- 3.8.1 Exercise Requirements (Cont.)

Appendix III, paragraph III-3721 "HSSC MOVs" requires that HSSC MOVs shall be tested in accordance with para. III-3300 and exercised in accordance with paragraph III-3600. HSSC MOVs that can be operated during plant operation shall be exercised quarterly, unless the potential increase in core damage frequency (CDF) and large early release (LER) associated with a longer exercise interval is small.

Based on the aforementioned Appendix III MOV exercising requirements, R. E. Ginna Station will implement as follows:

- 1. IF the HSSC MOV can be exercised on-line, the valve must be exercised quarterly unless:
 - (a) The site proposes an extended exercise test interval

AND

The deferral justification (CSJ / ROJ) for the exercise test has a supporting documented PRA evaluation of the deferral risk showing the risk impact of the deferral is acceptably small (See 10CFR50.55 and RG 1.192 OMN-1 conditions – "potential increase in CDF and risk associated with the extension is small and consistent with the intent of the Commission's Safety Goal Policy Statement.")

- 2. IF the HSSC MOV cannot be exercised on-line, the valve may be exercised at cold shutdown (CSJ) or refueling outages (ROJ)
 - (a) A CSJ or ROJ is required; however, a supporting PRA evaluation is NOT required

Refer below for examples of when a PRA evaluation would or would not be required:

- A HSSC MOV has a current CSJ or ROJ deferral and review of the deferral justification concludes the deferral is based on plant physical operating restrictions that prohibit exercising the valve on-line. The valve exercising is deferred to Cold Shutdown or refueling outages and a PRA evaluation is **NOT** required.
- 2. A HSSC MOV has a current CSJ or ROJ deferral and review of the deferral justification concludes the deferral is based on plant /personnel safety concerns that preclude exercising the valve on-line. The valve exercising is deferred to Cold Shutdown or refueling outages and a PRA evaluation is **NOT** required.
- 3. A HSSC MOV has a current CSJ or ROJ deferral and review of the deferral justification concludes the deferral is **NOT based on plant physical operating restrictions or plant/personnel safety concerns** that precludes exercising the valve on-line (i.e.; it's a deferral based on convenience man-power reduction, scheduling benefit, etc.). **The valve exercising must be done quarterly.**

- 3.8.1 Division 1, Mandatory Appendix III Exercise Requirements (Cont.)
 - (a) This testing may be deferred to a longer interval (on-line, Cold Shutdown, or refueling outages) provided a supporting PRA evaluation is performed and documented that concludes the risk impact of the deferral (the extended exercising frequency) is acceptably small as defined in 10CFR50.55 and Reg. Guide 1.174.

3.8.2 MOV Stroke Time

Effective on August 17, 2017 the NRC added a new condition as 10CFR50.55a(b)(3)(ii)(D), "MOV stroke time," to require that, when applying Paragraph III-3600, "MOV Exercising Requirements," of Appendix III to the OM Code, licensees shall verify that the stroke time of the MOVs specified in plant technical specifications satisfies the assumptions in the plant's safety analyses. This condition retains the MOV stroke time requirement for a smaller set of MOVs than was specified in previous editions and addenda of the OM Code. For these MOVs, a stroke time test is listed in Attachment 15, "Inservice Testing Valve Table."

3.9 Position Indication (PI) Verification (ISTC-3700)

Verification of proper remote position indication will normally be accomplished by locally observing the position of the valve and comparing it with the remote indication. Some valves are not equipped with a local means to verify position. Therefore, position will be verified by the observation of system parameters such as flow, pressure, temperature, or level. For valves having remote position indicators at multiple locations that include the control room, the control room remote position indicator will be verified for accuracy and the remote position indicator used for exercise testing and stroke timing the valve will also be verified for accuracy. If exercise testing and stroke timing are performed using only the control room remote position indicator needs to be verified for accuracy.

Effective on August 17, 2017 the NRC added a new condition as 10CFR50.55a(b)(3)(xi), "Valve Position Indication," to emphasize, when implementing OM Code (2012 Edition), Subsection ISTC-3700, "Position Verification Testing," licensees shall implement the OM Code provisions to verify that valve operation is accurately indicated (i.e., Supplemental Position Indication). This condition emphasizes the OM Code requirements for valve position indication and is not a change to those requirements.

Ginna evaluated all valves in the IST Program where an IST-3700 position indication test was listed in Attachment 15 to ensure the requirements of the 10CFR50.55a(b)(3)(xi) condition were met. Steps in the implementing procedures which were specifically credited by this evaluation have been identified by [IST/SPI].

- 3.10 Category A Containment Isolation Valve (CIV) and RCS Pressure Isolation Valve Leak Testing
 - a. All valves included in the Containment Leak Rate Test (CLRT) Program complying to 10 CFR 50, Appendix J, shall be included in the IST Program as Category A valves.
 - b. All valves designated as RCS Pressure Isolation Valves (PIVs) are considered to perform a pressure isolation function between the Reactor Coolant System (RCS) and systems of a lower design pressure and are included in the IST Program as Category A valves. The listing of designated PIVs also include isolation valves, optionally classified as PIVs, which prevent the communication of a high pressure source with the low pressure suction piping of a pump contained in a high pressure system.

3.11 IST Plan Valve Table Description

The valves included in the R. E. Ginna Station IST Program are listed in Attachment 15. The information contained in that table identifies those valves required to be tested to the requirements of the ASME OM Code, the testing methods and frequency of testing, associated Relief Requests, comments, and other applicable information. The column headings for the Valve Table are delineated below with an explanation of the content of each column.

<u>Valve ID</u> or <u>Valve EIN</u>	The unique identification number for the valve, as designated on the System P&ID or Flow Diagram.		
<u>Description</u>	The descriptive name for the valve [use PIMS, Passport, FCMS, etc. names for consistency].		
<u>Class</u>	The ASME Safety Class (i.e., 1, 2 or 3) of the valve. Non-ASME Safety Class valves are designated by "N/A".		
<u>Cat</u>	The ASME Code category or categories of the valve as defined in Reference 1.5.f.		
<u>Act/Pass</u>	"A" or "P", used to designate whether the valve is active or passive in fulfillment of its safety function. The terms "active valves" and "passive valves" are defined in Reference 1.5.f.		
<u>Size</u>	The nominal size of the valve in inches.		
<u>Valve Type</u>	An abbreviation used to designate the body style of the valve: 3W 3-Way 4W 4-Way BAL Ball BTF Butterfly CK Check DIA Diaphragm GA Gate GL Globe PLG Plug RPD Rupture Disk RV Relief SCK Stop-Check SHR Shear (SQUIB) TRV Thermal Relief Valve XFC Excess Flow Check		
<u>Actuator Type</u>	An abbreviation which designates the type of actuator on the valve. Abbreviations used are: AO Air Operator HO Hydraulic Operator M Manual MO Motor Operator SA Self-Actuating SO Solenoid Operator		
- 3.11 Valve Table Information Description (Cont.)
 - <u>Drawing (P&ID)</u> The Piping and Instrumentation Diagram or Flow Drawing and sheet number on which the valve is shown.
 - <u>Coord</u> Coordinates of the P&ID where the valve is shown.

PositionsAbbreviations used to identify the normal, fail, and safety-related
positions for the valve. Abbreviations used are:

- Al As Is
- C Closed
- D De-energized
- D/E De-energizedorEnergized
- E Energized
- LC Locked Closed
- LO Locked Open
- LT Locked Throttled
- O Open
- O/C Open or Closed
- T Throttled

Testing

Requirements

- <u>Test</u> A listing of abbreviations used to designate the types of testing which are required to be performed on the valve based on its category and functional requirements. Abbreviations used are:
 - BDC Bidirectional Check Valve test (non-safety related closure test)
 - BDO Bidirectional Check Valve test (non-safety related open test)
 - CC² Check Valve Exercise Test Closed
 - CO² Check Valve Exercise Test Open
 - CP² Check Valve Partial Exercise Test
 - DIAG MOV "Inservice" Diagnostic Test per Appendix III
 - DT Category D Test
 - EC Exercise Test Closed (manual valve)
 - EO Exercise Test Open (manual valve)
 - FC Fail-Safe Exercise Test Closed
 - FO Fail-Safe Exercise Test Open
 - LT¹ Leak Rate Test
 - PI Position Indication Verification Test
 - RT Relief Valve Test
 - SC Exercise Closed (without stroke-timing)
 - SO Exercise Open (without stroke-timing)
 - SP Partial Exercise (Cat. A or B)
 - STC Exercise/Stroke-Time Closed
 - STO Exercise/Stroke-Time Open

3.11 Valve Table Information Description (Cont.)

Testing
Requirements
(Continued)

¹ A third letter, following the "LT" designation for leakage rate test, may be used to differentiate between the tests. For example, Appendix J leak tests will be designated as "LTJ", low pressure (non-Appendix J) leak tests as "LTL", and high pressure leak tests as "LTH".

² Three letter designations should be used for check valve tests to differentiate between the various methods of exercising check valves. The letter following "CC", "CO" or "CP" should be "A" for acoustics, "D" for disassembly and inspection, "F" for flow indication, "M" for magnetics, "R" for radiography, "U" for ultrasonics, or "X" for manual exercise.

- <u>Freq</u> An abbreviation which designates the frequency at which the associated test is performed. Abbreviations used are:
 - AJ Per Appendix J
 - CM Per Check Valve Condition Monitoring Program
 - CS Cold Shutdown
 - M[n] Once Every n Months
 - MOV Per MOV Program
 - Q Quarterly
 - R Refuel Outage
 - R[n] Once Every n Refuel Outages
 - SA Sample Disassemble & Inspect
 - TS Per Technical Specification Requirements
 - Y[n] Once Every n Years
- <u>RR/CSJ/ROJ</u> A cross-reference to the number of the Relief Request applicable to the specified test, the applicable Cold Shutdown Justification or Refuel Outage Justification which describes the reason why reduced-frequency exercise testing is necessary for the applicable valve.
- <u>Procedure</u> Test Procedure which implements the testing identified in the previous column left
- <u>Comments</u> Any appropriate reference or explanatory information (e.g., CVCMP, Technical Positions, etc.).

4.0 Attachments

- 1. System and P&ID Listing
- 2. Pump Relief Request Index
- 3. Pump Relief Requests
- 4. Valve Relief Request Index
- 5. Valve Relief Requests
- 6. Relief Request RAIs and SER
- 7. Code Case Index
- 8. Cold Shutdown Justification Index
- 9. Cold Shutdown Justifications
- 10. Refueling Outage Justification Index
- 11. Refueling Outage Justifications
- 12. Technical Position Index
- 13. Technical Positions
- 14. Inservice Testing Pump Table
- 15. Inservice Testing Valve Table
- 16. Check Valve Condition Monitoring Plan Index

Attachment 1

System Name / Code / P&ID

SYSTEM NAME	CODE	P&ID(s)
Auxiliary Feedwater		33013-1237
Auxiliary Feedwater Lube Oil Skid		33013-2285
Auxiliary/Intermediate Bldg HVAC		33013-1870
Component Cooling Water		33013-1245
Component Cooling Water		33013-1246-1,2
Containment HVAC, Purge Exhaust		33013-1866
Containment HVAC, Purge Supply		33013-1865
Containment HVAC, Recirculation		33013-1863
Containment Spray		33013-1261
Containment Vessel Air Test		33013-1882
CVCS Charging		33013-1265-1,2
CVCS Letdown		33013-1264
Diesel Generators		33013-1239-1,2
Fire Protection Plant Systems		33013-1989
Fire Protection: Construction		
Fire Service Water		33013-1991
Hydrogen Recombiners		33013-1275-1,2
Instrument Air		33013-1887
Instrument Air		33013-1893
Main Feedwater		33013-1236-1,2
Main Steam		33013-1231
Nuclear Sampling		33013-1278-1,2
Post Accident Sampling		33013-1279
Primary Water Treatment - DI Water		33013-1908-3
RCS Overpressure Protection		33013-1263
Reactor Coolant		33013-1260
Reactor Coolant Drain Tank		33013-1272-2
Reactor Coolant Pressurizer		33013-1258
Residual Heat Removal		33013-1247
Residual Heat Removal		33013-1260
Safety Injection & Accumulators		33013-1262-1,2
Service Air		33013-1886-2
Service Water		33013-1250-1,2,3
Spent Fuel Pool Cooling		33013-1248
Standby Auxiliary Feedwater		33013-1238
Steam Generator Blowdown		33013-1277-1
Waste Disposal - Gas		33013-1273-2

Attachment 2

Pump Relief Request Index

Pump Relief Request Index

<u>RELIEF</u> <u>REQUEST</u> NUMBER	RELIEF REQUEST TITLE	APPROVAL DATE
PR-01	D/G Fuel Oil Transfer System Flow Rate	8/5/2019
PR-02	PAF01A, PAF01B, PSF01A, PSF01B	8/5/2019
PRE-01	Alternative Relief Evaluation CVCS Charging Pumps (PCH01A, PCH01B, and PCH01C)	Not Required
PRE-02	Alternative Relief Evaluation SFPC Pump A (PAC07A)	Not Required

Attachment 3

Pump Relief Requests

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2) PR-01, Diesel Generator Fuel Oil Transfer Pumps – Flow Rate

1. ASME Code Component(s) Affected

Component	Description		Group
PDG02A	Diesel Generator A Fuel Oil Transfer Pump	3	А
PDG02B	Diesel Generator B Fuel Oil Transfer Pump	3	А

The diesel fuel oil transfer pumps are required to transfer fuel oil from the storage tank to the day tank. This function ensures a continuous fuel supply to support long term operation of the Diesel during accident conditions.

2. Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code) 2012 Edition with no Addenda.

3. Applicable Code Requirement

ISTB-3550, *Flow Rate,* states, in part, "When measuring flow rate, a rate or quantity meter shall be installed in the pump test circuit. If a meter does not indicate the flow rate directly, the record shall include the method used to reduce the data."

4. Reason for Request

Pursuant to 10 CFR 50.55a, *Codes and standards*, paragraph (z)(2), an alternative is proposed to the pumptestingrequirements regarding pump flow rate in OM-2012 Code paragraph ISTB-3550.. The basis of the request is that compliance with the specified requirements would result in hardship or unusual difficulty without compensating increase in the level of quality and safety.

There are no installed instruments on the diesel fuel oil transfer system that allow a direct measurement of the flow rate when testing the diesel oil fuel transfer pumps. The pump flow rate can be calculated by measuring the change in day tank level or volume and the pump operation time required to make that change. The accuracy of this method is documented in design analysis Engineering Work Request (EWR) 4526-ME-20 (Reference 1). This method determines a flow rate for a pump that can be used to evaluate the pump's hydraulic performance.

5. Proposed Alternative and Basis for Use

Ginna's diesel fuel oil transfer pumps, PDG02A & PDG02B, are positive displacement pumps. The flow rate for these pumps is determined by measuring the indicated level change in the diesel generator fuel oil day tank during a timed pump run and converting this data into fuel oil transfer pump flow rate for both the Group B and comprehensive pump tests.

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2) PR-01, Diesel Generator Fuel Oil Transfer Pumps – Flow Rate

Level gauges LG-2044 ("A" Emergency Diesel Generator) and LG-2045 ("B" Emergency Diesel Generator) are utilized to measure the change in indicated level while the fuel oil transfer pump is running and restoring fuel oil day tank level. Both LG-2044 and LG-2045 (sight glasses equipped with a reference scale in inches of level) have a range of indicated level of 9 inches (2.5 inches to 11.5 inches).

The respective day tank is drained to an initial indicated level of 5.0 to 5.5 inches before initiating the fuel oil pump start. This level is logged as the initial level. The pump is then started coincident with starting the stopwatch and the system allowed to stabilize. A minimum 2-minute stabilization period is observed for the comprehensive test.

Following a total minimum run time of 5 minutes (or exceeding an indicated tank level of 11 inches), the pump is stopped coincident with stopping the stopwatch and the day tank level is read in inches to the nearest 0.25 inch. This level is logged as the final level.

The change in day tank level is determined in inches and then converted to total gallons pumped using the constant conversion factor of 24.76 gallons per inch. The constant of 24.76 gallons per inch of indicated level on the day tank sight glass was established by EWR 4526-ME-20 based on the tank's geometrical dimensions. The total gallons pumped is then divided by the total pump run time to arrive at the pump test flow rate in gallons per minute (gpm). This calculation is documented in the pump test procedures.

The test circuit for each pump is a fixed flow path from the storage tank (pump suction) to the day tank (pump discharge). Pump suction pressure is nearly constant because of the very small change in storage tank level. This change in suction pressure during pump operation is considered negligible. The normal rise in day tank level is approximately 5.5 inches, which corresponds to a quantity of approximately 136 gallons pumped during the 5 minutes of pump operation, resulting in a typical flow rate of approximately 27 gpm.

The small rise in day tank level during pump operation does not affect pump discharge pressure or flow rate. This conclusion is supported by the discussion in NUREG-1482, Revision 2, Section 5.5.2, *Use of Tank Level to Calculate Flow Rate for Positive Displacement Pumps*, where the NRC states: "Pump discharge pressure will match system pressure up to the shutoff head of the positive displacement pump. Because of the characteristics of a positive displacement pump, there should be virtually no change in pump discharge flow rate as a result of the rising tank level. Therefore, rising tank level will not have an impact on test results. By having approximately the same level in the tank at the beginning of each test, licensees can achieve repeatable results."

The accuracy of level gauges, LG-2044 and LG-2045, is determined using the 9-inch indicated range of level and the constant of 24.76 gallons per inch. This yields a total volume change of 222.84 gallons. Based on a readability uncertainty of +/-0.125 inch (0.25-inch scaling), which is equivalent to 3.10 gallons, divided by the total indicated volume of 222.84 gallons, the overall accuracy of the sight glass is \pm 1.39%.

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2) PR-01, Diesel Generator Fuel Oil Transfer Pumps – Flow Rate

In addition, the stopwatch used to measure the time the pump is operating and pumping fuel oil is now accurate to within \pm 3 seconds per 24 hours (formerly \pm 0.6% second per minute) for a calibrated accuracy of \pm 0.004% (formerly \pm 1.0%). Combining the accuracy of the stopwatch with the level gauge sight glass, using the square root of the sum of the squares method, results in an insignificant decrease with an overall indicated accuracy of \pm 1.39% (formerly \pm 1.71%). This overall accuracy has been improved from that which was provided in the alternative previously authorized for use during the fifth 10-year interval 1ST program.

Therefore, the pump flow rate can be accurately calculated by measuring the change in day tank level or volume and the pump operation time required to make that change. This method determines a flow rate for these pumps that can be used to evaluate the pump's hydraulic performance and provide reasonable assurance of pump operational readiness. Therefore, relief is requested pursuant to 10 CFR 50.55a(z)(2) based on the determination that compliance with the Code pump testing requirements regarding pump flow rate cannot be achieved without resulting in a hardship or unusual difficulty without a compensating increase in the level of quality and safety; and the proposed alternative of using the tank level change vs. time to calculate the flow rate provides reasonable assurance of operational readiness and provides an acceptable level of quality and safety.

6. Duration of Proposed Alternative

This request, upon approval, will be applied to the R. E. Ginna Nuclear Power Plant sixth 10year IST interval, which begins on January 1, 2020, and is scheduled to end on December 31, 2029.

7. Precedent

This relief request was previously approved for the fifth 10-year interval at Ginna, as documented in NRC safety evaluation, "Alternative Requests for Fifth 10-Year Pump and Valve Inservice Testing Program – R. E. Ginna Nuclear Power Plant (TAC Nos. ME2232, ME2233, ME2234, ME2235, ME2236, ME2237, ME2238, and ME2239)," dated December 30, 2009 (ML093570173).

8. <u>References</u>

- 1. Engineering Work Request 4526-ME-20, Evaluation of Instrument Setpoints for EDG Fuel Oil System.
- 2. NUREG-1482, *Guidelines for Inservice Testing at Nuclear Power Plants*, Revision 2.

Proposed Alternativein Accordance with 10 CFR 50.55a(z)(2) PR-02 - Auxiliary Feedwater (AFW) Pumps – Flow Rate

Component ID	Description	Code Class	Group
PAF01A	"A" Preferred Motor Driven AFW Pump	3	А
PAF01B	"B" Preferred Motor Driven AFW Pump	3	A
PSF01A	"C" Standby Motor Driven AFW Pump	3	В
PSF01B	"D" Standby Motor Driven AFW Pump 3		В

1. ASME Code Component(s) Affected

The AFW pumps are required to be capable of supplying AFW flow to the steam generators during a loss of normal feedwater flow or a steam line break in conjunction with a loss of off-site power. This function maintains steam generator water level to provide a secondary heat sink for residual heat removal of the reactor coolant system.

2. Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code) 2012 Edition with no Addenda.

3. Applicable Code Requirement

ISTB-3550, *Flow Rate,* states, in part, "When measuring flow rate, a rate or quantity meter shall be installed in the pump test circuit. If a meter does not indicate the flow rate directly, the record shall indicate the method used to reduce the data."

Table ISTB-3000-1, *Inservice Test Parameters*, specifies the parameters of Flow Rate (Q) and Differential Pressure (ΔP) for Group A pump testing and Flow Rate (Q) or Differential Pressure (ΔP) for Group B pump testing.

ISTB-5121, *Group A Test Procedure*, states, in part, "Group A tests shall be conducted with the pump operating as close as practical to a specified reference point and within the variances from the reference point as described in this paragraph. The test parameters shown in Table ISTB-3000-1 shall be determined and recorded as required by this paragraph."

ISTB-5121(*c*) states "Where it is not practical to vary system resistance, flow rate and pressure shall be determined and compared to their respective reference values."

ISTB-5122, *Group B Test Procedure*, states that "Group B tests shall be conducted with the pump operating as close as practical to a specified reference point and within the variances from the reference point as described in this paragraph. The test parameter value identified in Table ISTB-3000-1 shall be determined and recorded as required by this paragraph."

ISTB-5122(*c*) states, in part, "System resistance may be varied as necessary to achieve a point as close as practical to the reference point. If the reference point is flow rate, the variance from the reference point shall not exceed +2% or -1%."

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2) PR-02 - Auxiliary Feedwater (AFW) Pumps – Flow Rate

4. Reason for Request

Pursuant to 10 CFR 50.55a, *Codes and standards*, paragraph (z)(2), an alternative is proposed to the pumptesting requirements regarding pump flow rate in the ASME OM-2012 Code. The basis of the request is that compliance with the specified requirements would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety.

The AFW pumps each have a minimum flow path that can be utilized for the respective Group A and Group B pump tests. The minimum flow lines provide a fixed resistance flow path from the pump discharge to the condensate storage or demineralized water storage tank, as applicable, then back to the suction of each pump. However, the minimum flow lines are not provided with flow instrumentation.

Compliance with the Code is an undue burden due to existing design limitations in that a flow rate measuring device is not installed in the associated pump minimum flow recirculation line being employed as the pump test circuit. Costly major hardware modifications would be required to provide a permanent flow measuring device in each affected line. It has been estimated that the cost would exceed \$75,000 annually to install and maintain temporary flow measuring devices or more than \$375,000 to install permanent flow measuring devices into the minimum flow recirculation lines in order to meet the ASME OM Code requirements and support the quarterly testing of the four AFW pumps. Additionally, flow is not variable since an installed flow orifice establishes a 40 gpm flow rate when the pump is operated in the recirculation mode.

The flow path to the steam generators has flow instrumentation; however, this flow path has the potential for service water intrusion and requires a reactivity change. This flow path is used for the biennial comprehensive pump test.

Therefore, the instrumented flow path which has the potential for service water intrusion into the steam generators and requires a reactivity change, and the cost of installing either temporary or permanent flow instrumentation in the minimum flow recirculation lines imposes an undue burden without a compensating increase in the level of quality or safety.

5. Proposed Alternative and Basis for Use

The performance of pump tests using a fixed resistance flow path is an acceptable alternative to the Code requirements per NUREG-1482, Revision 2, Section 5.9, *Pump Testing Using Minimum Flow Return Lines With or Without Flow Measuring Devices*. During the performance of quarterly pump testing, pump differential pressure will be measured and trended. This provides a reference value for differential pressure that can be duplicated during subsequent tests. This methodology provides for the acquisition of repeatable differential pressure, which is an adequate means of monitoring for pump degradation.

Concerns identified in NRC Bulletin 88-04, *Potential Safety-Related Pump Loss*, with regard to minimum recirculation flow line sizing were assessed and verified to not be of concern during pump testing.

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2) PR-02 - Auxiliary Feedwater (AFW) Pumps – Flow Rate

5. Proposed Alternative and Basis for Use (Cont.)

Quarterly testing of the designated Group A AFW centrifugal pumps (PAF01A, PAF01B) will be performed on minimum flow recirculation measuring differential pressure across the pump and measuring vibration per ASME OM-2012 Code, paragraph ISTB-5121 and using NUREG-1482, Revision 2, Section 5.9 for guidance.

Quarterly testing of the designated Group B Standby AFW centrifugal pumps (PSF01A, PSF01B) will be performed on minimum flow recirculation measuring differential pressure across the pump per ASME OM-2012 Code, paragraph ISTB-5122 and using NUREG-1482, Revision 2, Section 5.9 for guidance.

Therefore, relief is requested pursuant to 10 CFR 50.55a(z)(2) based on the determination that compliance with the Code required Groups A and B centrifugal pump test requirements cannot be achieved without resulting in a hardship or unusual difficulty without a compensating increase in the level of quality and safety; and the proposed alternative testing provides reasonable assurance of the AFW pumps' operational readiness.

6. Duration of Proposed Alternative

This request, upon approval, will be applied to the R. E. Ginna Nuclear Power Plant sixth 10year IST interval, which begins on January 1, 2020, and is scheduled to end on December 31, 2029.

7. Precedent

This relief request was previously approved for the fifth 10-year interval at Ginna, as documented in NRC safety evaluation, "Alternative Requests for Fifth 10-Year Pump and Valve Inservice Testing Program – R. E. Ginna Nuclear Power Plant (TAC Nos. ME2232, ME2233, ME2234, ME2235, ME2236, ME2237, ME2238, and ME2239)," dated December 30, 2009 (ML093570173).

8. <u>References</u>

- 1. NUREG-1482, Guidelines for Inservice Testing at Nuclear Power Plants, Revision 2.
- 2. NRC Bulletin 88-04, Potential Safety-Related Pump Loss.

Alternative Relief Evaluation Providing an Acceptable Level of Quality and Safety In Accordance with 10 CFR 50.55a(f)(4), PRE-01, Rev 0, Chemical and Volume Control System (CVCS) Pumps

1. ASME Code Component(s) Affected

The following CVCS Pumps are affected:

Component	Description	Class	Group
PCH01A	CVCS Pump A	2	А
PCH01B	CVCS Pump B	2	А
PCH01C	CVCS Pump C	2	А

The charging pumps together with the charging system perform the following process functions during normal plant operation: 1) control reactor coolant inventory, chemistry conditions, activity level, and boron concentrations, 2) provide seal water injection flow to the reactor coolant pumps, 3) process reactor coolant effluent for reuse of boric acid and makeup water.

Safety related functions of the charging pumps together with the charging system are to provide makeup and boration to the RCS. The charging pumps normally provide borated water from the boric acid storage tanks or the refueling water storage tank (RWST) via four potential flow paths. Those flow paths include; 1) normal charging lines to either the hot leg or cold leg, 2) the alternate charging line to the loop B hot leg, 3) auxiliary pressurizer spray line, or 4) reactor coolant pump seals. Of these four potential flow paths, credit is taken for makeup and boration to the RCS via the RCP seal injection flow paths that have no air operated valves (AOVs) or, as a backup method, by providing makeup and boration via the alternate charging path to the RCS loop B hot leg. The alternate charging flow path is provided with a fail-close AOV (392A) that is designed to allow charging flow to the RCS at a differential pressure set point of 250 psid. During the safety related function of makeup and boration the borated water supply source would be provided from the RWST. One charging pump alone can provide cold shutdown boration requirements immediately following reactor shutdown.

The charging pumps are included in the IST Program scope as Augmented components since their only credited function is achieving cold shutdown. Ginna Station's safe shutdown condition is the Hot Shutdown condition; therefore, they do not meet the scoping/selection criteria specified in paragraph ISTA-1100 of the OM Code.

2. Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code) 2012 Edition with no Addenda.

3. Applicable Code Requirement

ISTB-3400, Frequency of inservice Tests, states "An inservice test shall be run on each pump as specified in Table ISTB-3400-1."

Table ISTB-3400-1, Inservice Test Frequency, requires a quarterly Group A test, a biennial Comprehensive test, and a biennial Pump Periodic Verification test (PPVT).

10CFR50.55a(f)(4), Inservice Testing Standards Requirements for Operating Plants, published July 18, 2017, requires an augmented inservice testing program be developed for pumps and valves within the scope of the ASMEOM Code that are not code class 1, 2, or 3 components.

4. Reason for Evaluation

The CVCS (Charging) pumps, PCH01A/B/C, are augmented components in the Inservice Testing (IST) Program, as they are not required to achieve the Ginna safe shutdown condition of Hot Shutdown, only cold shutdown. Therefore, while they do not meet the scope requirements to be included in the IST Program, Ginna has optionally included them and has applied the requirements of 10CFR50.55a, paragraph (f)(4), to formally document the alternative testing performed.

Pursuant to 10CFR50.55a, *Codes and Standards*, paragraph (f)(4), a deviation from the ASME OM Code provisions is being implemented since the testing performed at Ginna provides an acceptable level of quality and safety.

These pumps are presently tested to meet Group A pump testing requirements. The pump speed is set and the discharge pressure and pump flow are determined per ISTB-5321(c). The pump flow acceptance criterion is required to be between approximately 35 gpm and 41.8 gpm. The present test acceptance criterion includes a low alert range between approximately 35 gpm and 36 gpm in order to detect pump degradation. The acceptance criterion also ensures sufficient flow and pressure to meet the requirements of Mandatory Appendix V, for the PPVT. Since the pumps are normally in operation while at power and are routinely monitored by operations, a separate comprehensive test (CPT) is not warranted.

The testing described above provides an acceptable level of quality and safety.

5. Proposed Alternative and Basis for Use

The Charging pumps will be tested on a semi-annual frequency as an alternative to the ASME OM Code specified quarterly testing. Ginna will continue to test the pumps as Group A pumps with acceptance criterion sufficient to meet the PPVT requirements. This testing will include an alert range to detect pump degradation. This deviation from the ASME OM Code is justified as the Charging pumps are normally in operation while at power. Degraded performance of these pumps will be observed without the need for quarterly testing or a biennial CPT.

This testing provides an acceptable level of quality and safety and also ensures the pump degradation is detected and that the design requirements are met.

Therefore, the alternative relief is being implemented pursuant to 10CFR50.55a(f)(4) based on the determination that the testing at Ginna provides an acceptable level of quality and safety and that the proposed alternative provides reasonable assurance of pump operational readiness.

6. Duration of Proposed Alternative

This alternative will be applied to the Ginna sixth 10-year interval, which begins on January 1, 2020, and is scheduled to end on December 31, 2029.

Alternative Relief Evaluation Providing an Acceptable Level of Quality and Safety In Accordance with 10 CFR 50.55a(f)(4), PRE-02, Rev 0, Spent Fuel Pool Cooling (SFPC) A Pump – Alert Range

1. ASME Code Component(s) Affected

Component	Description	Class	Group
PAC07A	SPENT FUEL POOL RECIRCULATION PUMP A	SSC	A

The spent fuel pool recirculation pump A performs the safety significant function of providing heat removal from the spent fuel pool by circulating fuel pool inventory through SFP heat exchanger A, allowing the residual heat to be transferred to the service water system. This function is required to limit the pool temperature to less than or equal to the administrative limit of 120F during maximum normal heat load conditions associated with a refueling outage.

2. Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code) 2012 Edition with no Addenda.

3. Applicable Code Requirement

10CFR50.55a(f)(4), Inservice Testing Standards Requirements for Operating Plants, published July 18, 2017, requires an augmented inservice testing program be developed for pumps and valves within the scope of the ASME OM Code that are not code class 1, 2, or 3 components.

Table ISTB-3400-1, Inservice Test Frequency, requires a quarterly Group A test, a biennial Comprehensive pump test (CPT), and a biennial Pump Periodic Verification test (PPVT).

ISTB-5123, Comprehensive Test Procedure, states, in part, "All deviations from the reference values shall be compared with the ranges of Table ISTB-5121-1 and corrective action taken as specified in para. ISTB-5121-1."

Table ISTB-5121-1, Centrifugal Pump Test Acceptance Criteria, provides the acceptance criteria for the CPT parameters of Flow Rate (Q)and (or) Differential Pressure (ΔP). The table specifies an Alert Range of 0.90 to <0.93 of reference differential pressure.

4. Reason for Evaluation

Pursuant to 10CFR50.55a, *Codes and Standards*, paragraph (f)(4) an alternative augmented test plan is being implemented to the pump testing requirements regarding pump differential pressure in the ASME OM-2012 Code. The basis for the alternative is that the alternative test plan demonstrates an acceptable level of quality and safety.

The pump is presently tested to meet quarterly Group A pump testing requirements. The acceptance criterion also ensures sufficient flow and pressure to meet the requirements of Mandatory Appendix V, for the PPVT.

5. Proposed Alternative and Basis for Use

Spent fuel pool recirculation pump PAC07A will have a Group A test performed quarterly with no CPT. This deviation from the Code is justified by the fact that the quarterly Group A test meets all of the requirements of a CPT, Group A test, and a PPVT with regards to required test flow, differential pressure, vibrations, test instrument accuracy, and Acceptance Criteria with only one exception. The exception being the required Alert Range of 0.90 to <0.93 of reference for dP required for the CPT is not applied. However, given that the test will be performed and trended by engineering on an increased quarterly frequency instead of once every 2 years as required per Code there will be added assurance that any degradation will be adequately identified and addressed in a timely manner. Per ISTB-6200(a) if a measured test parameter value falls within the alert range the frequency of the testing shall be doubled, the quarterly frequency effectively increases the CPT frequency by a factor of 8 which conservatively exceeds the Code requirement for an increased test frequency of a CPT.

Ginna will continue to test spent fuel pool recirculation pump A as a Group A pump with acceptance criterion sufficient to meet CPT and PPVT requirements, with the exceptaion of application of an alert range. This testing provides an acceptable level of quality and safety and also ensures any pump degradation is detected and that the design requirements are met.

Therefore, the alternative relief is being implemented pursuant to 10CFR50.55a(f)(4) based on the determination that the testing at Ginna provides an acceptable level of quality and safety and that the proposed alternative provides reasonable assurance of pump operational readiness.

6. Duration of Proposed Alternative

This alternative will be applied to the Ginna sixth 10-year interval, which begins on January 1, 2020, and is scheduled to end on December 31, 2029.

Attachment 4

Valve Relief Request Index

ValveRelief Request Index

<u>RELIEF REQUEST</u> <u>NUMBER</u>	RELIEF REQUEST TITLE	<u>APPROVAL</u> DATE
GR-01	RCPB Isolation Valves - Leak Testing	8/5/2019
VR-01	4324, 4325, 4326	8/5/2019
VR-02	434, 435	8/5/2019

Attachment 5

Valve Relief Requests

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2), GR-01 - Reactor Coolant Pressure Boundary Isolation Valve – Leak Testing

Valve	System	Code Class	Category	Configuration/Type
878A	SI	2	А	MOV
878C	SI	2	A	MOV
877A	SI	1	A/C	Event V CV
877B	SI	1	A/C	Event V CV
878F	SI	1	A/C	Event V CV
878H	SI	1	A/C	Event V CV

1. ASME Code Component(s) Affected

The Reactor Coolant System (RCS) Pressure Isolation Valves (PIVs) function to provide reactor coolant system pressure boundary isolation.

2. Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code) 2012 Edition with no Addenda.

3. Applicable Code Requirement

ISTC-3630, *Leakage Rate for Other Than Containment Isolation Valves*, states, in part, that "Category A valves with a leakage requirement not based on an Owner's 10 CFR 50, Appendix J program, shall be tested to verify their seat leakages [are] within acceptable limits. Valve closure before seat leakage testing shall be by using the valve operator with no additional closing force applied."

ISTC-3630(a), Frequency, states, "Tests shall be conducted at least once every 2 yr."

4. Reason for Request

Pursuant to 10 CFR 50.55a, *Codes and Standards*, paragraph (z)(2), an alternative to the requirement of ASME OM-2012 Code, paragraph ISTC-3630(a) is proposed. The basis of the request is that compliance with the specified requirements would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety.

Safety injection (SI) hot leg check valves 877A, 877B, 878F, and 878H and motor operated valves (MOVs) 878A and 878C are considered to be passive. During operation, the check valves are normally closed and their associated MOV is also closed and de-energized.

Leakage testing for these valves, including testing requirements, is governed by plant Technical Specification (TS) 3.4.14, *RCS Pressure Isolation Valve (PIV) Leakage*. TS Surveillance Requirement (SR) 3.4.14.2 requires that Ginna verify leakage from each SI system hot leg injection line RCS PIV at a prescribed differential pressure. The seat leakage is measured, analyzed, and compared to permissible leakage rates at a frequency prescribed by the Surveillance Frequency Control Program (SFCP), which is 40 months for SR 3.4.14.2.

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2), GR-01 - Reactor Coolant Pressure Boundary Isolation Valve – Leak Testing

Due to the lack of test connections, each series pair of check valves (877A/878F and 877B/878H) form one of the two pressure boundaries required to be tested with the second boundary being its associated MOV. Failure of a leakage test of a tested pair would require that both check valves be declared inoperable and in need of rework. Any valve failing the acceptance criteria of TS 3.4.14 shall be declared inoperable and entered into a TS Action in TS Section 3.4.14. Testing of series pairs of check valves in this configuration is allowed by the OM Code, paragraph ISTC-5223, *Series Valves in Pairs*, and utilizes the guidance found in NUREG-1482, Revision 2, Section 4.1.1, *Closure Verification for Series Check Valves without Intermediate Test Connections*, which states that testing of the pair of valves is acceptable if the configuration does not require two valves and the safety analysis for such a configuration would credit either of the two valves.

Since the series pairs of check valves 877A/878F and 877B/878H do not have the needed test connections to individually test each valve and since testing of these valves with their adjacent MOVs is specified adequately by TS, it is an undue burden to comply with the OM Code requirements to perform separate leak rate tests. The plant TS establish the maximum permissible leakage rates, test pressure requirements, test frequency requirements, and the required action if the leak rate limit is exceeded. To make modifications to include the proper test connections and perform leak rate testing in accordance with the OM Code would be costly and increase personnel radiation exposure and would not result in a compensating increase in the level of quality and safety.

5. Proposed Alternative and Basis for Use

In lieu of the Code-required separate leak rate tests, these series pair check valves will be leak rate tested in accordance with the RCS PIV leak rate testing per TS 3.4.14. The proposed alternative testing will provide reasonable assurance of the valves' operational readiness. Therefore, this alternative to the Code required leakage rate testing of the RCS PIVs is proposed pursuant to 10 CFR 50.55a(z)(2).

6. Duration of Proposed Alternative

This request, upon approval, will be applied to the R. E. Ginna Nuclear Power Plant sixth 10year IST interval, which begins on January 1, 2020, and is scheduled to end on December 31, 2029.

7. <u>Precedent</u>

This relief request was previously approved for the fifth 10-year interval at Ginna, as documented in NRC safety evaluation, "Alternative Request GR-01 for the Fifth 10-Year Pump and Valve Inservice Testing Program – R. E. Ginna Nuclear Power Plant (TAC No. ME2238)," dated April 14, 2010 (ML100890237).

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2), GR-01 - Reactor Coolant Pressure Boundary Isolation Valve – Leak Testing

8. <u>References</u>

- 1. NUREG-1482, *Guidelines for Inservice Testing at Nuclear Power Plants*, Revision 2.
- 2. Technical Specifications 3.4.14, *RCS Pressure Isolation Valve (PIV) Leakage*, and associated TS Surveillance Requirement SR-3.4.14.2.
- 3. Ginna Surveillance Frequency Control Program

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2), VR-01 - Service Water Solenoid-Operated Valves (SOVs) – Stroke Time Testing

1. ASME Code Component(s) Affected

Valve	Description	Code Class	Category
4324	TDAFW Pump SW Strainer Bypass SOV	3	В
4325	MDAFW Pump A SW Strainer Bypass SOV	3	В
4326	MDAFW Pump B SW Strainer Bypass SOV	3	В

These service water (SW) valves open upon an auxiliary feedwater (AFW) pump bearing cooling water supply high strainer differential pressure (DP) to provide cooling water to the driver's bearings.

2. Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code) 2012 Edition with no Addenda.

3. Applicable Code Requirement

ISTC-5150, *Solenoid-Operated Valves*, paragraph ISTC-5151, *Valve Stroke Testing*, states: *"(a)* Active valves shall have their stroke times measured when exercised in accordance with para. ISTC-3500.

(b) The limiting value(s) of full-stroke time of each valve shall be specified by the Owner. *(c)* Stroke time shall be measured to at least the nearest second.

(d) Any abnormality or erratic action shall be recorded (see para. ISTC-9120), and an evaluation shall be made regarding need for corrective action."

ISTC-5152, *Stroke Test Acceptance Criteria*, states, in part, "Test results shall be compared to reference values established in accordance with para. ISTC-3300, ISTC-3310, or ISTC-3320."

4. Reason for Request

Pursuant to 10 CFR 50.55a, *Codes and Standards*, paragraph (z)(2), an alternative to the requirements of ASME OM-2012 Code, paragraphs ISTC-5151 and ISTC-5152 is proposed. The basis of the request is that compliance with the specified requirements would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety.

These SOVs are normally closed rapid acting valves that automatically actuate to the open position on high differential pressure across the supply strainer. Measurement of stroke times during manual actuation using conventional methods cannot be performed to produce consistent, meaningful or trendable test results. The valves are not provided with control switches to allow for conventional stroke timing methodology. Additionally, there is no remote valve position indication or other positive means to determine valve disc position. Without concise methods of initiating valve movement or determining when the stroke is completed, it is difficult to obtain repeatable stroke time data to monitor for degradation. It would be

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2), VR-01 - Service Water Solenoid-Operated Valves (SOVs) – Stroke Time Testing

necessary to disassemble the respective differential pressure switch in order tocontrol actuation of these valves and as a result of this disassembly, stroke timing during power operation would require rendering these valves inoperable and entering a limiting condition for operation (LCO) from which prompt restoration would not be possible.

These valves are tested on a quarterly frequency during AFW pump testing. This testing includes strainer cleaning, strainer isolation, high differential pressure simulation, verification of valve operation, and flow observation. Failure of these valves to stroke in conjunction with a clogged strainer would result in a lack of pressure at the bearing cooler inlet and a high DP alarm, at which time an Operator would be dispatched to manually trip the respective valve.

This quarterly verification, while not measuring stroke time or monitoring for valve degradation, does provide an indication that each SOV is moving to its safety position by verifying disc movement and is consistent with the guidelines provided in NUREG-1482, Revision 2, Section 4.2.3, *Stroke Time for Solenoid-Operated Valves*.

Therefore, relief is requested pursuant to 10 CFR 50.55a(z)(2) based on the determination that compliance with the Code SOV testing requirements regarding stroke timing cannot be achieved without resulting in a hardship or unusual difficulty without a compensating increase in the level of quality and safety; and the proposed alternative testing including strainer cleaning, strainer isolation, high differential pressure simulation, verification of valve operation, and flow observation provides reasonable assurance of operational readiness and provides an acceptable level of quality and safety.

5. Proposed Alternative and Basis for Use

These valves will be stroke tested during associated AFW pump testing by closing the valve downstream of the strainer. Acceptable valve operation will be based on:

- Verifying locally that the valve has de-energized and tripped open.
- Verifying the presence of a steady stream of water from the affected floor drain funnel.
- Verifying that the associated main control board annunciator alarms.

The proposed alternative testing will accurately reflect obturator position and will provide reasonable assurance of the valves' operational readiness. Thus, this alternative to the requirements of the Code-required stroke time testing of the SW SOVs is proposed pursuant to 10 CFR 50.55a(z)(2).

6. Duration of Proposed Alternative

This request, upon approval, will be applied to the R. E. Ginna Nuclear Power Plant sixth 10year interval, which begins on January 1, 2020, and is scheduled to end on December 31, 2029.

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2), VR-01 - Service Water Solenoid-Operated Valves (SOVs) – Stroke Time Testing

7. <u>Precedent</u>

This relief request was previously approved for the fifth 10-year interval at Ginna, as documented in NRC safety evaluation, "Alternative Requests for Fifth 10-Year Pump and Valve Inservice Testing Program – R. E. Ginna Nuclear Power Plant (TAC Nos. ME2232, ME2233, ME2234, ME2235, ME2236, ME2237, ME2238, and ME2239)," dated December 30, 2009 (ML093570173).

8. <u>References</u>

1. NUREG-1482, *Guidelines for Inservice Testing at Nuclear Power Plants*, Revision 2.

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2), VR-02 - Pressurizer Safety Relief Valves – Position Indication

1. ASME Code Component(s) Affected

Component ID	Description	Code Class	Category
434	Pressurizer Relief Valve	1	С
435	Pressurizer Relief Valve	1	С

The Pressurizer Safety Relief Valves provide over-pressurization protection for the Reactor Coolant System (RCS)/Pressurizer.

2. Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code) 2012 Edition with no Addenda.

3. Applicable Code Requirement

Mandatory Appendix I, paragraph I-7310, *Class 1 Safety Valves*, states, in part, "Tests before maintenance or set-pressure adjustment, or both, shall be performed for subparas. I-7310(a) through (c) in sequence. The remaining shall be performed after maintenance or set-pressure adjustment."

Subparagraph I-7310(f) states, "determination of operation and electrical characteristics of position indicators."

4. Reason for Request

Pursuant to 10 CFR 50.55a, *Codes and Standards*, paragraph (z)(2), an alternative to the requirement of ASME OM Code Mandatory Appendix I, subparagraph I-7310(f) is proposed. The basis of the request is that compliance with the specified requirements would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety.

These valves are mechanical spring-actuated valves with an externally mounted Linear Voltage Differential Transformer (LVDT) stem position indicator. The position indicator must be removed in order to permit removal of the safety valves each refueling outage for shipment to an off-site vendor for set pressure testing. It would be necessary to intentionally challenge RCS pressure limits to actuate these safety valves in order to perform position indication testing prior to removal for set pressure testing. Also, if these safety valves were actuated for a position indication test following re-installation, they would again need to be retested to ensure the set pressure has not been adversely affected. This involves increased testing and unnecessary radiation exposure to test personnel and results in a hardship without a compensating increase in the level of quality and safety.

Proposed Alternative in Accordance with 10 CFR 50.55a(z)(2), VR-02 - Pressurizer Safety Relief Valves – Position Indication

5. Proposed Alternative and Basis for Use

In accordance with plant administrative procedures, channel checks for Pressurizer safety relief valve position indication are performed once per shift and validated by comparison with tailpipe temperature indication. The valves are also simulated to actuate using station calibration procedures. The procedure utilizes movement of the valve's coil (up/down) and verifies position via an alarm in the Control Room. Calibration of these position indicators is governed by plant calibration procedures and is performed on a refueling outage frequency. These procedures verify that the proper clearance is obtained to ensure obturator position is accurately represented and provide reasonable assurance of valve operational readiness. Thus, this alternative to the Code-required testing of the pressurizer safety relief valves is proposed pursuant to 10 CFR 50.55a(z)(2).

6. Duration of Proposed Alternative

This request, upon approval, will be applied to the R. E. Ginna Nuclear Power Plant sixth 10year IST interval, which begins on January 1, 2020, and is scheduled to end on December 31, 2029.

7. Precedent

This relief request was previously approved for the fifth 10-year interval at Ginna, as documented in NRC safety evaluation, "Alternative Requests for Fifth 10-Year Pump and Valve Inservice Testing Program – R. E. Ginna Nuclear Power Plant (TAC Nos. ME2232, ME2233, ME2234, ME2235, ME2236, ME2237, ME2238, and ME2239)," dated December 30, 2009 (ML093570173).

Attachment 6

Relief Request RAI and SER



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

August 5, 2019

Mr. Bryan C. Hanson Senior Vice President Exelon Generation Company, LLC President and Chief Nuclear Officer Exelon Nuclear 4300 Winfield Road Warrenville, IL 60555

SUBJECT: R. E. GINNA NUCLEAR POWER PLANT– ISSUANCE OF RELIEF REQUEST ASSOCIATED WITH ALTERNATIVES PR-01 AND PR-02 FOR THE SIXTH 10-YEAR INSERVICE TESTING PROGRAM (EPID L-2018-LLR-0381)

Dear Mr. Hanson:

By letter dated December 13, 2018 (Agencywide Documents Access and Management System Accession No. ML18347B036), Exelon Generation Company, LLC (the licensee) requested relief from the requirements of the American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code) associated with pump inservice testing for the R. E. Ginna Nuclear Power Plant.

Specifically, pursuant to Title 10 of the Code of Federal Regulations (10 CFR) 50.55a(z)(2), the licensee requested to use the proposed alternatives in requests PR-01 and PR-02 on the basis that the ASME OM Code requirements present an undue hardship, without a compensating increase in the level of quality or safety.

The U.S. Nuclear Regulatory Commission (NRC) staff has determined that compliance with the specified requirements would result in hardship or unusual difficulty, without a compensating increase in the level of quality and safety. Accordingly, the NRC staff concludes that the licensee has adequately addressed all the regulatory requirements set forth in 10 CFR 50.55a(z)(2). Therefore, the NRC staff authorizes the use of these alternative requests for the sixth 10-year inservice testing program interval, which begins on January 1, 2020, and is scheduled to end on December 31, 2029.

All other ASME OM Code requirements for which relief was not specifically requested and approved in the subject request for relief remain applicable.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

August 5, 2019

Mr. Bryan C. Hanson Senior Vice President Exelon Generation Company, LLC President and Chief Nuclear Officer Exelon Nuclear 4300 Winfield Road Warrenville, IL 60555

SUBJECT: R. E. GINNA NUCLEAR POWER PLANT- ISSUANCE OF RELIEF REQUEST ASSOCIATED WITH ALTERNATIVES GR-01, VR-01, AND VR-02 FOR THE SIXTH 10-YEAR INSERVICE TESTING PROGRAM (EPID L-2018-LLR-0382; EPID L-2018-LLR-0383)

Dear Mr. Hanson:

By letter dated December 13, 2018 (Agencywide Documents Access and Management System Accession No. ML18347B036), Exelon Generation Company, LLC (the licensee) requested relief from the requirements of the American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code), associated with valve inservice testing for the R. E. Ginna Nuclear Power Plant (Ginna).

Specifically, pursuant to Title 10 of the Code of Federal Regulations (10 CFR) 50.55a(z)(2), the licensee requested to use the proposed alternatives in requests GR-01, VR-01, and VR-02 on the basis that the ASME OM Code requirements present an undue hardship, without a compensating increase in the level of quality or safety.

The U.S. Nuclear Regulatory Commission (NRC) staff has determined that compliance with the specified requirements would result in hardship or unusual difficulty, without a compensating increase in the level of quality and safety. Accordingly, the NRC staff concludes that the licensee has adequately addressed all the regulatory requirements set forth in 10 CFR 50.55a(z)(2). Therefore, the NRC staff authorizes the use of these alternative requests for the sixth 10-year IST program interval, which begins on January 1, 2020, and is scheduled to end on December 31, 2029.

All other ASME OM Code requirements for which relief was not specifically requested and approved in the subject request for relief remain applicable.

Attachment 7

Code Case Index

CODE CASE <u>TITLE</u> NUMBER

OMN-20 Inservice Test Frequency

Attachment 8

Cold Shutdown Justification Index

<u>CSJ NUMBER</u>	<u>REV #</u>	TITLE
CS-01	0	590, 591, 592, 593
CS-02	0	8616A, 8616B, 8619A, 8619B, 8620A, 8620B, 8630A, 8630B
CS-03	0	700, 701, 720, 721
CS-04	0	841, 865
CS-05	0	702
CS-06	0	710A, 710B
CS-07	0	112B, 357, LCV-112C
CS-08	0	142, 370B, 392A, 393, 295, 297, 9313, 9314, 9315
CS-09	0	200A, 200B, 202, 371
CS-10	0	270A, 270B, 304A, 304B
CS-11	0	386
CS-12	0	383A, 383B, 392B
CS-13	0	850A, 850B
CS-14	0	750A, 750B, 753A, 753B
CS-15	0	951, 953, 955, 951C, 953C, 955C
CS-16	0	3516, 3517
CS-17	0	3518, 3519
CS-18	0	3992, 3993
CS-19	0	3994, 3995, 4269, 4270, 4271, 4272
CS-20	0	3994G, 3995G
CS-21	0	856
CS-22	0	896A, 896B
CS-23	0	897, 898
CS-24	0	4083
Attachment 9

Cold Shutdown Justifications

COLD SHUTDOWN JUSTIFICATION - CS-01

Component ID	Class	Cat.	System
590	2	В	Reactor Coolant
591	2	В	Reactor Coolant
592	2	В	Reactor Coolant
593	2	В	Reactor Coolant

FUNCTION

These normally closed pilot operated solenoid valves are part of the RCS head vent system. The valves must be capable of opening to vent non-condensable gases from the reactor vessel head space during post-accident conditions. This function supports post accident recovery by allowing the removal of gases from the reactor vessel head space which could inhibit adequate core cooling during natural circulation. The valves perform a safety function in the closed position to maintain pressure boundary integrity of the RCS.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASISFOR JUSTIFICATION

Periodic full or part-stroke exercising in the open and closed directions during normal plant operation could degrade this system by repeatedly challenging the downstream valves due to a phenomenon known as "burping." This phenomenon has been previously described in ASME report "Spurious Opening of Hydraulic-Assisted, Pilot-Operated Valves - An Investigation of the Phenomenon." The phenomenon involves a rapid pressure surge buildup at the valve inlet caused by opening the upstream valve in a series double isolation arrangement or closing a valve in a parallel redundant flow path isolation arrangement. The pressure surge is sufficient enough to lift the valve plug until a corresponding pressure increase in a control chamber above the pilot and disc can create enough downward differential pressure to close the valve. Failure of any one of these valves in the open direction would reduce the pressure boundary status from double-valve protection to single-valveprotection between the Reactor Coolant System (RCS) and the Containment building atmosphere.

ALTERNATE TESTING

Valve full stroke exercising shall be performed during cold shutdowns when RCS pressure has been reduced.

Component ID	Class	Cat.	<u>System</u>
8616A	3	В	Reactor Coolant
8616B	3	В	Reactor Coolant
8619A	3	В	Reactor Coolant
8619B	3	В	Reactor Coolant
8620A	NC	В	Reactor Coolant
8620B	NC	В	Reactor Coolant
8630A	3	С	Reactor Coolant
8630B	3	С	Reactor Coolant

COLD SHUTDOWN JUSTIFICATION - CS-02

FUNCTION

Solenoid-operated valves 8616A and 8616B are Overpressure Protection System (OPS) surge tank charging valves. Solenoid-operated valves 8619A, 8619B, 8620A and 8620B are nitrogen three way valves for the PORVs. Valves 8630A and 8630B are the PORV actuating line check valves. All these valves must be capable of position change to support actuation of the Pressurizer power operated relief valves (PORV).

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Full or partial exercising of these valves during power operation would actuate the power operated relief valves. Since the associated inlet block valves are not required to be Category A valves and their seat tightness is not credited in the licensing basis, actuation of the PORVs during power operation could cause unplanned pressure transients in the RCS resulting in a reactor trip.

ALTERNATE TESTING

Valve full stroke exercising shall be performed during cold shutdowns in conjunction with PORV exercising.

Component ID	Class	Cat.	System
700	1	А	Residual Heat Removal (RHR)
701	1	А	RHR
720	1	А	RHR
721	1	А	RHR

COLD SHUTDOWN JUSTIFICATION - CS-03

FUNCTION

These normally closed motor operated valves are located in the RHR supply line from the RCS loop A hot leg (700, 701) and the RHR pump discharge to the Loop B cold Leg (720, 721). Thevalves must open for initiation of RHR shutdown cooling. The shutdown cooling mode of RHR is not required for accident mitigation or to achieve/maintain safe shutdown and is not considered safety related since Ginna is licensed for hot shutdown being the safe shutdown condition. It is; however, considered a risk significant function and components supporting this function may be subject to testing. These valves perform a safety function in the closed position to isolate RCS pressure from the lower design pressure of the RHR system. Valves 701 and 720 also perform a safety function in the closed position to provide containment isolation for penetrations P140 and P111.

TEST REQUIREMENT

Mandatory Appendix III, paragraph III-3721, HSSC MOVs, states that HSSC MOVs shall be exercised in accordance with para. III-3600. HSSC MOVs that can be operated during plant operation shall be exercised quarterly, unless the potential increase in core damage frequency (CDF) and large early release (LER) associated with a longer exercise interval is small.

BASIS FOR JUSTIFICATION

For valves 700 and 721, exercising is not possible due to a high pressure interlock which prevents the valve from opening when RCS pressure is above 410 psig, thereby, preventing the inadvertent overpressurization of the RHR system piping and components.

For valves 701 and 720, exercising during power operation is impractical. Failure of the valve in the open position would reduce the system from double to single-valve-protection between the RCS and RHR systems. Leakage of the associated inboard valve could result in over-pressurization of the RHR system piping and components or cause an inter-system LOCA.

ALTERNATE TESTING

Valve full stroke exercising shall be performed during cold shutdowns when RCS pressure is below the valve interlock and is reduced to the point of allowing the valves to be safely opened.

COLD \$	SHUTDOWN	JUSTIFICATION	-	CS-04
---------	----------	---------------	---	-------

Component ID	Class	Cat.	<u>System</u>
841	2	В	Safety Injection
865	2	В	Safety Injection

FUNCTION

These normally open motor operated valves, located in the outlet piping from the Safety Injection (SI) accumulators, must remain open to allow injection of the accumulator inventory to the RCS loop A/B cold leg when RCS pressure has been reduced below accumulator nitrogen pressure. During normal plant operation the valves have the control power removed to ensure the safety function of the accumulator can be accomplished. They receive a confirmatory safety injection signal to ensure that they are fully open.

The valves perform a safety significant function in the closed position. As directed by an EOP, the valves are closed after the accumulator contents have been injected to prevent nitrogen intrusion into the RCS. This function promotes natural circulation of safety injection flow by minimizing voids in the RCS.

TEST REQUIREMENT

Mandatory Appendix III, paragraph III-3721, HSSC MOVs, states that HSSC MOVs shall be exercised in accordance with para. III-3600. HSSC MOVs that can be operated during plant operation shall be exercised quarterly, unless the potential increase in core damage frequency (CDF) and large early release (LER) associated with a longer exercise interval is small.

BASIS FOR JUSTIFICATION

Valves 841 and 865 are SI accumulator isolation valves. The valves are closed to isolate the SI accumulators during Reactor Coolant System (RCS) cooldown. Exercising these valves during power operation is not practical because it would unnecessarily place the plant in a more risk-significant configuration (even though it is not a significant risk contributor, the isolated accumulator could not inject during a LOCA sequence) without a corresponding increase in safety. Additionally, exercising these valves during power operation would cause a loss of system function if they were to fail in a non-conservative position during the cycling test. There is also a Technical Specification requirement to maintain these valves locked open with power removed when RCS pressure is above 1600 psig. Failure of these valves in the closed position would require shutting down the reactor.

ALTERNATE TESTING

Valve full stroke exercising shall be performed during cold shutdowns when the accumulators can be isolated without compromising plant safety.

COLD SHUTDOWN JUSTIFICATION - CS-05

Component ID	Class	Cat.	<u>System</u>
702	2	С	Residual Heat Removal (RHR)

FUNCTION

This normally closed check valve is located in a branch connection to CVCS letdown off the RHR low head safety injection (LHSI)/shutdown cooling header inside the primary containment. The valve must open to provide a pressure relief flow path between the LHSI/RHR piping and the letdown orifice outlet relief valve, 203. Overpressure protection is required to prevent over-pressurization of the lower pressure LHSI piping in the event of in-leakage from the high pressure RCS. Additionally, Ginna's response to GL 96-06 credits 702 with opening to prevent thermal over-pressurization of containment penetration P111 piping and components during post-LOCAconditions.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Full exercising this check valve during power operation would require isolating letdown which could cause perturbations in or result in a loss of Pressurizer level control possibly resulting in a reactor trip.

ALTERNATE TESTING

Valve full stroke exercising shall be performed during cold shutdowns when letdown is not required to be in service.

COLD SHUTDOWN JUSTIFICATION - CS-06

Component ID	Class	Cat.	<u>System</u>
710A	2	С	Residual Heat Removal (RHR)
710B	2	С	RHR

FUNCTION

These check valves are located at the discharge of RHR pumps. The valves must be capable of opening during post-accident low head safety injection and during the recirculation phase of safety injection. The check valves must be capable of closure if the adjacent train is out of service to prevent diversion of the in service pump's recirculation flow or to prevent diversion if train A and B are cross-tied.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Closure testing of valves during power operation is not practical since this would require cross-tying the RHR pumps discharge headers thus rendering both trains of RHR inoperable. In accordance with NUREG 1482, Rev.2, Section 3.1.2, entry into multiple LCOs to facilitate testing is to be avoided.

ALTERNATE TESTING

Valve full stroke exercising shall be performed during cold shutdowns when the system can be aligned to facilitate testing.

COLD SHUTDOWN JUSTIFICATION - C					
Component ID	Class	Cat.	<u>System</u>		
112B	2	В	Chemical and Volume Control		
112C	NC	В	Chemical and Volume Control		
357	2	С	Chemical and Volume Control		

COLD SHUTDOWN JUSTIFICATION - CS-07

FUNCTION

112B is a normally closed air operated valve located in the RWST supply line to the charging pumps suction. The valve performs a safety significant function in the open position to align the RWST inventory to the charging pumps suction. 112C is a normally open non-Code class air operated valve located in the VCT outlet line to the charging pumps suction. The valve performs a safety significant function in the closed position to isolate the VCT when the charging pumps suction is aligned to the RWST. 112C is interlocked with the RWST supply valve 112B such that 112B auto opens and 112C auto closes when the VCT level reaches 5% as indicated on LT-112 and LT-139. The RWST is designated as the emergency supply source of borated water for makeup and boration of the RCS. Likewise, 357 is a normally closed check valve located in the RWST supply line to the charging pumps suction. 357 performs a safety significant function in the open direction to provide a flow path for RWST inventory to the charging pumps suction.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Exercising these valves during power operation would cause a sudden increase in the RCS boron inventory, and thereby cause a plant transient and possible shutdown.

ALTERNATE TESTING

Valve full stroke exercising shall be performed when transitioning to or during cold shutdowns when boron concentration is not a concern.

Component ID	Class	Cat.	<u>System</u>
142	2	В	Chemical and Volume Control
370B	2	AC	Chemical and Volume Control
392A	2	BC	Chemical and Volume Control
393	1	С	Chemical and Volume Control
9315	1	С	Chemical and Volume Control
295	1	С	Chemical and Volume Control
297	1	С	Chemical and Volume Control
9313	1	С	Chemical and Volume Control
9314	1	С	Chemical and Volume Control

COLD SHUTDOWN JUSTIFICATION - CS-08

FUNCTION

Normally open air operated valve (142) and check valve 370B are located in the charging header. The valves perform a safety significant function in the open position to provide a flow path for RCS makeup and boration when the charging pumps are aligned to receive suction from the RWST as the emergency makeup supply source ofborated water. Additionally, 370B performs an open safety function for penetration over pressure protection to address GL 96-06 concerns and as a designated containment isolation valve must close for containment integrity post-LOCA. 392A, 393, and 9315 are normally closed valves located in the alternate charging line from the regenerative heat exchanger to the RCS Loop B hot leg.

392A is a normally closed Class 2 air operated valve. 393 and 9315 are Class 1 check valves. They perform a safety significant function in the open direction since this flow path is designated as the safety related flow path for the purpose of providing makeup and boration to the RCS when the suction of the charging pumps is aligned to the RWST. 392A serves as an isolation valve and a relief valve. The valve performs a safety function in its relieving position. Although 392A fails to the closed position on a loss of actuating air or control power, it is designed to open at a differential pressure setpoint of 250 psid to allow sufficient charging flow to provide cold shutdown boration.

295, 297, 9313, and 9314 are Class 1 check valves in the normal charging (295, 9314) and auxiliary pressurizer spray (297, 9313) flow paths. These valves perform a reactor coolant pressure boundary function.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Exercising these valves during power operation would isolate charging flow to the RCS which could result in loss of Pressurizer level control and a reactor trip. In addition, exercising these valves during power operation may result in excessive thermal cycles to the regenerative heat exchanger potentially resulting in premature equipment failure and reduction in its expected service life.

ALTERNATE TESTING

Valve full stroke exercising shall be performed when transitioning to or during cold shutdowns when charging flow can be secured.

COLD SHUTDOWN JUSTIFICATION	-	CS-09
-----------------------------	---	-------

Component ID	Class	Cat.	<u>System</u>
200A	1	А	Chemical and Volume Control
200B	1	А	Chemical and Volume Control
202	1	А	Chemical and Volume Control
371	2	А	Chemical and Volume Control

FUNCTION

200A, 200B, and 202 are air operated valves located downstream of the letdown orifices. 371 is an air operated valve located in the normal letdown line from the RCS loop B to the non-regenerative heat exchanger. The valves perform a safety function in the closed position to maintain containment integrity during post-LOCA conditions. The valves are designated inboard containment isolation valves for penetrations P111 and P112.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Full or partial exercising of AOV 371 during power operation would interrupt or isolate letdown flow from the RCS which would result in loss of Pressurizer level control and, potentially, a reactor trip. Full or partial exercising of AOVs-200A, 200B, or 202 during power operation could result in severe letdown flow perturbations that could potentially result in adverse Pressurizer level and RCS pressure transients.

ALTERNATE TESTING

Valve full stroke exercising shall be performed when transitioning to or during cold shutdowns when letdown flow can be secured.

Component ID	Class	Cat.	<u>System</u>	
270A	2	В	Chemical and Volume Control	
270B	2	В	Chemical and Volume Control	
304A	1	С	Chemical and Volume Control	
304B	1	С	Chemical and Volume Control	

COLD SHUTDOWN JUSTIFICATION - CS-10

FUNCTION

270A and 270B are air operated valves located in the seal water return lines from the RCP shaft seals. The valves perform a safety significant function in the closed position. Although the valves fail open, they are the only power operated valves located in the pressure class 2501 seal leak-off piping. Should a catastrophic leak occur at the RCP seal, the valves may be required to close to isolate the pressure class 151 piping and components associated with containment penetration P108 from RCS pressure, although this piping is also protected by a relief valve. 304A and 304B are check valves located in the CVCS seal water injection lines to the RCP shaft seals. They perform a safety significant function in the open direction by allowing at least 8 gpm flow to accomplish the emergency boration function. Additionally, per response to GL 96-06, the valves must be capable of partially opening to provide a thermal over-pressure protection safety function for penetrations P106 and P110 during post-LOCA conditions if flow is terminated to the seals. They must also close to provide containment isolation for the associated containment penetrations.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Exercising these valves during power operation would interrupt flow to and from RCP seals which could result in RCP seal damage and require the plant to shut down.

ALTERNATE TESTING

Valve exercising shall be performed during cold shutdowns when RCP seal water flow can be interrupted.

COLD SHUTDOWN JUSTIFICATION - CS-11

Component ID	Class	Cat.	<u>System</u>
386	2	В	Chemical and Volume Control

FUNCTION

386 is an air operated valve located in the seal bypass line from RCP A and B. 386 is the only power operated valve located in the pressure class 2501 seal bypass piping. Should a catastrophic leak occur at either RCP seal while the seal bypass is in service, 386 may be required to close to isolate the pressure class 151 piping and components associated with containment penetration P108 from RCS pressure.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Exercising this valve during power operation would divert flow from the RCP seals which could result in RCP seal damage and require the plant to shut down.

ALTERNATE TESTING

Valve exercising shall be performed during cold shutdowns when RCP seal water flow can be interrupted.

COLD SHUTDOWN JUSTIFICATION - CS-12

Component ID	Class	Cat.	<u>System</u>
383B	2	AC	Chemical and Volume Control
392B	1	BC	Chemical and Volume Control
383A	1	С	Chemical and Volume Control

FUNCTION

These valves are located in the CVCS alternate charging line to the RCS loop A cold leg. The valves perform a safety function in both the open and closed directions. They must open for GL 96-06 concerns and 383, as a designated containment isolation valve, must be capable of closure on cessation or reversal of flow to maintain containment integrity.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Reverse flow exercising of these valves is impractical during power operation because this test would result in substantial radiation exposure to test personnel raising ALARA concerns. The valves are located inside containment and reverse exercising requires the use of temporary test equipment and an outside pressure source.

ALTERNATE TESTING

Valve exercising shall be performed during cold shutdowns.

COLD SHUTDOWN JUSTIFICATION - CS-13

Component ID	Class	Cat.	<u>System</u>
850A	2	В	Residual Heat Removal (RHR)
850B	2	В	RHR

FUNCTION

These normally closed motor operated valves, located in the RHR pump supply lines from the containment sumps, must open during low head safety injection, upon depletion of the usable portion of the RWST inventory (28%), to provide a flow path for sump inventory to the RHR pumps suction for continued core cooling during the recirculation phase of safety injection.

The valves perform a passive safety function in the closed position. Upon low head safety injection actuation, the normally closed position of the valves will prevent the diversion of RWST inventory to the containment sump in lieu of being directed to the core deluge nozzles. The valves are also designated containment isolation valves for penetrations P141/P142.

TEST REQUIREMENT

Mandatory Appendix III, paragraph III-3721, HSSC MOVs, states that HSSC MOVs shall be exercised in accordance with para. III-3600. HSSC MOVs that can be operated during plant operation shall be exercised quarterly, unless the potential increase in core damage frequency (CDF) and large early release (LER) associated with a longer exercise interval is small.

BASIS FOR JUSTIFICATION

Exercising these valves during power operation is not practical because it requires the energizing and closure of inboard suction line passive MOVs 851A/B. MOVs 851A/B are specially designed with a 20 foot reach rod connecting the motor operator actuator to the actual valve. This design creates a higher possibility of damage/separation between the actuator and valve. Lack of full closure of 851A/B would result in loss of RWST inventory to the containment sump so stroking of MOVs 851A/B online is not recommended. The lineup for exercising these valves requires entry into an LCO due to inoperability of RHR. Per NUREG 1482 Revision 2 section 3.1.2, entry into such an LCO is adequate justification for deferral of Inservice Testing.

ALTERNATE TESTING

Valve full stroke exercising shall be performed during cold shutdowns when the Containment Sump inventory can be isolated without compromising plant safety.

COLD SHUTDOWN J	USTIFICATION	- CS-14
------------------------	---------------------	---------

Component ID	Class	Cat.	System
750A	2	С	Component Cooling Water (CCW)
750B	2	С	CCW
753A	2	С	CCW
753B	2	С	CCW

FUNCTION

These check valves are located inside containment in the cooling water supply lines to the RCP thermal barrier coolers. The cooling coils of the thermal barriers are part of the RCS pressure boundary. A rupture in the RCP thermal barrier cooling coils would result in the release of reactor coolant to the attached CCW piping. Closure of these valves minimizes the low pressure CCW closed system piping exposed to RCS pressure.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Reverse flow exercising of these valves during operation at power would require isolation of CCW flow to the thermal barriers. This could result in damage to an operating reactor coolant pump and a reactor trip. Additionally, reverse exercising these check valves requires entry into containment and the installation of temporary test equipment.

ALTERNATE TESTING

Valve exercising shall be performed during cold shutdowns when the RCPs can be removed from service.

Component ID	Class	Cat.	<u>System</u>
951C	1	С	Plant Sampling
953C	1	С	Plant Sampling
955C	1	С	Plant Sampling
951	1	В	Plant Sampling
953	1	В	Plant Sampling
955	1	В	Plant Sampling

COLD SHUTDOWN JUSTIFICATION - CS-15

FUNCTION

Check valves 951C, 953C, and 955C serve as thermal over-pressure protection devices for containment penetration piping and components. The valves were installed to satisfy GL 96-06 concerns. Air-operated valves (AOVs) 951, 953, and 955 are normally closed RCS and Pressurizer sample valves. They have no open safety function. They are non-credited inboard containment isolation valves for penetrations P205, P206a, & P207a. They receive a confirmatory containment isolation signal to enhance the isolation capabilities of the associated penetrations.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Exercising the check valves (951C, 953C, and 955C) quarterly requires entry into Containment inside the missile barrier to connect test equipment, perform the test and disconnect test equipment. Under power operating conditions, this area is a high radiation area and not readily accessible. Since the personnel safety risks and ALARA concerns far outweigh the benefit achieved with a quarterly test, testing of these check valves will be performed during cold shutdowns. Quarterly exercising of the Primary Sample AOV's (951, 953, and 955), also located inside containment inside the missile barrier, increases the potential risk for excessive packing leakage and an excessive packing leak may cause an unplanned reactor shutdown as was the case at LaSalle Unit 2.

ALTERNATE TESTING

Valve exercising shall be performed during cold shutdowns.

COLD SHUTDOWN JUSTIFICATION - CS-16

Component ID	Class	Cat.	System
3516	2	В	Main Steam
3517	2	В	Main Steam

FUNCTION

These air operated check valves are located in the main steam headers and serve as the main steam isolation valves (MSIV). The valves perform a safety function in the closed direction to prevent the unrestricted release of steam from the steam generator during a steam line break (SLB) and to protect the integrity of the unaffected steam generator for decay heat removal. Additionally, as designated containment isolation valves, they must also be capable of closure to maintain containment integrity.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Exercising these valves during normal operation isolates one line of steam flow to the turbine. Isolation of a main steam header would cause a severe pressure transient in the associated main steam line possibly resulting in a plant trip. Additionally, closure of an MSIV, at power, could potentially result in challenging the set point of the main steam relief valves causing inadvertent lifting. Reducing power level to perform testing without causing a transient would significantly impact plant operations and power production.

ALTERNATE TESTING

Valve exercising shall be performed during cold shutdowns when the main steam headers can be isolated.

COLD SHUTDOWN JUSTIFICATION - CS-17

Component ID	Class	Cat.	System
3518	3	С	Main Steam
3519	3	С	Main Steam

FUNCTION

These check valves are located downstream of MSIVs. The valves perform a safety function in the closed direction. A steam line rupture downstream of the non-return valves would require valve closure to prevent unrestricted blow-down of the unaffected steam generator. This function prevents the addition of large amounts of mass and energy to containment which could compromise containment integrity and protects the integrity of the unaffected steam generator so it may be used for decay heat removal.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Exercising of these values to the closed position is not possible without isolating the main steam header. Isolation of a main steam header would cause a severe pressure transient in the associated main steam line possibly resulting in a plant trip. Reducing power level to perform testing without causing a transient would significantly impact plant operations and power production.

ALTERNATE TESTING

These valves will be verified to be capable of closing during normal plant shutdown to cold shutdown, following closure of the main steam isolation valves. If the plant shutdown is a result of a plant trip, these valves will be verified to be capable of closing subsequent to the plant trip.

COLD SHUTDOWN JUSTIFICATION - CS-18

Component ID	Class	Cat.	<u>System</u>
3992	2	С	Main Feedwater
3993	2	С	Main Feedwater

FUNCTION

These check valves are located outside containment in the normal feedwater flow path to steam generators. The valves perform a safety function in the closed direction to prevent the diversion of AFW flow from the steam generator to the non-safety-related feedwater piping. Also, subsequent to feedwater isolation during a SGTR or MSLB, closure of the check valves on reversal of flow serves to isolate the faulted steam generator. Additionally, as designated containment isolation valves, they may be required to close for containment integrity.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Exercising the feedwater injection check valves in the reverse direction is impracticable quarterly during power operation due to the necessity of isolating normal feedwater flow to the associated steam generator. Isolation of feedwater flow during normal operation would cause a loss of steam generator level control potentially resulting in a plant trip.

ALTERNATE TESTING

Valve full stroke exercising shall be performed during cold shutdowns when the system can be aligned to facilitate testing.

Component ID	Class	Cat.	<u>System</u>
3994	3	В	Main Feedwater
3995	3	В	Main Feedwater
4269	3	В	Main Feedwater
4270	3	В	Main Feedwater
4271	3	В	Main Feedwater
4272	3	В	Main Feedwater

COLD SHUTDOWN JUSTIFICATION - CS-19

FUNCTION

4269 and 4270 are located in the main feedwater supply headers to the steam generators and serve as mainfeedwater regulating valves (MFRV). 4271 and 4272 are located in the bypass lines around the MFRVs. 3994 and 3995 are located in the main feedwater headers to the steam generators and serve as the main feedwater isolation valves (MFIV). These six air operated valves perform a safety function in the closed position to isolate feedwater flow during a steam line break (SLB) or feedwater line break (FWLB). 3994 and 3995 provide redundant isolation of the feedwater header in conjunction with the upstream MFRVs and their bypass valves. Their closure capability is credited in the accident analysis for redundant isolation of feedwater.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Full or partial exercising of these valves during operation at power is impractical since closing the flow control valves or the isolation valves would isolate feedwater to the respective steam generator and opening the bypass valves would result in feedwater flow perturbations and potentially severe transients including loss of RCS heat sink, loss of steam generator level control and a reactor trip.

ALTERNATE TESTING

Valve testing will be performed during cold shutdown or in transition to hot shutdown when isolation of feedwater will not impact plant safety.

COLD SHUTDOWN JUSTIFICATION - CS-20

Component ID	Class	Cat.	System
3994G	3	С	Main Feedwater
3995G	3	С	Main Feedwater

FUNCTION

These check valves are located in the instrument air supply lines to the actuating air accumulators for main feedwater isolation valves (MFIV). The valves perform a safety function in the closed direction. Subsequent to a loss of normal instrument air, closure of the check valve maintains pressure boundary integrity of the accumulator. The accumulator provides a backup actuating air supply to the MFIV which closes upon receipt of an SI signal. Closure of the MFIV provides redundant isolation capability, in conjunction with the MFRVs and their bypass valves, of the feedwater header.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Closure testing of these check valves entails a pressure drop/decay test of the associated air accumulator. During power operation, check valve closure testing is impractical since an inadvertent loss of air pressure would result in the associated main feedwater isolation valve going closed (fails closed on loss of air pressure). Isolating feedwater to the respective steam generator would result in potentially severe transients including loss of steam generator level control, loss of RCS heat sink and a reactor trip.

ALTERNATE TESTING

Valve testing will be performed during cold shutdown or in transition to hot shutdown when main feedwater can be isolated.

COLD SHUTDOWN JUSTIFICATION - CS-21

Component ID	Class	Cat.	<u>System</u>
856	2	В	Residual Heat Removal (RHR)

FUNCTION

This normally open motor operated valve allows passage of flow from the RWST to RHR pump suction upon a low head safety injection actuation. The valve must close to isolate the RWST during the recirculation phase of safety injection. This closure minimizes the potential for radioactive leakage to the atmosphere via the RWST vent.

TEST REQUIREMENT

Mandatory Appendix III, paragraph III-3721, HSSC MOVs, states that HSSC MOVs shall be exercised in accordance with para. III-3600. HSSC MOVs that can be operated during plant operation shall be exercised quarterly, unless the potential increase in core damage frequency (CDF) and large early release (LER) associated with a longer exercise interval is small.

BASIS FOR JUSTIFICATION

Valve 856 is the RHR pump suction supply valve from the RWST. It is not practical to exercise this valve during power operation as this would isolate the RWST from the RHR system. This would render both RHR trains of low head safety injection inoperable which would require plant shutdown. In accordance with NUREG 1482, section 3.1.2, entry into multiple LCOs is to be avoided.

ALTERNATE TESTING

COLD SHUTDOWN JUSTIFICATION	-	CS-22
-----------------------------	---	-------

Component ID	Class	Cat.	<u>System</u>
896A	2	А	Containment Spray
896B	2	А	Containment Spray

FUNCTION

These normally open motor operated valves are located at the RWST outlet to the Containment Spray (CS) and safety injection pumps suction and are installed in series. The valves must remain open to provide a suction supply flow path to the CS pumps subsequent to a LOCA or steam line break for containment heat removal and to the SI pumps for core cooling.

The valves must close to isolate the RWST during the recirculation phase of safety injection. When the RWST inventory reaches a low level during the injection phase, the CS pumps are provided suction supply from the containment sump via the RHR system. During the recirculation phase, closure of 896A and 896B prevents the release of radioactivity to the atmosphere via the RWST vent. 896A and 896B are interlocked with RHR isolation valves 857A, 857B, and 857C. This interlock prevents opening of the RHR isolation valves unless either 896A or 896B are closed and either 897 or 898, SI pump min-flow isolation valves, are closed.

TEST REQUIREMENT

Mandatory Appendix III, paragraph III-3721, HSSC MOVs, states that HSSC MOVs shall be exercised in accordance with para. III-3600. HSSC MOVs that can be operated during plant operation shall be exercised quarterly, unless the potential increase in core damage frequency (CDF) and large early release (LER) associated with a longer exercise interval is small.

BASIS FOR JUSTIFICATION

These valves should not be exercised during power operation as this would isolate the RWST from the Containment Spray and Safety Injection systems, rendering all trains of these engineered safeguards systems inoperable and would require initiation of a plant shutdown. In accordance with NUREG 1482, section 3.1.2, entry into multiple LCOs is to be avoided.

ALTERNATE TESTING

COLD SHUTDOWN J	USTIFICATION	-	CS-23
-----------------	--------------	---	--------------

Component ID	Class	Cat.	<u>System</u>
897	2	А	Containment Spray
898	2	А	Containment Spray

FUNCTION

These normally open motor operated valves, located in the Safety injection (SI) pumps minimum flow line to the RWST, are installed in series and must open to provide a flow path for SI pump minimum flow when the pumps are operating in low flow or dead-head conditions. The minimum flow path is necessary to prevent the pumps from overheating.

The valves must close to isolate the RWST during the recirculation phase of safety injection. When the RWST inventory reaches a low level during the injection phase, the SI pumps are provided suction supply from the containment sump via the RHR system. During the recirculation phase, closure of 897 and 898 prevents the release of radioactivity to the atmosphere via the RWST vent. 897 and 898 are interlocked with RHR isolation valves 857A, 857B, and 857C. This interlock prevents opening of the RHR isolation valves unless either 897 or 898 are closed and either 896A or 896B, RWST to CS pump isolation valves, are closed.

TEST REQUIREMENT

Mandatory Appendix III, paragraph III-3721, HSSC MOVs, states that HSSC MOVs shall be exercised in accordance with para. III-3600. HSSC MOVs that can be operated during plant operation shall be exercised quarterly, unless the potential increase in core damage frequency (CDF) and large early release (LER) associated with a longer exercise interval is small.

BASIS FOR JUSTIFICATION

During power operation, these valves are maintained open to provide minimum flow protection for the SI pumps. Closing of either of these valves renders all three SI pumps inoperable. In accordance with NUREG 1482, section 3.1.2, entry into multiple LCOs is to be avoided.

ALTERNATE TESTING

COLD SHUTDOWN JUSTIFICATION - CS-24

Component ID	Class	Cat.	<u>System</u>
4083	3	С	Auxiliarv Feedwater

FUNCTION

This normally closed check valve is located in the condensate pressurization supply line to the AFW pumps suction. This valve performs an ACTIVE safety function in the CLOSED direction to prevent the diversion of condensate storage tank water supply to the AFW pumps during accident conditions when the AFW system is required to operate. This check valve serves as the Class 3 to non-Code boundary barrier.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Performing the check valve exercise testing during power operations is not practical since it requires isolating the condensate pressurization line to both trains of AFW. Isolating the condensate pressurization line increases the potential for service water intrusion into both trains of AFW suction piping.

ALTERNATE TESTING

Attachment 10

Refueling Outage Justification Index

ROJ NUMBER	<u>REV #</u>	<u>TITLE</u>
ROJ-01	0	8606A, 8606B
ROJ-02	0	697A
ROJ-03	0	853A, 853B
ROJ-04	0	878G, 878J
ROJ-05	0	870A, 870B
ROJ-06	0	5392
ROJ-07	0	854
ROJ-08	0	9708A, 9708B, 9781
ROJ-09	0	302C, 302D
ROJ-10	0	624, 625

Attachment 11

Refueling Outage Justifications

REFUELING OUTAGE JUSTIFICATION - ROJ-01

Component ID	Class	Cat.	<u>System</u>
8606A	3	AC	Reactor Coolant
8606B	3	AC	Reactor Coolant

FUNCTION

These check valves are located in the nitrogen supply lines to the RCS over-pressure protection accumulators and serve as Class 3 to non-Code boundary barriers. The valves perform a safety function in the closed direction. Closure capability maintains pressure boundary integrity of the accumulator by providing a barrier between the Class 3 and non-Code class portions of the system.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

When these valves are in operation, there is no practical means to test valve closure. Valve closure cannot be verified due to system design. To perform a closure verification constitutes a leak test which presents a significant hardship during operation at power and cold shutdowns. Leak testing requires an extended period of time where the low temperature overpressure protection system will be out of service.

ALTERNATE TESTING

Valve closure verification will be performed in conjunction with a seat leakage test conducted during refueling outages when the over-pressure protection accumulators can be removed from service.

REFUELING OUTAGE JUSTIFICATION - ROJ-02

Component ID	Class	Cat.	<u>System</u>
697A	2	С	Residual Heat Removal

FUNCTION

This check valve is located in the outlet line from RHR heat exchanger "A". It performs a safety function in the open and closed directions. During post accident low head safety injection and during the recirculation phase of safety injection this valve must pass safety injection flow to reactor vessel upper plenum to maintain sufficient core inventory. The check valve isolates the Train A and Train B recirculation flow paths from each other. Additionally, during post-accident system operation, this check valve would be required to close in the event that Train A became unavailable thereby, preventing diversion of Train B flow to an out of service Train A in lieu of being directed to the core.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Full stroke exercising this valve in the forward direction quarterly during power operation is not possible since the RCS is the only available flow path for valve full flow exercising and the RHR pump has insufficient discharge head to overcome reactor pressure. Full stroke exercising this valve in the forward direction during cold shutdown is precluded by restrictions related to LTOP concerns.

ALTERNATE TESTING

Full stroke exercising in the forward direction shall be performed during refueling outages when sufficient expansion volume exists in the RCS to accommodate the required flow rate.

REFUELING OUTAGE JUSTIFICATION - ROJ-03

Component ID	Class	Cat.	<u>System</u>
853A	1	AC	Residual Heat Removal (RHR)
853B	1	AC	RHR

FUNCTION

These check valves are located inside containment in the low head safety injection lines to the reactor vessel. The valves are the first of two valves that serve as the Class 1 to Class 2 boundary barrier. The valves perform a safety function in the open and closed directions. They must open to provide a flow path for injection flow to the reactor vessel upon a low head safety injection actuation and as PIVs, must close to isolate the attached upstream lower pressure RHR system piping from the RCS.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Full stroke exercising these valves in the forward direction quarterly during power operation is not possible due to insufficient RHR pump discharge head to overcome reactor pressure. Full stroke exercising these valves in the forward direction during cold shutdown is precluded by restrictions related to LTOP concerns. During power operation, there is no practical means to test valve closure due to system design. To perform a closure verification constitutes a leak test, which presents significant hardships during cold shutdown, such as the use of temporary test equipment inside containment, excessive radiation exposure to test personnel, and extended outage time.

ALTERNATE TESTING

Full stroke exercising in the forward direction shall be performed during refueling outages when sufficient expansion volume exists in the RCS to accommodate the required flow rate. Reverse flow exercising shall be performed at refueling during the performance of PIV seat leakage testing per TS 3.4.14.

REFUELING OUTAGE JUSTIFICATION - ROJ-04

Component ID	Class	Cat.	System
878G	1	AC	Safety Injection
878J	1	AC	Safety Injection

FUNCTION

These check values are located in the safety injection lines to the RCS cold legs from the SI pumps discharge. The values perform a safety function in the open and closed directions. They must be capable of opening to provide a flow path to the RCS for high head safety injection. As PIVs the values must be capable of closure to maintain the integrity of the RCS pressure boundary and to isolate RCS pressure from the lower pressure SI piping and components.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Full stroke exercising these valves in the forward direction quarterly during power operation is not possible due to insufficient SI pump discharge head to overcome reactor pressure. Full stroke exercising these valves in the forward direction during cold shutdown is precluded by restrictions related to LTOP concerns. During power operation, there is no practical means to test valve closure due to system design. To perform a closure verification constitutes a leak test, which presents significant hardships during cold shutdown, such as the use of temporary test equipment inside containment, excessive radiation exposure to test personnel, and extended outage time.

ALTERNATE TESTING

Full stroke exercising in the forward direction shall be performed during refueling outages when sufficient expansion volume exists in the RCS to accommodate the required flow rate. Reverse exercising shall be performed at refueling during the performance of PIV seat leakage testing per TS 3.4.14.

REFUELING OUTAGE JUSTIFICATION - ROJ-05

Component ID	Class	Cat.	<u>System</u>
870A	2	С	Safety Injection
870B	2	С	Safety Injection

FUNCTION

These check valves are located in the C SI pump discharge lines. The valves perform a safety function in the open and closed directions. They must be capable of opening to provide a flow path to the RCS subsequent to the SI pumps starting on receipt of a safety injection actuation signal. As designated containment isolation valves, they must be capable of closure on reversal of flow to maintain containment integrity of the closed system outside containment. The valves must also be capable of closure to ensure SI pump flow is properly directed to the RCS subsequent to a failure of an SI pump to start.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Full stroke exercising these valves in the forward direction quarterly during power operation is not possible due to insufficient SI pump discharge head to overcome reactor pressure. Full stroke exercising these valves in the forward direction during cold shutdown is precluded by restrictions related to LTOP concerns. The performance of closure verification constitutes pressurizing downstream components inside containment which may impact operability caused by excessive component leakage thereby requiring containment entry at power or potentially requiring the safe shutdown of the reactor. Containment entry at power to isolate and repair leaking components could lead to excessive radiation exposure to plant personnel.

ALTERNATE TESTING

Full stroke exercising in the forward direction shall be performed during refueling outages when sufficient expansion volume exists in the RCS to accommodate the required flow rate. These valves shall be exercised closed during refueling outages when valve closure testing will not impact operability of downstream components inside containment.

REFUELING OUTAGE JUSTIFICATION - ROJ-06

Component IDClassCat.System53922AInstrument Air

FUNCTION

This air operated valve is located in the instrument air supply line to containment. As a designated containment isolation valve, 5392 performs a safety function in the closed position for containment isolation.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Stroking valve 5392 during operation and cold shutdown is impractical because it would interrupt instrument air to containment and be disruptive to those components inside containment that are dependent upon instrument air to accomplish a function. Loss of instrument air would cause all air-operated valves to be actuated to their fail-safe position. During power operation, this would lead to a reactor trip and, during cold shutdown, this would compromise plant operation due to the loss of various components used in maintaining the reactor in a cold shutdown condition. Additionally, the valve control circuitry does not provide for partial stroke capability.

ALTERNATE TESTING:

This valve will be full-stroke exercised during refueling outages when valve closure will not impact downstream component operability.

REFUELING OUTAGE JUSTIFICATION - ROJ-07

Component IDClassCat.System8542CResidual Heat Removal

FUNCTION

This check valve is located in the RHR pump suction supply piping from the RWST. The valve performs a safety function in the open and closed directions. It must becapable of passing flow to RHR pump suction upon a low head safety injection actuation. The valve must be capable of closure during the recirculation phase of safety injection to minimize the potential for radioactive leakage to the atmosphere via the RWST vent.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Valve exercising is not possible during power operation since RHR pump discharge pressure is insufficient to overcome RCS pressure. This valve cannot be full-stroke exercised during cold shutdown because establishing the required safety analysis flow through the valve could result in excessive RCS cooldown rates. Closure verification is not possible since this would require isolation of the vital flow path from the RWST. Valve 854 will be full stroke exercised and closure verified tested during refueling outages. Radiographic testing has been performed for valve 854 and proven to successfully demonstrate positive indication of the valve disk in the closed position. Employing radiographic testing of this valve in the closed position provides positive indication of the required change of disk position.

ALTERNATE TESTING

Full stroke exercising in the forward direction shall be performed during refueling outages. Reverse exercising shall be performed during refueling outages by utilizing non-intrusive radiographic testing.
REFUELING OUTAGE JUSTIFICATION - ROJ-08

Component ID	Class	Cat.	System
9708A	3	С	Standby Auxiliary Feedwater
9708B	3	С	Standby Auxiliary Feedwater
9781	NC	С	Standby Auxiliary Feedwater

FUNCTION

These normally closed check valves are located between the SAFW de-ionized water storage tank and SAFW A/C pump suctions. Valves 9708A/B perform a safety significant function in the open direction to allow the fire protection system to be utilized as a backup to SW as a suction supply source by connecting fire hoses subsequent to a tornado. This configuration would only be used during design basis event tornado conditions if both seismically qualified electrical trains of SW were unavailable.

The valves also perform a safety significant function in the open direction to allow the preferred source of water from the de-ionized water tank to the suction of the SAFW Pumps. The addition of the new de-ionized water tank and associated piping enhance the capability and diversity of the SAFW pumps, and is needed to mitigate the risk significance of the turbine driven auxiliary feedwater pump.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

The SAFW pumps each have a minimum flow path that is utilized for the quarterly pump tests. The flow path to the steam generators has flow instrumentation; however, this flow path has the potential for service water intrusion and requires a reactivity change. This flow path is not used for the quarterly pump tests only the biennial comprehensive pump test (CPT). The quarterly minimum flow path limits flow to 40 gpm which only provides a partial stroke of these valves.

ALTERNATE TESTING

Full stroke exercising in the forward direction shall be performed at refueling outages during the respective pump's CPT.

REFUELING OUTAGE JUSTIFICATION - ROJ-09

Component ID	Class	Cat.	<u>System</u>
302C	1	С	Chemical and Volume Control
302D	1	С	Chemical and Volume Control

FUNCTION

These normally open check valvesare located in the CVCS seal water injection lines to the RCP shaft seals. The valves perform an ACTIVE safety significant function in the OPEN direction. The RCP seal injection lines are one of two emergency boration flow paths when the charging pumps are aligned to the RWST. The valves must be capable of passing at least 8 gpm to accomplish their emergency boration function.

The valves have NO safety function in the CLOSED direction.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

Exercising these valves closed during power operation would interrupt flow to and from the RCP seals which could result in RCP seal damage and require the plant to shut down.

ALTERNATE TESTING

Normal operations satisfies the forward flow exercising requirements as the valves see continuous flow during power operations. Full stroke bi-directional reverse flow exercising shall be performed during refueling outages when RCP seal water flow can be interrupted and the valves are accessible for testing.

REFUELING OUTAGE JUSTIFICATION - ROJ-10

Component ID	Class	Cat.	<u>System</u>
624	2	В	Residual Heat Removal
625	2	В	Residual Heat Removal

FUNCTION

These normally open, air operated flow control valves are located in the discharge lines from RHR heat exchangers A and B. The valves perform a safety function in the open position and fail to the open position in the event of a loss of instrument air or electrical control power. During normal plant operation, the RHR system is maintained in the standby mode for Low Head Safety Injection (LHSI) with these valves in the administratively controlled throttled open position. They are not required to re-position during an accident. The valves are throttled during a normal cooldown to cold shutdown conditions.

TEST REQUIREMENT

OM Code paragraph ISTC-3510 requires Active Category A and B valves and Category C check valves to be exercised nominally every 3 months during operation at power to the position(s) required to fulfill its function(s), except as provided by ISTC-3520, ISTC-3540, ISTC-3550, ISTC-3570, ISTC-5221 and 5222.

BASIS FOR JUSTIFICATION

These control valves are exempted from testing per OM Code ISTC-1200(b), since they perform no specific active function in shutting down the reactor or mitigating the consequences of an accident. During normal plant operation, the RHR system is maintained in the standby mode for LHSI with 624/625 in the administratively controlled throttled open position. Therefore, the valves are not required to change position to perform their safety function when the RHR system is aligned in standby for LHSI. The valves also are not required to be repositioned when aligning the safety injection and RHR systems for the recirculation mode of operation. Ginna has chosen to observe operation of the valve as a good engineering practice. As such, system manipulations to allow exercising the valves quarterly or during cold shutdowns are deemed unnecessary.

ALTERNATE TESTING

Full stroke exercising shall be performed during refueling outages.

Attachment 12

Technical Position index

TECHNICAL POSITION NUMBER	<u>REV #</u>	TITLE
		Corporate
CTP-IST-001	1	Preconditioning of IST Program Components
CTP-IST-003	0	Quarterly Testing of Group B Pumps
CTP-IST-007	2	Skid-Mounted Components
CTP-IST-008	2	Position Verificaton Testing
CTP-IST-014	0	Bi-directional Testing of Check Valves to Their Safety and Non- Safety Related Positions
		Site Specific
TJ-01		Deleted
TJ-02		5933A, 5933B, 5934A, 5934B – Skid-Mounted Classification
/76++95-7J-03		5907, 5907A, 5908, 5908A – Skid-Mounted Classification
1		Deferral Justification Test Window
31320		
I J-04		
TJ-05		On-Line Maintenance
TJ-06		8616A, 8616B, 8619A, 8619B, 8620A, 8620B, 8630A, 8630B – Skid-Mounted Classification
TJ-07		Component Cooling Water Total Pump Flow
TJ-08		Deleted
TJ-09		Deleted
TJ-10		LLRT Scope Reduction Valve Category

<u>984</u>

Attachment 13

Technical Positions

Technical Position Justifications – Corporate

Number: CTP-IST-001, Rev. 1

Title: Preconditioning of IST Program Components

- **Applicability:** All Exelon IST Programs. This issue also applies to other Technical Specification surveillance testing where preconditioning may affect the results of the test. This Technical Position may be adopted optionally by other Exelon organizations.
- **Background:** There are no specified ASME Code requirements regarding preconditioning or the necessity to perform as-found testing, with the exception of setpoint testing of relief valves and MOV testing performed in accordance with Code Case OMN-1 or Mandatory Appendix III. Nevertheless, there has been significant concern raised by the NRC, and documented in numerous publications, over this issue. Section 3.5 of Reference 2 provides guidance on preconditioning as it relates to IST; Section 3.6 provides additional guidance on as-found testing. It is the intent of this Technical Position to provide a unified, consistent approach to the issue of preconditioning as it applies to IST Programs throughout the Exelon fleet.

The purpose of IST is to confirm the operational readiness of pumps and valves within the scope of the IST Program to perform their intended safety functions whenever called upon. This is generally accomplished by testing using quantifiable parameters which provide an indication of degradation in the performance of the component. Preconditioning can diminish or eradicate the ability to obtain any meaningful measurement of component degradation, thus defeating the purpose of the testing.

Preconditioning is defined as the alteration, variation, manipulation, or adjustment of the physical condition of a system, structure, or component before Technical Specification surveillance or ASME Code testing. Since IST is a component-level program, this Technical Position will address preconditioning on a component-level basis. Preconditioning may be acceptable or unacceptable.

- Acceptable preconditioning is defined as preconditioning which is necessary for the protection of personnel or equipment, which has been evaluated as having insufficient impact to invalidate the results of the surveillance test, or which provides performance data or information which is equivalent or superior to that which would be provided by the surveillance test.
- Unacceptable preconditioning is preconditioning that could potentially mask degradation of a component and allow it to be returned to or remain in service in a degraded condition.

In most cases, the best means to eliminate preconditioning concerns is to perform testing in the as-found condition. When this is not practical, an evaluation must be performed to determine if the preconditioning is acceptable. Appendix 1 to this Technical Position may be used to document this evaluation.

CTP-IST-001, Rev. 1 (Cont.)

The acceptability or unacceptability of preconditioning must be evaluated on a caseby-case basis due to the extensive variability in component design, operation, and performance requirements. Preconditioning of pumps may include filling and venting of pump casings, venting of discharge piping, speed adjustments, lubrication, adjustment of seals or packing, etc. Preconditioning of valves may include stem lubrication, cycling of the valve prior to the "test" stroke, charging of accumulators, attachment of electrical leads or jumpers, etc.

Factors to be considered in the evaluation of preconditioning acceptability include component size and type, actuator or driver type, design requirements, required safety functions, safety significance, the nature, benefit, and consequences of the preconditioning activity, the frequencies of the test and preconditioning activities, applicable service and environmental conditions, previous performance data and trends, etc.

Lubrication of a valve stem provides an example of the variability of whether or not a preconditioning activity is acceptable. For example, lubrication of the valve stem of an AC-powered MOV during refueling outages for a valve that is exercise tested quarterly would normally be considered acceptable, unless service or environmental conditions could cause accelerated degradation of its performance. Lubrication of a valve stem each refueling outage for an MOV that is exercise tested on a refueling outage frequency may be unacceptable if the lubrication is always performed prior to the exercise test. Lubrication of a valve stem for an AOV prior to exercise testing is likely to be unacceptable, unless it can be documented that the preconditioning (i.e., maintenance or diagnostic testing) can provide equal or better information regarding the as-found condition of the valve. Manipulation of a check valve or a vacuum breaker that uses a mechanical exerciser to measure breakaway force prior to surveillance testing would be unacceptable preconditioning. Additional information regarding preconditioning of MOVs may be found in Reference 4.

Position:

- 1. Preconditioning **SHALL** be avoided unless an evaluation has been performed to determine that the preconditioning is acceptable. Appendix 1 to this Technical Position may be used to document this evaluation. In cases where the same information applies to more than one component, a single acceptability evaluation may be performed and documented
- 2. Evaluations **SHALL** be prepared, reviewed and approved by persons with the appropriate level of knowledge and responsibility. For example, persons preparing an evaluation should hold a current certification in the area related to the activity. Reviewers should be certified in a related area.
- 3. The evaluation **SHALL** be approved by a Manager or designee.
- 4. If it is determined that an instance of preconditioning has occurred without prior evaluation, the evaluation **SHALL** be performed as soon as practicable following discovery. If the evaluation concludes that the preconditioning is unacceptable, an IR shall be written to evaluate the condition and identify corrective actions.

CTP-IST-001 APPENDIX 1 EVALUATION OF PRECONDITIONING ACCEPTABILITY

Description of activity:			
Section 1: NRC Inspection Manual Part 9900 Review:			
Answer the following questions to determine the acceptability of the prece Section D.2 of Reference 3.	onditior	ning activ	vity based on
Question	Yes	<u>No</u>	Not Determined
 Does the alteration, variation, manipulation or adjustment ensure that the component will meet the surveillance test acceptance criteria? 			
2. Would the component have failed the surveillance without the alteration, variation, manipulation or adjustment?			
3. Does the practice bypass or mask the as-found condition?			
4. Is the alteration, variation, manipulation or adjustment routinely performed just before the testing?			
5. Is the alteration, variation, manipulation or adjustment performed only for scheduling convenience?			
If all the answers to Questions 1 thru 5 are No, the activity is acceptable; o Otherwise, continue to Section 2.	go to Se	ction 3.	
Section 2: Additional Evaluation			
The following questions may be used to determine if preconditioning active screening criteria of Section 1 are acceptable	vities th	at do no	t meet the
Question		<u>Yes</u>	No
Is the alteration, variation, manipulation or adjustment required to prevent personnel injury or equipment damage? If yes, explain below.			
7. Does the alteration, variation, manipulation or adjustment provide performance data or information that is equivalent or superior to that provided by the surver test? If yes, explain below.	ce eillance		
8. Is the alteration, variation, manipulation or adjustment being performed to reprepare, inspect or test an SSC that is inoperable or is otherwise unable to m surveillance test acceptance criteria? If yes, explain below.	oair, eet the		
 Is there other justification to support classification of the alteration, variation, manipulation or adjustment as acceptable preconditioning? If yes, explain be and provide references. 	elow		
Explanation / Details: (attach additional sheets as necessary)			
Conclusion: The preconditioning evaluated herein (is / is not) acceptable. (Cire	cle one)		
Section 3: Review / Approve			
Prepared by:	Date:		
Reviewed by:	Date:		
Approved by:	Date:		

Number: CTP-IST-003, Rev. 0

Title: Quarterly Testing of Group B Pumps

Applicability: ASME OM-1995 Code and Later

Background: Pumps included in IST Programs that must comply with the 1995 Edition of the ASME OM Code and later are required to be classified as either Group A or Group B pumps. The OM Code defines a Group A pump as a pump that is operated continuously or routinely during normal operation, cold shutdown, or refueling operations. A Group B pump is defined as a pump in a standby system that is not operated routinely except for testing.

Testing of pumps is performed in accordance with Group A, Group B, comprehensive or preservice test procedures. In general, a Group A test procedure is intended to satisfy quarterly testing requirements for a Group A pump, a Group B test procedure is intended to satisfy quarterly testing requirements for a Group B pump, and a comprehensive test procedure is required to be performed on a frequency of once every two years for all Group A and Group B pumps. A Group A test procedure may be substituted for a Group B procedure and a comprehensive or preservice test procedure may be substituted for a Group A or a Group B procedure at any time.

A Group A test procedure is essentially identical to the quarterly pump test that was performed in accordance with OM-6 and earlier Code requirements. Group B testing was introduced to the nuclear industry when the NRC endorsed the OM-1995 Edition with OMa-1996 Addenda in 10 CFR 50.55a(b)(3). The intent of the Group B test was to provide assurance that safety related-pumps that sit idle essentially all of the time (e.g. ECCS pumps) would be able to start on demand and achieve a pre-established reference condition. The requirements for Group B testing were significantly relaxed when compared with the Group A (traditional) pump test requirements based on the assumption that there were no mechanisms or conditions that would result in pump degradation while the pump sat idle.

Strong differences of opinion regarding the intent and requirements for Group B testing developed and have persisted since the beginning. These differences span the industry, the NRC, and even members of the OM Code Subgroup-ISTB who created them. One opinion is that the Group B test is intended to be a "bump" test in which the pump is started, brought up to reference flow or pressure, and then stopped. The opposing opinion is that the Group B test requires the pump to be brought to the reference flow or pressure followed by recording and evaluation of both the flow and pressure readings. Both opinions can be supported by the applicable OM Code verbiage. However, NRC personnel have expressed a reluctance to accept the "bump" test interpretation.

Position: Group B pump testing should be performed as follows:

1. When performing a Group B pump test, both hydraulic test parameters (i.e., flow and differential pressure OR flow and discharge pressure) shall be measured and evaluated in accordance with the applicable Code requirements for the pump type.

CTP-IST-003, Rev. 0 (Cont.)

2. Vibration measurements are not required for Group B pump tests. Vibration measurements may continue to be taken optionally. In the event that a vibration reading exceeds an alert or required action limit for the comprehensive test for the pump being tested, an IR shall be written and corrective action taken in accordance with the CAP process.

References:

1. ASME OM Code, Code for Operation and Maintenance of Nuclear Power Plants, 1995 Edition and later, Subsection ISTB.

Number: CTP-IST-007, Rev. 2

Title: Skid-Mounted Components

Applicability: All Exelon IST Programs

- **Background:** The term "skid-mounted component" was coined to describe support components, such as pumps and valves for the purposes of IST, that function in the operation of a supported component in such a way that their proper functioning is confirmed by the operation of the supported component. For example, the successful operation of an emergency diesel-generator set confirms that essential support equipment, such as cooling water and lube oil pumps and valves, are functioning as required. The concept of "skid-mounted" is actually irrespective of physical location.
- **Position:** Components that are required to perform a specific function in shutting down a reactor to the safe shutdown condition, in maintaining the safe shutdown condition, or in mitigating the consequences of an accident are required to tested in accordance with the ASME Code-in-effect for the station's IST Program. It is not the intent of the skid-mounted exemption that it be used in cases where the specific testing requirements of the Code for testing of pumps and valves can be met. For example, if adequate instrumentation is provided to measure a pump's flow and differential pressure, and if required points for vibration measurement can be accessed, then invoking the skid-mounted exemption would be inappropriate.

The "skid-mounted" exclusion as stated in references 2 and 3, below, may be applied to pumps or valves classified as "skid-mounted" in the IST Program provided that they are tested as part of the major component and are justified to be adequately tested. Such components **SHALL** be listed in the Program Plan document and identified as skid-mounted. Pump or Valve Data Sheets which contain the justification regarding the adequacy of their testing **SHALL** be provided in the IST Bases Document.

References:

- 1. NUREG-1482 Rev. 2, Section 3.4, Skid-Mounted Components and Component Subassemblies
- 2. ASME OM Code, Code for Operation and Maintenance of Nuclear Power Plants, 1995 Edition OMa-1996 Addenda, ISTA 1.7, ISTC 1.2.
- 3. ASME OM Code, Code for Operation and Maintenance of Nuclear Power Plants, 1998 Edition and later, ISTA-2000 and ISTC-1200.

Number: CTP-IST-008, Rev. 2

Title: Position Verification Testing

Applicability: All Exelon IST Programs

- **Background:** Valves with remote position indicators are required to be observed locally at least once every two years to verify that valve operation is accurately indicated. This local observation should be supplemented by other indications to verify obturator position. Where local observation is not possible, other indications shall be used for verification of valve operation.
- **Position:** All valves within the scope of the IST Program that are equipped with remote position indicators, shall be tested. The testing shall clearly demonstrate that the position indicators operate as required and are indicative of obturator position. For example, a valve that has open and closed indication shall be cycled to demonstrate that both the open and closed indicators perform as designed, including both or neither providing indication when the valve is in mid-position. Valves that have indication in one position only shall be cycled to ensure that the indicator is energized/de-energized when appropriate. These requirements apply to all IST valves, regardless of whether they are classified as active or passive.

References:

- 1. ASME OM Code, Code for Operation and Maintenance of Nuclear Power Plants, 1995 Edition with OMa-1996 Addenda, para ISTC 4.1.
- 2. ASME OM Code, Code for Operation and Maintenance of Nuclear Power Plants, 1998 Edition and later, para ISTC-3700.
- 3. NUREG-1482, Rev. 2, Section 4.2.8

Number: CTP-IST-014, Rev. 0

Title:Bi-directional Testing of Check Valves to Their Safety and Non-Safety Related
Positions

Applicability: All Exelon IST Programs

Background: This CTP addresses those cases in which inservice testing of check valves is performed in accordance with the requirements of ISTC-5221. It does not address these issues for check valves that are included in a Condition Monitoring Program. References 2 and 3 of this CTP provide additional information regarding check valve testing and Condition Monitoring.

The OM Code changed the focus of inservice testing of check valves from the ability to demonstrate that a check valve was capable of being in its safety-related position to demonstrating that the obturator was capable of free, unobstructed movement in both directions. This was accomplished by introducing a bidirectional testing requirement to inservice testing of check valves. Confirmation of this change in focus is evidenced by the fact that the Code required frequency for bi-directional testing of check valves is the lesser of the frequencies that the open direction and close direction tests can be performed. In other words, if a check valve is capable of being tested in the open direction quarterly but can only be tested closed during refueling outages, the Code required frequency for the bidirectional test is every refueling outage irrespective of the valve's safety position(s).

Condition Monitoring is the preferred method for check valve testing and inspection. For check valves that are not in a Condition Monitoring Program, the OM Code provides three options: flow/flow reversal, use of an external mechanical exerciser, and sample disassembly/examination. Of these, the flow and mechanical exerciser methods are preferred; the Code limits sample disassembly/ examination to those cases where the others are impractical. In all of these non-Condition Monitoring methods, demonstration of unobstructed obturator travel in the open and closed directions is required.

Position: The following requirements **SHALL BE MET** when implementing this CTP:

 When using flow to demonstrate opening of a check valve with an open safety function, OBSERVE that the obturator has traveled to EITHER the full open position OR to the position required to perform its intended safety function(s). Travel to the position required to perform its intended safety function(s) is defined as the minimum flow required to mitigate the system's most limiting accident requirements. For example, if three different accident scenarios called for flows of 300, 600 and 1000 gpm respectively, the required test flow would be 1000 gpm.

The full open position is defined as the point at which the obturator is restricted from further travel (e.g., hits the backstop). Methods for demonstrating travel to the full open position must be qualified if less than required accident flow is used.

Number: CTP-IST-014, Rev. 0 (Cont.)

- 2. When using flow to demonstrate that the obturator of a valve that does not have an open safety function has traveled open, the test **MUST DEMONSTRATE** that the obturator is unimpeded.
- 3. Tests for check valve closure **MUST DEMONSTRATE** that the check valve has travelled to the closed position, not merely that it is in the closed position.
- 4. Whenever design requirements are used for IST acceptance criteria, instrument accuracy **MUST BE CONSIDERED**. This can be accomplished by determining that sufficient margin was included in the design calculation or by adding a correction to the IST acceptance criteria.
- Non-intrusive methods used to credit obturator position SHALL BE QUALIFIED. Documentation of the means used to qualify the test method(s) shall be documented in the IST Bases Document.
- 6. The Code requirement satisfied for each check valve, identification of the method used to satisfy the Code requirement, and a description of how the method satisfies the requirement **SHALL BE PROVIDED OR RERENENCED** on the Valve Data Sheet in the IST Bases Document for each check valve.

References:

- 1. ASME OM Code, Code for Operation and Maintenance of Nuclear Power Plants, 1995 Edition and later, Subsection ISTC.
- 2. ER-AA-321, Administrative Requirements for Inservice Testing
- 3. ER-AA-321-1005, Condition Monitoring for Inservice Testing of Check Valves

Technical Position Justifications –Site Specific

- TJ-01 Deleted
- TJ-02 5933A, 5933B, 5934A, 5934B Skid-Mounted Classification

Solenoid-operated valves 5933A, 5933B, 5934A and 5934B open to provide starting air to the diesel generators. These are rapid acting solenoid valves whose design prohibits visual observance of stroking as there are no external indicators on these valves. Diesel start times are affected by valve stroke times. Measurement and evaluation of stroke times shall not be performed. Valve exercising is performed monthly in conjunction with diesel generator start testing. Per the guidance provided by NUREG 1482, Rev.2, Section 3.4, Skid-Mounted Components and Component Subassemblies, and as allowed by ISTC-1200, valve stroking parameters will be considered acceptable if the associated diesel generator start is acceptable. Additionally, diesel start and bus re-energization times are verified each refueling outage to be less than the Technical Specification acceptance criteria of 10 seconds.

TJ-03 5907, 5907A, 5908, 5908A – Skid-Mounted Classification

Solenoid-operated valves 5907, 5907A, 5908 and 5908A open and close to direct fuel oil to Diesel Generator (D/G) day tanks or back to the diesel fuel oil storage tanks. These are rapid acting solenoid valves whose design prohibits visual observation of stroking as there are no external indicators on these valves. These valves are automatically actuated as necessary based upon diesel fuel oil day tank levels. These valves do not have control switches. Diesel generators are tested monthly (per Technical Specifications), during which these valves actuate for filling the fuel oil day tanks and for diesel fuel oil recirculation. Measurement and evaluation of stroke time shall not be performed. These valves shall be exercised and fail safe tested at least quarterly during diesel generator testing. Per the guidance provided by NUREG 1482, Rev.2, Section 3.4 and as allowed by ISTC-1200, valve stroking parameters will be considered acceptable based upon satisfactory actuation as demonstrated by adequate fuel oil delivery during the D/G tests.

TJ-04 Deferral Justification Test Window

Inservice Test (IST) Program components which are required to be tested during a refueling outage (RFO) may be tested in conjunction with *plant "coast-down"* (i.e. a period where a conscious deviation from normal operating temperature and power occurs in conjunction with reactor fuel depletion) as qualified below, or a *planned load reduction* (e.g. reduction in turbine load via a selected downward ramp rate) intended to take the plant from Mode 1, power operation, to an offline condition, and ultimately to Mode 6, refueling.

The period where the load reduction is accomplished via plant coast-down potentially can encompass a period of weeks before the actual start of an RFO. The existing regulatory guidance for allowing deferral of testing to an RFO is based on the impracticality of being able to perform the test on a quarterly basis. Performing tests which have been deferred to an RFO weeks in advance of the RFO is not in

TJ-04 keeping with the spirit of the deferral latitude. As such, testing being performed to (Cont.) satisfy various IST program deferrals, while in plant coast-down, should only take place when the *projected end of the coast down window* is 120 hours or less. Five working days affords adequate time to accomplish the anticipated limited test scope and is not considered excessive when compared to the intent of the Code deferral allowance.

All IST components required to be tested during an RFO shall have their prescribed test satisfactorily completed and demonstrated operable prior to resumption of power operation and before exceeding the associated Technical Specification Mode of applicability, unless specifically stated otherwise in the Technical Specifications.

TJ-05 On-Line Maintenance

The advent of on-line plant maintenance to perform work on safety related components and systems outside of the traditional refueling outage (RFO) time frame, is designed to maximize component/system availability while favorably impacting RFO duration and the associated corporate financial impact. The practice of doing on-line maintenance represents a departure from the norm where the bulk of the maintenance was performed while engaged in an RFO. As such, the Inservice Test Program, which is directed by the ASME Code which does not take into account on-line maintenance practices, can experience implementation issues when on-line preventative maintenance or corrective maintenance is performed.

Typically, a number of Inservice Test Program components can't meet Code based quarterly test frequency due to the practicality of performing the testing. System alignments, operating conditions (pressure, flow, temperature, etc.) and other such restrictions often render the testing impracticable. The Code allows the affected testing to be deferred to a lower plant MODE, from MODE 5, cold shutdown to MODE 6, Refueling. The understanding between the Licensee and the NRC is that such testing will take place in the highest MODE deemed practicable by the Licensee with the assumption that sufficient basis to justify the deferred MODE exists. Contrary to what occurred in the past, the NRC is no longer required to approve such deferrals. As such, along with the deferral comes the expectation that testing can and should only be performed when in the applicable deferred MODE unless extenuating circumstances exist. Performance of online maintenance and the need to demonstrate post-maintenance operability for the component/system worked on clearly is an example of an extenuating circumstance given its prevalent implementation and widespread acceptance throughout the nuclear industry.

Inservice Test Program components which have had their associated Code required tests deferred from the normal "during operation at power" time frame, either to cold shutdown (using a Cold Shutdown Justification (CSJ) or Refueling Shutdown (using a Refueling Outage Justification (ROJ)), *may revert back to the at power time frame, on a limited basis*, to accomplish post-maintenance operability testing (PMOT) following performance of on-line maintenance provided that:

TJ-05 A) The testing that will occur during power operation will not expose plant personnel(Cont.) to unsafe working conditions nor place components or systems in alignments adverse to plant safety.

AND

B) One or more of the following maintenance scope activities are desired and serves to justify the performance of deferred testing at the normal at power time frame:

1) Corrective on-line maintenance is desired to be performed on the component to restore the component to the operable condition and testing required to demonstrate component/system post-maintenance operability is contained in the surveillance test(s) used to satisfy the associated IST Program Code requirements.

2) Preventative on-line maintenance is desired to be performed on the component to lessen or eliminate RFO time frame system/component unavailability (e.g. performing the maintenance in a plant MODE that poses a lesser or no adverse risk probability to plant safety) and the testing required to demonstrate component/system post-maintenance operability is contained in the surveillance test(s) used to satisfy the associated IST Program Code requirements.

The relaxation of the associated CSJ or ROJ is only to be exercised on a limited basis. Limited is defined as not more than once per 18 months (All Ginna Technical Specification surveillance requirements which tie performance to a *fuel cycle frequency*, utilize an 18 month fuel cycle duration) unless additional documented justification is provided in advance of the proposed maintenance. The IST Program Owner and Site Implementer must review and concur with such justification before the proposed maintenance can proceed.

TJ-06 8616A, 8616B, 8619A, 8619B, 8620A, 8620B, 8630A, 8630B – Skid-Mounted Classification

Solenoid-operated valves 8616A, 8616B, 8619A, 8619B, 8620A and 8620B open (8620A/B close) to provide nitrogen to cycle the power operated relief valves (PORVs) which provide RCS overpressure protection. These solenoid valves are totally enclosed and have no externally visible indication of valve position. Since these valves function to admit nitrogen to the Pressurizer PORVs to open, it can be indirectly verified that each valve has actuated by monitoring the operation of the PORVs. Measuring the stroke times of a PORV provides indication of solenoid-operated valve degradation since any significant increase in solenoid valve stroke time would result in longer PORV stroke times and may result in the PORV exceeding its stroke time limit. Per the guidance provided by NUREG 1482, Rev.2, Section 3.4, Skid-Mounted Components and Component Subassemblies, and as allowed by ISTC-1200, valve stroking parameters will be considered acceptable if the associated PORV cycling is acceptable.

TJ-07 Component Cooling Water Total Pump Flow

Testing of the Component Cooling Water (CCW) pumps does not monitor total pump flow. Flow through the branch line to the sample system heat exchangers is not included in the determination of pump reference value flow. This branch connection is upstream of main header flow indicator FI-619 used for pump testing.

TJ-07 A surveillance test procedure prerequisite requires that flow through this line, as (Cont.) indicated on FI-603, be validated and recorded as being greater than 75 gpm. Actual pump flow is determined from a test point (TP) connection feed from FT-619 but the sample branch line flow is not included in this determination. The flow through this branch line is approximately 3% of the pump reference flow (2500 gpm).

> A CAUTION appears prior to that procedural prerequisite step where the sample heat exchanger total return flow is measured and verified to be greater than 75 gpm. The CAUTION step reads: "IF any condition is NOT met, THEN performance of either CCW Pump test may NOT proceed. These CCW system alignments SHALL exist in order to obtain valid repeatable test conditions for present OR future pump degradation assessments."

> The CAUTION ensures that the test of either CCW pump would not occur in the event that sample heat exchanger total flow was less than 75 gpm. This in turn assures that pump flow, as measured at the TP of FT-619 combined with the flow recorded on FI-603, would not be less than 2575 gpm on a repeatable basis. This ensures repeatability of the pump test and acts to provide reasonable assurance that pump degradation monitoring remains effective and the intent of the ASME OM Code is met.

In the event that sample heat exchanger total flow were to rise above the nominal and expected value of ~75-100 gpm, that would constitute a conservative effect on the resultant pump test differential pressure value. Higher sample heat exchanger total flow would mean that pump total flow would in turn be higher making the differential pressure value lower. This would be construed as evidence of potential pump degradation and could either be detected during data trend analysis or on a more extreme level if the higher flow resulted in the differential pressure value entering the Alert or Required Action range. Subsequent test verification/validation efforts would identify the higher than anticipated sample heat exchanger total flow contribution and impact, and facilitate root cause determination and resolution in a timely matter. This scenario has not occurred in the previous 3rd, 4th, or 5th 10-Year IST intervals and there is no reason to expect it will in the current 6th interval.

ASME CODE 2012 Edition, Subsection ISTB, paragraph ISTB-3550 Flow Rate, considerations:

"External recirculated flow is not required to be measured if it is not practical to isolate, has a fixed resistance, and has been evaluated by the Owner to not have a substantial effect on the results of the test."

CONSIDERATION 1 - Practicality of Isolation:

While isolation of the five (5) associated heat exchangers serviced by CCW would eliminate the unmeasured flow condition, it would require quarterly entry into a highly contaminated and space limited area (Sample Shed) area. This area poses a high potential for personnel contamination and adverse safety conditions due to the need to gain access to the associated CCW isolation valves in a very congested and limited mobility-location.

TJ-07 Isolation of flow to these sample heat exchangers could result in system process
 (Cont.) temperature and sampling perturbations when cooling water is interrupted for up to 2-3 hours during conduct of pump testing.

CONSIDERATION 2 – Has a Fixed Resistance:

Although not fitting the classic description of a "fixed resistance" (i.e. contains an inlineflow orifice or a means of setting a desired flow and preventing that flow from changing,the variation in the individual sample heat exchanger cooling water load is very slightmaking the overall combined flow rate of 75-100 gpm very consistent. Each heat exchanger's manual outlet CCW valve is maintained full-open and once aligned remains that way. There are no significant fluctuations in flow as there are no temperature or pressure control valves present in any of the sample heat exchangers. Short of locking open the main branch line supply and return isolation valves, this portion of the CCW system functions as a "fixed resistance".

CONSIDERATION 3 - Evaluated to not have a substantial effect on the results of the test:

As stated previously, the proceduralized requirement to ensure sample heat exchanger total flow is greater than 75 gpm as a prerequisite to beginning the test of either CCW pump, ensures that a repeatable IST pump test will occur. The slight variations in total Flow, as observed over the past two IST program 10-year intervals, has not been shown to be a significant factor in Ginna's ability to track and trend pump performance nor effectively monitor for pump degradation. Likewise, the overall impact of ~3% of total pump flow not being monitored has not been an inhibiting force to maintaining consistent test results. In fact if flow were to increase substantially above the 75-100 gpm flow rate typically recorded, the resultant pump differential pressure would be lower acting to provide a conservative test result and triggering Code mandated corrective action earlier.

The CCW flow meter (FI-619) used to assess initial flow rate being greater than 75 gpm has an accuracy tolerance of 2% of span. Being a 0-700 gpm span device, this translates into a potential flow variation of +/- 14.0 gpm. The 14.0 gpm value represents a potential variance in external recirculated flow of 0.56%, a value so insignificant as to essentially comprise an unmeasurable impact upon pump differential pressure.

CONCLUSION:

Ginna will continue to ensure sample heat exchanger total flow is greater than 75 gpm during CCW pump testing. Based on the conservative approach this practice presents, there is no adverse impact upon the ability to effectively monitor for and identify pump degradation as per the IST program.

- TJ-08 Deleted
- TJ-09 Deleted

Technical Position Justifications –Site Specific (Continued)

TJ-10 LLRT Scope Reduction Valve Category

As per DA-ME-17-007 (ECP-17-000450), the following CIV's listed in Table-1 below, are no longer credited as post-LOCA leakage limiting barriers in accordance with 10CFR Part100 criteria. However, Ginna Station has elected to retain their prior IST Program Category A classification based on compensatory leakage determination testing performed following valve maintenance, repair, modification, or adjustment activities which could affect the valves leak tightness since last being quantified. Such testing is being conducted as required, and intended to ensure a known capability should the subject valve be required to provide a back-up leakage barrier role. The associated maximum seat leakage allowed for such compensatory testing is established by the site via administrative controls. These valves do not have any other IST program function for which seat leakage is limited to a specific maximum amount in the closed position to ensure fulfillment of their required function as specified in ISTA-1100.

TABLE 1												
Penetration	Valve	System	Туре	Actuator	Valve Category							
100	370B	CVCS	Check	SAV	AC							
102	383B	CVCS	Check	SAV	AC							
105	869A	CS	Globe	MAN	А							
105	2856	CS	Gate	MAN	А							
105	2825	CS	Gate	MAN	А							
105	2825A	CS	Ball	MAN	А							
105	868C	CS	Globe	MAN	A							
105	868E	CS	Globe	MAN	А							
105	869E	CS	Relief	SAV	AC							
108	313	CVCS	Gate	MOV	A							
109	869B	CS	Globe	MAN	А							
109	2858	CS	Gate	MAN	A							
109	2826	CS	Gate	MAN	A							
109	2826A	CS	Ball	MAN	A							
109	868D	CS	Globe	MAN	A							
109	868E	CS	Globe	MAN	Α							
109	869E	CS	Relief	SAV	AC							
112	200A	CVCS	Globe	AOV	A							
112	200B	CVCS	Globe	AOV	A							
112	202	CVCS	Globe	AOV	A							
112	203	CVCS	Relief	SAV	AC							
112	371	CVCS	Globe	AOV	AC							
124c	745	CCW	Globe	AOV	A							
125	759B	CCW	Gate	MOV	Δ							
126	759A	CCW	Gate	MOV	A							
127	749A	CCW	Gate	MOV	A							
128	749B	CCW	Gate	MOV	A							
130	814	CCW	Gate	MOV	A							
131	813	CCW	Gate	MOV	A							
201b	4636	SW	Butterfly	MAN	A							
201b	4658	SW	Relief	SAV	AC							
206b	5735	SGS	Gate	AOV	Α							
2005 207b	5736	SGS	Gate	AOV	Α							
209b	4758	SW	Butterfly	MAN	Α							
2005 209b	4759	SW	Relief	SAV	AC							
308	4629	SW	Butterfly	ΜΔΝ	Δ							
308	4655	SW	Relief	SAV	AC							
311	4630	SW	Butterfly	MAN	Δ							
311	4656	SW	Relief	SAV	AC							
315	4643	SW	Butterfly	ΜΔΝ	Δ							
315	4659	SW	Relief	SAV	AC							
321	5738	SGRD	Gate		Δ							
322	5737	SGRD	Gate		Δ							
323	4644	SW	Butterfly	MAN	Δ							
323	4660	SW	Relief	SAV	AC							

Technical Position Justifications – Site Specific (Continued)

Attachment 14

Inservice Testing Pump Table

AFW - AUXILIARY FEEDWATER

		Code										
Component	PID(Coord)	Class	Group	Press	DP	Flow	VIB	Speed	Procedure	Freq	Dev.	Comments
PAF01A AUXILIARY FEEDWATER PL	1237 (B-5) JMP A	3	А	No	Yes	Yes	Yes	No No	STP-O-16-COMP-A	2Y		Delief is far flow rate massurement
Centrifugal				NO	165	NU	165	NO	31F-0-10QA	Q	FK - 02	Relief is for now rate measurement
PAF01B AUXILIARY FEEDWATER PL	1237 (E-5) JMP B	3	А	No	Yes	Yes	Yes	No	STP-O-16-COMP-B	2Y		
Centrifugal				INU	res	INU	res	NO	31F-0-10QB	Q	FK - 02	Relief is for flow rate measurement
PAF03 TURBINE DRIVEN AUXILIAR	1237 (I-5) IY FEEDWATER PUMP	3	В	No No	Yes Yes	Yes Yes	No Yes	Yes Yes	STP-O-16QT STP-O-16-COMP-T	Q 2Y		
Centrilugai												

CCW - COMPONENT COOLING WATER

		Code		Disch.	Tes	st Parar	neters		Code			
Component	PID(Coord)	Class	Group	Press	DP	Flow	VIB	Speed	Procedure	Freq	Dev.	Comments
PAC02A COMPONENT COOLING WA Centrifugal	1245 (D-5) ATER PUMP A	3	A	No No	Yes Yes	Yes Yes	Yes Yes	No No	STP-O-2.8Q STP-O-2.8-COMP-A	Q 2Y		See TJ-07 on Total Pump Flow See TJ-07 on Total Pump Flow
PAC02B COMPONENT COOLING WA Centrifugal	1245 (E-5) ATER PUMP B	3	A	No No	Yes Yes	Yes Yes	Yes Yes	No No	STP-O-2.8Q STP-O-2.8-COMP-B	Q 2Y		See TJ-07 on Total Pump Flow See TJ-07 on Total Pump Flow

CS - CONTAINMENT SPRAY

		Code		Disch.	Tes	st Parar	neters	Code				
Component	PID(Coord)	Class	Group	Press	DP	Flow	VIB	Speed	Procedure	Freq	Dev.	Comments
PSI02A CONTAINMENT SPRAY PUN Centrifugal	1261 (E-3) MP A	2	В	No No	Yes Yes	Yes Yes	Yes No	No No	STP-O-3-COMP-A STP-O-3QA	2Y Q		
PSI02B CONTAINMENT SPRAY PUN Centrifugal	1261 (I-3) ИР В	2	В	No No	Yes Yes	Yes Yes	Yes No	No No	STP-O-3-COMP-B STP-O-3QB	2Y Q		

CVCS - CVCS CHARGING

		Code		Disch.	Те	st Para	Code					
Component	PID(Coord)	Class	Group	Press	DP	Flow	VIB	Speed	Procedure	Fre	q Dev.	Comments
PCH01A CHARGING PUMP A	1265-2 (E-5)	2	А	Yes	No	Yes	Yes	Yes	STP-O-31A	61	1 PRE - 01	Augmented Component
Positive Displacement												
PCH01B CHARGING PUMP B	1265-2 (G-5)	2	А	Yes	No	Yes	Yes	Yes	STP-O-31B	6N	1 PRE - 01	Augmented Component
Positive Displacement												
PCH01C CHARGING PUMP C	1265-2 (H-5)	2	А	Yes	No	Yes	Yes	Yes	STP-O-31C	6N	1 PRE - 01	Augmented Component
Positive Displacement												

EDG - EMERGENCY DIESEL GENERATOR

		Code		 Disch	Те	st Parar	Code					
Component	PID(Coord)	Class	Group	Press	DP	Flow	VIB	Speed	Procedure	Freq	Dev.	Comments
PDG02A DIESEL GENERATOR A FUE	1239-1 (I-3) EL OIL TRANSFER PUMP	3	В	Yes Yes	No No	Yes Yes	No Yes	No No	STP-O-12.6A STP-O-12.6-COMP-A	Q 2Y	PR - 01	Relief is for flow rate measurement
Positive Displacement												
PDG02B DIESEL GENERATOR B EUE	1239-2 (I-9) EL OIL TRANSFER PUMP	3	В	Yes	No	Yes	Yes	No	STP-O-12.6-COMP-B	2Y	55 64	
Positive Displacement				Yes	No	Yes	No	No	STP-O-12.6B	Q	PR - 01	Relief is for flow rate measurement

RHR - RESIDUAL HEAT REMOVAL

	Code											
Component	PID(Coord)	Class	Group	Press	DP	Flow	VIB	Speed	Procedure	Freq	Dev.	Comments
PAC01A RESIDUAL HEAT REMOVAL	1247 (F-5) . PUMP A	2	A	No No	Yes Yes	Yes Yes	Yes Yes	No No	STP-O-2.2QA STP-O-2.2-COMP-A	Q 2Y		
PAC01B	1247 (B-5)	2	Α	No	Yes	Yes	Yes	No	STP-O-2.2QB	Q		
RESIDUAL HEAT REMOVAL	. PUMP B			No	Yes	Yes	Yes	No	STP-O-2.2-COMP-B	2Y		
Centrifugal												

SAFW - STANDBY AUXILIARY FEEDWATER

		Code										
Component	PID(Coord)	Class	Group	Press	DP	Flow	VIB	Speed	Procedure	Freq	Dev.	Comments
PSF01A STANDBY AUXILIARY FEED Centrifugal	1238 (B-5) WATER PUMP C	3	В	No No	Yes Yes	No Yes	No Yes	No No	STP-O-36QC STP-O-36-COMP-C	Q 2Y	PR - 02	Relief is for flow rate measurement
PSF01B STANDBY AUXILIARY FEED Centrifugal	1238 (I-5) DWATER PUMP D	3	В	No No	Yes Yes	No Yes	No Yes	No No	STP-O-36Q-D STP-O-36-COMP-D	Q 2Y	PR - 02	Relief is for flow rate measurement

SFPC - SPENT FUEL POOL COOLING

		Code		Disch.	Tes	st Parar	Code					
Component	PID(Coord)	Class	Group	Press	DP	Flow	VIB	Speed	Procedure	Freq	Dev.	Comments
PAC07A SPENT FUEL POOL RECIRC	1248 (H-3) CULATION PUMP A	SSC	А	No	Yes	Yes	Yes	No	STP-O-33A	Q	PRE - 02	Augmented Component
Centrifugal												
PAC07B SPENT FUEL POOL RECIRC	1248 (I-3) CULATION PUMP B	3	А	No No	Yes Yes	Yes Yes	Yes Yes	No No	STP-O-33B STP-O-33-COMP-B	Q 2Y		
Centrifugal			110	100	100	100	110		21			

SI - SAFETY INJECTION AND ACCUMULATORS

			Code									
Component	PID(Coord)	Class	Class Group		DP	Flow	VIB	Speed	Procedure	Freq	Dev.	Comments
PSI01A	1262-1 (C-4)	2	В	No	Yes	Yes	Yes	No	STP-O-2.1-COMP-A	2Y		
SAFETY INJECTION PUMP A	A Contraction of the second seco			No	Yes	Yes	No	No	STP-O-2.1QA	Q		
Centrifugal												
PSI01B	1262-1 (F-4)	2	В	No	Yes	Yes	No	No	STP-O-2.1QB	Q		
SAFETY INJECTION PUMP B	3			No	Yes	Yes	Yes	No	STP-O-2.1-COMP-B	2Y		
Centrifugal												
PSI01C	1262-1 (D-4)	2	В	No	Yes	Yes	Yes	No	STP-O-2.1-COMP-C	2Y		
SAFETY INJECTION PUMP C				No	Yes	Yes	No	No	STP-0-2.10C	Q		
Centrifugal										-		

SW - SERVICE WATER

Test ParametersCode Code														
Component	PID(Coord)	Class Group		Press	DP	Flow	VIB	Speed	Procedure	Freq	Dev.	Comments		
PSW01A SERVICE WATER PUMP A	1250-1 (D-2)	3	А	No No	Yes Yes	Yes Yes	Yes Yes	No No	STP-O-2.7.1-COMP-A	2Y 0				
Vertical Centrifugal Line-Shaft	t			No	100	100	100		011 0 2.1.17	Q				
PSW01B SERVICE WATER PUMP B	1250-1 (E-2)	3	А	No No	Yes Ves	Yes	Yes	No No	STP-O-2.7.1-COMP-B	2Y				
Vertical Centrifugal Line-Shaft	t			NO	103	103	103	NO	011-0-2.7.10	Q				
PSW01C SERVICE WATER PUMP C	1250-1 (F-2)	3	А	No No	Yes Yes	Yes Yes	Yes Yes	No No	STP-O-2.7.1-COMP-C STP-O-2.7.1C	2Y 0				
Vertical Centrifugal Line-Shaft	t			110	100	100	100	110		u				
PSW01D SERVICE WATER PUMP D Vertical Centrifugal Line-Shaft	1250-1 (G-2)	3	A	No No	Yes Yes	Yes Yes	Yes Yes	No No	STP-O-2.7.1-COMP-D STP-O-2.7.1D	2Y Q				

Attachment 15

Inservice Testing Valve Table

Revision: 0

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

23 - BDB

Valve ID Description	Class	Aug	. Cat.	A/P	Size	Valve Type	Actuator Type	Drawing & Coord	Normal	· Positi Safety	on Fail-Safe	Required Test	Frequency	RR/CSJ/ROJ	Procedure	Comme	nts / Notes
9080C	2	Ν	С	А	0.25	RV	SA	33013-1230 (G-3)	С	С	NA	RT	10Y		P312241		
Alt RCS Inj RLF V	′LV																

Revision: 0

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID Description	tion Class Aug. Cat. A/P Size		Valve Type	Actuator Type	Drawing & Coord	Position Normal Safety Fail-Safe			Required Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes			
9786	SSC	Υ	В	А	4	BAL	М	1238 (F-1)	С	0	NA	EC/EO	2Y		STP-O-36R	
DI WATER TANK	SUPPL	Ү НС	SE C	ONN IS	SOL VOV											
Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table AFW - AUXILIARY FEEDWATER

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	g. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
3996	3	Ν	BC	А	5	SCK	MO	1237 (I-6)	С	O/C	AI	BDC CO	CM Q		STP-O-5 STP-O-16QT	CVCMP
TDAFW PUMP	DISCHAF	RGE	VLV M	OV-39	96							CO D&I DIAG PI SC/SO	Q CM MOV MOV 2Y		STP-O-16-COMP-T GMP-37-08-3996 MA-AA-723-300-1006 MA-AA-723-300-1006 STP-O-16-COMP-T	
3998 TURBINE DRIV	3 'EN AUX I	N FW F	C PUMP	A DISCH	5 ARGE CH	CK IECK VLV	SA	1237 (I-8)	С	O/C	NA	CC CO D&I	CM CM CM		STP-O-16-COMP-T STP-O-16-COMP-T CMP-37-05-3998	CVCMP
4000A AUXILIARY FER	3 EDWATEI	N R CF	B ROSSC	A VER N	3 NOTOR O	GL PERATED	MO STOP CHEC	1237 (D-7) CK VALVE	С	O/C	AI	DIAG PI SC/SO SC/SO	MOV MOV Q		MA-AA-723-300-1006 MA-AA-723-300-1006 STP-O-16QA STP-O-16-COMP-A	
4000B AUXILIARY FER	3 EDWATE	N R CF	B	A VER N	3 NOTOR O	GL PERATED	MO STOP CHEC	1237 (D-8) CK VALVE	С	O/C	AI	DIAG PI SC/SO	MOV MOV Q		MA-AA-723-300-1006 MA-AA-723-300-1006 STP-O-16QB	
				A CK V	3 ALVE	СК	SA	1237 (B-10)	С	O/C	NA	CC CC CO	CM 2Y		STP-O-16-COMP-A STP-O-16-COMP-A STP-O-16-COMP-A	CVCMP
4000D	2 B DISCH	N			3 ALVE	СК	SA	1237 (E-10)	С	O/C	NA	CC CO	CM 2Y		STP-O-16-COMP-B STP-O-16-COMP-B	CVCMP
4003 TURBINE DRIV	2 EN AUX	N FW F		A	3 ARGE CH	CK IECH VLV 1	SA TO STEAM (1237 (I-11) GENERATOR	C A	O/C	NA	CC CO D&I	CM CM CM		STP-O-5 STP-O-16-COMP-T GMP-37-09-900/3/CV	CVCMP
4004 TURBINE DRIV	2 'EN AUX I	N FW F	C PUMP	A DISCH	3 ARGE CH	CK IECH VLV 1	SA TO STEAM (1237 (J-10) GENERATOR	C B	O/C	NA	CC CO D&I	CM CM CM		STP-O-5 STP-O-16-COMP-T GMP-37-09-900/3/CV	CVCMP
4007 MDAFW PUMP	3 A DISCH	N IARG	B GE VAL	A VE MO	3 DV-4007	GL	МО	1237 (B-8)	0	O/C	AI	DIAG PI SC/SO SC/SO	MOV MOV Q Q		MA-AA-723-300-1006 MA-AA-723-300-1006 STP-O-16QA STP-O-16-COMP-A	
4008 MDAFW PUMP	3 B DISCH	N IARG	B BE VLV	A MOV-	3 4008	GL	МО	1237 (E-8)	0	O/C	AI	DIAG PI SC/SO SC/SO	MOV MOV Q Q		MA-AA-723-300-1006 MA-AA-723-300-1006 STP-O-16QB STP-O-16-COMP-B	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table AFW - AUXILIARY FEEDWATER

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
4009 AUX FW PUMP	3 P A DISC⊢	N IARG	C E CHI	A ECK VI	3 .V	СК	SA	1237 (B-5)	0	O/C	NA	CC CO D&I	CM 2Y CM		STP-O-5 STP-O-16-COMP-A GMP-37-02-900/3/TD	CVCMP
4010 AUX FW PUMP	3 P B DISC⊢	N IARG	C E CHI	A ECK VI	3 .V	СК	SA	1237 (E-5)	0	O/C	NA	CC CO D&I	CM 2Y CM		STP-O-5 STP-O-16-COMP-B GMP-37-05-900/3/TD	CVCMP
4013	3 /EN ALIX I	N =w F	B	A SW SU	4 CTION V	GA	MO	1237 (I-2)	С	0	AI	DIAG PI SC/SO	MOV MOV R		MA-AA-723-300-1006 MA-AA-723-300-1006 STP-O-2.4	
4014	3 CK VI V T				4		SA	1237 (H-2)	С	O/C	NA	CC CO	CM CM		STP-O-16-COMP-T STP-O-16-COMP-T	CVCMP
4016	3 CK VI V T	N			4	CK	SA	1237 (E-2)	С	O/C	NA	CC CO	2Y 2Y		STP-O-16-COMP-B STP-O-16-COMP-B	CVCMP
4017	3 CK VI V T				4 • • •	СК	SA	1237 (B-2)	С	O/C	NA	CC CO	2Y 2Y		STP-O-16-COMP-A STP-O-16-COMP-A	CVCMP
4020	3		<u> </u>		75	RV/	SA	1237 (1-3)	C	0/0	ΝΔ	PT	107		GMP-37-06-150-P\//	
TURBINE DRIV	/ <u>EN AUX </u> 3	<u>=W F</u> N	UMP C	SUCTION	ON RELIE	EF VLV RV	SA	1237 (B-2)	C	0/C	NA	RT	10Y		GMP-37-06-150-RV4	
AUX FW PUMP	A SUCTI	ON F	RELIEI	= VLV												
4022	3	Ν	С	А	.75	RV	SA	1237 (E-3)	С	O/C	NA	RT	10Y		GMP-37-06-150-RV4	
AUX FW PUMP	B SUCTI	ON F	RELIEI	= VLV												
4023 TURBINE DRIV	3 /EN AUX	N FW F	C PUMP	A RECIR	1.5 CULATIO		SA /LV	1237 (I-5)	С	0	NA	CC CO CO	QQQ		STP-O-16QA or B STP-O-16QT STP-O-16-COMP-T	
4027 SW SUCTION N	3 MOV FOR		B 01A (I	A MDAFV	4 V PUMP /	GA	МО	1237 (C-3)	С	0	AI	DIAG PI SC/SO	MOV MOV R		MA-AA-723-300-1006 MA-AA-723-300-1006 STP-O-2.4	
4028 SW SUCTION N	3 MOV FOR	N	B :01B (I	A MDAFV	4 V PUMP I	GA 3)	MO	1237 (D-3)	С	0	AI	DIAG PI SC/SO	MOV MOV R		MA-AA-723-300-1006 MA-AA-723-300-1006 STP-O-2.4	
4083 CONDENSATE	3 PUMP IN	N	C CHEC	A K VLV	1 TO AUX	CK	SA S	1237 (H-3)	O/C	С		BDO CC	CS CS	CS - 24 CS - 24	STP-O-2.9 STP-O-2.9	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

AFW - AUXILIARY FEEDWATER

Valve ID						Valve	Actuator	Drawing		Positio	n	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
4098	3	Ν	В	А	4	GA	М	1237 (I-2)	С	0	NA	EC/EO	2Y		STP-O-2.4	
SW INLET ISOL	VLV TO	TUR	BINE I	DRIVE	N AUX F	W PUMP										
4291	3	Ν	В	А	1.5	GA	AO	1237 (H-5)	0	O/C	0	FO	Q		STP-O-16QT	
								· · · ·				FO	Q		STP-O-16-COMP-T	
TURBINE DRIVE	N AUXI	LIAR	Y FEE	DWAT	ER PUM	P RECIRCU	JLATION AIR	OPERATED	VAL VE			PI	2Y		STP-O-16-COMP-T	
												SC/SO	Q		STP-O-16QT	
												SC/SO	Q		STP-O-16-COMP-T	
												STO	Q		STP-O-16QT	
												STO	Q		STP-O-16-COMP-T	
4297	3	Ν	В	А	3	GL	AO	1237 (I-10)	0	0	0	FO	Q		STP-O-16QT	
												FO	Q		STP-O-16-COMP-T	
CONTROL VALV	E ON P	AF03	(TDA	FW PL	JMP) DIS	CHARGE T	O EMS01B (SG A)				PI	2Y		STP-O-16-COMP-T	
			-									SC/SO	Q		STP-O-16QT	
												SC/SO	Q		STP-O-16-COMP-T	
4298	3	Ν	В	А	3	GL	AO	1237 (J-8)	0	0	0	FO	Q		STP-O-16QT	
												FO	Q		STP-O-16-COMP-T	
CONTROL VALV	E ON P	AF03	(TDA	FW PL	JMP) DIS	CHARGE T	O EMS01B (SG B)				PI	2Y		STP-O-16-COMP-T	
					,		· ·	,				SC/SO	Q		STP-O-16QT	
												SC/SO	Q		STP-O-16-COMP-T	
4304	3	Ν	В	А	1	GA	AO	1237 (C-6)	С	O/C	0	FO	Q		STP-O-16QA	
								, ,				FO	Q		STP-O-16-COMP-A	
MDAFW PUMP A	A RECIR	RC VL	V AO	/-4304	Ļ							PI	2Y		STP-O-16-COMP-A	
												SC/SO	Q		STP-O-16QA	
												SC/SO	Q		STP-O-16-COMP-A	
												STO	Q		STP-O-16QA	
												STO	Q		STP-O-16-COMP-A	
4304A	3	Ν	С	А	1	CK	SA	1237 (C-6)	С	0	NA	BDC	CM		STP-O-5	CVCMP
												CP	CM		STP-O-16QA	
MDAFW PUMP A	A RECIR	RC CH	IECK									CP	CM		STP-O-16-COMP-A	
												D&I	CM		GMP-37-08-600/CV1	
4310	3	Ν	В	А	1	GA	AO	1237 (E-6)	С	O/C	0	FO	Q		STP-O-16QB	
								, ,				FO	Q		STP-O-16-COMP-B	
MDAFW PUMP E	B RECIR	RC VL	V AO	/-4310)							PI	2Y		STP-O-16-COMP-B	
												SC/SO	Q		STP-O-16QB	
												SC/SO	Q		STP-O-16-COMP-B	
												STO	Q		STP-O-16QB	
												STO	Q		STP-O-16-COMP-B	
4310A	3	Ν	С	А	1	СК	SA	1237 (E-6)	С	0	NA	BDC	CM		STP-O-5	CVCMP
												CP	CM		STP-O-16QB	
MDAFW PUMP E	B RECIR	RC C⊢	IECK									CP	CM		STP-O-16-COMP-B	
					<u> </u>					<u> </u>		D&I	CM		GMP-37-08-600/CV1	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table AFW - AUXILIARY FEEDWATER

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	s Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Normal	Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
4324	3	Ν	В	A	.75	GA	SO	1237 (J-3)	С	0	0	FO FO	Q Q		STP-O-16QT STP-O-16-COMP-T	
TURBINE DRIVE	N AUX	FW F	PUMP	SW ST	RAINER	BYPASS SO	V					SC/SO SC/SO STO STO		VR - 01	STP-O-16QT STP-O-16-COMP-T STP-O-16QT STP-O-16-COMP-T	
4325	3	Ν	В	А	.5	DIA	SO	1237 (C-4)	С	0	0	FO FO	Q		STP-O-16QA STP-O-16-COMP-A	
AUX FW PUMP	A SW S	TRAII	NER B	YPAS	S SOV							SC/SO SC/SO STO	Q Q	VR - 01	STP-O-16QA STP-O-16-COMP-A	
4326 AUX FW PUMP E	3 3 SW S	N TRAII	B NER B	A YPAS:	.5 S SOV	DIA	SO	1237 (F-3)	С	0	0	FO FO SC/SO	Q Q Q		STP-O-16QB STP-O-16-COMP-B STP-O-16QB	
												SC/SO STO	Q	VR - 01	STP-O-16-COMP-B	
4344	3	Ν	В	А	4	GA	М	1237 (E-3)	С	0	NA	EC/EO	2Y		STP-O-2.4	
SW INLET ISOL	VLV TC) AUX	FW P	UMP E	3											
4345	3	Ν	В	A	4	GA	М	1237 (C-3)	С	0		EC/EO	2Y		STP-O-2.4	
SW INLET ISOL	VLV TC) AUX	FW P	UMP A	4											
4480	3	Ν	A	A	1.5	GA	AO	1237 (B-6)	С	С	С	FC FC	Q Q		STP-O-16QA STP-O-16-COMP-A	
BYPASS VALVE	ON AU	XILIA	RY FE	EDWA	ATER TO	EMS01A (S	TEAM GENE	ERATOR A)				LI-X PI SC/SO SC/SO STC STC	2Y 2Y Q Q Q Q		STP-O-16-COMP-A STP-O-16QA STP-O-16COMP-A STP-O-16QA STP-O-16QA STP-O-16-COMP-A	
4481 BYPASS VALVE	3 ON AU	N XILIA	A RY FE	A EDWA	1.5 ATER TO	GA EMS01B (S	AO TEAM GENE	1237 (F-6) ERATOR B)	С	С	С	FC FC LT-X PI SC/SO	Q Q 2Y Q Q		STP-O-16QB STP-O-16-COMP-B STP-O-16-4B STP-O-16-COMP-B STP-O-16QB STP-O-16 COMP B	
												STC STC	Q Q		STP-O-16-COMP-B STP-O-16-COMP-B	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CCW - COMPONENT COOLING WATER

Valve ID						Valve	Actuator	Drawing		Positio	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
17	3	Ν	В	А	1	GL	AO	1245 (A-3)	0	С	С	FC PI	Q 2Y		STP-O-2.5 STP-O-2.5	
CCW SURGE T	ANK VEN	IT RO	CV-01	7								SC/SO STC	QQ		STP-O-2.5 STP-O-2.5	
651	3	Ν	С	A	2	RV	SA	1245 (A-3)	С	O/C	NA	RT	2Y		STP-M-R-13	
VACUUM BREA	KER FO	R TA	C01 (0	CCW S	SURGE T	ANK)RELIEF	= V.									
723A	3	Ν	С	А	8	NCV	SA	1245 (D-6)	O/C	O/C	NA	CC CC	Q 2Y		STP-O-2.8Q STP-O-2.8-COMP-B	
NOZZLE CHEC	K VALVE	FOR	R COM	IPONE	ENT COO	LING WATE	R PUMP A D	DISCHARGE				CO CO	Q 2Y		STP-O-2.8Q STP-O-2.8-COMP-A	
723B	3	Ν	С	А	8	NCV	SA	1245 (E-6)	O/C	O/C	NA	00 00	Q 2Y		STP-O-2.8Q STP-O-2.8-COMP-A	
NOZZLE CHEC	K VALVE	FOR	R COM	IPONE	ENT COO	LING WATE	r pump b d	DISCHARGE				CO CO	Q 2Y		STP-O-2.8Q STP-O-2.8-COMP-B	
732	3	Ν	С	A	3	RV	SA	1245 (A-3)	С	O/C	NA	RT	10Y		CMP-37-06-732	
CCW SURGE T	ANK REL	IEF ۱.	VLV T	O WA	STE HOL	DUP TANK										
738A	3	Ν	В	А	10	GA	MO	1245 (F-3)	С	0	NA	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
MOTOR OPERA HEAT REMOVA	ATED BLO	DCK EXCH	VALV HANG	E FOF ER A)	R COMPC	NENT COO	LING WATE	R SUPPLY TO	DEAC02	2A (RESI	DUAL	SC/SO	2Y		STP-O-2.8-COMP-A	
738B	3	Ν	В	Α	10	GA	MO	1245 (H-4)	С	0	NA	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
MOTOR OPERA HEAT REMOVA	ATED BLO	OCK EXCH	VALV HANG	E FOF ERB)	R COMPC	NENT COO	LING WATE	R SUPPLY TO	DEAC02	2B (RESI	DUAL	SC/SO	2Y		STP-O-2.8-COMP-B	
740A	3	Ν	С	А	1	TRV	SA	1245 (G-3)	С	0	NA	RT	10Y		CMP-37-06-275/RV1	
RHR HX A CCW	OUTLE	T RE	LIEF \	/LV												
740B	3	Ν	С	А	1	TRV	SA	1245 (I-3)	С	0	NA	RT	10Y		CMP-37-06-275/RV1	
RHR HX B CCW	OUTLE	T RE	LIEF \	/LV												
743	2	Ν	С	A	2	СК	SA	1246-1 (C-6)	0	С	NA	BDO CC	OP Q		STP-O-2.5 STP-O-2.5	
CCW INLET IN	NER CHE	CK V	LV TO	DEXC	ESS LET	DOWN HX (IN CNMT)		-							
744	2	Ν	С	A	.75	TRV	SA	1246-1 (C-7)	С	O/C	NA	RT	10Y		GMP-37-06-150/RV1	
CCW OUTLET I	RELIEF V	ALVE	E FOR	R ECH	03 (EXCE	SS LETDOV	VN HEAT EX	(CHANGER)								

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table CCW - COMPONENT COOLING WATER

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
745	2	Ν	А	А	2	GL	AO	1246-1 (B-6)	0	С	С	FC	Q		STP-O-2.5	
								- (-)				LT-X	2Y		STP-O-8.13	
EXCESS LETDO	SWN HX	CCW	/ OUTI	LET CI	NMT ISO	L AOV-745						PI	2Y		STP-O-2.5	
												SC/SO	Q		STP-O-2.5	
												STC	Q		STP-O-2.5	
749A	2	Ν	А	А	3	GA	MO	1246-1 (B-5)	0	С	AI	DIAG	MOV		MA-AA-723-300-1006	
												LT-X	2Y		STP-O-8.13	
CCW TO RCP A	A ISOL VL		OV-74	9A								PI			MA-AA-723-300-1006	
7400	0	NI	^	•	2	<u> </u>	MO	4040 4 (D 4)		~	A 1	30/30	TOIM MOV		STF-0-2.4	
/430	2	IN	А	А	3	GA	MO	1246-1 (В-4)	0	C	AI				MA-AA-723-300-1006	
		V M		0P								PI	MOV		MA-AA-723-300-1006	
		_	0 - 1 -	50								SC/SO	18M		STP-O-2.4	
750A	2	N	С	Α	4	СК	SA	1246-1 (C-5)	0	С	NA	BDO	OP		Normal Ops	
	-		Ŭ	,,	-	on	0,1	12101(00)	Ũ	Ŭ		CC	CS	CS - 14	STP-O-2.10	
RCP A CCW IN	LET CHE	CK V	LV (IN	I CNM	Г)											
750B	2	Ν	Ċ	А	4	СК	SA	1246-1 (C-3)	0	С	NA	BDO	OP		Normal Ops	
								- ()				CC	CS	CS - 14	STP-O-2.10	
RCP B CCW IN	LET CHE	CK V	′LV (IN	I CNM	Г)											
753A	2	Ν	С	А	1.5	СК	SA	1246-1 (F-5)	0	С	NA	BDO	OP		Normal Ops	
								()				CC	CS	CS - 14	STP-O-2.10	
CCW SUPPLY	CHECK V	'ALVE	E TO F	RCP "A	" THERM	AL BARRIE	R									
753B	2	Ν	С	А	1.5	СК	SA	1246-1 (F-2)	0	С	NA	BDO	OP		Normal Ops	
								. ,				CC	CS	CS - 14	STP-O-2.10	
CCW SUPPLY	CHECK V	'ALVE	E TO F	RCP "B	" THERN	AL BARRIE	R									
755A	2	Ν	С	А	.75	RV	SA	1246-1 (G-6)	С	O/C	NA	RT	10Y		GMP-37-06-2500/RV	
RCP A THERM	AL BARR	IER (CCW C	DUTLE	T RELIE	F VLV (IN CN	IMT)									
755B	2	Ν	С	А	.75	RV	SA	1246-1 (G-3)	С	O/C	NA	RT	10Y		GMP-37-06-2500/RV	
RCP B THERM	AL BARR	IER (CCW C	DUTLE	T RELIE	F VLV (IN CN	NMT)									
758A	2	Ν	С	А	2	RV	SA	1246-1 (H-5)	С	O/C	NA	RT	10Y		GMP-37-06-150/RV2	
RCP A CCW OL	JTLET RE	ELIEF	- VLV	(IN CN	MT)											
758B	2	Ν	С	А	2	RV	SA	1246-1 (H-2)	С	O/C	NA	RT	10Y		GMP-37-06-150/RV2	
			// . /		• 4T \											
KCA R CCM OF	JILEI RE	LIF	- VLV	(IN CN	IVII)											

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table CCW - COMPONENT COOLING WATER

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
759A	2	Ν	A	А	3	GA	MO	1246-1 (I-5)	0	С	AI	DIAG LT-X	MOV 2Y		MA-AA-723-300-1006 STP-O-8.13	
CCW FROM RC	CP A ISO	L VL\	/ MOV	-759A								PI SC/SO	MOV 18M		MA-AA-723-300-1006 STP-O-2.4	
759B	2	Ν	А	А	3	GA	MO	1246-1 (I-2)	0	С	AI	DIAG LT-X	MOV 2Y		MA-AA-723-300-1006 STP-O-8.13	
CCW FROM RC	P B ISO	L VL\	/ MOV	-759B								PI SC/SO	MOV 18M		MA-AA-723-300-1006 STP-O-2.4	
766	3	Ν	С	А	.75	TRV	SA	1246-2 (G-8)	С	0	NA	RT	10Y		GMP-37-06-150/RV	
CCW OUTLET I	RELIEF \	/ALVI	E FOR	ECH0	4 (SEAL	WATER HE	AT EXCHAI	NGER)								
770	3	Ν	С	А	.75	TRV	SA	1245 (F-7)	С	0	NA	RT	10Y		GMP-37-06-150/RV	
CCW INLET RE	LIEF VA	_VE F	OR S	AMPLE	E HEAT E	EXCHANGE	RS									
774A	3	Ν	С	А	.75	TRV	SA	1246-2 (D-5)	С	0	NA	RT	10Y		GMP-37-06-150/RV	
CCW OUTLET F	RELIEF \	/ALVI	E FOR	EWDO)1B (WA	STE GAS CO	OMP RESS	OR B SEAL W	ATER H	EAT						
774B	3	Ν	С	А	.75	TRV	SA	1246-2 (C-3)	С	0	NA	RT	10Y		GMP-37-06-150/RV	
CCW OUTLET I	RELIEF \	/ALVI	E FOR	ECH0	7 (BORIO	C ACID EVA	PORATOR	CONDENSER)							
774C	3	Ν	С	А	.75	TRV	SA	1246-2 (B-4)	С	0	NA	RT	10Y		GMP-37-06-150/RV	
CCW OUTLET I	RELIEF \	/ALVI	E FOR	ECH0	1 (BORIO	C ACID EVA	PORATOR	DISTILLATE C	OOLER	2)						
774D	3	Ν	С	А	.75	TRV	SA	1246-2 (C-8)	С	0	NA	RT	10Y		GMP-37-06-150/RV	
CCW OUTLET F	RELIEF \	/ALVI	E FOR	EWDO	01A (WAS	STE GAS CO	OMP RESS	OR A SEAL W	ATER H	EAT						
776	3	Ν	С	А	.75	TRV	SA	1246-2 (H-9)	С	0	NA	RT	10Y		GMP-37-06-150/RV	
CCW OUTLET I	RELIEF \	/ALVI	E FOR	NON I	REGENE	RATIVE HE	AT EXCHAI	NGER								
813	2	Ν	А	А	6	GA	MO	1246-1 (B-8)	0	С	AI	DIAG LT-X	MOV 2Y		MA-AA-723-300-1006 STP-O-8.13	
CCW TO Rx SU	IPPORT	000	LERS	ISOL V	LV MOV	-813						PI SC/SO STC	MOV 18M 18M		MA-AA-723-300-1006 STP-O-2.3 STP-O-2.3	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CCW - COMPONENT COOLING WATER

Valve ID						Valve	Actuator	Drawing	P	Positio	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Normal Sa	afety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
814	2	Ν	А	А	6	GA	МО	1246-1 (I-8)	0	С	Al	DIAG LT-X	MOV 2Y		MA-AA-723-300-1006 STP-O-8.13	
CCW FROM Rx S	SUPPO	RT CI	LRS IS	SOL VL	V MOV-8	814						PI	MOV		MA-AA-723-300-1006	
												SC/SO STC	18M 18M		STP-O-2.3 STP-O-2.3	
817	3	Y	В	NA	8	GA	МО	1246-1 (A-4)	0	NA	AI	PI SC/SO	2Y R		STP-O-2.4 STP-O-2.4	
CCW TO CNMT	ISOL VL	V MO	DV-81	7								STC	R		STP-O-2.4	
818	2	Ν	С	А	.75	TRV	SA	1246-1 (H-8)	С	O/C	NA	RT	10Y		GMP-37-06-150/RV1	
CCW OUTLET R	ELIEF \	/ALVI	E FOR	REAC	CTOR SU	IPPORT CO	OLERS									
823	3	Ν	В	Р	2	GA	MO	1245 (D-2)	С	С	AI	PI	2Y		STP-O-2.4	
RMW TO CCW S	SURGE	TANK	MOV	-823												

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CFSW - CONSTRUCTION FIRE SERV WATER

Valve ID Description	Class	Aug	Cat.	A/P	Size	Valve Type	Actuator Type	Drawing & Coord	Normal	Positi Safety	on Fail-Safe	Required Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
5129	2	Ν	А	Ρ	2	GA	М	1991 (D-7)	С	С	NA	LJ-C	AJ		STP-O-23.49	
FIREWATER/SW	SUPPL	у то	CMN	T DUR	ING CON	STRUCTIC	N ONLY									

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CHPE - CONTAINMENT HVAC PURGE EXHAUST

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
1596	2	Ν	А	А	1	GL	М	1866 (I-10)	0	С	NA	EC/EO	2Y		STP-O-2.5.5	
INLET BLOCK V	LV TO A	OV 1	597 (0	CNMT	AIR SAM	PLE INLET)						LJ-C	AJ		51P-0-23.15	
1597	2	Ν	A	А	1	DIA	AO	1866 (I-9)	0	С	С	FC	Q		STP-O-2.5.5	
								()				LJ-C	AJ		STP-O-23.15	
CNMT AIR SAM	PLE ISO	L VL	V AOV	-1597								PI	2Y		STP-O-2.5.5	
												SC/SO	Q		STP-O-2.5.5	
												STC	Q		STP-O-2.5.5	
1598	2	Ν	Α	А	1	DIA	AO	1866 (G-10)	0	С	С	FC	Q		STP-O-2.5.5	
								· · · ·				LJ-C	AJ		STP-O-23.14	
CONTAINMENT	AIR SAM	NPLE	ISOL	VLV A	OV-1598							PI	2Y		STP-O-2.5.5	
												SC/SO	Q		STP-O-2.5.5	
												STC	Q		STP-O-2.5.5	
1599	2	Ν	А	А	1	DIA	AO	1866 (G-10)	0	С	С	FC	Q		STP-O-2.5.5	
								()				LJ-C	AJ		STP-O-23.14	
CONTAINMENT	AIR SAM	NPLE	ISOL	VLV A	OV-1599							PI	2Y		STP-O-2.5.5	
												SC/SO	Q		STP-O-2.5.5	
												STC	Q		STP-O-2.5.5	
5879	2	Ν	В	Α	48	BTF	AO	1866 (I-2)	С	С	С	FC	R		STP-O-2.5.2	OOS - flange
												PI	2Y		STP-O-2.5.2	installed
CONTAINMENT	PURGE	EXH	IAUST	VLV A	OV-5879							SC/SO	R		STP-O-2.5.2	
												STC	R		STP-O-2.5.2	
7970	2	Ν	А	А	6	BTF	AO	1870 (G-2)	O/C	С	С	FC	Q		STP-O-2.5.1	
								. ,				LJ-C	AJ		STP-O-23.34	
CONTAINMENT	MINI PU	IRGE	EXHA	AUST V	/ALVE IN	SIDE						PI	2Y		STP-O-2.5.1	
												SC/SO	Q		STP-O-2.5.1	
												STC	Q		STP-O-2.5.1	
7971	2	Ν	А	А	6	BTF	AO	1870 (G-4)	O/C	С	С	FC	Q		STP-O-2.5	
								· · · ·				LJ-C	AJ		STP-O-23.34	
CONTAINMENT	MINI PU	RGE	EXHA	AUST V	ALVE O	UTSIDE						PI	2Y		STP-O-2.5	
												SC/SO	Q		STP-O-2.5	
												STC	Q		STP-O-2.5	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CHPS - CONTAINMENT HVAC PURGE SUPPLY

Valve ID						Valve	Actuator	Drawing		Positio	on	Required				
Description	Class	Aug	J. Cat.	A/P	Size	Туре	Туре	& Coord	Normal	Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
5869	SSC	; N	В	А	48	BTF	AO	1865 (F-10)	С	С	С	FC PI	R 2Y		STP-O-2.5.2 STP-O-2.5.2	OOS - flange installed
CONTAINMENT	T PURGE	SUF	PLY A	IR OP	ERATED	VALVE						SC/SO STC	R R		STP-O-2.5.2 STP-O-2.5.2	
7445	2	Ν	А	А	6	BTF	AO	1865 (H-7)	O/C	С	С	FC LJ-C	Q AJ		STP-O-2.5.5 STP-O-23.44	
CNMT MINI PUI	RGE SUI	PPLY	VLV (DUTSIE	DE AOV-	7445						PI SC/SO STC	2Y Q Q		STP-O-2.5.5 STP-O-2.5.5 STP-O-2.5.5	
7478	2	Ν	А	А	6	BTF	AO	1865 (H-8)	O/C	С	С	FC LJ-C	Q AJ		STP-O-2.5.1 STP-O-23.44	
CNMT MINI PUI	RGE SUI	PPLY	VLV (DUTSIE	DE AOV-	7478						PI SC/SO STC	2Y Q Q		STP-O-2.5.1 STP-O-2.5.1 STP-O-2.5.1	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CHR - CONTAINMENT HVAC & RECIRC

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
1557	2	Ν	А	Р	.75	DIA	М	1863 (C-5)	С	С	NA	LJ-C	AJ		STP-O-23.50A	
A RECIRC FAN	AIR SAM	1PLE	LINE I	PRI ISO	OL, PEN	ET-305										
1558	2	Ν	А	Р	.5	GA	М	1863 (C-5)	С	С	NA	LJ-C	AJ		STP-O-23.50A	
A RECIRC FAN	AIR SAM	1PLE	LINE	VENT,	PENET-	305										
1559	2	Ν	Α	Р	.75	DIA	М	1863 (C-4)	С	С	NA	LJ-C	AJ		STP-O-23.50A	
A REIRC FAN AI	R SAMF	LE LI	INE SE	EC ISC	L, PENE	ET-305										
1560	2	Ν	Α	Р	.75	DIA	М	1863 (D-5)	С	С	NA	LJ-C	AJ		STP-O-23.50A	
A & B RECIRC F	AN AIR	SAM	PLE R	ETUR	N LINE F	RI ISOL, PE	NET-305									
1561	2	Ν	А	Р	.5	GA	М	1863 (D-5)	С	С	NA	LJ-C	AJ		STP-O-23.50A	
A & B RECIRC F	AN AIR	SAM	PLE R	ETUR		'ENT, PENE	T-305									
1562	2	Ν	А	Р	.75	DIA	М	1863 (D-5)	С	С	NA	LJ-C	AJ		STP-O-23.50A	
A & B RECIRC F	AN AIR	SAM	PLE R	ETUR	I LINE S	EC ISOL, P	ENET-305									
1572	2	Ν	А	Р	.75	DIA	М	1863 (B-12)	С	С	NA	LJ-C	AJ		STP-O-23.50C	
C RECIRC FAN	AIR SAN	1PLE	RETU	IRN LIN	NE PRI I	SOL, PENET	⊺-12 4									
1573	2	Ν	А	Р	.5	GA	М	1863 (B-12)	С	С	NA	LJ-C	AJ		STP-O-23.50C	
C RECIRC FAN	AIR SAN	1PLE	RETU	IRN LIN		, PENET-12	24									
1574	2	Ν	А	Р	.75	DIA	М	1863 (B-12)	С	С	NA	LJ-C	AJ		STP-O-23.50C	
C RECIRC FAN	AIR SAN	1PLE	RETU	IRN SE	C ISOL,	PENET-124	Ļ									

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve ID						Valve	Actuator	Drawing		Positic	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
1802	2	Ν	С	А	.75	RV	SA	1261 (F-3)	С	0	NA	RT	10Y		GMP-37-06-275/RV3	
SPRAY ADDITI	IVE TANK	REL	IEF VI	LV TO	ATMOSF	PHERE										
1819A	2	Ν	А	А	.75	GL	М	1261 (A-10)	0	O/C	NA	EC/EO	2Y		PTT-23.17A	
INSTR ISOL VI	LV TO PT-	-945 (r pres	SS)			. ,				LJ-C	AJ		STP-O-23.17A	
1819B	2	N	A	А	.75	GL	М	1261 (A-9)	0	O/C	NA	EC/EO	2Y		PTT-23.17A	
INSTR ISOL VL	_V TO PT-	-946 (r PRES	SS)							LJ-C	AJ		STP-0-23.17A	
1819C	2	N	A	Α	.75	GL	М	1261 (B-10)	0	O/C	NA	EC/EO	2Y		PTT-23.17B	
		047 ((22			()				LJ-C	AJ		STP-O-23.17B	
18190	2 1011	N 140			75	GI	М	1261 (B_0)	0	0/0	ΝΔ	EC/EO	27		PTT_23 17B	
10130	2	IN	A	A	.75	GL	IVI	1201 (B-9)	0	0/0	IN/A	LJ-C	AJ		STP-O-23.17B	
INSTR ISOL VL	V TO PT	-948 (r PRES	SS)											
1819E	2	Ν	Α	А	.75	GL	М	1261 (C-10)	0	O/C	NA	EC/EO	2Y		PTT-23.17C	
												LJ-C	AJ		STP-O-23.17C	
INSTR ISOL VL	_V TO PT·	-949 (r PRES	SS)											
1819F	2	Ν	Α	А	.75	GL	М	1261 (C-9)	0	O/C	NA	EC/EO	2Y		PTT-23.17C	
		050 /			29)							LJ-C	AJ		STP-0-23.17C	
18196	2 10 FI	-9 <u>50 (</u>			75	CI	M	1261 (C 10)	0	0/0	ΝΙΔ		27		DTT 22 17C	
10130	2	IN	A	A	.75	GL	IVI	1201 (C-10)	0	0/0	IN/N	LJ-C	21 A.I		STP-0-23 17C	
INSTR ISOL VL		-944 (CNM	r PRES	SS)							20 0			0.1. 0 2011 0	
2825	2	Ν	A	Р	.75	GA	М	1261 (E-8)	С	С	NA	LJ-C	AJ		STP-O-23.18A	
CONTAINMEN	T SPRAY	PUM	PAD	ISCHA	RGE INN	IER DRAIN	VLV									
2825A	2	Ν	А	Р	.5	BAL	М	1261 (F-8)	С	С	NA	LJ-C	AJ		STP-O-23.18A	
CONTAINMEN	T SPRAY	PUM	PAD	ISCHA	RGE OU	TER DRAIN	VIV									
2826	2	N	A	P	.75	GA	M	1261 (I-8)	С	С	NA	LJ-C	AJ		STP-O-23.18B	
	-			•		0,1			Ū	Ū.		20 0			011 0 201102	
CONTAINMEN	T SPRAY	PUM	PBD	ISCHA	RGE INN	IER DRAIN	VLV									
2826A	2	Ν	А	Ρ	.5	BAL	М	1261 (J-8)	С	С	NA	LJ-C	AJ		STP-O-23.18B	
CONTAINMEN	T SPRAY	PUM	PBD	ISCHA	RGE OU	TER DRAIN	VLV									
2856	2	Ν	А	Р	.75	GA	М	1261 (D-9)	С	С	NA	LJ-C	AJ		STP-O-23.18A	
INSTR ISOL VL	_V TO PI-9	933A	& 278	0 (CNN	/IT SPRA		SCH)									

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CS - CONTAINMENT SPRAY

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
2858	2	Ν	А	Ρ	.75	GA	М	1261 (I-9)	С	С	NA	LJ-C	AJ		STP-O-23.18B	
INSTR ISOL VL	/ TO PI-	933B	& 277	9 (CNI	IT SPRA	Y PMP B DI	SCH)									
2863R	2	Ν	С	А	.75	TRV	SA	1261 (H-10)	С	С	NA	RT	10Y		GMP-37-49-50X350/RV	Added per NRC GL 96-06
CHARCOAL FIL	TER DO	USIN	G HEA	ADER I	RELIEF V	ALVE										
836A	2	Ν	В	А	2	GL	AO	1261 (H-3)	С	0	0	FO	Q		STP-O-3QA	
												FO	2Y		STP-O-3-COMP-A	
CNMT SPRAY N	IAOH AE	DDITIO	ON AC	DV-836	A							SC/SO	Q		STP-O-3QA	
												SC/SO	2Y		STP-O-3-COMP-A	
												STO	Q		STP-O-3QA	
												STO	2Y		STP-O-3-COMP-A	
836B	2	Ν	В	Α	2	GL	AO	1261 (H-3)	С	0	0	FO	Q		STP-O-3QB	
												FO	2Y		STP-O-3-COMP-B	
CNMT SPRAY N		DITIO	ON AC	V-836	В							SC/SO	Q		STP-O-3QB	
												SC/SO	2Y		STP-O-3-COMP-B	
												STO	Q		STP-O-3QB	
												STO	2Y		STP-O-3-COMP-B	
845C	3	Ν	С	А	2	RV	SA	1261 (F-4)	С	0	NA	RT	2Y		STP-M-R-13	
CONTAINMENT	SPRAY	ADD	ITIVE	TANK	VACUUN	IBREAKER	-RELIEF VA	LVE								
845D	3	Ν	С	А	2	RV	SA	1261 (F-4)	С	0	NA	RT	2Y		STP-M-R-13	
CONTAINMENT	SPRAY	ADD	ITIVE	TANK	VACUUN	IBREAKER	-RELIEF VA	LVE								
847A	2	Ν	С	А	2	СК	SA	1261 (G-5)	С	O/C	NA	CC	Q		STP-O-3QB	
	-		•			0.11			•	0,0		ČČ	2Ŷ		STP-O-3-COMP-B	
SPRAY ADDITIV	/F TANK		IFTC	HECK	VIV TO	CNMT SPR	AY EDUCTO	OR A				CO	Q		STP-O-3QA	
			0		12110							CO	2Ŷ		STP-O-3-COMP-A	
847B	2	N	С	Α	2	СК	SA	1261 (H-5)	С	0/C	NA	00	0		STP-O-30A	
0.1.2	2		0	~	-	ÖR	0/1	1201 (110)	0	0/0	NV V	00	27		STP-O-3-COMP-A	
	ε τανικ			HECK		CNMT SPR) R B				00	0		STP-O-30B	
		001										co	2Y		STP-O-3-COMP-B	
860A	2	N	Δ	Δ	6	GA	MO	1261 (F-7)	C	0/0	AI	DIAG	MOV		MA-AA-723-300-1006	
	2		~	~	Ũ	0/1	MO	1201 (E 7)	0	0/0	7.0	1 T-X	27		STP-0-8 11	
	SPRAV		рΔм					F				PI	MOV		MA-AA-723-300-1006	
	STIVAT	1 0101						–				SC/SO	2Y		STP-O-3-COMP-A	
												STO	2Y		STP-O-3-COMP-A	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table CS - CONTAINMENT SPRAY

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
860B	2	Ν	А	А	6	GA	MO	1261 (E-7)	С	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	
								()				LT-X	2Y		STP-O-8.11	
CONTAINMENT	FSPRAY	PUM	P A DI	ISCHA	RGE ISC	LATION MO	DTOR OPER	ATED VALVE				PI	MOV		MA-AA-723-300-1006	
												SC/SO	2Y		STP-O-3-COMP-A	
												STO	2Y		STP-O-3-COMP-A	
860C	2	Ν	Α	А	6	GA	MO	1261 (I-7)	С	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	
												LT-X	2Y		STP-O-8.11	
CONTAINMENT	FSPRAY	PUM	P B DI	ISCHA	RGE ISC	DLATION MO	DTOR OPER	ATED VALVE				PI	MOV		MA-AA-723-300-1006	
												SC/SO	2Y		STP-O-3-COMP-B	
												STO	2Y		STP-O-3-COMP-B	
860D	2	Ν	А	А	6	GA	MO	1261 (I-7)	С	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	
								. ,				LT-X	2Y		STP-O-8.11	
CONTAINMENT	FSPRAY	PUM	РВМ	OTOR	OPERA	TED DISCH	ARGE ISOLA	TION VALVE				PI	MOV		MA-AA-723-300-1006	
												SC/SO	2Y		STP-O-3-COMP-B	
												STO	2Y		STP-O-3-COMP-B	
861	2	Ν	С	А	.75	RV	SA	1261 (J-2)	С	O/C	NA	RT	10Y		GMP-37-06-255/RV	
CONTAINMENT	T SPRAY	PUM	PS SL	ото	N RELIEF	= VLV										
862A	2	N	С	Α	6	CK	SA	1261 (F-8)	С	O/C	NA	00	18M		STP-0-3-COMP-A	CVCMP
••=-	2		U		Ū.	ÖR	0/1	1201 (E 0)	0	0/0		co	18M		STP-O-3-COMP-A	0,000
CONTAINMENT	T SPRAY	PUM	P A DI	ISCHA	RGE CH	ECK VLV						00	10111			
862B	2	Ν	С	А	6	СК	SA	1261 (I-8)	С	O/C	NA	CC	18M		STP-O-3-COMP-B	CVCMP
								()				CO	18M		STP-O-3-COMP-B	
CONTAINMENT	F SPRAY	PUM	P B DI	ISCHA	RGE CH	ECK VLV										
868C	2	Ν	А	Р	6	GL	М	1261 (F-8)	С	С	NA	LJ-C	AJ		STP-O-23.18A	
					<u> </u>			4004 (0.0)	-		N1.0					
8680	2	N	А	Р	6	GL	IVI	1261 (G-8)	C	C	NA	LJ-C	AJ		STP-0-23.18B	
CS PUMP B RE		IE IS	OL VA	LVE												
868E	2	Ν	А	Р	6	GL	М	1261 (F-8)	С	С	NA	LJ-C	AJ		STP-O-23.18A	
		ISOI	\/A1\	/=												
		1301			75			4004 (F 0)	<u>^</u>	0	NIA		A 1		CTD 0 02 404	
OUJA	2	IN	А	Р	.15	GL	IVI	1201 (E-9)	C	C	NA	LJ-C	AJ		517-U-23.18A	
INSTR ROOT V	LV TO PI	-933/	۹ & 27	80 (CN	IMT SPR	AY PMP A [DISCH)									
869B	2	Ν	А	Ρ	.75	GL	М	1261 (I-9)	С	С	NA	LJ-C	AJ		STP-O-23.18B	
INSTR ROOT V	'LV TO PI	-933F	3 & 27	79 (CN	IMT SPR	AY PMP B I	DISCH)									
							- /									

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CS - CONTAINMENT SPRAY

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
869E	2	Ν	AC	А	0.5	TRV	SA	1261 (G-8)	С	O/C	NA	LJ-C RT	AJ 10Y		STP-O-23.18A GMP-37-55-450/RV	
CS TEST LINE	RV															
875A	2	Ν	В	Р	2	GL	MO	1261 (F-9)	С	С	AI	PI	2Y		STP-O-2.4	
UPPER CNMT	SPRAY CH	HAR	COAL	FILTE	R DOUS	ING MOTOF	R OPERATEI	D VALVE								
875B	2	Ν	В	Р	2	GL	MO	1261 (G-9)	С	С	AI	PI	2Y		STP-O-2.4	
UPPER CNMT	SPRAY CI	HAR	COAL	FILTE	R DOUS	ING MOV-8	75B									
876A	2	Ν	В	Р	2	GL	MO	1261 (H-9)	С	С	AI	PI	2Y		STP-O-2.4	
LOWER CONT	AINMENT	SPR	AY CH	HARCO	DAL FILT	ER DOUSIN		OPERATED V	ALVE							
876B	2	Ν	В	Р	2	GL	MO	1261 (G-9)	С	С	AI	PI	2Y		STP-O-2.4	
LOWER CNMT	SPRAY C	HAR	COAL	FILTE	R DOUS	ING MOV-8	76B									
896A	2	Ν	А	А	10	GA	MO	1261 (C-2)	0	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	High Risk MOV
		теп											Z Y MOV		STP-0-8.12 MA-AA-723-300-1006	
RWSI OUILEI		1 35	RAIC	X SAFE				JOA				SC/SO	CS	CS - 22	STP-O-2.4	
896B	2	Ν	Α	А	10	GA	MO	1261 (D-2)	0	O/C	AI	DIAG	MOV	-	MA-AA-723-300-1006	High Risk MOV
												LT-X	2Y		STP-O-8.12	3
RWST OUTLET	TO CNM	T SP	RAY 8	& SAFE	ETY INJE	CTION PUN	APS MOV-89	96B				PI	MOV		MA-AA-723-300-1006	
												SC/SO	CS	CS - 22	STP-O-2.4	
897	2	Ν	А	А	2	GL	MO	1261 (C-7)	0	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	Treat as High Risk
								. ,				LT-X	2Y		STP-O-8.12	MOV
SAFETY INJEC	TION REC	CIRC	TOR	WSTN	10V-897							PI	MOV		MA-AA-723-300-1006	
												SC/SO	CS	CS - 23	STP-O-2.4	
898	2	Ν	А	Α	2	GL	MO	1261 (C-7)	0	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	Treat as High Risk
												LT-X	2Y		STP-O-8.12	MOV
SAFETY INJEC	TION REC	CIRC	TOR	WST N	10V-898							PI	MOV		MA-AA-723-300-1006	
												SC/SO	CS	CS - 23	STP-O-2.4	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CVAT - CONTAINMENT VESSEL AIR TEST

Valve ID Description	Class	s Aug	J. Cat.	A/P	Size	Valve Type	Actuator Type	Drawing & Coord	 Normal	· Positi Safetv	on Fail-Safe	Required Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
7443	2	N	A	Р	6	BTF	M	1882 (E-10)	С	C	NA	LJ-C	AJ		STP-O-23.43	
CONTAINMENT LEAK TEST ISOL VLV MOV-7443																
7443A	2	Ν	AC	А	6	CK	SA	1882 (E-10)	С	С	NA	LJ-C	AJ		STP-O-23.43	Drawing #33013-1262
CONTAINMENT	LEAK T	EST	ISOL	VLV M	OV-7443A	۱										
7444	2	Ν	Α	Ρ	6	BTF	М	1882 (I-5)	С	С	NA	LJ-C	AJ		STP-O-23.42	
CONTAINMENT	I FAK T	FST	мотс	R OPI	RATED	/AI VE										

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CVCS - CVCS CHARGING

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
112B	2	Y	В	А	4	BTF	AO	1265-2 (F-3)	С	0	С	PI	2Y		STP-O-2.5.2	
								. ,				SC/SO	CS	CS - 07	STP-0-2.5.2	
EMERG MAKE	UP RWS1	г то (CHAR	GING	PUMP LO	CV-112B						STO	CS	CS - 07	STP-0-2.5.2	
112C	SSC	Y	В	А	4	BTF	AO	1265-2 (D-3)	0	С	0	PI	2Y		STP-O-2.5.2	
												SC/SO	CS	CS - 07	STP-O-2.5.2	
VCT OUTLET V	/LV LCV-	112C										SIC	CS	CS - 07	STP-0-2.5.2	
142	2	Y	В	А	2	GL	AO	1265-2 (E-10)	0	0	0	FO	CS	CS - 08	STP-O-2.5.2	
												PI	2Y	00 00	STP-O-2.5.2	
CHARGING FL	OW TO R	EGEI	N HX I	HCV-1	42							SC/SU STO	CS CS	CS - 08	STP-0-2.5.2 STP-0-2.5.2	
257	222	N	<u> </u>	٨	2	D\/	61	1265 2 (A 4)	<u> </u>	0/0	ΝΑ	 	101	00-00	CMD 27 06 257	
251	330		C	A	2	ΓV	SA	1205-2 (A-4)	C	0/0	INA	RI.	101		CIVIF-37-00-237	
VCT RELIEF V	ALVE TO	HOL	DUP T	ANKS												
268	SSC	Y	В	А	4	BTF	М	1265-2 (F-3)	0	O/C	NA	EC/EO	2Y		STP-O-2.6.4	
								, , , , , , , , , , , , , , , , , , ,								
VCT SUCTION	ISOL VL	/ TO	CHAR	GING	PUMP B	& C										
270A	2	Υ	В	А	2	GL	AO	1265-1 (F-3)	0	С	0	PI	2Y		STP-O-2.5.2	
												SC/SO	CS	CS - 10	STP-O-2.5.2	
RCP A SEAL C	UTLET V	LV AC	OV-27	0A								STC	CS	CS - 10	STP-O-2.5.2	
270B	2	Y	В	А	2	GL	AO	1265-1 (F-6)	0	С	0	PI	2Y		STP-O-2.5.2	
												SC/SO	CS	CS - 10	STP-O-2.5.2	
RCP B SEAL C	OUTLET V	LV AC	OV 270	0B								SIC	CS	CS - 10	STP-0-2.5.2	
283	2	Ν	С	А	.75	RV	SA	1265-2 (H-6)	С	O/C	NA	RT	10Y		GMP-37-06-2687RV	
		сна	RGEI	RELIE		VCT										
284	2	N	C		75	R\/	S۵	1265-2 (E-6)	C	0/0	NΔ	RT	107		GMP-37-06-2687R\/	
204	L		0	А			UA	1203-2 (1-0)	0	0/0			101		0001-07-00-200710	
CHARGING PL	JMP B DIS	SCHA	RGE I	RELIE	= VLV TO	D VCT										
285	2	Ν	С	А	.75	RV	SA	1265-2 (E-6)	С	O/C	NA	RT	10Y		GMP-37-06-2687RV	
		сци		סכווכו		VCT										
					2		64	1065 1 (D 10)	0	<u> </u>	NIA	RDO	66	<u> </u>		
295	I	IN	C	A	2	CK	SA	1203-1 (B-10)	0	C	INA	00	CS CS	CS - 08	STP-0-2.9 STP-0-2.9	
		CHE	CK VI	V TO I	OOP B		(RCS IMB)					00	00	00-00	011 0-2.0	
297	1	N	0	Δ	2	CK	<u></u>	1265-1 (C.10)	C	C	NΔ	BDO	CS	CS - 08	STP-0-2.9	
	1	IN	0	~	<i>L</i>	ON	54	1200-1 (0-10)	U	0		CC	CS	CS - 08	STP-0-2.9	
CHARGING	NE AUX S	PRA			ECK VL V	TO PRESS	URIZER (IM	B)								
							(/								

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CVCS - CVCS CHARGING

Valve ID						Valve	Actuator	Drawing		Positio	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
302C	1	Y	С	А	2	СК	SA	1265-1 (G-6)	0	0	NA	BDC CO	R OP	ROJ - 09	STP-O-2.9 Normal Ops	
RCP B SEAL IN	JECTION	INLE	ЕТ СН	ECK V	/LV								-			
302D	1	Y	С	А	2	СК	SA	1265-1 (G-3)	0	0	NA	BDC CO	R OP	ROJ - 09	STP-O-2.9 Normal Ops	
RCP A SEAL IN	JECTION	I INLE	ЕТ СН	ECK V	/LV										•	
304A	1	Ν	С	А	2	CK	SA	1265-1 (H-3)	0	O/C	NA	CC CO	CS Q	CS - 10	STP-O-2.9 STP-O-31A	
RCP A SEAL IN	JECTION	IINLE	ET CH	ECK V	/ALVE							CO CO	Q Q		STP-O-31B STP-O-31C	
304B	1	Ν	С	А	2	СК	SA	1265-1 (H-6)	0	O/C	NA	CC CO	CS Q	CS - 10	STP-O-2.9 STP-O-31A	
RCP B SEAL IN	JECTION	INLE	ET CH	ECK V	′LV							CO CO	Q		STP-O-31B STP-O-31C	
313	2	Ν	А	А	3	GA	MO	1265-2 (D-8)	0	С	Al	DIAG	MOV AJ		MA-AA-723-300-1006 STP-O-23 11	
SEAL OR EXC	ESS LETE	NOON	N RET	URN I	SOLATIC	N MOTOR	OPERATED	VALVE TEST				PI SC/SO	MOV 18M		MA-AA-723-300-1006 STP-O-2.4	
24.4				•	0	5) (SIC	18M		STP-0-2.4	
314	2	N	С	A	2	RV	SA	1265-1 (B-4)	C	0	NA	RI	10Y		CMP-37-06-314	
SEAL WATER	RETURN	RELI	EF VL	V TO F	PRT											
357	2	Y	С	A	4	CK	SA	1261 (B-3)	С	0	NA	BDC CO	CS CS	CS - 07 CS - 07	STP-O-2.9 STP-O-2.6.4	
RWST SUCTIO	N CHECK	(VLV	' TO C	HARG	ING PUN	/IPS										
358	2	Y	В	A	4	BTF	М	1265-2 (F-3)	С	O/C	NA	EC/EO	2Y		STP-O-2.6.4	
RWST MAKEU	P AOV BY	PAS	S VLV	TO CI	HARGIN	G PUMPS S	UCTION									
370B	2	Ν	AC	А	2	CK	SA	1265-1 (B-2)	0	O/C	NA	CC CO	CS CS	CS - 08 CS - 08	STP-O-2.10 STP-O-2.6.4	
CHARGING PU	IMP DISC	Н СН	IECK	VLV TO	D REGEN	I HX'S						LJ-C LT-X	AJ 2Y		STP-O-23.8 STP-O-8.4	
383A	1	Ν	С	А	2	CK	SA	1265-1 (F-2)	С	0	NA	BDC CO	CS CS	CS - 12 CS - 12	STP-O-2.6.4 STP-O-2.6.4	
ALTERNATE C	HARGING	G LINI	e inle	ET CHI	ECK VLV	TO LOOP	A COLD LEC	3								
383B	2	Ν	AC	A	2	СК	SA	1265-1 (H-2)	С	O/C	NA	CC CO	CS CS	CS - 12 CS - 12	STP-O-2.10 STP-O-2.10	
ALTERNATE C	HARGING	3 LINI	e inle	ET CHI	ECK VLV	TO LOOP	A COLD LEC	÷				LJ-C LT-X	AJ 2Y		STP-O-23.10 STP-O-8.7	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table

CVCS - CVCS CHARGING

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
386	2	Ν	В	А	1	GA	AO	1265-1 (C-4)	С	С	С	FC	CS	CS - 11	STP-O-2.5.2	
												PI	2Y		STP-O-2.5.2	
RCP A & B SEA	AL BYPAS	S AC	V-386	i								SC/SO	CS	CS - 11	STP-O-2.5.2	
												SIC	CS	CS - 11	STP-0-2.5.2	
392A	2	Ν	BC	А	2	GL	AO	1265-1 (A-9)	С	0	С	PI	2Y		STP-O-2.6.4	
												RT	10Y		STP-O-2.6.4	
CHARGING VL	V RHX TC	D LOC	DP B F	IOT AG	DV-392A							SC/SO	CS	CS - 08	STP-O-2.6.4	
												STO	CS	CS - 08	STP-O-2.6.4	
392B	1	Ν	В	А	2	GL	AO	1265-1 (F-2)	С	0	С	PI	2Y		STP-O-2.6.4	
								. ,				RT	10Y		STP-O-2.6.4	
ALT CHARGIN	G VLV CH	G PL	JMP T	O LOC	P A COL	_D AOV-392	В					SC/SO	CS	CS - 12	STP-O-2.6.4	
												STO	CS	CS - 12	STP-O-2.6.4	
393	1	Ν	С	А	2	CK	SA	1265-1 (A-10)	С	O/C	NA	CC	CS		STP-O-2.9	
								· · · ·				CO	CS	CS - 08	STP-O-2.6.4	
CHARGING LIN	IE INLET	CHE	CK VL	V TO L	OOP B	HOT LEG (IN	MB)									
9313	1	Ν	С	А	2	CK	SA	1265-1 (C-9)	С	С	NA	BDO	CS	CS - 08	STP-O-2.9	
								()				CC	CS	CS - 08	STP-O-2.9	
CHARGING LIN	NE AUX SI	PRAY	INLE	T CHE	CK VLV	TO PRESS	JRIZER (IM	B)								
9314	1	Ν	С	А	2	СК	SA	1265-1 (B-9)	0	С	NA	BDO	CS	CS - 08	STP-O-2.9	
								()				CC	CS	CS - 08	STP-O-2.9	
CHARGING LIN	IE INLET	CHE	CK VL	V TO L	OOP B	COLD LEG (RCS,IMB)									
9315	1	Ν	С	А	2	СК	SA	1265-1 (A-9)	С	O/C	NA	CC	CS	CS - 08	STP-O-2.9	
	-		-					,	-			CO	ĊS	CS - 08	STP-O-2.6.4	
CHARGING LIN		CHE		ν το ι	OOP B	HOT LEG (R	CS.IMB)									
						(-	- , ,									

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

CVL - CVCS LETDOWN

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	Aug	Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
123	1	Ν	А	Ρ	.75	GL	AO	1264 (E-9)	С	С	С	LT-X	2Y		STP-O-8.5	
EXCESS LETDO	OWN HX I	-LOV		ITROL	. HCV-12	3										
200A	1	Ν	А	А	2	GL	AO	1264 (B-11)	O/C	С	С	FC	CS	CS - 09	STP-O-2.5.2	
												LJ-C	AJ		STP-O-23.6	
LTDN ORIFICE	AOV-200/	Ą										LT-X	2Y		STP-O-8.1	
												PI	2Y		STP-O-2.5.2	
												SC/SO	CS	CS - 09	STP-O-2.5.2	
												STC	CS	CS - 09	STP-O-2.5.2	
200B	1	Ν	Α	А	2	GL	AO	1264 (B-10)	O/C	С	С	FC	CS	CS - 09	STP-O-2.5.2	
												LJ-C	AJ		STP-O-23.6	
LTDN ORIFICE	AOV-200	В										LT-X	2Y		STP-O-8.1	
												PI	2Y		STP-O-2.5.2	
												SC/SO	CS	CS - 09	STP-O-2.5.2	
												STC	CS	CS - 09	STP-O-2.5.2	
202	1	Ν	А	А	2	GL	AO	1264 (B-10)	С	С	С	FC	CS	CS - 09	STP-O-2.5.2	
								. ,				LJ-C	AJ		STP-O-23.6	
LTDN ORIFICE	AOV-202											LT-X	2Y		STP-O-8.1	
												PI	2Y		STP-O-2.5.2	
												SC/SO	CS	CS - 09	STP-O-2.5.2	
												STC	CS	CS - 09	STP-O-2.5.2	
203	2	Ν	AC	А	2	RV	SA	1264 (A-8)	С	O/C	NA	LJ-C	AJ		STP-O-23.6	
												RT	10Y		CMP-37-06-203	
LOOP B LETDC RELIEF TANK	OWN TO N	ION-I	REGE	NERA	TIVE HEA	AT EXCHAN	IGER RELIE	F VALVE TO	PRESSU	IRIZER						
310	1	Ν	В	Р	.75	GL	AO	1264 (C-9)	С	С	С	PI	2Y		STP-O-2.5.2	
EXCESS LTDN	LOOP A		о то н		V-310											
371	2	Ν	А	А	2	GL	AO	1264 (B-7)	0	С	С	FC	CS	CS - 09	STP-O-2.5.2	
	-	••							-	-	-	LJ-C	ÂĴ		STP-O-23.6	
	IVIVRH	R TC	NRH		-371							PI	2Y		STP-O-2.5.2	
22.00000					011							SC/SO	CS	CS - 09	STP-O-2.5.2	
												STC	ĊS	CS - 09	STP-O-2.5.2	
702	2	Ν	С	А	.75	СК	SA	1264 (A-10)	С	0	NA	BDC	OP		Normal Ops	
-	-	••	•						-	-		CO	ČS.	CS - 05	STP-O-2.10.12	
RHRIETDOWN	J INI ET C	HEC	K VI V			FR PRESS	PROTECTIO	ואכ					-			

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

EDG - EMERGENCY DIESEL GENERATOR

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	J. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
12398G	3	Ν	В	А	1	GA	М	1239-1 (E-3)	0	O/C	NA	EC/EO	2Y		STP-O-12.6-COMP-A	
A D/G FUEL OIL	SOLEN	OID	RECIR	c iso		/ALVE										
12399G	3	Ν	В	А	1	GA	М	1239-2 (E-8)	0	O/C	NA	EC/EO	2Y		STP-O-12.6-COMP-B	
B-D/G FUEL OIL	SOLEN	OID	RECIR	C ISC	L VLV											
5907	3	Ν	В	А	1	GA	SO	1239-1 (E-3)	0	O/C	С	FC SC/SO	Q		STP-O-12.1	T 1-03
D/G A FUEL OIL	SOV TO	DA	Y TANI	K								STC STO	Q Q		STP-O-12.1 STP-O-12.1	10 00
5907A	3	Ν	В	А	.75	GA	SO	1239-1 (E-3)	С	O/C	0	FO	Q		STP-O-12.1 STP O 12.1	T I 03
D/G A FUEL OIL	TRANS	FER	PUMP	SOLE	ENOID OF	PERATED F	RECIRC VLV					STC STO	Q Q Q		STP-0-12.1 STP-0-12.1 STP-0-12.1	13-03
5908	3	Ν	В	А	1	GA	SO	1239-2 (E-9)	0	O/C	С	FC SC/SO	Q Q		STP-O-12.2 STP-O-12.2	TJ-03
D/G B FUEL OIL	SOLEN	OID	VLV TO	D DAY	' TANK							STC STO	Q Q		STP-O-12.2 STP-O-12.2	
5908A	3	Ν	В	А	.75	GA	SO	1239-2 (E-9)	С	O/C	0	FO SC/SO	Q Q		STP-O-12.2 STP-O-12.2	TJ-03
D/G B FUEL OIL	TRANS	FER	PUMP	RECI	RCULATI	ON SOV						STC STO	Q		STP-O-12.2 STP-O-12.2	
5933A	3	N	В	A	1.5	GA	SO	1239-1 (G-11)	С	0	AI	SC/SO STO	Q Q		STP-O-12.1 STP-O-12.1	TJ-02
D/G A STARTIN	G AIR SO			•	15	<u> </u>	<u> </u>	4000 4 (E 44)		0	A 1	60/60	0			
5355B	3	IN .	В	А	1.5	GA	50	1239-1 (F-11)	C	0	AI	SC/SO STO	Q		STP-0-12.1 STP-0-12.1	TJ-02
D/G A STARTIN	G AIR SC		_	^	1 5	<u> </u>	<u> </u>	4000 0 (0 0)		0	A 1	00/00	0		CTD 0 40.0	
			В	А	1.5	GA	50	1239-2 (C-2)	C	0	AI	SC/SO STO	Q Q		STP-0-12.2 STP-0-12.2	TJ-02
5934R	2 AIN 30		P	۸	15	CA.	50	1220 2 (P 2)	C	0	Δ1	50/50	0		STD () 12.2	
		IN	D	A	1.5	GA	30	1239-2 (D-2)	C	0	AI	STO	Q		STP-0-12.2 STP-0-12.2	TJ-02
D/G B STARTIN	G AIR SO		B	٨	1	CI	М	1220 1 (E 2)	C	0/0	ΝΔ	EC/EO	2V			
		אי ראס <i>י</i>				GL	IVI	1209-1 (E-0)	C	0,0		20/20	21		511 -0-12.0-00WP-A	
5938	. 50V BY	PAS N	B VLV		JAY IK) 1	CI	N/	1230-2 (E-8)	<u> </u>	0/0	NA	EC/EO	2∨			
	SOLEN	יי סוס	VI V 50		'PASS VI		TK)	1200-2 (L-O)	U	0,0		LO/LO	21		011-0-12.0-00ivii-D	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

EDG - EMERGENCY DIESEL GENERATOR

Valve ID						Valve	Actuator	Drawing		Positic	on	Required				
Description	Class	Au	g. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
5941A	3	Ν	С	А	.75	CK	SA	1239-1 (F-1)	С	С	NA	BDO CC	Q		Normal Ops STP-O-12 74	
DISCHARGE CI	HECK VA	ALVE	FOR	CDG0	1A (D/G A	STARTING	AIR COMP	RESSOR)				00	Q		011 0 12.17	
5942A	3	Ν	С	А	.75	CK	SA	1239-2 (F-11)	С	С	NA	BDO	Q		Normal Ops	
												CC	Q		STP-O-12.7B	
D/G B STARTIN	IG AIR C	OMF	RESS	or di	SCHARG	E CHECK V	LV									
5943A	3	Ν	С	А	.75	RV	SA	1239-1 (F-1)	С	O/C	NA	RT	10Y		GMP-37-06-275/RV2	
DISCHARGE RI	ELIEF VA		FOR	CDG0	1A (D/G A	STARTING	AIR COMP	RESSOR)								
5944A	3	N	С	A	.75	RV	SA	1239-2 (F-11)	С	O/C	NA	RT	10Y		GMP-37-06-275/RV2	
								, , , , , , , , , , , , , , , , , , ,								
D/G B STARTIN	IG AIR C	OMF	RESS	or di	SCHARG	E RELIEF V	LV									
5947B	3	Ν	С	А	.75	RV	SA	1239-1 (F-1)	С	O/C	NA	RT	10Y		GMP-37-06-275/RV2	
		C02		A 67/												
5947C	2	G03/		A 317	75		<u>SA</u>	1230 1 (C 1)	C	0/0	ΝΔ	DT	10V		CMD 37 06 275/DV/2	
33470	5	IN	U	~	.75	IXV	34	1239-1 (G-1)	C	0/0	IN/A		101		GIVIF-37-00-273/11V2	
RELIEF VALVE	FOR TD	G03I	B (D/G	A STA	ARTING A	IR RECEIVE	ER A2)									
5948B	3	Ν	С	А	.75	RV	SA	1239-2 (G-10)	С	O/C	NA	RT	10Y		GMP-37-06-275/RV2	
D/G B STARTIN		ECE	IVERE	32 REL		51/	~ ~ ~			0/0						
5948C	3	Ν	С	A	.75	RV	SA	1239-2 (F-10)	С	O/C	NA	RI	10Y		GMP-37-06-275/RV2	
D/G B STARTIN	IG AIR R	ECIE	EVER E	31 REL	LIEF VLV											
5955	3	Ν	С	А	3	СК	SA	1239-1 (I-1)	С	O/C	NA	CC	Q		STP-O-12.6A	
								· · · ·				CC	2Y		STP-O-12.6-COMP-A	
D/G A FUEL OII	L TRANS	FER	PUMP	SUC.	TION CHE	ECK VLV						CO	Q		STP-O-12.6A	
												CO	2Y		STP-O-12.6-COMP-A	
5956	3	Ν	С	А	3	CK	SA	1239-2 (I-10)	С	O/C	NA	CC	Q		STP-O-12.6B	
												CC	2Y		STP-O-12.6-COMP-B	
D/G B FUEL OII	L TRANS	FER	PUMP	SUC.	TION CHE	ECK VLV						CO	Q		STP-O-12.6B	
												CO	2Y		STP-O-12.6-COMP-B	
5959	3	Ν	С	А	1.5	RV	SA	1239-1 (G-3)	С	O/C	NA	RT	10Y		GMP-37-06-275/RV	
		FFR	PUMP	ספוס י	HARGE											
5960	2 110 110		C	Δ	15	RV	S۵	1239-2 (G-8)	0	0/0	ΝΔ	RT	10Y		GMP-37-06-275/RV	
0000	3	IN	U	A	1.5	INV	34	1209-2 (0-0)	U	0,0	11/21	NI -	101		Givii -37-00-273/INV	
D/G B FUEL OII	L TRANS	FER	PUMP	DISC	HARGE F	RELIEF VLV										

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

EDG - EMERGENCY DIESEL GENERATOR

Valve ID							Valve	Actuator	Drawing		Positi	on	Required				
Description	Cla	ISS /	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
5960A		3	Ν	С	А	1.5	СК	SA	1239-1 (C-1)	С	O/C	NA	D&I	СМ		GMP-37-40-250/1.5/CV	CVCMP
D/G A FUEL OIL	60A 3 N C A 1.5 CK SA 1239-1 (C-1) C O/C NA D&I CM GMP-37-40-250/1.5/CV CVCMP 'G A FUEL OIL DAY TANK CHECK VLV TO STORAGE TANK A																
5960B		3	Ν	С	А	1.5	СК	SA	1239-2 (C-11)	С	O/C	NA	D&I	CM		GMP-37-40-250/1.5/CV	CVCMP
D/G B FUEL OIL	. DAY	TAN	IK C	HECK	VLV	TO STOR	AGE TANK	В									

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

FP - FIRE PROTECTION

Valve ID	Class	Δυσ	L Cat	∧ /D	Sizo	Valve Type	Actuator	Drawing		- Positi	on	Required	Fraguanay		Drocoduro	Commonto / Notoo
Description	01033	Aug	. Cal.	A/F	0126	Type	туре	0.00010	Norma	Salety	Fall-Sale	Test	Frequency	KK/CSJ/KUJ	Procedure	Comments / Notes
9227	2	Ν	А	Ρ	4	BAL	М	1991 (B-5)	С	С	NA	LJ-C	AJ		STP-O-23.52	
CONTAINMENT	FIRE H	OSE	SUPPI		OPERA	TED VALVE										
9229	2	Ν	AC	А	4	CK	SA	1991 (C-5)	С	O/C	NA	CC CO	AJ R		STP-O-23.52 FPS-14	CVCMP
CNMT HOSE RE	EEL SUP	PLY	CHEC	K VLV	(IN CNM	1T)						LJ-C	AJ		STP-O-23.52	
9230R	2	Ν	С	А	.75	TRV	SA	1991 (C-5)	С	0	NA	RT	10Y		GMP-37-49-50X350/RV	Added per NRC GL 96-06

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

HREC - H2 RECOMBINERS

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	Au	g. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
10205S1	2	Ν	А	Р	1	GA	SO	1275-1 (B-7)	С	С	NA	LJ-C	AJ		STP-O-23.51A	
H2 PILOT LINE S	SOLENC	DID	OPERA	TED IS	SOL VLV	TO RECOM	BINER A									
10209S1	2	Ν	Α	Р	1	GA	SO	1275-1 (D-7)	С	С	NA	LJ-C	AJ		STP-O-23.51A	
H2 MAIN FUEL L	INE SO	LEN		PERAT	ED ISOL	. VLV TO RE	COMBINER	RA .								
10211S1	2	Ν	Α	Р	1	GA	SO	1275-1 (E-8)	С	С	NA	LJ-C	AJ		STP-O-23.51B	
H2 PILOT LINE S		חו	OPERA	TED IS	SOL VLV	TO RECOM	BINER B									
10213S1	2	N	A	P	1	GA	SO	1275-1 (G-8)	С	С	NA	LJ-C	AJ		STP-O-23.51B	
HYDROGEN MA	IN FUFI	1 11		RECON		B ISOLATIO	N SOLENOL		VAI VE							
10214S1	2	N	A	P	1	GA	SO	1275-1 (C-1)	C	С	NA	LJ-C	AJ		STP-O-23.51C	
O2 LINE A SOL (OPERAT	ГED	ISOL \	/LV TC		/ENT DUCT	(CNMT ISO	L)								
10215S1	2	Ν	А	Р	1	GA	SO	1275-1 (E-1)	С	С	NA	LJ-C	AJ		STP-O-23.51C	
O2 LINE B SOL (OPERAT	ГED	ISOL \	/LV TC		/ENT DUCT	(CNMT ISO	L)								
1076A	2	Ν	Α	Р	1	DIA	M	1275-1 (B-7)	С	С	NA	LJ-C	AJ		STP-O-23.51A	
HYDROGEN RE	COMBIN	JFR			NFR IS		JUAL CNMT	ISOL)								
1076B	2	N	A	P	1	DIA	M	1275-1 (E-8)	С	С	NA	LJ-C	AJ		STP-O-23.51B	
HYDROGEN RE	COMBIN	JFR	B PIL (NFR IS		JUAL CNMT	ISOL)								
1080A	2	N	A	P	1	GA	M	1275-1 (E-1)	С	С	NA	LJ-C	AJ		STP-O-23.51C	
02 ISOL VLV TO	CNMT	VE		т												
1084A	2	N	A	P	1	DIA	М	1275-1 (D-7)	С	С	NA	LJ-C	AJ		STP-O-23.51A	
	COMBIN	JER	Δ ΜΔΙΙ		ISOL V	Ι V (ΜΑΝΠΔΙ	CNMT ISO)))								
1084B	2	N	A	P	1	DIA	M	1275-1 (G-8)	С	С	NA	LJ-C	AJ		STP-O-23.51B	
HYDROGEN RE	COMBIN	IER	B MAII	N FUEL	ISOL V	LV (MANUAL	. CNMT ISO	DL)								

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table

IA - INSTRUMENT AIR

Valve ID Description	Class	Aug	. Cat.	A/P	Size	Valve Type	Actuator Type	Drawing & Coord	 Normal S	Positio Safety	on Fail-Safe	Required Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
5392	2	Ν	А	А	2	GA	AO	1893 (A-11)	0	С	С	FC	R	ROJ - 06	STP-O-2.5.2 STP-O-23.32	
INSTR AIR TO	CONTAI	NMEN	IT ISO	PL AOV	-5392							PI SC/SO STC	2Y R R	ROJ - 06 ROJ - 06	STP-O-2.5.2 STP-O-2.5.2 STP-O-2.5.2	
5393	2 CK VLV T	N O CO			2 (IN CNN	CK (IT)	SA	1887 (D-4)	0	С	NA	BDO CC LJ-C	OP AJ AJ		Normal Ops PTT-23.32 STP-O-23.32	CVCMP
7034A2	3 Y CHECł	N K VAL	C .VE TO	A D AOV	3/8 -9632A	СК	SA	33013-1892 (C-11)	С	С	NA	BDO CC CC	OP Q Q		Normal OPS STP-O-36QC STP-O-36-COMP-C	
7034B2	3 Y CHECH	N K VAL	C .VE TO	A D AOV	3/8 -9632B	СК	SA	44013-1892 (C-11)	С	С	NA	BDO CC CC	OP Q Q		Normal OPS STP-O-36Q-D STP-O-36-COMP-D	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

MFW - MAIN FEEDWATER

Valve ID						Valve	Actuator	Drawing		Positio	n	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
3992	2	Ν	С	А	14	CK	SA	1236-2 (J-3)	0	С	NA	BDO CC	OP CS	CS - 18	Normal Ops STP-O-2.10.9	
S/G B FW INLE	ET CHECK	(VLV														
3993	2	Ν	С	А	14	СК	SA	1236-2 (A-3)	0	С	NA	BDO CC	OP CS	CS - 18	Normal Ops STP-O-2.10.9	
S/G A FW INLE	ET CHECK	(VLV														
3994	3	Ν	В	А	14	GL	AO	1236-2 (J-3)	0	С	С	PI SC/SO	2Y CS	CS - 19	STP-O-2.5.2 STP-O-2.5.2	
MAIN FW INLE	T BLOCK	VLV	TO S/	GΒ								STC	CS	CS - 19	STP-O-2.5.2	
3994G	3	Ν	С	А	.75	CK	SA	1236-3 (I-7)	С	С	NA	BDO CC	CS CS	CS - 20	STP-O-2.10 STP-O-2.10	
MFIV ACCUMU	JLATOR C	HEC	K VAL	VE												
3994K	3	Ν	С	А	.75	RV	SA	1236-3 (G-8)	С	O/C	NA	RT	10Y		GMP-37-06-395/RV	
MFIV ACCUMU	JLATOR R	RELIE	F VAL	VE												
3995	3	Ν	В	А	14	GL	AO	1236-2 (A-3)	0	С	С	PI SC/SO	2Y CS	CS - 19	STP-O-2.5.2 STP-O-2.5.2	
MAIN FW INLE	T BLOCK	VLV	TO S/	GΑ								STC	CS	CS - 19	STP-O-2.5.2	
3995G	3	N	С	A	.75	CK	SA	1236-3 (E-7)	С	С	NA	BDO CC	CS CS	CS - 20	STP-O-2.10 STP-O-2.10	
MFIV ACCUMU	JLATOR C	HEC		.VE	75		0.4	4000.0 (0.0)	0	0/0	NIA	DT	40)/			
3999N	3	IN	C	A	.75	RV	SA	1236-3 (C-8)	C	0/0	NA	RI	104		GMP-37-06-395/RV	
MFIV ACCUML	JLATOR R	RELIE	F VAL	VE												
4269	3	Ν	В	A	12	GL	AO	1236-2 (D-3)	0	С	С	FC PI	CS 2Y	CS - 19	STP-O-R-1.5 STP-O-R-1.5	
MAIN FW CON	ITROL AO	V ТО	S/G A	A								SC/SO	CS	CS - 19	STP-O-R-1.5	
4270	3	Ν	В	А	12	GL	AO	1236-2 (G-3)	0	С	С	FC	CS	CS - 19	STP-O-R-1.5	
MAIN FW CON	ITROL AO	V ТО	S/G E	3								PI SC/SO	2Y CS	CS - 19	STP-O-R-1.5 STP-O-R-1.5	
4271	2	N	Р	٨	4	CI	10	1026 0 (D 2)	<u> </u>	<u> </u>	0	510		<u>CS - 19</u>	STP-U-R-1.3	
4271	3	IN	в	А	4	GL	AU	1236-2 (D-3)	C	C	C	PI	2Y	CS - 19	STP-O-R-1.5 STP-O-R-1.5	
FW BYPASS C	ONTROL	AOV	4271	TO S/C	S A AOV							SC/SO STC	CS CS	CS - 19 CS - 19	STP-O-R-1.5 STP-O-R-1.5	
4272	3	Ν	В	А	4	GL	AO	1236-2 (H-3)	С	С	С	FC PI	CS 2Y	CS - 19	STP-O-R-1.5 STP-O-R-1.5	
FW BYPASS C	ONTROL	AOV	4272	TO S/C	G B AOV							SC/SO STC	ČS CS	CS - 19 CS - 19	STP-O-R-1.5 STP-O-R-1.5	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table

MS - MAIN STEAM

Valve ID						Valve	Actuator	Drawing		Positio	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
3410	2	Ν	В	А	6	GA	AO	1231 (l-5)	С	O/C	С	FC	CS		STP-O-2.6.1	
								()				PI	2Y		STP-O-2.6.1	
STEAM GENER	RATOR B	ATM	OSPH	IERIC F	RELIEF	VALVE						SC/SO	CS		STP-O-2.6.1	
3411	2	Ν	В	А	6	GA	AO	1231 (C-5)	С	O/C	С	FC	CS		STP-O-2.6.1	
								. ,				PI	2Y		STP-O-2.6.1	
STEAM GENER	RATOR B	ATM	OSPH	IERIC F	RELIEF	VALVE						SC/SO	CS		STP-O-2.6.1	
3412A	2	Ν	В	А	.5	GL	М	1231 (G-6)	0	С	NA	EC/EO	2Y		STP-O-2.9	
S/G B MS LOO	P HEADE		NER S			/LV										
3413A	2	N	В	Α	.5	GL	М	1231 (B-6)	0	С	NA	EC/EO	2Y		STP-O-2.9	
S/G A MS LOO	P HEADE	R IN	NER S	AMPL	E ISOL \	/LV										
3504A	2	Ν	В	А	6	GA	MO	1231 (F-4)	С	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	
								· · · ·				PI	MOV		MA-AA-723-300-1006	
MOV FOR SG I	B MAIN S	TEAN	/I SUP	PLY TO	D PAF03	(TURBINE	DRIVEN AFV	V PUMP)				SC/SO	2Y		STP-O-16-COMP-T	
3504B	3	Ν	С	А	6	СК	SA	1231 (E-4)	С	O/C	NA	CC	CM		STP-O-16-MSCV-T	CVCMP, 3504B
								. ,				CP	2Y		STP-O-16-COMP-T	
CHECK VALVE	FOR SG	BMA	AIN ST	TEAM 1		3 (TURBINE	DRIVEN AF	W PUMP)								
3505A	2	Ν	В	А	6	GA	MO	1231 (B-4)	С	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	
								. ,				PI	MOV		MA-AA-723-300-1006	
MOV FOR SG /	A MAIN S	TEAN	/I SUP	PLY T	D PAF03	3 (TURBINE	DRIVEN AFV	V PUMP)				SC/SO	2Y		STP-O-16-COMP-T	
3505B	3	Ν	С	А	6	СК	SA	1231 (D-4)	С	O/C	NA	CC	CM		STP-O-16-MSCV-T	CVCMP, 3505B
												CP	2Y		STP-O-16-COMP-T	
CHECK VALVE	FOR SG	AMA	AIN ST	TEAM 1		3 (TURBINE	DRIVEN AF	W PUMP)								
3506	2	Ν	В	А	6	GA	М	1231 (H-4)	0	O/C	NA	EC/EO	2Y		PLIS036	Radiography
S/G B MS INI E		VI V		RV/ 341	0											
3507	2		B	^	6	GA.	M	1221 (C 1)	0	0/0	ΝΙΔ		2∨		PI 15036	Padiography
5507	2	IN	D	A	0	GA	IVI	1231 (0-4)	0	0/0	INA	EC/EU	21		FLISUSO	Radiography
S/G A MS INLE			το Α	RV 341	1											
3508	2	N	C	Α	6	RV	SA	1231 (G-5)	С	0/C	NA	RT	5Y		STP-O-R-10.3	
	2		Ŭ	~	Ũ		0/1	1201 (0.0)	Ũ	0/0			01			
S/G B MS SAFE	ETY VLV															
3509	2	Ν	С	А	6	RV	SA	1231 (A-5)	С	O/C	NA	RT	5Y		STP-O-R-10.3	
S/G A MS SAFI	ETY VLV															
3510	2	Ν	С	А	6	RV	SA	1231 (G-6)	С	O/C	NA	RT	5Y		STP-O-R-10.3	
SIG D IVIS SAFI																

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

MS - MAIN STEAM

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
3511	2	Ν	С	А	6	RV	SA	1231 (A-6)	С	O/C	NA	RT	5Y		STP-O-R-10.3	
S/G A MS SAFET	Y VLV															
3512	2	Ν	С	А	6	RV	SA	1231 (G-7)	С	O/C	NA	RT	5Y		STP-O-R-10.3	
S/G B MS SAFET	Y VLV															
3513	2	Ν	С	А	6	RV	SA	1231 (A-7)	С	O/C	NA	RT	5Y		STP-O-R-10.3	
S/G A MS SAFET	Y VLV															
3514	2	Ν	С	А	6	RV	SA	1231 (G-8)	С	O/C	NA	RT	5Y		STP-O-R-10.3	
S/G B MS SAFET	Y VLV															
3515	2	Ν	С	А	6	RV	SA	1231 (A-7)	С	O/C	NA	RT	5Y		STP-O-R-10.3	
S/G A MS SAFET	Y VLV															
3516	2	Ν	В	А	30	CK	AO	1231 (G-10)	0	С	С	BDO	OP	00.40	Normal Ops	
MSIV B AOV-3516	\$											FC PI	2Y	CS - 16	STP-O-2.10.5 STP-O-2.10.5	
	,											SC/SO	CS	CS - 16	STP-O-2.10.5	
												STC	CS	CS - 16	STP-O-2.10.5	
3517	2	Ν	В	А	30	CK	AO	1231 (A-11)	0	С	С	BDO	OP	00.40	Normal Ops	
	-											FC	CS	CS - 16	STP-0-2.10.5	
MSIV A AUV-351												SC/SO	21 CS	CS - 16	STP-0-2.10.5	
												STC	CS	CS - 16	STP-O-2.10.5	
3518	3	Ν	С	А	30	СК	SA	1231 (G-10)	0	С	NA	BDO	OP		Normal Ops	
			// \/									CC	CS	CS - 17	STP-O-2.10.15	
3/G D MAIN 31 EF			/LV	•	20	01/	0.4	4004 (4 44)			NIA	550	0.0		Nerrorationa	
3519	3	N	C	А	30	CK	SA	1231 (A-11)	0	C	NA	BDO	OP CS	CS - 17	Normal Ops	
S/G A MAIN STEA		ск /	/I V									00	00	00-11	011-0-2.10.10	
3520	2	N	В	А	2	GL	М	1231 (F-10)	0	С	NA	EC/EO	2Y		STP-O-2.9	
INI FT ISOL VI V	ro s/g	B DF	RAIN/T	RAPS												
3521	2	N	В	A	2	GL	М	1231 (B-11)	0	С	NA	EC/EO	2Y		STP-O-2.9	
INLET ISOL VI V	TO S/G	A DF	RAIN/T	RAPS												
3652	3	N	B	A	3	GA	НО	1231 (D-2)	0	O/C	AI	SC/SO	Q		STP-O-16QT	skid-mounted
TURBINE DRIVEN	I AUX I	FW P	UMP -	TRIP T	HROTTL	E VALVE						SC/SO	Q		STP-0-16-COMP-T	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table

MS - MAIN STEAM

Valve ID Description	Class	s Aug	J. Cat.	A/P	Size	Valve Type	Actuator Type	Drawing & Coord	 Norma	- Positio Safety	on Fail-Safe	Required Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
3668	2	Ν	В	А	1	GL	М	1231 (G-9)	0	С	NA	EC/EO	2Y		STP-O-2.9	
S/G B MS INLET	BLOCK	K VLV	тоте	EMPE	RATURE	COMPENS	ATED SUPPO	ORTS								
3669	2	Ν	В	А	1	GL	М	1231 (B-9)	0	С	NA	EC/EO	2Y		STP-O-2.9	
S/G A MS INLET	BLOCK		TO TE	EMPER	RATURE	COMPENS	ATED SUPPO	ORTS								

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

NS - NUCLEAR SAMPLING

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	Aug	J. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
7448	2	Ν	А	Ρ	.375	GA	М	1278-1 (G-1)	С	С	NA	LJ-C	AJ		STP-O-23.45	
CONTAINMENT	T H2 MON		R A S/	AMPL	E INLET L	INE TEST C	ONN ISOL	VLV								
7452	2	Ν	Α	Ρ	.375	GA	М	1278-1 (H-2)	С	С	NA	LJ-C	AJ		STP-O-23.45	
CONTAINMENT			RS SA	MPL		N LINE TEST	CONN ISO	L VLV								
7456	2	Ν	Α	Ρ	.375	GA	М	1278-1 (l-1)	С	С	NA	LJ-C	AJ		STP-O-23.45	
CONTAINMENT	T H2 MON		R B S/	AMPL	E INLET L	INE TEST C	ONN ISOL	/LV								
921	2	Ν	Α	Α	.375	GA	SO	1278-1 (G-1)	С	С	С	FC	Q		STP-O-2.5.5	
												LJ-C	AJ		STP-O-23.45	
H2 MONITOR A	A INLET IS	SOLA	TION	VLV	SOV-921							PI	2Y		PTT-23.45/PT-2.5.5.1	
												PI	24M		STP-O-2.5.5	
												SC/SO	Q		STP-0-2.5.5	
												SIC	Q		STP-0-2.5.5	
												510	Q		STP-0-2.5.5	
922	2	Ν	A	A	.375	GA	SO	1278-1 (H-2)	С	С	С	FC	Q		STP-O-2.5.5	
												LJ-C	AJ		STP-0-23.45	
H2 MONITOR A	A RETURI	NISC		/ 50\	/-922								21		P11-23.45/P1-2.5.5.1	
												FI SC/SO	24101		STP-0-2.5.5	
												30/30 STC	Q		STP-0-2.5.5 STP 0 2 5 5	
												STO	Q		STP-0-2.5.5	
000	0		•	•	075	0.4		4070 4 (1 4)			-	510	<u>Q</u>		STF-0-2.5.5	
923	2	IN	A	А	.375	GA	50	1278-1 (J-1)	C	C	C	FC	Q		STP-0-2.5.5	
			TION									LJ-C	AJ		STP-U-23.45 DTT 22.45/DT 2.5.5.1	
H2 MONITOR B	SINLET	SOLA	ATION	VLV	500-923								21		STD O 2 5 5	
												50/SO	24101		STP-0-2.5.5 STP-0-2.5.5	
												STC	Ő		STP-0-2.5.5	
												STO	õ		STP-O-2.5.5	
924	2	N	Α	Α	.375	GA	SO	1278-1 (I-2)	С	С	С	FC	0		STP-0-2.5.5	
	2		~			O/(00	12/01(12)	Ũ	0	Ũ	LJ-C	ÂĴ		STP-O-23.45	
H2 MONITOR B		NISC		/ 50\	/-924							PI	2Y		PTT-23.45/PT-2.5.5.1	
												PI	24M		STP-O-2.5.5	
												SC/SO	Q		STP-O-2.5.5	
												STC	Q		STP-O-2.5.5	
												STO	Q		STP-O-2.5.5	
951	1	Y	В	NA	.375	GL	AO	1278-1 (E-8)	С	NA	С	FC	CS		STP-O-2.5.2	
								. ,				PI	2Y		STP-O-2.5.2	
PRESSURIZER	STEAM	SPA	CE SA	MPLE	E ISOL AO	V						SC/SO	CS	CS - 15	STP-O-2.5.2	
												STC	CS		STP-O-2.5.2	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table NS - NUCLEAR SAMPLING

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	Aug	J. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
951C	1	Ν	С	А	.375	СК	SA	1278-1 (E-8)	С	0	NA	BDC	CS		STP-O-2.10.16	Added per NRC GL
												CO	CS	CS - 15	STP-O-2.10.16	96-06
AOV-951 BYPA	SS CHEC	CK V	ALVE													
953	1	Y	В	NA	.375	GL	AO	1278-1 (D-8)	С	NA	С	FC	CS		STP-O-2.5.2	
												PI	2Y		STP-O-2.5.2	
PRESSURIZER	R LIQUID S	SPA	CE SA	MPLE	ISOL AOV	/						SC/SO	CS	CS - 15	STP-O-2.5.2	
												STC	CS		STP-0-2.5.2	
953C	1	Ν	С	А	.375	CK	SA	1278-1 (D-8)	С	0	NA	BDC	CS		STP-O-2.10.16	Added per NRC GL
												CO	CS	CS - 15	STP-O-2.10.16	96-06
AOV-953 BYPA	SS CHEC	CK V	ALVE													
955	1	Y	В	NA	.5	GL	AO	1278-1 (B-8)	С	NA	С	FC	CS		STP-O-2.5.2	
												PI	2Y		STP-O-2.5.2	
LOOP B HOT L	EG SAMF	PLE I	SOL A	OV								SC/SO	CS	CS - 15	STP-O-2.5.2	
												STC	CS		STP-O-2.5.2	
955C	1	Ν	С	А	.375	CK	SA	1278-1 (B-8)	С	0	NA	BDC	CS		STP-O-2.10.16	Added per NRC GL
	-		-						-	-		CO	CS	CS - 15	STP-O-2.10.16	96-06
AOV-955 BYPA	SS CHEC	CK V	ALVE													
956D	2	N	Α	Α	375	GI	М	1278-1 (B-9)	0	С	NA	EC/EO	2Y		STP-0-2.9	
	-					0L		12101(20)	Ũ	Ũ	101	LJ-C	A.J		STP-0-23 12C	
INLET BLOCK	VLV TO A	OV 9	966C (I	LOOP	B HOT LE	G SAMPLI	E CNMT ISO	L)				20 0			0.1. 0 20.120	
956E	2	N	Δ	Δ	375	GI	M	1278-1 (D-9)	0	C	NA	EC/EO	28		STP-0-2.9	
0002	2		~	~	.010	OL	IVI	1270-1 (D-3)	0	0	IN/A		A.I		STP-0-23 12B	
INLET BLOCK	VLV TO A	OV 9	966B (I	PRZR	LIQUID S/	AMPLE CN	MT ISOL)					20 0	7.0		011 0 20.120	
956F	2	N	Δ	Δ	375	GI	M	1278-1 (F-9)	0	C	NA	EC/EO	28		STP-0-2.9	
	2		~		.010	0L	ivi	12101(E0)	Ū	U		L.I-C	A.I		STP-0-23 12A	
INLET BLOCK	VLV TO A	OV 9	966A (I	PRZR	STEAM S	AMPLE CN	MT ISOL)					20 0	7.0			
966A	2	N	Α	Α	.375	GI	AO	1278-1 (F-9)	С	С	С	FC	0		STP-0-2.5.1	
	-					0L	710	12101(20)	Ũ	Ũ	Ũ	LJ-C	A.J		STP-O-23 12A	
PRESSURIZER	STEAM	SPA			CONTAIN							PI	2Y		STP-0-2.5.1	
TREGOUNIZEN												SC/SO	Q		STP-O-2.5.1	
												STC	Q		STP-O-2.5.1	
966B	2	N	Α	А	.375	GI	AO	1278-1 (D-9)	С	С	С	FC	0		STP-0-2 5 1	
0002	2		~	~	.010	0L	7.0	12101(0.0)	U	U	Ũ	LJ-C	A.J		STP-0-23 12B	
PRESSURIZER	י חוווסו ו	SPAC			CONTAIN	MENT ISO						PI	2Y		STP-0-2.5.1	
					CONTAIN							SC/SO	0		STP-0-2.5.1	
												STC	õ		STP-0-2.5.1	
													-			

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table

NS - NUCLEAR SAMPLING

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	Aug	J. Cat.	A/P	Size	Туре	Туре	& Coord	Normal	Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
966C	2	Ν	Α	А	.375	GA	AO	1278-1 (B-9)	С	С	С	FC	Q		STP-O-2.5.1	
												LJ-C	AJ		STP-O-23.12C	
LOOP B HOT LE	G SAMI	PLE (CONTA	INME	NT ISOL /	AOV						PI	2Y		STP-O-2.5.1	
												SC/SO	Q		STP-O-2.5.1	
												STC	Q		STP-O-2.5.1	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

PAS - POST ACC SAMP

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	a Aug	J. Cat.	A/P	Size	Туре	Туре	& Coord	Normal	Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
1723	2	Ν	В	А	3	DIA	AO	1279 (E-2)	0	С	С	FC PI	Q 2Y		STP-O-2.5 STP-O-2.5	
CONTAINMENT	SUMP	A SAN	MPLE	PUMP	DISCHA	RGE ISOL \	LV TO PAS	S WHUT				SC/SO STC	Q Q		STP-O-2.5 STP-O-2.5	
1728	2	Ν	В	А	3	DIA	AO	1279 (F-2)	0	С	С	FC Pl	Q 2Y		STP-O-2.5 STP-O-2.5	
CONTAINMENT	SUMP	A SAN	MPLE	PUMP	DISCHA	RGE ISOL \	LV TO PASS	S WHUT				SC/SO STC	Q Q		STP-O-2.5 STP-O-2.5	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

PWT - PRIMARY WATER TREATMENT

Valve ID						Valve	Actuator	Drawing	Position			Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
8418	2	Ν	А	А	2	GL	AO	1908-3 (A-4)	С	С	С	FC	Q A.I		STP-O-2.5.5 STP-O-23 39	
CONTAINMENT DEMIN WATER ISOL VLV AOV-8418												PI SC/SO	2Y Q		STP-O-2.5.5 STP-O-2.5.5	
												STC	Q		STP-O-2.5.5	
8419	2	Ν	AC	A	2	CK	SA	1908-3 (A-5)	С	O/C	NA	CC CO	AJ CM		STP-O-23.39 STP-O-2.9.1	CVCMP
CONDENSATE	or di W	ATE	r inle	ET CHE	ECK VLV	TO CONTA	INMENT (IN	LJ-C	AJ		STP-O-23.39					
8421R	2	Ν	С	А	.25	TRV	SA	1908-3 (A-5)	С	0	NA	RT	10Y		GMP-37-49-50X350/RV	Added per NRC GL 96-06
PENETRATION	P324 T⊢	IERM	IAL RE	ELIEF												
Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table RCDT - REACTOR COOLANT DRAIN TANK

Valve ID							Valve	Actuator	Drawing		Positi	on	Required				
Description	Clas	s Au	g. C	at.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
1003A	2	N	ŀ	Ą	А	3	DIA	AO	1272-2 (D-4)	O/C	С	С	FC	Q		STP-O-2.5	
	_		-	-					()		-	-	LJ-C	ÂĴ		STP-O-23.22	
RCDT OUTLET	ISOL V	ALVE	E AO	V-10	003A								PI	2Y		STP-O-2.5	
													SC/SO	Q		STP-O-2.5	
													STC	Q		STP-O-2.5	
1003B	2	Ν	A	4	А	3	DIA	AO	1272-2 (E-4)	O/C	С	С	FC	Q		STP-O-2.5	
													LJ-C	AJ		STP-O-23.22	
RCDT OUTLET	ISOL V	ALVE	E AO	V-10	003B								PI	2Y		STP-O-2.5	
													SC/SO	Q		STP-O-2.5	
													STC	Q		STP-O-2.5	
1655	2	Ν	A	4	А	.375	GL	М	1272-2 (B-2)	0	С	С	EC/EO	2Y		STP-O-2.9	
													LJ-C	AJ		STP-O-23.21	
RCDT OUTLET	ISOL VI	V TO) GA	AS A	NALY	ZER											
1709G	2	Ν	A	4	Ρ	.75	GA	М	1272-2 (E-3)	С	С	NA	LJ-C	AJ		STP-O-23.22	
RCDT OUTLET	LINE DI	RAIN	VLV	/													
1713	2	Ν	A	C	Ρ	1	СК	SA	1272-2 (A-3)	С	С	NA	LJ-C	AJ		STP-O-23.20	
N2 INLET CHEC		TO R	CDT	Γ													
1721	2	Ν	A	4	А	3	DIA	AO	1272-2 (D-3)	0	С	С	FC	Q		STP-O-2.5	
													LJ-C	AJ		STP-O-23.22	
RCDT OUTLET	ISOL V	ALVE	E AO'	V-17	721								PI	2Y		STP-O-2.5	
													SC/SO	Q		STP-O-2.5	
													STC	Q		STP-0-2.5	
1722	2	Ν	A	4	Ρ	4	DIA	М	1272-2 (D-3)	С	С	NA	LJ-C	AJ		STP-O-23.22	
REFUELING CA	ANAL DF	RAIN	ISOI	L VL	_	RCDT F	MP										
1786	2	Ν	A	4	А	1	DIA	AO	1272-2 (B-5)	0	С	С	FC	Q		STP-O-2.5	
													LJ-C	AJ		STP-O-23.20	
PRT RCDT ISOI	L TO VE	NT F	IEAD	DER	ISOL	VALVE	AOV-1786						PI	2Y		STP-O-2.5	
													SC/SO	Q		STP-O-2.5	
													STC	Q		STP-O-2.5	
1787	2	N	A	4	А	1	DIA	AO	1272-2 (B-5)	0	С	С	FC	Q		STP-O-2.5	
													LJ-C	AJ		STP-O-23.20	
PRT RCDT ISOI	L TO VE	NT F	IEAD	DER	ISOL	VALVE	AOV-1787						PI	2Y		STP-O-2.5	
													SC/SO	Q		STP-O-2.5	
													STC	Q		STP-O-2.5	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table

RCDT - REACTOR COOLANT DRAIN TANK

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Normal	Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
1789	2	Ν	А	А	.75	DIA	AO	1272-2 (B-5)	O/C	С	С	FC	Q		STP-O-2.5	
												LJ-C	AJ		STP-O-23.21	
RCDT OUTLET	ISOL AC	о тс	GAS	ANAL	YZER							PI	2Y		STP-O-2.5	
												SC/SO	Q		STP-O-2.5	
												STC	Q		STP-O-2.5	
1793	2	Ν	А	Ρ	1	DIA	М	1272-2 (A-3)	С	С	NA	LJ-C	AJ		STP-O-23.20	
N2 INLET ISOL	VLV TO	RCD ⁻	Г													

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table RCP - REACTOR COOLANT PRZR

Valve ID						Valve	Actuator	Drawing		Positio	n	Required				
Description	Class	Aug	Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
430	1	Ν	В	А	3	GL	AO	1258 (B-8)	С	O/C	С	FC FC	CS CS		STP-O-2.6.5 STP-O-2.6.5SD	
PRESSURIZER F	OWER	OPE	RATE	D RELI	EF VALVE							PI	2Y		STP-O-R-16.1	
												SC/SO	CS		STP-O-2.6.5	
												SC/SO	CS		STP-0-2.6.5SD	
												SIC			STP-0-2.0.5	
												STO	C3 CS		STP-0-2.6.5	
												STO	CS CS		STP-0-2.6.5	
431C	1	Ν	В	А	3	GL	AO	1258 (C-8)	С	O/C	С	FC	CS		STP-O-2.6.5	
								()				FC	CS		STP-O-2.6.5SD	
PRESSURIZER F	OWER	OPE	RATE	D RELI	EF VALVE							PI	2Y		STP-O-R-16.1	
												SC/SO	CS		STP-O-2.6.5	
												SC/SO	CS		STP-O-2.6.5SD	
												STC	CS		STP-O-2.6.5	
												SIC	CS		STP-0-2.6.5SD	
												SIO	CS		STP-0-2.6.5	
434	1	N	C	Δ	4	RV/	S۵	1258 (Δ_0)	C	0/0	ΝΔ	DI	22	\/R _ 02		
		1.1	0	Α	•	I X V	0A	1200 (A-0)	0	0/0		RT	R	VIX - 02	MET-049	
PRESSURIZER F	RELIEF	VLV 1	IO PR	ESSU	RIZER REL	IEF TANK	ζ.									
435	1	Ν	С	А	4	RV	SA	1258 (C-9)	С	O/C	NA	PI	2Y	VR - 02	CPI-LVDT-435	
								· · · ·				RT	R		MET-049	
PRESSURIZER F	RELIEF	VLV 1	ro pr	ESSU	RIZER REL	IEF TANK	<u> </u>									
508	2	Ν	А	А	2	DIA	AO	1258 (F-7)	С	С	С	FC	Q		STP-O-2.5	
												LJ-C	AJ		STP-O-23.3	
RMW TO CNMT I	SOL VL	V AC	V-508									PI	21		STP-0-2.5	
												SC/SU	Q		STP-0-2.5	
515	1	N	B	Δ	3	GA	MO	1258 (C_8)	0	0/0	ΔΙ				MA_AA_723_300_1006	
010	1	IN	D	~	0	0A	NIO	1200 (0-0)	0	0/0		PI	MOV		MA-AA-723-300-1000	
PRZR PORV BLC		/ мо	V-515									SC/SO	18M		STP-O-R-16.1	
516	1	Ν	В	А	3	GA	МО	1258 (B-8)	0	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	
								· · · ·				PI	MOV		MA-AA-723-300-1006	
PRZR PORV BLC	OCK VL	/ MO	V-516									SC/SO	18M		STP-O-R-16.1	
528	2	Ν	AC	A	2	CK	SA	1258 (E-9)	С	С	NA	BDO	CM		S-2.3A	CVCMP
												CC	AJ		STP-O-23.2	
N2 INLET CHECK	K VLV T	O PR	ESSU	RIZER	RELIEF T	ANK						LJ-C	AJ		STP-O-23.2	
529	2	Ν	AC	А	2	CK	SA	1258 (F-9)	С	O/C	NA	CC	AJ		STP-O-23.3	CVCMP
												CO	CM		STP-O-2.9.1	
RMW PUMP DISC	CHARG	E CH	ECK \	/LV TC	PRT (IN C	CNMT)						LJ-C	AJ		STP-0-23.3	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table RCP - REACTOR COOLANT PRZR

Valve ID						Valve	Actuator	Drawing		Positio	on	Required				
Description	Clas	s Au	ig. Cat	. A/P	Size	Туре	Туре	& Coord	Normal	Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
539	2	N	A	А	.375	GL	AO	1258 (E-7)	С	С	С	FC LJ-C	Q AJ		STP-O-2.5 STP-O-23.1	
PRT SAMPLE	ISOL AO	V ТС) GAS	ANAL`	YZER (CN	IMT ISOL)						PI SC/SO STC	2Y Q Q		STP-O-2.5 STP-O-2.5 STP-O-2.5	
546	2	N	А	А	.375	GL	М	1258 (E-8)	0	С	NA	EC/EO LJ-C	2Y AJ		STP-O-2.9 STP-O-23.1	
PRT SAMPLE	ISOL VL	v то	GAS	ANALY	ZER (OU	TSIDE CNM	Т)									
547	2	N	А	Ρ	.75	GL	М	1258 (E-8)	LC	С	NA	LJ-C	AJ		STP-O-23.2	
N2 INLET ISOL		PRE	ESSUF	RIZER	RELIEF T	ANK (OUTSI	IDE CNMT)									
568R	2	N	С	А	.75	TRV	SA	1258 (F-9)	С	0	NA	RT	10Y		GMP-37-49-50X350/RV	Added per NRC GL 96-06
THERMAL REL	LIEF FOF		ING B	ETWE	EN RMW	DISCH V-50	8 AND PRT	V-548								

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table RCS - REACTOR COOLANT SYSTEM

Valve ID						Valve	Actuator	Drawing		Positio	on	Required				
Description	Class	a Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
590	2	Ν	В	А	1	GL	SO	1260 (J-5)	С	O/C	С	FC	CS	CS - 01	STP-O-R-16	
												PI	2Y		STP-O-R-16	
REACTOR HE/	AD VENT	OUTE	ER SO	LENO	D OPER	ATED VAL	/E					SC/SO	CS	CS - 01	STP-O-R-16	
												STC	CS	CS - 01	STP-O-R-16	
												STO	CS	CS - 01	STP-O-R-16	
591	2	Ν	В	А	1	GL	SO	1260 (J-5)	С	O/C	С	FC	CS	CS - 01	STP-O-R-16	
								· · · ·				PI	2Y		STP-O-R-16	
REACTOR HE	AD VENT	OUTE	R SO				/F					SC/SO	CS	CS - 01	STP-O-R-16	
							_					STC	CS	CS - 01	STP-O-R-16	
												STO	CS	CS - 01	STP-O-R-16	
592	2	Ν	В	А	1	GL	SO	1260 (J-5)	С	O/C	С	FC	CS	CS - 01	STP-O-R-16	
								· · · ·				PI	2Y		STP-O-R-16	
REACTOR HE	AD VENT	INNE	R SOI	FNOI		ATED VALV	F					SC/SO	CS	CS - 01	STP-O-R-16	
							_					STC	CS	CS - 01	STP-O-R-16	
												STO	CS	CS - 01	STP-O-R-16	
593	2	Ν	В	А	1	GL	SO	1260 (J-5)	С	O/C	С	FC	CS	CS - 01	STP-O-R-16	
												PI	2Y		STP-O-R-16	
REACTOR HE	AD VENT	INNE	R SOI	ENOI			F					SC/SO	CS	CS - 01	STP-O-R-16	
												STC	ĊS	CS - 01	STP-O-R-16	
												STO	CS	CS - 01	STP-O-R-16	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

RCSOP - RCS OVERPRESSURE PROTECTION

Valve ID						Valve	Actuator	Drawing		Positio	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
8606A	3	N	AC	A TT CU		СК	SA	1263 (B-4)	С	С	NA	BDO CC	Q R 2V	ROJ - 01	S-29.2 STP-O-8.2 STP-O-8.2	
		N				CK	54	1062 (C 4)	<u> </u>	<u> </u>	NIA		21		S1F-0-0.2	
	о О 11 4 1 4 4		AC	А -т оц		CK	54	1203 (G-4)	C	C	NA		R	ROJ - 01	S-29.2 STP-O-8.2	
NITROGEN AC	CUMULA	IOR	BINL	= I CH	ECK VLV								ZŤ		51P-0-0.2	
8608A	3	Ν	С	A	.75	RV	SA	1263 (C-4)	С	O/C	NA	RT	10Y		GMP-37-15-824/RV	
NITROGEN AC	CUMULA	TOR	A REL	IEF V	LV											
8608B	3	Ν	С	А	.75	RV	SA	1263 (G-4)	С	O/C	NA	RT	10Y		GMP-37-15-824/RV	
NITROGEN AC	CUMULA	TOR	B REL	IEF V	LV											
8615A	3	Ν	С	А	1	RV	SA	1263 (B-6)	С	O/C	NA	RT	10Y		GMP-37-15-125/RV	
N2 INLET TO N	12 SURGE		IK A R	ELIEF	VLV (A T	RAIN)										
8615B	3	Ν	С	А	1	RV	SA	1263 (F-6)	С	O/C	NA	RT	10Y		GMP-37-15-125/RV	
N2 INLET TO N	12 SURGE		IK B R	ELIEF	VLV (B T	RAIN)										
8616A	3	Ν	В	А	.75	3W	SO	1263 (B-7)	С	0	Al	SC/SO SC/SO	CS CS	CS - 02	STP-O-2.6.5SD STP-O-2.6.5	TJ-06 - Satisfied by
ACCUM TO SU	RGE TAN	IK VL	V SO	/-8616	βA							STO STO	CS CS		STP-O-2.6.5SD STP-O-2.6.5	
8616B	3	Ν	В	А	.75	3W	SO	1263 (G-7)	С	0	Al	SC/SO SC/SO	CS CS	CS - 02	STP-O-2.6.5SD STP-O-2.6.5	T.I-06 - Satisfied by
ACCUM TO SU	RGE TAN	IK VL	V SO	/-8616	ЪВ							STO	CS CS		STP-O-2.6.5SD STP-O-2.6.5	
8619A	3	Ν	В	А	1	3W	SO	1263 (C-9)	С	O/C	AI	SC/SO	CS	CS - 02	STP-O-2.6.5SD	
N2 ARMING VL	V SOV-8	619A										SC/SO STC	CS CS		STP-O-2.6.5 STP-O-2.6.5SD	IJ-06 - Satisfied by
												STO	CS		STP-O-2.6.5 STP-O-2.6.5SD	
												STO	CS		STP-0-2.6.5	
8619B	3	Ν	В	A	1	3W	SO	1263 (G-9)	С	O/C	AI	SC/SO	CS	CS - 02	STP-0-2.6.5SD	TIOS Satisfied by
		210B										STC	CS CS		STP-0-2.0.5 STP-0-2.6.5SD	1J-00 - Satisfied by
INZ AINING VL		0190										STC	CS		STP-0-2.6.5	
												STO	CS		STP-O-2.6.5SD	
												STO	CS		STP-O-2.6.5	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

RCSOP - RCS OVERPRESSURE PROTECTION

Valve ID						Valve	Actuator	Drawing		- Positio	on	Required				
Description	Class	a Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Normal	Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
8620A	NC	Ν	В	А	.75	3W	SO	1263 (C-10)	0	С	Al	SC/SO SC/SO	CS CS	CS - 02	STP-O-2.6.5SD STP-O-2.6.5	TJ-06 - Satisfied by
IA SOV TO PCV	/ 430 (PC	DRV A	ACTUA	TION	A TRAIN)							STC STC	CS CS		STP-O-2.6.5SD STP-O-2.6.5	
8620B	NC	Ν	В	А	.75	3W	SO	1263 (H-10)	0	С	AI	SC/SO SC/SO	CS CS	CS - 02	STP-O-2.6.5SD STP-O-2.6.5	TJ-06 - Satisfied by
IA SOV TO PCV	/ 431C (F	PORV	ACTL	JATION	I B TRAIN	N)						STC STC	CS CS		STP-O-2.6.5SD STP-O-2.6.5	
8630A	3	Ν	С	А	1	СК	SA	1263 (C-9)	0	O/C	NA	CC CO	CS CS	CS - 02 CS - 02	STP-O-2.6.5 STP-O-2.6.5	TJ-06 - Satisfied by
NITROGEN INL	ET CHE	CK VI	V TO	PVC 4	30 (A TR	AIN)										-
8630B	3	Ν	С	А	1	СК	SA	1263 (G-9)	0	O/C	NA	CC CO	CS CS	CS - 02 CS - 02	STP-O-2.6.5 STP-O-2.6.5	TJ-06 - Satisfied by
NITROGEN INL	ET CHE	CK VI	_V TO	PCV 4	31C (B TI	RAIN)										-

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

RHR - RESIDUAL HEAT REMOVAL

Valve ID						Valve	Actuator	Drawing		Positio	n	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
1813A	2	Ν	А	Ρ	6	GA	MO	1247 (E-3)	С	С	AI	LJ-C Pl	AJ 2Y		STP-O-23.5A STP-O-2.4	
REACTOR COC VALVE	LANT DI	RAIN	TANK	PUM	P SUCTIO	ON FROM C	ONTAINMEN	NT SUMP B M	IOTOR (OPERATE	ED					
1813B	2	Ν	А	Ρ	6	GA	MO	1247 (B-4)	С	С	AI	LJ-C Pl	AJ 2Y		STP-O-23.5B STP-O-2.4	
REACTOR COC VALVE	LANT DI	RAIN	TANK	PUM	P SUCTIO	ON FROM C	ONTAINMEN	NT SUMP B N	IOTOR (OPERATE	Đ					
624	2	Y	В	Ρ	8	BTF	AO	1247 (J-7)	0	0	0	SC/SO	R	ROJ - 10	CPI-CV-624	
RHR HEAT EXC	HANGE	RВF	LOW	CONT	ROL											
625	2	Y	В	Ρ	8	BTF	AO	1247 (I-8)	0	0	0	SC/SO	R	ROJ - 10	CPI-CV-625	
RHR HEAT EXC	HANGE	R A F	LOW	CONT	ROL											
626	2	Y	В	A	6	BTF	AO	1247 (H-7)	С	С	С	FC SC/SO	Q Q		STP-O-2.5 STP-O-2.5	
RHR HEAT EXC	HANGE	R BYI	PASS													
686G	2	N	С	A	0.25		SA	1247 (D-8)	С	O/C	NA	RT	10Y		GMP-37-55-135/RV	Added per PCR 2008-0015
			<u>1951</u>		RELIEF V		C 4	4047 (0.0)	0	0/0	NIA	DT	101/			
			U JPSTF	A REAM	RELIFE V		5A	1247 (C-6)	C	0/0	INA	КI	101		GMP-37-33-133/RV	2008-0015
6861	2	N	<u>с С</u>	A	0.25	TRV	SA	1247 (D-8)	С	0/C	NA	RT	10Y		GMP-37-55-135/RV	Added per PCR
RHR PUMP A R	ECIRC L			ISTRE	AM RELI	EF VALVE		(_ 0)	C	0,0						2008-0015
686J	2	Ν	С	А	0.25	TRV	SA	1247 (C-8)	С	O/C	NA	RT	10Y		GMP-37-55-135/RV	Added per PCR 2008-0015
RHR PUMP B R	ECIRC L	INE D	DOWN	ISTRE	AM RELI	EF VALVE										
697A	2	Ν	С	A	8	СК	SA	1247 (F-9)	С	O/C	NA	CC CC	Q 2Y		STP-O-2.2QB STP-O-2.2-COMP-B	
RHR HEAT EXC	HANGE	RAC	UTLE	T CHE	ECK VLV							CO	R	ROJ - 02	STP-O-2.10.2	
697B	2	Ν	С	A	8	СК	SA	1247 (B-9)	С	O/C	NA	CC CC	Q 2Y		STP-O-2.2QA STP-O-2.2-COMP-A	
RHR HEAT EXC	HANGE	RBC	UTLE	T CHE	ECK VLV							CO CO	Q 2Y		STP-O-2.2QB STP-O-2.2-COMP-B	
700	1	Ν	A	A	10	GA	MO	1247 (G-1)	С	O/C	AI	DIAG LT-X	MOV 2Y		MA-AA-723-300-1006 STP-O-8.0	High Risk MOV
RHR PUMP SU	CTION FI	ROM	LOOF	P A HC	T LEG M	OV-700						PI SC/SO	MOV CS	CS - 03	MA-AA-723-300-1006 STP-O-2.4.1	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table RHR - RESIDUAL HEAT REMOVAL

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
701	1	N	A	А	10	GA	МО	1247 (G-2)	С	O/C	AI	DIAG LT-X	MOV 2Y		MA-AA-723-300-1006 STP-O-8.0	High Risk MOV
RHR PUMP SUG	CTION F	ROM	LOOF	P A HO	T LEG M	OV-701						PI SC/SO	MOV CS	CS - 03	MA-AA-723-300-1006 STP-O-2.4.1	
704A	2	N	В	A	10	GA	MO	1247 (D-4)	0	O/C	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
RESIDUAL HEA	I REMO	VAL	PUMP	A SUC	CTION M	OTOR OPE	RATED VAL	VE				50/50	18M		STP-0-2.4.1	
	2 T REMO	N	B	A	10 TION M			1247 (C-4)	0	O/C	AI	DIAG PI SC/SO	MOV MOV 18M		MA-AA-723-300-1006 MA-AA-723-300-1006 STP-O-2.4.1	
		VAL		<u>ь зос</u>					<u> </u>	0/0	NIA	00/00	000	<u> </u>	STD 0 2 24	
RHR PUMP A D	Z ISCHAR	™ GE C	HECK		0	CK	54	1247 (F-0)	C	0/0	NA	CO CO	Q 2Y	CS - 00	STP-0-2.2QA STP-0-2.2QA STP-0-2.2-COMP-A	
710B	2	Ν	С	А	8	СК	SA	1247 (B-6)	С	O/C	NA	CC	CS	CS - 06	STP-O-2.2A	
RHR PUMP B D	ISCHAR	GE C	HECK	VLV								CO CO	Q 2Y		STP-O-2.2QB STP-O-2.2-COMP-B	
720	1	Ν	A	А	10	GA	MO	1247 (I-2)	С	O/C	AI	DIAG LT-X	MOV 2Y		MA-AA-723-300-1006 STP-O-8.0	High Risk MOV
RHR PUMP DIS	CHARGE	Е ТО	LOOP	B COI	D LEG N	/IOV-720						PI SC/SO	MOV CS	CS - 03	MA-AA-723-300-1006 STP-O-2.4.1	
721	1	Ν	А	А	10	GA	MO	1247 (I-1)	С	O/C	AI	DIAG	MOV 2Y		MA-AA-723-300-1006 STP-O-8.0	High Risk MOV
RHR PUMP DIS	CHARGE	Е ТО	LOOP	B COI		/IOV-721						PI	MOV		MA-AA-723-300-1006	
_					-	-						SC/SO	CS	CS - 03	STP-O-2.4.1	
850A	2	Ν	В	А	10	GA	МО	1247 (F-4)	С	O/C	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	High Risk MOV
RHR PUMP SUG	CTION F	ROM	CNMT	L SUMI	P B MOV	-850A						SC/SO	CS	CS - 13	STP-O-2.4.1	
850B	2	Ν	В	А	10	GA	MO	1247 (B-4)	С	O/C	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	High Risk MOV
RHR PUMP MO	TOR OPI	ERA	ED SI	UCTIO	N FROM	CNMT SUM	/IP B					SC/SO	CS	CS - 13	STP-O-2.4.1	
851A	2	Ν	В	Ρ	10	GA	МО	1247 (B-1)	0	0		PI PI	2Y 2Y		STP-O-2.3.3 A-3.1	
RHR PUMP MO	TOR OPI	ERA	ED SI	UCTIO	N FROM	CNMT SUM	/IP B									
851B	2	Ν	В	Ρ	10	GA	МО	1247 (B-2)	0	0		PI PI	2Y 2Y		STP-O-2.3.3 A-3.1	
RHR PUMP MO	TOR OPI	ERA	FED SI	UCTIO	N FROM	CNMT SUM	/IP B								-	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table RHR - RESIDUAL HEAT REMOVAL

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Normal	Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
852A	1	Ν	А	А	6	GA	MO	1260 (F-4)	С	O/C	AI	DIAG LT-X	MOV 2Y		MA-AA-723-300-1006 STP-O-8.0	
RHR PUMP DIS	SCHARGE	то	REAC	TOR \	ESSEL I	DELUGE MO	DV-852A					PI SC/SO SC/SO	MOV 18M 18M		MA-AA-723-300-1006 STP-O-2.4 STP-O-2.10.2	
852B	1	N	A	Α	6	GA	MO	1260 (F-4)	С	O/C	AI	DIAG LT-X	MOV 2Y		MA-AA-723-300-1006 STP-O-8.0	
RHR PUMP DIS	SCHARGE	то	REAC	TOR	ESSEL I	DELUGE MC	DV-852B					SC/SO SC/SO	18M 18M		MA-AA-723-300-1006 STP-O-2.4 STP-O-2.10.2	
853A		N	AC		6		SA	1260 (F-5)	С	O/C	NA	CC CO	R R R	ROJ - 03 ROJ - 03	STP-O-8.0 STP-O-2.10.2 STP-O-8.0	
853B		101 N			ESSEL C			1260 (E 5)	C	0/0	ΝΔ	CC			STP 0 8 0	
								1200 (F-3)	C	0/0	INA	CO LT-XT	R	ROJ - 03 ROJ - 03	STP-0-8.0 STP-0-2.10.2 STP-0-8.0	
854	2	N	C		10		SL SA	1247 (G_4)	C	0/0	ΝΔ	00	CM	RO I - 07	PI 19037	
		- NI		ח סט	IMDS	ÖK	54	1247 (0-4)	U	0/0		CO D&I	R 15V	ROJ - 07	STP-O-2.10.2	
856			8 R		10	GA	MO	1247 (G-5)	0	0/0	ΔΙ		MOV		MA_AA_723_300_1006	Treat as High Risk
						GA DWCT	WO	1247 (G-3)	0	0/0	Ai	PI	MOV	CS 21	MA-AA-723-300-1000 MA-AA-723-300-1006	MOV
RHR PUMP MO			IED SI			RWSI	140	4047 (0.44)	0	0/0	A 1	30/30		03-21	31F-U-2.4	
85/A	2	N	В	А	0	GA	MO	1247 (C-11)	C	0/0	AI	DIAG	MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
RHR PUMP DIS	CHARGE	МО	TOR)PER/	ATED VA	LVE TO SAF	ETY INJEC	TION PUMP S	UCTION			SC/SO SC/SO	18M 18M		STP-O-2.2-COMP-A STP-O-2.3	
857B	2	Ν	В	А	6	GA	МО	1247 (B-11)	С	O/C	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	Treat as High Risk MOV
RHR PUMP MO	TOR OPE	ERA	TED D	ISCHA	RGE TO	SAFETY IN	JECTION PL	JMP SUCTION	N			SC/SO SC/SO	Q 2Y		STP-O-2.2QB STP-O-2.2-COMP-B	
857C	2	Ν	В	A	6	GA	МО	1247 (B-11)	С	O/C	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
RHR PUMP MO	TOR OPE	ERA	TED D	ISCHA	RGE TO	SAFETY IN	JECTION PL	JMP SUCTION	N			SC/SO SC/SO	18M 2Y		STP-O-2.3 STP-O-2.2-COMP-A	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

SA - SERVICE AIR

Valve ID Description	Class	s Au	g. Cat.	. A /	P S	Size	Valve Type	Actuator Type	Drawing & Coord	Norma	- Positi I Safety	on Fail-Safe	Required Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
7141	2	Ν	А	Ρ		2	GA	М	1886-2 (C-3)	С	С		LJ-C	AJ		STP-O-23.33	
SA MIDDLE ISC		-0 C	ΟΝΤΑΙ	NME	ENT (II	NTER E	BLDG)										
7226	2	Ν	AC	Ρ		2	CK	SA	1886-2 (C-5)	С	С	NA	LJ-C	AJ		STP-O-23.33	
SERVICE AIR T	O CON	ΓΑΙΝΙ	MENT	CHE	CK V	ALVE											

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

SAFW - STANDBY AUXILIARY FEEDWATER

Valve ID	•	-			•	Valve	Actuator	Drawing		Positio	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
9629A		N	B	A / 0620	4	GA	МО	1238 (B-3)	С	0	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006 STP O 36 COMP C	
SAFW PUMP C	, <u>soc no</u>			/-9029	A	~	MO	4000 (1.0)		0	A 1	50/30	21		STF-0-30-COMF-C	
9029D			B	A / 0620	4 D	GA	MO	1238 (1-3)	U	0	AI	PI SC/SO	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006 STP-0-36-COMP-D	
SAFW PUMPL	0 500 110			/-9029	D 2	01/	0.1	1000 (D. 0)	0	0/0	NIA	00/00	21			0) (0) (0)
					3	CK	SA	1238 (B-6)	C	0/0	NA	CO D	2Y CM		STP-0-5 STP-0-36-COMP-C GMP-37-08-1500/3/CV	CVCMP
		N			2	CK	64	1000 (1.6)	<u> </u>	0/0	NIA	BDC	CM		STD O 5	
					VE	UK	54	1238 (1-0)	U	0/0	NA	CO D&I	2Y CM		STP-0-5 STP-0-36-COMP-D GMP-37-08-1500/3/CV	CVCMP
9701A	2	N	B		3	CI	MO	1228 (P. 7)	0	0	Δ1		MOV		MA AA 723 300 1006	Troat as High Rick
5/01A	3	IN	D	A	5	GL	IVIO	1230 (B-7)	0	0	AI	PI	MOV		MA-AA-723-300-1000 MA-AA-723-300-1006	MOV
SAFW PUMP C	DISCHA	RGE	VLV N	10V-97	701A							SC/SO SC/SO	Q Q		STP-O-36QC STP-O-36-COMP-C	mot
9701B	3	Ν	В	А	3	GL	MO	1238 (I-7)	0	0	Al	DIAG	MOV		MA-AA-723-300-1006	Treat as High Risk
												PI	MOV		MA-AA-723-300-1006	MOV
SAFW PUMP D	DISCHA	RGE	VLV N	10V-97	701B							SC/SO SC/SO	Q Q		STP-O-36Q-D STP-O-36-COMP-D	
9703A	3	Ν	В	А	3	GL	MO	1238 (F-8)	С	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	
0741000												PI	MOV		MA-AA-723-300-1006	
STANDBY AUX	K FW PUN	1P CF	rosso	OVER	VLV MO	V-9703A						SC/SO	2Y		STP-O-36-COMP-C	
9703B	3	Ν	В	А	3	GL	MO	1238 (F-8)	С	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	
						107000							MOV		MA-AA-723-300-1006	
STANDBY AUX			10550	JVER		V-9703B		1000 (5.0)	-	0/0		30/30	21			0.40145
9704A	2	N	BC	A	3	SCK	MO	1238 (B-9)	C	0/0	AI	BDC	CM		Rep Task P501364	CVCMP
			۸/۸ T E I									180	CM		GMP-37-08-1500/3/GSV	
STANDBT AUX				R F UW			AILD STOP	CHECK ISOL	AHON	VALVE		DIAG	MOV		MA-AA-723-300-1006	
												PI	MOV		MA-AA-723-300-1006	
												SC/SO	2Y		STP-O-36-COMP-C	
9704B	2	Ν	BC	А	3	SCK	MO	1238 (I-9)	С	O/C	AI	BDC	СМ		Rep Task P501366	CVCMP
												CO	2Y		STP-O-36-COMP-D	
STANDBY AUX	K FW PUN	1P D I	ISOL \	/LV MO	OV-9704	В						D&I	CM		GMP-37-08-1500/3/GSV	
												DIAG	MOV		MA-AA-723-300-1006	
												21 02/32			NIA-AA-723-300-1006 STP-0-36-00MP-D	
												30/30	21		511-0-30-COIVIF-D	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

SAFW - STANDBY AUXILIARY FEEDWATER

Valve ID						Valve	Actuator	Drawing		Positio	on	Required				
Description	Class	Aug	J. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
9705A	2	Ν	С	A	3	CK	SA	1238 (B-10)	С	O/C	NA	CC CO	CM 2Y		STP-O-36-COMP-C STP-O-36-COMP-C	CVCMP
SAFW PUMP C	DISC CH	HECK	(VALV	'E TO	SG "A"											
9705B	2	Ν	С	А	3	СК	SA	1238 (I-10)	С	O/C	NA	CC CO	CM 2Y		STP-O-36-COMP-D STP-O-36-COMP-D	CVCMP
SAFW PUMP D	DISC CH	HECK	(VALV	'E TO	SG "B"											
9708A	3	Ν	С	А	4	СК	SA	1238 (H-1)	С	С	NA	CC CC	18M Q		STP-O-36-COMP-C STP-O-36QC	
SAFW PUMP DI	WATEF	STC	RAGE	TAN	K CHECK	VLV TO ST	ANDBY AUX	K FW PUMP C	;			CO CP	18M Q	ROJ - 08	STP-O-36-COMP-C STP-O-36QC	
9708B	3	Ν	С	А	4	CK	SA	1238 (C-2)	С	С	NA	CC CC	18M Q		STP-O-36-COMP-D STP-O-36Q-D	
SAFW PUMP DI	WATER	STC	RAGE	TAN	< CHECK	VLV TO ST	ANDBY AUX	K FW PUMP D)			CO CP	18M Q	ROJ - 08	STP-O-36-COMP-D STP-O-36Q-D	
9709A	3	Ν	С	А	1	RV	SA	1238 (B-3)	С	O/C	NA	RT	10Y		GMP-37-06-150/RV3	
STANDBY AUX		IP C	SUCT	ION LI	NE RELI	EF VLV										
9709B	3	Ν	С	А	1	RV	SA	1238 (I-3)	С	O/C	NA	RT	10Y		GMP-37-06-150/RV3	
STANDBY AUX I	W PUN	/P D	SUCTI	ION LI	NE RELI	EF VLV										
9710A	3	Ν	В	Α	1.5	GL	AO	1238 (C-7)	С	O/C	0	FO	Q		STP-O-36QC	
												FO	Q		STP-O-36-COMP-C	
STANDBY AUX I	-W PUN	IP C	RECIE	RCULA	ATION VL	V AOV-9710	A						21		STP-0-36-COMP-C	
												SC/SO	Q		STP-0-36-COMP-C	
												STO	õ		STP-0-36QC	
												STO	Q		STP-O-36-COMP-C	
9710B	3	Ν	В	А	1.5	GI	AO	1238 (H-7)	С	0/C	0	FO	0		STP-0-36Q-D	
	-		_						-		-	FO	Q		STP-O-36-COMP-D	
STANDBY AUX F	W PUN	/P D	RECIE	RCULA	TION VL	V AOV-9710	В					PI	2Y		STP-O-36-COMP-D	
							-					SC/SO	Q		STP-O-36Q-D	
												SC/SO	Q		STP-O-36-COMP-D	
												STO	Q		STP-O-36Q-D	
												STO	Q		STP-O-36-COMP-D	
9721A	3	N	С	Α	.5	CK	SA	1238 (C-3)	С	O/C	NA	CC	Q		STP-O-36QC	
												CC	Q		STP-O-36-COMP-C	
CONDENSATE F	PRESSL	JRIZA	ATION	CHEC	K VALVE	E TO SAFW I	PUMP "C"					CO	Q		STP-O-36QC	
												CO	Q		STP-O-36-COMP-C	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

SAFW - STANDBY AUXILIARY FEEDWATER

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
9721B	3	Ν	С	А	.5	СК	SA	1238 (G-3)	С	O/C	NA	CC CC	Q Q		STP-O-36Q-D STP-O-36-COMP-D	
CONDENSATE	PRESSU	RIZA	TION	CHECI	(VALV	E TO SAFW	PUMP "d"					CO CO	Q Q		STP-O-36Q-D STP-O-36-COMP-D	
9746	3	Ν	В	А	3	GA	MO	1238 (I-8)	0	O/C	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
EMERGENCY D	ISCHAR	GE N	IOV F	OR PA	=01B (S	AFW PUMP	D)					SC/SO	2Y		STP-O-36-COMP-D	
9781	SSC	Ν	С	A	4	CK	SA	1238 (E-2)	С	0	NA	BDC CO	18M 18M	ROJ - 08	STP-O-2.9 STP-O-36-COMP-D	
DI WATER TAN	K SUPPL	Y CH	IECK \	VIv								CO	18M	ROJ - 08	STP-O-36-COMP-C	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

SFPC - SPENT FUEL POOL COOLING

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	a Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
782	3	Ν	В	А	4	GA	М	1248 (D-1)	С	0	NA	EC/EO	2Y		STP-O-33-COMP-B	
LOW SUCTION	ISOL VI	V ТО	SPEN	IT FUE	L POOL	. RECIRC PU	IMPS (ALT)									
8152	2	Ν	А	Ρ	1	GA	М	1248 (C-5)	С	С	NA	LJ-TS	AJ		STP-O-23.54	
PRESSURE TE	ST VAL	/Е ТО	DOUI	BLE O-	RING BI	LIND FLANG	E SAC05									
8614	3	Ν	В	А	4	GA	М	1248 (H-8)	0	O/C	NA	EC/EO	2Y		STP-O-33-COMP-B	
SPENT FUEL P	OOL HE	AT EX	KCHAN	GER /	A OUTLI	ET ISOL VLV	,									
8654	3	Ν	В	А	6	GA	М	1248 (H-2)	0	O/C	NA	EC EO	2Y Q		STP-O-33-COMP-B STP-O-33A	
SUCTION BLOG	CK VLV	TO SF	PENT F	UEL P	OOL RE	ECIRC PUMF	ΡA									
8655	SSC	C N	С	А	4	СК	SA	1248 (H-4)	С	O/C	NA	CC CO	QQ		STP-O-33B STP-O-33A	
SPENT FUEL P	OOL RE	CIRC	PUMF	P A DIS	CHARG	E CHECK V	LV									
8658	3	Ν	С	А	6	СК	SA	1248 (I-4)	С	O/C	NA	CC CO	Q Q		STP-O-33A STP-O-33B	
SPENT FUEL P	OOL RE	CIRC	PUMF	P B DIS	CHARG	E CHECK VI	LV									

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table SGBD - S/G BLOWDOWN

Valve ID						Valve	Actuator	Drawing		- Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
5735	2	Ν	А	А	.75	GA	AO	1277-1 (A-4)	0	С	С	FC	Q		STP-O-2.5.6	
												LT-X	2Y		STP-O-8.10	
STEAM GENER	RATOR A	BLOV	NDON	VN SAN	MPLE AI	R OPERATE	ED ISOLATIO	ON VALVE				PI	2Y		STP-O-2.5.6	
												SC/SO	Q		STP-O-2.5.6	
												STC	Q		STP-O-2.5.6	
5736	2	Ν	А	А	.75	GA	AO	1277-1 (F-4)	0	С	С	FC	Q		STP-O-2.5.6	
								· · · ·				LT-X	2Y		STP-O-8.10	
STEAM GEN B		OWN :	SAMP	I F ISC		OV-5736						PI	2Y		STP-O-2.5.6	
												SC/SO	Q		STP-O-2.5.6	
												STC	Q		STP-O-2.5.6	
5737	2	Ν	А	А	2	GA	AO	1277-1 (H-5)	0	С	С	FC	Q		STP-O-2.5.6	
								()				LT-X	2Y		STP-O-8.9	
STEAM GENER	RATOR B	BI OV	NDON	VN ISO	ATION	AIR OPERA		=				PI	2Y		STP-O-2.5.6	
0.12, 02.12.								-				SC/SO	Q		STP-O-2.5.6	
												STC	Q		STP-O-2.5.6	
5738	2	Ν	А	А	2	GA	AO	1277-1 (C-5)	0	С	С	FC	Q		STP-O-2.5.6	
								()				LT-X	2Y		STP-O-8.9	
STEAM GEN A) WN	ISOL V		℃-5738							PI	2Y		STP-O-2.5.6	
OTE, UN OENT	5201100		COL									SC/SO	Q		STP-O-2.5.6	
												STC	Q		STP-O-2.5.6	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID					<u>.</u>	Valve	Actuator	Drawing		Positio	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Гуре	Гуре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
1815A	2	Ν	В	А	4	GA	МО	1262-1 (D-4)	0	0	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
SI PUMP C SU	CTION V	ALVE										SC/SO	18M		STP-O-2.3Q-MOV	
1815B	2	Ν	В	А	4	GA	МО	1262-1 (D-3)	0	0	Al	DIAG	MOV		MA-AA-723-300-1006	
SI PUMP C SU		ALVE										PI SC/SO	MOV 18M		MA-AA-723-300-1006 STP-O-2.3Q-MOV	
1817	2	Ν	С	А	.75	RV	SA	1262-1 (D-4)	С	O/C	NA	RT	10Y		GMP-37-06-255/RV	
SI PUMP C SU	CTION RI	ELIEF	VLV	TO CN	IMT SPR/	AY PUMP D	ISCHARGE									
830A	2	Ν	С	А	1	RV	SA	1262-2 (A-6)	С	O/C	NA	RT	10Y		GMP-37-06-1440/1X2RV	
LOOP B ACCUI	MULATO	RAR	ELIEF	VLV												
830B	2	Ν	С	А	1	RV	SA	1262-2 (E-6)	С	O/C	NA	RT	10Y		GMP-37-06-1440/1X2RV	
LOOP A ACCUI	MULATO	RBR	ELIEF	VLV												
834A	2	Ν	В	Ρ	1	GL	AO	1262-2 (A-5)	С	С	С	PI	2Y		STP-O-2.5.2	
SI ACCUMULA	TOR A N	2 AIR	OPER	RATED	FILL/VEI	NT VALVE										
834B	2	Ν	В	Ρ	1	GL	AO	1262-2 (E-5)	С	С	С	PI	2Y		STP-O-2.5.2	
SI ACCUMULA	TOR B AI	R OP	ERAT	ED NI	TROGEN	FILL/VENT	VALVE									
835A	2	Ν	В	Ρ	1	GL	AO	1262-2 (C-4)	С	С	С	PI	2Y		STP-O-2.5.2	
SI ACCUMULA	TOR A AI	R OP	ERAT	ED FIL	L VALVE											
835B	2	Ν	В	Ρ	1	GL	AO	1262-2 (G-5)	С	С	С	PI	2Y		STP-O-2.5.2	
SI ACCUMULA	TOR B AI	R OP	ERAT	ED FIL	L VALVE											
839A	2	N	В	Ρ	.75	GL	AO	1262-2 (C-8)	С	С	С	PI	2Y		STP-O-2.5.2	
SI ACCUMULA	TOR A TE	EST V	ALVE	AOV-8	839A											
839B	1	Ν	В	Ρ	.75	GL	AO	1262-2 (D-8)	С	С	С	PI	2Y		STP-O-2.5.2	
SI LINE LOOP F	B TEST V	AI VF	AOV	-839B												
840A	2	N	В	P	.75	GL	AO	1262-2 (G-7)	С	С	С	PI	2Y		STP-O-2.5.2	
SLACCUMULA		=ST V			840A											
840B	1	N	B	P	.75	GL	AO	1262-2 (H-7)	С	С	С	PI	2Y		STP-O-2.5.2	
SI LINE LOOP I	B TEST V	/ALVE	AOV	-840B												

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID Description	Class	Δuc	ten r	۸/D	Size	Valve Type	Actuator	Drawing & Coord	Norma	Positio	on	Required	Fraguanay		Procedure	Commonts / Notos
Description	01033	Λu	j. Gal.	A/F	0120	Туре	Туре	accord	Norma	alSalety	Fall-Sale	Test	Frequency	KK/CSJ/KUJ	Procedure	Comments / Notes
841	2	Ν	В	A	10	GA	MO	1262-2 (C-7)	0	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	Treat as High Risk
		0011	TOI									PI	MOV		MA-AA-723-300-1006	MOV
SIACCUMULA	TORADI	SCH	IOLO	JOP B	WOV-84							30 02/32	CS CS	CS - 04	0-2.2 STP-0-2.4	
												SO	CS	00 04	0-1.1	
842A	1	Ν	AC	А	10	СК	SA	1262-2 (D-7)	С	O/C	NA	CC	СМ		STP-O-8.8	CVCMP
												CO	CM		STP-O-R-24	
LOOP B ACCU	MULATO	RAD	DUMP	LINE (CHECK VI	LV						CO	18M		STP-O-2.10.7	
												LT-X	2Y		STP-O-8.8	
842B	1	Ν	AC	А	10	CK	SA	1262-2 (G-7)	С	O/C	NA	CC	CM		STP-O-8.8	CVCMP
												CO	CM		STP-O-R-24	
LOOP A ACCU	MULATO	RBD	DUMP	LINE (CHECK VI	LV						CO	18M		STP-O-2.10.7	
												LI-X	2Y		STP-0-8.8	
844A	2	Ν	В	Р	1	GL	AO	1262-2 (C-8)	С	С	С	PI	2Y		STP-O-2.5.2	
SI ACCUMULA	TOR A DI	RAIN	VALV	E AOV	′-844A											
844B	2	Ν	В	Р	1	GI	AO	1262-2 (G-8)	С	С	С	PI	2Y		STP-0-2.5.2	
	-		-	•				(0 0)	°,	U U	U U				0 0 1.0.1	
SI ACCUMULA	TOR B DI	RAIN	VALV	E AOV	′-844B											
846	2	Ν	А	А	1	GL	AO	1262-1 (A-6)	С	С	С	FC	Q		STP-O-2.5	
								. ,				LJ-C	AJ		STP-O-23.46	
ACCUM N2 SU	PPLY ISC	DL VA	ALVE A	40V-84	46							PI	2Y		STP-O-2.5	
												SC/SO	Q		STP-O-2.5	
												STC	Q		STP-O-2.5	
8623	2	Ν	AC	А	1	CK	SA	1262-2 (A-3)	С	С	NA	BDO	18M		S-16.2	CVCMP
												CC	AJ		STP-O-23.46	
N2 INLET CHE	CK VLV T	O AC	CCUM	ULATC	ORS A & E	}						LJ-C	AJ		STP-O-23.46	
865	2	Ν	В	А	10	GA	MO	1262-2 (G-7)	0	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	Treat as High Risk
												PI	MOV		MA-AA-723-300-1006	MOV
SI ACCUMULA	TOR B DI	SCH	ARGE	TOLC	DOP A MO	DTOR OPER	RATED VAL	VE				SC	CS		0-2.2	
												SC/SO	CS	CS - 04	STP-O-2.4	
												SO	CS		0-1.1	
867A	1	Ν	AC	Α	10	CK	SA	1262-2 (D-7)	С	O/C	NA	CC	R		STP-O-2.10.4	CVCMP
												CO	R		STP-O-2.10.1	
SI PUMP DISC	HARGE A	ND A	ACCU	MULAT	OR TAN	< A CHECK	VALVE TO	LOOP B COLE) LEG			CO	CM		STP-O-R-24	
												LT-XT	R		STP-O-2.10.4	
867B	1	Ν	AC	А	10	CK	SA	1262-2 (H-7)	С	O/C	NA	CC	R		STP-O-2.10.4	CVCMP
												CO	CM		STP-O-R-24	
SI PUMP DISC	HARGE A	ND A	ACCU	MULAT	OR TAN	K B CHECK	VALVE TO	LOOP A COLE) LEG				ĸ		STP-0-2.10.1	
												LI-XI	к		STP-0-2.10.4	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID Description	Class	Aug	. Cat.	A/P	Size	Valve Type	Actuator Type	Drawing & Coord	 Norma	Positional Safety	on Fail-Safe	Required Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
870A	2	Ν	С	А	3	СК	SA	1262-1 (C-7)	С	O/C		CC CC	18M 18M		STP-O-2.1-COMP-A STP-O-2.1-COMP-C	
SI PUMP C DIS	SCHARGE	CHE	ECK VI	LV TO	LOOP B	COLD LEG						CO	R	ROJ - 05	STP-O-2.10.1	
870B	2	Ν	С	А	3	СК	SA	1262-1 (E-7)	С	O/C		CC CC	18M 18M		STP-O-2.1-COMP-B STP-O-2.1-COMP-C	
SI PUMP C DIS	SCHARGE	CHE	ECK VI	LV TO	LOOP A	COLD LEG						CO	R	ROJ - 05	STP-O-2.10.1	
871A	2	Ν	В	А	3	GA	МО	1262-1 (D-7)	0	O/C	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
SI PUMP C DIS	SCHARGE	то	LOOP	B MO	/-871A							SC/SO STC	18M 18M		STP-O-2.3 STP-O-2.3	
871B	2	Ν	В	А	3	GA	MO	1262-1 (E-7)	0	O/C	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
SI PUMP C DIS	SCHARGE	то	LOOP	A MO	/-871B							SC/SO STC	18M 18M		STP-O-2.3 STP-O-2.3	
877A	1	Ν	AC	Ρ	2	СК	SA	1262-2 (E-3)	С	С	NA	LT-XT	40M	GR - 01	STP-O-2.10.4	
SI PUMP A DIS	CHARGE	CHE	ECK VI	_V TO	LOOP B	HOT LEG										
877B	1	Ν	AC	Ρ	2	СК	SA	1262-2 (l-6)	С	С	NA	LT-XT	40M	GR - 01	STP-O-2.10.4	
SI PUMP B DIS	CHARGE	CHE	ECK VI	_	LOOP A	HOT LEG										
878A	2	Ν	А	Ρ	2	GL	MO	1262-2 (E-3)	С	С	AI	LT-XT Pl	40M 2Y	GR - 01	STP-O-2.10.4 STP-O-2.10.4	
SI PUMP A DIS	CHARGE	ТО	LOOP	в нот	LEG MO	DV-878A										
878B	2	Ν	В	Ρ	2	GL	МО	1262-2 (D-4)	0	0	AI	PI	2Y		STP-O-2.10.4	
SI PUMP A DIS	CHARGE	TO	LOOP	B COL	D LEG N	IOTOR OPE	RATED VA	LVE								
878C	2	Ν	А	Ρ	2	GL	MO	1262-2 (I-5)	С	С	AI	LT-XT Pl	40M 2Y	GR - 01	STP-O-2.10.4 STP-O-2.10.4	
SI PUMP B DIS	CHARGE	TO	LOOP	A HOT	LEG MO	DV-878C										
878D	2	Ν	В	Ρ	2	GL	MO	1262-2 (H-5)	0	0	AI	PI	2Y		STP-O-2.10.4	
SI PUMP B DIS	CHARGE	то	LOOP	A COL	D LEG N	10V-878D										
878F	1	Ν	AC	Ρ	2	СК	SA	1262-2 (E-3)	С	С	NA	LT-XT	40M	GR - 01	STP-O-2.10.4	
SI PUMP A DIS	CHARGE	CHE	ECK VI	_v то	LOOP B	HOT LEG										
878G	1	N	AC	A	2	CK	SA	1262-2 (D-5)	С	O/C	NA	22 02	R	ROJ - 04 ROJ - 04	STP-O-2.10.4 STP-O-2.10.1	
SI PUMP A DIS	CHARGE	CHE	ECK VI	_v то	LOOP B	COLD LEG						LT-XT	R	1100 - 04	STP-O-2.10.4	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID							Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	a Au	ıg. Ca	t. /	4/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
878H	1	Ν	AC	;	Ρ	2	СК	SA	1262-2 (l-6)	С	С	NA	LT-XT	40M	GR - 01	STP-O-2.10.4	
SI PUMP B DISC	CHARGE	E C⊦	IECK	VLV	TOL		HOT LEG										
878J	1	Ν	AC	;	A	2	СК	SA	1262-2 (H-6)	С	O/C	NA	CC	R	ROJ - 04	STP-O-2.10.4	
													CO	R	ROJ - 04	STP-O-2.10.1	
SI PUMP B DISC	CHARGE	E C⊦	IECK	VLV	' TO L	OOP A (COLD LEG						LT-XT	R		STP-O-2.10.4	
885A	2	Ν	В		A	.75	GL	М	1262-1 (C-7)	0	O/C	NA	EC/EO	2Y		STP-O-2.1-COMP-A	
INSTR ROOT VI	LV TO P	T-92	22 & P	I-92	2A (S	I PMP A	DISCH)										
885B	2	Ν	В		A	.75	GA	М	1262-1 (F-8)	0	O/C	NA	EC/EO	2Y		STP-O-2.1-COMP-B	
INSTR ROOT VI	LV TO P	T-92	23 & P	I-92	3A (S	I PMP B	DISCH)										
887	2	Ν	С		A	.75	TRV	SA	1262-2 (H-8)	С	O/C	NA	RT	10Y		CMP-37-06-887	
LOOP A ACCUN	IULATO	RΒ	TEST	LIN	IE RE		V TO PRT (I	N CNMT)									
889A	2	Ν	С		A	3	СК	SA	1262-1 (C-5)	С	O/C	NA	CC	18M		STP-O-2.1-COMP-A	
													CC	Q		STP-O-2.1QA	
SI PUMP A DISC	CHARGE	E C⊦	IECK	VLV									CO	R		STP-O-2.10.1	
													CO	Q		STP-O-2.1QA	
					-	_							00	18M		STP-0-2.1-COMP-A	
889B	2	N	С		A	3	CK	SA	1262-1 (F-6)	С	O/C	NA	CC	18M		STP-O-2.1-COMP-B	
		- ~			,									Q		STP-0-2.10B	
SI PUMP B DISC	HARGE		IECK	VLV									00			STP-0-2.10.1 STP-0-2.10B	
													00	18M		STP-O-2 1-COMP-B	
890	2	Ν	С		A	0.75	RV		33013-1262-2	С	С	NA	RT	10Y		CMP-37-06-890	
Safety Injection	Pump He	eade	er Relie	ef VI	LV (IN	CNMT)			(1-3)								
891A	2	Ν	С		A	1.5	CK	SA	1262-1 (B-3)	С	O/C	NA	CC	18M		STP-O-2.1-COMP-B	
													CC	Q		STP-O-2.1QB	
SI PUMP A REC	IRC LIN	EC	HECK	٧L	V TO I	RWST							CO	18M		STP-O-2.1-COMP-A	
			_										CO	Q		STP-0-2.1QA	
891B	2	N	С		A	1.5	CK	SA	1262-1 (D-5)	С	O/C	NA	CC	18M		STP-O-2.1-COMP-A	
														Q		STP-0-2.1QA	
SI PUMP C REC	JRC LIN	EC	HECK	VL'	V IO	RVVSI							00			STP-0-2 100	
8910	2	N	C		Δ	15	CK	54	1262-1 (E-5)	C	0/0	NΔ		<u> </u>		STP-0-2.100	
0010	2	IN	U		~	1.5	UI	34	1202-1 (E-3)	C	0/0	IN/A	00	18M		STP-0-2 1-COMP-A	
SI PUMP B REC		F C	HECK	VIV	и то і	RWST							cõ	Q		STP-O-2.1QB	
													CO	18M		STP-O-2.1-COMP-B	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
893	2	Ν	С	А	0.75	RV	SA	1262 (F-3)	С	O/C	NA	RT	10Y		CMP-37-06-893	
SI PUMP HDR R	ELIEF V	ALVE														

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID						Valve	Actuator	Drawing		Positio	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
4561	3	Ν	В	А	14	BTF	AO	1250-3 (G-9)	0	0	0	FO	Q		STP-O-2.5.5	
												SC/SO	Q		STP-O-2.5.5	
CONTAINMEN	COOLE	RS S	W OU	TLET I	FLOW CO	ONTROL AO	V					STO	Q		STP-O-2.5.5	
4562	3	Ν	В	А	14	BTF	AO	1250-3 (G-10)	С	0	0	FO	Q		STP-O-2.5.5	
												SC/SO	Q		STP-O-2.5.5	
AIR OPERATEI AOV)) BYPAS	S OF	VALV	E 456′	I (CONT/	AINMENT FA	AN COOLEF	RS SW OUTLE	T FLOW	CONTR	OL	STO	Q		STP-O-2.5.5	
4598G	3	Ν	В	Α	4	GL	AO	1250-1 (C6)	С	0	0	FO	Q		STP-O-2.5.7A	
												SC/SO	Q		STP-O-2.5.7A	
EDG A SW ISO	L VALVE											STO	Q		STP-O-2.5.7A	
4598H	3	Ν	В	А	4	GL	AO	1250-1 (C6)	С	0	0	FO	Q		STP-O-2.5.7A	
												SC/SO	Q		STP-O-2.5.7A	
EDG A SW ISO	L VALVE											STO	Q		STP-O-2.5.7A	
4599G	3	Ν	В	Α	4	GL	AO	1250-1 (E6)	С	0	0	FO	Q		STP-O-2.5.7B	
												SC/SO	Q		STP-O-2.5.7B	
EDG B SW ISO	L VALVE											STO	Q		STP-O-2.5.7B	
4599H	3	Ν	В	А	4	GL	AO	1250-1 (E6)	С	0	0	FO	Q		STP-O-2.5.7B	
								. ,				SC/SO	Q		STP-O-2.5.7B	
EDG B SW ISO	L VALVE											STO	Q		STP-O-2.5.7B	
4601	3	Ν	С	А	14	CK	SA	1250-1 (D-2)	O/C	O/C	NA	CC	Q		STP-O-2.7.1B	
								. ,				CO	Q		STP-O-2.7.1A	
NOZZLE CHEC	K VALVE	FOR	SER	/ICE V	VATER P	UMP "A" DIS	SCHARGE									
4602	3	Ν	С	А	14	CK	SA	1250-1 (E-2)	O/C	O/C	NA	CC	Q		STP-O-2.7.1A	
								()				CO	Q		STP-O-2.7.1B	
NOZZLE CHEC	K VALVE	FOR	SER\	/ICE V	VATER P	UMP "B" DIS	SCHARGE									
4603	3	Ν	С	А	14	CK	SA	1250-1 (F-2)	O/C	O/C	NA	CC	Q		STP-O-2.7.1D	
								. ,				CO	Q		STP-O-2.7.1C	
NOZZLE CHEC	K VALVE	FOR	SER\	/ICE V	VATER P	UMP "C" DIS	SCHARGE									
4604	3	Ν	С	А	14	CK	SA	1250-1 (G-2)	O/C	O/C	NA	CC	Q		STP-O-2.7.1C	
								· · · ·				CO	Q		STP-O-2.7.1D	
NOZZLE CHEC	K VALVE	FOR	SER	/ICE V	VATER P	UMP "D" DIS	SCHARGE									
4609	3	Ν	В	А	8	BTF	MO	1250-1 (C-2)	0	С	AI	DIAG	MOV		MA-AA-723-300-1006	
								. ,				PI	MOV		MA-AA-723-300-1006	
SCREENHOUS	E SW ISC	JL VL	V MO	V-4609	9							SC/SO	18M		STP-O-2.3	
												STC	18M		STP-O-2.3	
4613	3	Ν	В	А	10	BTF	MO	1250-1 (D-6)	0	С	AI	DIAG	MOV		MA-AA-723-300-1006	
												PI	MOV		MA-AA-723-300-1006	
TURBINE BUIL	DING SEI	RVIC	E WA1	FER IS	OLATIO	N MOTOR O	PERATED	VALVE				SC/SO	18M		STP-0-2.3	
												SIC	18M		STP-0-2.3	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Valve Table SW - SERVICE WATER

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
4614	3	Ν	В	А	10	BTF	MO	1250-3 (H-2)	0	С	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
TURBINE BUILD	ING SEF	RVIC	E WAT	TER IS	OLATION	MOTOR C	PERATED \	/ALVE				SC/SO STC	18M 18M		STP-O-2.3 STP-O-2.3	
4615	3	Ν	В	А	20	GA	MO	1250-1 (J-9)	0	O/C	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
AUX BLDG SW I	SOL VL\	/ MO	V-461	5								SC/SO STC	18M 18M		STP-O-2.3 STP-O-2.3	
4616	3	Ν	В	А	20	GA	MO	1250-1 (A-9)	0	O/C	AI	DIAG	MOV MOV		MA-AA-723-300-1006	
AUX BLDG SW I	SO VLV	MO∖	/-4616									SC/SO STC	18M 18M		STP-O-2.3 STP-O-2.3	
4619C	3	Ν	В	А	12	GA	М	1250-2 (F-6)	С	0	NA	EC/EO	2Y		STP-O-2.10.11	
CCW HX A RED	UNDANT	sw	OUTL	ET IS	OL VLV											
4620B	3	Ν	В	А	12	GA	М	1250-2 (E-6)	С	0	NA	EC/EO	2Y		STP-O-2.10.11	
CCW HX B RED	UNDANT	SW	OUTL	ET IS	DL MOV											
4622	3	Y	В	А	6	GL	М	1250-2 (H-8)	0	O/C	NA	EC/EO	2Y		STP-O-2.10.11	
SFP HX A SW O	UTLET I	SOL	VLV													
4622A	3	Y	В	А	6	GA	М	1250-2 (H-7)	С	0	NA	EC/EO	2Y		STP-O-2.10.11	
SFP HX A REDU	INDANT	SW	OUTLE	ET ISO	L VLV											
4629	2	Ν	А	А	8	BTF	Μ	1250-3 (B-7)	0	O/C	NA	EC/EO LT-X	2Y 2Y		STP-O-2.9 STP-O-R-2.4	
SERVICE WATE	R OUTL G FAN A	ET B	LOCK	VALV 3) & A0	E FOR A CA10 (CN	CA01A, ACA	01E, ACA0 ² C FAN A MT	1F (CONTAINN R CLR)	ME NT							
4630	2	Ν	A	А	8	BTF	М	1250-3 (C-7)	0	O/C	NA	EC/EO LT-X	2Y 2Y		STP-O-2.9 STP-O-R-2.4	
SERVICE WATE	R OUTL G FAN B	ET B		VALV S) & AC	E FOR AG CA07 (CN	CA01B, ACA	01G, ACA0 C FAN B MT	1H (CONTAIN R CLR)	ME NT							
4635	2	Ν	В	Â	8	BTF	М	1250-3 (D-7)	0	С	NA	EC/EO	2Y		STP-O-2.5.1	
SW INLET BLOC	K VLV T	OR	ЕАСТО	DR CO	MPARTM	IENT COOL	ER B									
4636	2	Ν	А	А	2.5	BTF	М	1250-3 (F-7)	0	С	NA	EC/EO LT-X	2Y 2Y		STP-O-2.9 STP-O-R-2.8	
REACTOR COM	PARTME	ENT (COOLI	ER B S	W OUTL	ET BLOCK	VLV									

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID						Valve	Actuator	Drawing		- Positio	on	Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Normal	Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
4643	2	Ν	А	А	8	BTF	М	1250-3 (G-7)	0	O/C	NA	EC/EO LT-X	2Y 2Y		STP-O-2.9 STP-O-R-2.4	
SERVICE WAT	ER OUTL NG FAN C	ET B CO	LOCK	VALV S) & A	E FOR A CA08 (CN	CA01C, ACA	A01J, ACA0 C FAN C MT	1K, (CONTAINI 'R CLR)	M ENT							
4644	2	Ν	A	A	8	BTF	М	1250-3 (H-7)	0	O/C	NA	EC/EO LT-X	2Y 2Y		STP-O-2.9 STP-O-R-2.4	
SERVICE WAT	ER OUTL NG FAN D	ET B CO	LOCK	VALV S) & A	E FOR A CA09 (CN	CA01D, ACA	A01L, ACA0 C FAN D MT	1M, (CONTAIN `R CLR)	M ENT							
4653	3	Ν	С	А	.75	TRV	SA	1250-2 (F-6)	С	0	NA	RT	10Y		GMP-37-06-125/RV	
CCW HX A SW	OUTLET	REL	IEF VL	V												
4653A	3	Ν	D	A	.75	RPD	SA	1250-2 (F-6)	С	0	NA	RD	5Y		Rep Task P311162	
CCW HX A SW	Outlet Re	elief V	/alve -	Ruptu	re Disk											
4654	3	Ν	С	A	.75	TRV	SA	1250-2 (D-6)	С	0	NA	RT	10Y		GMP-37-06-125/RV	
CCW HX B SW	OUTLET	REL	IEF VL	.V												
4654A	3 Outlet Re	N N	D	A	.75 re Disk	RPD	SA	1250-2 (D-6)	С	0	NA	RD	5Y		Rep Task P311164	
4655	2	N		Δ	75	RV	SA	1250-3 (A-7)	C	0/0	NA	I T-X	2Y		STP-O-R-24	
CONTAINMEN					sw ou	LI FT RFI IF	F VI V	1200 0 (717)	U	0,0		RT	10Y		GMP-37-06-125/RV	
4655A	2	N	D	A	.75	RPD	SA	33013-1250 R3 (A-7)	С	0	NA	RD	5Y		P311190	
Containment Re	ecirculatio	n Far	n A Co	oler S	W Outlet	Relief VLV R	Rupture Disk									
4656	2	Ν	AC	A	.75	RV	SA	1250-3 (C-7)	С	O/C	NA	LT-X RT	2Y 10Y		STP-O-R-2.4 GMP-37-06-125/RV	
CONTAINMEN	T RECIRC	FAN	B CC	OLER	SW OU	FLET RELIE	F VLV									
4656A	2	Ν	D	A	.75	RPD	SA	33013-1250,3 (C-7)	С	0	NA	RD	5Y		P311191	
Containment Re	ecirc Fan I	B Co	oler SV	N Outl	et Relief	VLV Rupture	Disk									
4657	3	Y	С	A	.75	TRV	SA	1250-2 (H-8)	С	0	NA	RT	10Y		GMP-37-06-125/RV	
SFP HX A SW	OUTLET F	RELIE	EF VLV	/												
4657A	3	Ν	D	А	.75	RPD	SA	33013-1250,2 (H-8)	С	0	NA	RD	5Y		REP TASK P311984	
SFP HX A SW	OUTLREL	. RD														

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID						Valve	Actuator	Drawing		Positic	on	Required				
Description	Class	Aug	J. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
4658	2	Ν	AC	А	.75	RV	SA	1250-3 (E-7)	С	O/C	NA	LT-X RT	2Y 10Y		STP-O-R-2.8 GMP-37-06-125/RV	
REACTOR CO	MPARTME	ENT	COOL	ER B S	SW OUTL	ET RELIEF	VLV									
4658A	2	Ν	D	А	.75	RPD	SA	1250-3 (E-7)	С	0	NA	RD	5Y		P311060	
REACTOR CO	MPARTME	ENT	COOL	ER B S	W RELI	EF VLV RUF	TURE DIS	C								
4659	2	Ν	AC	А	.75	RV	SA	1250-3 (G-7)	С	O/C	NA	LT-X RT	2Y 10Y		STP-O-R-2.4 GMP-37-06-125/RV	
CONTAINMEN	T RECIRC	; FAN		OLER	SW OU	TLET RELIE	F VLV									
4659A	2	Ν	D	А	.75	RPD	SA	33013-1250,3 (G-7)	С	0	NA	RD	5Y		P311192	
Containment Re	ecirc Fan (C Co	oler S\	N Outl	et Relief	VLV Rupture	e Disk									
4660	2	Ν	AC	А	.75	RV	SA	1250-3 (H-7)	С	O/C	NA	LT-X RT	2Y 10Y		STP-O-R-2.4 GMP-37-06-125/RV	
CONTAINMEN	T RECIRC	FAN	N D CC	OLER	SW OU	TLET RELIE	F VLV									
4660A	2	Ν	D	A	.75	RPD	SA	33013-1250,3 (H-7)	С	0	NA	RD	5Y		P311193	
Containment Re	ecirc Fan I	D Co	oler S\	N Outl	et Relief	VLV Rupture	e Disk									
4663	3	Ν	В	А	6	BTF	MO	1250-3 (I-3)	0	С	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
AIR CONDITIO	NING SEF	RVIC	E WAT	ER M	OTOR O	PERATED IS	SOLATION	VALVE				SC/SO STC	18M 18M		STP-O-2.3 STP-O-2.3	
4664	3	Ν	В	А	10	GA	МО	1250-3 (H-2)	0	С	AI	DIAG PI	MOV MOV		MA-AA-723-300-1006 MA-AA-723-300-1006	
TURBINE BLD	G SW ISO	L VL	V MO	/-4664								SC/SO STC	18M 18M		STP-O-2.3 STP-O-2.3	
4670	3	Ν	В	А	10	GA	MO	1250-1 (D-5)	0	С	AI	DIAG	MOV MOV		MA-AA-723-300-1006	
TURBINE BLD	G SW ISO	L VL	V MOV	/-4670								SC/SO STC	18M 18M		STP-O-2.3 STP-O-2.3	
4717	3	Ν	С	А	.75	TRV	SA	1250-1 (D-7)	С	0	NA	RT	10Y		GMP-37-06-125/RV	
D/G A HX'S SW	OUTLET	REL	IEF V	LV												
4717A	3	Ν	D	А	.75	RPD	SA	33013-1250,1 (D-7)	С	0	NA	RD	5Y		REP TASK P311985	
D/G A HX'S SW	OUTLET	RD														
4718	3	Ν	С	A	.75	TRV	SA	1250-1 (H-5)	С	0	NA	RT	10Y		GMP-37-06-125/RV	
D/G B HX'S SW	OUTLET	REL	IEF V	LV												

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Description Class Aug. Cat. A/P Size Type Type K Corr Normal Safety Fail-Safe Test Frequency RRCSJ/ROJ Procedure Comments / Notes 4718A 3 N D A 75 RPD 300131260,1 C O NA RD SY P312104 OG B HX's SW OUTLET RD (H-5) (H-5) (H-5) O A PIA MOV MAAA.722-300-1006 AIR CONDITIONING SW ISOL VLV MOV-4733 B A 6 BTF MO 1250-3 (I-3) O C AI PIA MOV MAAA.722-300-1006 SCISO 18M STP-Q-2.3 TER-Q-2.3	Valve ID	•		_			Valve	Actuator	Drawing		Positio	on	Required				
4718A 3 N D A .75 RPD 33013-1250,1 C C O NA RD 5Y P312104 DG B HX's SW OUTLET RD (H-5) (H-5) (H-5) (H-5) (H-5) (H-5) 47133 3 N B A 6 BTF MO 1250-3 (I-3) 0 C AI DIAG MOV MAA.A723-300-1006 AR CONDITIONING SW ISOL VLV MOV-4733 STC 18M STP-0-2.3 4734 3 N B A 14 BTF MO 1250-2 (E-3) O O/C AI DIAG MOV MAA.A723-300-1006 41XILLARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE STC 18M STP-0-2.3 STC 18M STP-0-2.3 4739 3 N B A 18 BTF MO 1250-2 (B-2) O O/C AI DIAG MOV MAA.A723-300-1006 41XILLARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE STC 18M STP-0-2.3 STC<	Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
D/G B HX's SW OUTLET RD 4733 3 N B A 6 BTF M0 1250-3 (I-3) 0 C AI MOV MAAA-723-300-1006 AIR CONDITIONING SW ISOL VLV MOV-4733 SOL VLV MOV-4733 SC/SO IBM STP-0-2.3 4734 3 N B A 14 BTF MO QL AI MOV MAAA-723-300-1006 4734 3 N B A 14 BTF MO 1250-2 (E-3) O O/C AI DMAG MOV MAAA-723-300-1006 4734 3 N B A 14 BTF MO 1250-2 (E-3) O O/C AI DMAG MOV MAAA-723-300-1006 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE STC 18M STP-0-2.3 STC 18M STP-0-2.3 4739 3 N B A 3 GA M 1250-3 (E-7) O O/C AI DIAG MOV MAAA-723-300-1006 41739 2 N A 3 <th>4718A</th> <th>3</th> <th>Ν</th> <th>D</th> <th>А</th> <th>.75</th> <th>RPD</th> <th></th> <th>33013-1250,1 (H-5)</th> <th>С</th> <th>0</th> <th>NA</th> <th>RD</th> <th>5Y</th> <th></th> <th>P312104</th> <th></th>	4718A	3	Ν	D	А	.75	RPD		33013-1250,1 (H-5)	С	0	NA	RD	5Y		P312104	
4733 3 N B A 6 BTF MO 1250-3 (I-3) O C AI DIAG MOV MA-AA-723-300-1006 AIR CONDITIONING SW ISOL VLV MOV-4733 S STC 18M STF-O-2.3 STC 18M STF-O-2.3 4734 3 N B A 14 BTF MO 1250-2 (E-3) O O/C AI DIAG MOV MA-AA-723-300-1006 4734 3 N B A 14 BTF MO 1250-2 (E-3) O O/C AI DIAG MOV MA-AA-723-300-1006 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE SC/SO 18M STF-O-2.3 STC 18M STF-O-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STF-O-2.3 4739B 3 N B A 3 GA M 1250-3 (E-7) O C NA EC/EO 2Y STF-O-2.5.1 4739B	D/G B HX's SW	OUTLET	RD														
AIR CONDITIONING SW ISOL VLV MOV-4733 PI MOV MAAA723-300-1006 4734 3 N B A 14 BTF MO 1250-2 (E-3) 0 O/C AI DIAG MOV MAAA723-300-1006 4734 3 N B A 14 BTF MO 1250-2 (E-3) 0 O/C AI DIAG MOV MAAA723-300-1006 4736 3 N B A 18 BTF MO 1250-2 (B-2) 0 O/C AI PI MOV MAAA723-300-1006 4737 3 N B A 18 BTF MO 1250-2 (B-2) 0 O/C AI PI MOV MAAA723-300-1006 4737 3 N B A 3 GA M 1250-2 (B-2) O O/C AI PI MOV MAAA723-300-1006 47398 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-O-2.10.11 <td< td=""><td>4733</td><td>3</td><td>Ν</td><td>В</td><td>А</td><td>6</td><td>BTF</td><td>MO</td><td>1250-3 (I-3)</td><td>0</td><td>С</td><td>AI</td><td>DIAG</td><td>MOV</td><td></td><td>MA-AA-723-300-1006</td><td></td></td<>	4733	3	Ν	В	А	6	BTF	MO	1250-3 (I-3)	0	С	AI	DIAG	MOV		MA-AA-723-300-1006	
AIR CONDITIONING SW ISOL VLV MOV4/33 SUISU 18M S1P-02.3 4734 3 N B A 14 BTF MO 1250-2 (E-3) 0 O/C AI DIAG MOV MAAA.723-300-1006 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE SCISO 18M STP-02.3 4735 3 N B A 18 BTF MO 1250-2 (B-2) O O/C AI DIAG MOV MAAA.723-300-1006 4735 3 N B A 18 BTF MO 1250-2 (B-2) O O/C AI DIAG MOV MAAA.723-300-1006 40XILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE SCISO 18M STP-0-2.3 STC 18M STP-0-2.3 4739B 3 N B A 3 G M 1250-3 (E-7) O C NA EC/EO 2Y STP-0-2.10.11 AUXELDE MOTOR COOLERS SW OUTLET ISOL VLV (REDUNDANT) 4759 2 N A A 2.5 BTF M													PI	MOV		MA-AA-723-300-1006	
4734 3 N B A 14 BTF MO 1250-2 (E-3) O O/C AI DIAG MOV MAAAA-723-300-1006 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE SC/SO 18M STP-O-2.3 STC 18M STP-O-2.3 4735 3 N B A 18 BTF MO 1250-2 (B-2) O O/C AI DIAG MOV MAAAA-723-300-1006 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE STC 18M STP-O-2.3 STC 18M STP-O-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-O-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-O-2.10.11 AUX BLOG MOTOR COOLER SW OUTLET ISOL VLV (REDUNDANT) 4750 C NA EC/EO 2Y STP-O-2.5.1 SW INLET BLOCK VLV TO REACTOR COMPARTMENT COOLER A 4750 T N	AIR CONDITIO	NING SW	ISO	_ VLV	MOV-4	4733							SC/SU STC	18M		STP-0-2.3 STP-0-2.3	
AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE No. No. P. MOV MAAA-723-300-1006 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE SC.SO 18M STP-0-2.3 4735 3 N B A 18 BTF MO 1250-2 (B-2) 0 O/C AI DIAG MOV MAAA-723-300-1006 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE STC 18M STP-0-2.3 STC 18M STP-0-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-0-2.10.11 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE STC 18M STP-0-2.3 STP-0-2.3 4739B 3 N B A 8 BTF M 1250-1 (B-11) C O NA EC/EO 2Y STP-0-2.10.11 AUX BLDG MOTOR COOLERS SW OUTLET ISOL VLV (REDUNDANT)	4734	3	N	В	Α	14	BTF	МО	1250-2 (E-3)	0	0/C	AI	DIAG	MOV		MA-AA-723-300-1006	
AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE SC/SO 18M STP-O-2.3 4735 3 N B A 18 BTF MO 1250-2 (B-2) O O/C AI DIAG MOV MA-AA-723-300-1006 4739 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE SC/SO 18M STP-O-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-O-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-O-2.10.11 AUX BLOG MOTOR COOLERS SW OUTLET ISOL VLV (REDUNDANT) T T N B B BTF M 1250-3 (E-7) O C NA EC/EO 2Y STP-O-2.5.1 SW INLET BLOCK VLV TO REACTOR COMPARTMENT COOLER A HT M 1250-3 (D-7) O C NA EC/EO 2Y STP-O-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV HT-X ZY ST		Ū.		-			2		()	Ū	0,0		PI	MOV		MA-AA-723-300-1006	
STC 18M STP-O-2.3 4735 3 N B A 18 BTF MO 1250-2 (B-2) O O/C AI DIAG MOV MA-AA-723-300-1006 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE SC/SO 18M STP-O-2.3 STC 18M STP-O-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-O-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-O-2.10.11 AUX BLOG MOTOR COOLERS WUTLET ISOL VLV (REDUNDANT)	AUXILIARY BU	ILDING S	ERVI	CE W	ATER	ISOLATIO	ON MOTOR	OPERATE	D VALVE				SC/SO	18M		STP-O-2.3	
4735 3 N B A 18 BTF MO 1250-2 (B-2) O O/C AI DIAG MOV MA-AA-723-300-1006 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE STC 18M STP-O-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-O-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-O-2.10.11 AUX BLDG MOTOR COOLERS SW OUTLET ISOL VLV (REDUNDANT)													STC	18M		STP-0-2.3	
AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE PI MOV MAAA-7/23-300-1006 AUXILIARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE SCISO 18M STP-O-2.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-O-2.3 4779B 2 N B A 8 BTF M 1250-3 (E-7) O C NA EC/EO 2Y STP-O-2.5.1 SW INLET BLOCK VLV TO REACTOR COMPARTMENT COOLER A H 1250-3 (D-7) O C NA EC/EO 2Y STP-O-2.9 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV IT-X 2Y STP-O-2.9 LT-X 2Y REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV IT-X 2Y STP-O-R-2.8 MM 4759 2 N A .75 RV SA 1250-3 (D-7) C O/C NA RT 2Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV H H 1250-3 (D-7) C O NA RT <td>4735</td> <td>3</td> <td>Ν</td> <td>В</td> <td>А</td> <td>18</td> <td>BTF</td> <td>MO</td> <td>1250-2 (B-2)</td> <td>0</td> <td>O/C</td> <td>AI</td> <td>DIAG</td> <td>MOV</td> <td></td> <td>MA-AA-723-300-1006</td> <td></td>	4735	3	Ν	В	А	18	BTF	MO	1250-2 (B-2)	0	O/C	AI	DIAG	MOV		MA-AA-723-300-1006	
ADXILARY BUILDING SERVICE WATER ISOLATION MOTOR OPERATED VALVE S0/SO 18M STP-02.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-02.3 4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-02.3 4757 2 N B A 8 BTF M 1250-3 (E-7) O C NA EC/EO 2Y STP-02.10.11 4758 2 N A A 2.5 BTF M 1250-3 (D-7) O C NA EC/EO 2Y STP-0-2.9 STP-0-2.9 STP-0-8.2.8 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV V V STP-0-8.2.8 RT 10Y GMP-37-06-125/RV 4759 2 N A .75 RPD SA 1250-3 (D-7) C O NA RD 5Y P311072 4759A 2 N D A				05.14				0000.70					PI	MOV		MA-AA-723-300-1006	
4739B 3 N B A 3 GA M 1250-1 (B-11) C O NA EC/EO 2Y STP-0-2.10.11 AUX BLDG MOTOR COOLERS SW OUTLET ISOL VLV (REDUNDANT) 4757 2 N B A 8 BTF M 1250-3 (E-7) O C NA EC/EO 2Y STP-0-2.5.1 SW INLET BLOCK VLV TO REACTOR COMPARTMENT COOLER A 4758 2 N A A 2.5 BTF M 1250-3 (D-7) O C NA EC/EO 2Y STP-0-2.5.1 SW INLET BLOCK VLV TO REACTOR COMPARTMENT COOLER A 4758 2 N A A 2.5 BTF M 1250-3 (D-7) O C NA EC/EO 2Y STP-0-2.9 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV 4759 2 N A 7.5 RV SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-0-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV 4759 A 7.5 RVD SA 1250-3 (D-7) C O NA	AUXILIARY BU	ILDING S	ERVI	CE W	AIER	ISOLATIO	ON MOTOR	OPERATEL	J VALVE				SC/SU STC	18M		STP-0-2.3 STP-0-2.3	
AUX BLOG MOTOR COOLERS SW OUTLET ISOL VLV (REDUNDANT) 4757 2 N B A 8 BTF M 1250-3 (E-7) O C NA EC/EO 2Y STP-0-2.5.1 SW INLET BLOCK VLV TO REACTOR COMPARTMENT COOLER A 4758 2 N A A 2.5 BTF M 1250-3 (D-7) O C NA EC/EO 2Y STP-0-2.9 LT-X 2Y STP-0-2.9 LT-X 2Y STP-0-2.9 LT-X 2Y STP-0-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV 4759 2 N AC A .75 RV SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-0-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV 4759 2 N D A .75 RV SA 1250-3 (D-7) C O/C NA RD 5Y P311072 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV URPOWENT <	4739B	3	N	B	Δ	3	GA	М	1250-1 (B-11)	C	0	NA	EC/EO	22		STP-0-2 10 11	
AUX BLDG MOTOR COOLERS SW OUTLET ISOL VLV (REDUNDANT) 4757 2 N B A 8 BTF M 1250-3 (E-7) 0 C NA EC/EO 2Y STP-O-2.5.1 SW INLET BLOCK VLV TO REACTOR COMPARTMENT COOLER A 4758 2 N A 2.5 BTF M 1250-3 (D-7) 0 C NA EC/EO 2Y STP-O-2.9 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV AUX BLOG MOTOR COOLER A SW OUTLET RELIEF VLV AT59 2 N A 7.5 RV SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV 4759 2 N D A .75 RV SA 1250-3 (D-7) C O/C NA RT 10Y GMP-37-06-125/RV REACTOR COMPARTMENT COOLER A SW RELIEF VLV RUPTURE DISC 4770 3 Y C A .75 TRV		Ũ		2		-	0/1		1200 1 (2 11)	Ũ	Ũ	10.1	20,20				
4757 2 N B A 8 BTF M 1250-3 (E-7) 0 C NA EC/EO 2Y STP-O-2.5.1 SWINLET BLOCK VLV TO REACTOR COMPARTMENT COOLER A 4758 2 N A 2.5 BTF M 1250-3 (D-7) 0 C NA EC/EO 2Y STP-O-2.9 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV 4759 2 N AC A .75 RV SA 1250-3 (D-7) C O/C NA EC/EO 2Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV 4759 2 N AC A .75 RV SA 1250-3 (D-7) C O/C NA RT 10Y GMP-37-06-125/RV REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV 4770 3 Y C A .75 RPD SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV CONT PENETRATION COOLER SW OUTLET RELIEF VLV	AUX BLDG MO	TOR COC	DLER	s sw	OUTL	ET ISOL	VLV (REDU	NDANT)									
SW INLET BLOCK VLV TO REACTOR COMPARTMENT COOLER A 4758 2 N A 2.5 BTF M 1250-3 (D-7) O C NA EC/EO 2Y STP-O-R-2.9 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV VLV VLV SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET BLICK VLV VLV SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV SA 1250-3 (D-7) C O/C NA RD 5Y P311072 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV RPD SA 1250-1 (G-11) C O NA RD 5Y P311072 COMPARTMENT COOLER A SW RELIEF VLV RUPTURE DISC 4770 3 Y C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV CNMT PENETRATION COOLER SW OUTLET RELIEF VLV SA 1250-1 (E-10) C O NA RT </td <td>4757</td> <td>2</td> <td>Ν</td> <td>В</td> <td>А</td> <td>8</td> <td>BTF</td> <td>М</td> <td>1250-3 (E-7)</td> <td>0</td> <td>С</td> <td>NA</td> <td>EC/EO</td> <td>2Y</td> <td></td> <td>STP-O-2.5.1</td> <td></td>	4757	2	Ν	В	А	8	BTF	М	1250-3 (E-7)	0	С	NA	EC/EO	2Y		STP-O-2.5.1	
SW INLET BLOCK VLV TO REACTOR COMPARIMENT COOLER A 4758 2 N A 2.5 BTF M 1250-3 (D-7) O C NA EC/EO 2Y STP-O-2.9 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV 4759 2 N AC A .75 RV SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV V SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV V SA 1250-3 (D-7) C O/C NA RD 5Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV V V MT 10Y GMP-37-06-125/RV 4770 3 Y C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV CMMT PENETRATION COOLER ASW OUTLET RELIEF VLV SA 1250-1 (E-10) C O NA RT 10Y GMP-37-06-125/RV <td></td>																	
4758 2 N A A 2.5 BTF M 1250-3 (D-7) O C NA EC/EO 2Y STP-O-2.9 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV 4759 2 N AC A .75 RV SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-O-2.9 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV 4759 2 N AC A .75 RV SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV 4759 2 N D A .75 RPD SA 1250-3 (D-7) C O NA RD 5Y P311072 REACTOR COMPARTMENT COOLER A SW RELIEF VLV RUPTURE DISC 4770 3 Y C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV 4770A 3 N C A .75 TRV SA 1250-1 (E-10) C O NA </td <td>SW INLET BLC</td> <td>CK VLV 1</td> <td>0 R</td> <td>EACTO</td> <td>OR CO</td> <td>MPARTN</td> <td>IENT COOL</td> <td>ER A</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>	SW INLET BLC	CK VLV 1	0 R	EACTO	OR CO	MPARTN	IENT COOL	ER A									
ILI-A 21 STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV 4759 2 N AC A .75 RV SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV X SA 1250-3 (D-7) C O/C NA RT 10Y GMP-37-06-125/RV REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV 4759A 2 N D A .75 RPD SA 1250-3 (D-7) C O NA RD 5Y P311072 47700 3 Y C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV 4770 3 Y C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV 4770A 3 N C A .75 TRV SA 1250-1 (E-10)	4758	2	Ν	A	А	2.5	BTF	М	1250-3 (D-7)	0	С	NA	EC/EO	2Y		STP-O-2.9	
AREACTOR COMPARTMENT COOLER A SW OUTLET BLOCK VLV 4759 2 N AC A .75 RV SA 1250-3 (D-7) C O/C NA LT-X 2Y STP-O-R-2.8 REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV								\/I\/					LI-X	2 Y		51P-U-R-2.8	
47.33 2 N AC A .7.3 RV SA 1250-3 (D-7) C O/C NA RT 10Y GMP-37-06-125/RV REACTOR COMPARTMENT COOLER A SW OUTLET RELIEF VLV 4759A 2 N D A .75 RPD SA 1250-3 (D-7) C O NA RD 5Y P311072 REACTOR COMPARTMENT COOLER A SW RELIEF VLV RUPTURE DISC 4770 3 Y C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV CINT PENETRATION COOLER A SW RELIEF VLV RUPTURE DISC 4770A 3 N C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV 4770A 3 N C A .75 TRV SA 1250-1 (E-10) C O NA RT 10Y GMP-37-06-125/RV RHR PUMP COOLING FAN A SW OUTLET RELIEF VLV	4750					75			1250 2 (D 7)	<u> </u>	0/0	ΝΑ	ITV	21			
And the construction of the first of the	4755	Z	IN	AC	A	.75	ΓV	34	1250-5 (D-7)	C	0/0	INA	RT	2 f 10Y		GMP-37-06-125/RV	
4759A 2 N D A .75 RPD SA 1250-3 (D-7) C O NA RD 5Y P311072 REACTOR COMPARTMENT COOLER A SW RELIEF VLV RUPTURE DISC 4770 3 Y C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV CNMT PENETRATION COOLER SW OUTLET RELIEF VLV 4770A 3 N C A .75 TRV SA 1250-1 (E-10) C O NA RT 10Y GMP-37-06-125/RV RHR PUMP COOLING FAN A SW OUTLET RELIEF VLV	REACTOR CO	MPARTM	ENT	COOL	ERAS		ET RELIEF	VLV						101			
REACTOR COMPARTMENT COOLER A SW RELIEF VLV RUPTURE DISC 4770 3 Y C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV CNMT PENETRATION COOLER SW OUTLET RELIEF VLV 4770A 3 N C A .75 TRV SA 1250-1 (E-10) C O NA RT 10Y GMP-37-06-125/RV ATTOM COOLER SW OUTLET RELIEF VLV 4770A 3 N C A .75 TRV SA 1250-1 (E-10) C O NA RT 10Y GMP-37-06-125/RV RHR PUMP COOLING FAN A SW OUTLET RELIEF VLV	4759A	2	Ν	D	Α	.75	RPD	SA	1250-3 (D-7)	С	0	NA	RD	5Y		P311072	
REACTOR COMPARTMENT COOLER A SW RELIEF VLV RUPTURE DISC 4770 3 Y C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV CNMT PENETRATION COOLER SW OUTLET RELIEF VLV 4770A 3 N C A .75 TRV SA 1250-1 (E-10) C O NA RT 10Y GMP-37-06-125/RV RHR PUMP COOLING FAN A SW OUTLET RELIEF VLV		_		_						-	-			• •			
4770 3 Y C A .75 TRV SA 1250-1 (G-11) C O NA RT 10Y GMP-37-06-125/RV CNMT PENETRATION COOLER SW OUTLET RELIEF VLV 4770A 3 N C A .75 TRV SA 1250-1 (E-10) C O NA RT 10Y GMP-37-06-125/RV RHR PUMP COOLING FAN A SW OUTLET RELIEF VLV	REACTOR CO	MPARTM	ENT	COOL	ER A S	SW RELIE	EF VLV RUF	TURE DISC									
CNMT PENETRATION COOLER SW OUTLET RELIEF VLV 4770A 3 N C A .75 TRV SA 1250-1 (E-10) C O NA RT 10Y GMP-37-06-125/RV RHR PUMP COOLING FAN A SW OUTLET RELIEF VLV 3 N C GMP-37-06-125/RV	4770	3	Υ	С	А	.75	TRV	SA	1250-1 (G-11)	С	0	NA	RT	10Y		GMP-37-06-125/RV	
CNMT PENETRATION COOLER SW OUTLET RELIEF VLV 4770A 3 N C A .75 TRV SA 1250-1 (E-10) C O NA RT 10Y GMP-37-06-125/RV RHR PUMP COOLING FAN A SW OUTLET RELIEF VLV A																	
4770A 3 N C A .75 TRV SA 1250-1 (E-10) C O NA RT 10Y GMP-37-06-125/RV RHR PUMP COOLING FAN A SW OUTLET RELIEF VLV	CNMT PENET	RATION C	OOL	ER SV	V OUT	LET REL	IEF VLV										
RHR PUMP COOLING FAN A SW OUTLET RELIEF VLV	4770A	3	Ν	С	A	.75	TRV	SA	1250-1 (E-10)	С	0	NA	RT	10Y		GMP-37-06-125/RV	
			ΔΝΙ Δ	SW C) I TI E.												
	1770B	2		<u> </u>		75		64	1250 1 (D 10)	C	0	ΝΑ	DT	101		CMD 27 06 125/D\/	
$\frac{1}{100}$		3	IN	U	А	.15	117.1	34	1230-1 (D-10)	C	0	INA	ΓI	101		GIVIT -3/-00-123/KV	
RHR PUMP COOLING FAN B SW OUTLET RELIEF VLV	RHR PUMP CC	OLING F	AN B	SW C	UTLE	T RELIEF	- VLV										

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID						Valve	Actuator	Drawing		Positi	on	Required				
Description	Class	Aug	J. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	al Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
4770F	3	Y	С	А	.75	TRV	SA	1250-1 (C-11)	С	0	NA	RT	10Y		GMP-37-06-125/RV	
CHARGING PL	JMP ROO	мсс	OOLEF	RASW		T RELIEF VL	V									
4770G	3	Y	С	А	.75	TRV	SA	1250-1 (F-11)	С	0	NA	RT	10Y		GMP-37-06-125/RV	
CHARGING PL	JMP ROO	мсс	OOLEF	RBSW		T RELIEF VL	V									
4770H	3	Y	D	А	.75	RPD	SA	1250-1 (G-11)	С	0	NA	RD	5Y		P312031	
CNMT Penetrat	tion Coole	er SW	Outlet	t Relie	f Valve - I	Rupture Disk										
4770J	3	Ν	D	А	.75	RPD	SA	1250-1 (D-10)	С	0	NA	RD	5Y		Rep Task P311167	
RHR Pump Coo	oling Fan	A SW	/ Outle	t Relie	f Valve -	Rupture Disk	c									
4770L	3	Ν	D	А	.75	RPD	SA	1250-1 (D-10)	С	0	NA	RD	5Y		Rep Task P311168	
RHR Pump Coo	oling Fan	B SW	/ Outle	t Relie	f Valve -	Rupture Disk	C									
4770T	3	Y	D	А	.75	RPD	SA	33013-1250,1 (C-11)	С	0	NA	RD	5Y		P312042	
CHARGING PL	JMP ROO	мсс	OOLEF	RASW		T RUPTURE	DISK	(0-11)								
4770V	3	Y	D	А	.75	RPD	SA	33013-1250,1 (F-11)	С	0	NA	RD	5Y		P312043	
CHARGING PL	JMP ROO	мсс	OOLEF	RASW		T RUPTURE	DISK	(=)								
4780	3	Ν	В	А	8	BTF	MO	1250-1 (C-2)	0	С	AI	DIAG	MOV		MA-AA-723-300-1006	
SCREEN HOUS	SE SW IS		ту мс)\/-478	30							SC/SO	18M		STP-0-2.3	
	02 011 10	02.	20 100									STC	18M		STP-O-2.3	
8681	3	Ν	С	А	.75	TRV	SA	1250-2 (C-8)	С	0	NA	RT	10Y		GMP-37-06-125/RV	
SFP HX B SW	OUTLET	RELIE	EF VL	V												
8681A	3	Ν	D	А	.75	RPD	SA	33013-1250,2 (C-6)	С	0	NA	RD	5Y		P311194	
SFP HX B SW	Outlet Rel	lief VI	LV Rup	oture D	Disk			(0 0)								
8689	3	Y	В	А	10	BTF	М	1250-2 (E-9)	0	O/C	NA	EC/EO	2Y		STP-O-2.10.11	
SFP HX B SW	OUTLET	ISOL	VLV													
9627A	3	Ν	С	А	4	СК	SA	1250-2 (A-6)	С	O/C	NA	CP CP	CM		STP-O-36QC	CVCMP
SW INLET CHE	ECK VLV	TO S	TAND	BY AU	X FW PL	IMP ROOM						D&I	CM		GMP-37-53-150/4/CV	

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

Valve ID						Valve	Actuator	Drawing		Position F		Required				
Description	Class	Aug	. Cat.	A/P	Size	Туре	Туре	& Coord	Norma	I Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
9627B	3	Ν	С	А	4	СК	SA	1250-2 (B-6)	С	O/C	NA	CP CP	CM CM		STP-O-36Q-D STP-O-36-COMP-D	CVCMP
SW INLET CHE	CK VLV	TO ST	FANDE	BY AU	X FW PU	IMP ROOM						D&I	CM		GMP-37-53-150/4/CV	
9632A	3	Ν	В	А	1.5	GA	AO	1250-2 (E-9)	С	0	0	FO FO	Q		STP-O-36QC STP-O-36-COMP-C	
SAFW PUMP ROOM COOLING UNIT A SW OUTLET FLOW CONTROL AOV								V				SC/SO SC/SO	QQ		STP-O-36QC STP-O-36-COMP-C STP-O-36OC	
												STO	Q		STP-O-36-COMP-C	
9632B	3	Ν	В	А	1.5	GA	AO	1250-2 (E-10)	С	0	0	FO FO	Q Q		STP-O-36Q-D STP-O-36-COMP-D	
SAFW PUMP RO	ООМ СО	OLIN	g uni	T B S\	W OUTLE	ET FLOW CC	ONTROL AC	V				SC/SO SC/SO STO STO	Q Q Q Q Q		STP-O-36Q-D STP-O-36-COMP-D STP-O-36Q-D STP-O-36-COMP-D	
9634B	3	Ν	В	А	2	GL	М	1250-2 (F-10)	С	0	NA	EC/EO	2Y		STP-O-2.10.11	
SAFW PUMP RO	OOM CL	G UN	ITS A	& B S\	N ISOL V	LV TO RET	JRN HDR									

Exelon Generation (R. E. Ginna Nuclear Power Plant)

Unit 1

Valve Table

WDG - WASTE DISPOSAL - GAS

Valve ID						Valve	Actuator	Drawing		- Positi	ion	Required				
Description	Class /	Aug.	Cat.	A/P	Size	Туре	Туре	& Coord	Norma	l Safety	Fail-Safe	Test	Frequency	RR/CSJ/ROJ	Procedure	Comments / Notes
14	SSC	Ν	В	А	2	GL	AO	1273-2 (I-3)	С	С	С	FC	Q 2V		STP-O-2.5	
GAS DECAY TAN	IK RELE	ASE	AOV	TO PL	ANT VEN	T VIA CHA	RCOAL FILT	ER				SC/SO	Q		STP-0-2.5 STP-0-2.5	

Attachment 16

Check Valve Condition Monitoring Plan Index

IST Program Plan R. E. Ginna Nuclear Station Sixth Interval

<u>CVCM PLAN</u> NUMBER	<u>REV #</u>	TITLE
AFW-001	0	4014, 4016, 4017
AFW-002	0	3998, 4010
AFW-003	0	4009
AFW-004	0	4304A, 4310A
AFW-005	0	4000C, 4000D
AFW-006	0	4003, 4004
AFW-007	0	3996
CCW-001	0	Deleted
CS-002	0	862A, 862B
CVCS-001	0	Deleted
DFO-001	0	5960A, 5960B
FP-001	0	9229
IA-001	0	5393
MS-001	0	3504B, 3505B
PWT-001	0	8419
RCP-001	0	528
RCP-002	0	529
RHR-001	0	854
SAFW-001	0	9700A, 9700B, 9705A, 9705B
SAFW-002	0	9704A, 9704B
SI-001	0	842A, 842B, 867A, 867B
SI-002	0	8623
SW-001	0	9627A, 9627B
SW-002	0	Deleted