	Marcl 12, 1974						
	ERATING STATUS						
	REPORTING PERIOD: February 1		ebruary 28				
	GROSS HOURS IN REPORTING PERIOD: 672						
	CURRENTLY AUTHORIZED POWER LEVEL MWt 2568 MWe-L-T						
	POWER LEVEL TO WHICH RESTRICTED (IF A	NY): No	one				
	REASONS FOR RESTRICTIONS (IF ANY): Oconee Unit 2 is presently in power exoperable. Items 10-13 are not applications	THIS	TR-TO-DATE	CUMULATIVE			
	HOURS REACTOR WAS CRITICAL	0	85.6	743.0			
	HOURS GENERATOR ON-LINE	0	64.0	577.2			
	GROSS THERMAL POWER GENERATED (MWH)	0	104099	709271			
	GROSS ELECTRICAL POWER GENERATED (MWI		33000	209310			
	NET ELECTRICAL POWER GENERATED (MINIT)		23612	175899			
	REACTOR AVAILABILITY FACTOR (1)	100					
	PLANT AVAILABILITY FACTOR (2)						
	PLANT CAPACITY FACTOR (3)						
	FORCED OUTAGE RATE (4)						
SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE AND DURATION OF EACH):							
	IF SHUTDOWN AT END OF REPORT PERIOD,	ESTIMATED	DATE OF STA	RTUP:			
		EDCTAT OPE	RATION) REPO	RT THE FOLLO			
	PLANTS IN TEST STATUS (PRIOR TO COMM	ENGINE OFF					
	DA	TE LAST RECAST	DATE	REASON FOR DIFFERENCE			
	DA	TE LAST	DATE				
	DA PO	TE LAST	DATE ACHIEVED				
	INITIAL CRITICALITY  INITIAL ELECTRICAL POWER GENERATION	TE LAST	DATE ACHIEVED 11/11/73				
	INITIAL CRITICALITY  INITIAL ELECTRICAL POWER GENERATION  COMMERCIAL OPERATION  PRACTOR AVAILABILITY FACTOR = HOURS	TE LAST RECAST /15/74 REACTOR W/	DATE ACHIEVED 11/11/73 12/5/73	DIFFERENCE *100			
1)	INITIAL CRITICALITY  INITIAL CRITICALITY  INITIAL ELECTRICAL POWER GENERATION  COMMERCIAL OPERATION  REACTOR AVAILABILITY FACTOR = HOURS GROSS  PLANT AVAILABILITY FACTOR = HOURS GE	TE LAST RECAST  /15/74  REACTOR W/ HOURS IN E	DATE ACHIEVED  11/11/73  12/5/73  AS CRITICAL REPORTING PER PORTING PER PER PORTING PER PORTING PER PER PORTING PER	*100 *100			

8001080 \$35

二年三十二年

SUMMARY:

UNIT NAME Oconee Unit 2

DATE March 12, 1974

REPORT MONTH February, 1974

## PLANT SHUTDOWNS

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	COMMENTS
3	740122	F	672.0	A	В	Reactor coolant pump 2B2 seal failed.
						(1) REASON:  A-EQUIPMENT FAILURE (EXPLAIN)  B-MAINT. OF TEST  C-REFUELING  D-REGULATORY RESTRICTION  E-OPERATOR TRAINING AND  LICENSE EXAMINATION  F-ADMINISTRATIVE  G-OPERATIONAL ERROR  (EXPLAIN)