190

Commonwealth Edison Company

January 17, 1968

Dr. Peter A. Morris, Director Division of Reactor Licensing U. S. Atomic Energy Commission Washington, D.C. 20545

> Subject: Proposed Change No. 15 to the Operating License DPR-2, as Amended - Dkt 50-10

> > Regulatory Suppl File Cy.

Dear Dr. Morris:

Pursuant to 10 CFR 50.59 and paragraph 3.a(4) of License DPR-2, as amended ("DPR-2"), Commonwealth Edison requests that Appendix A of DPR-2 be changed to allow the refueling of the Dresden reactor without the use of cocked rods during fuel insertion as required in "DPR-2."

Reference is made to Proposed Change No. 14 of September 14, 1967 and as revised as of January 17, 1968, wherein the cocked rod refueling accident accident is evaluated.

Revise item "5.b." of Section "D. Power Operation" of Appendix "A" to DPR-2 to read in its entirety:

5. Reactivity Limits

b. With the reactor in any condition, the following shutdown criterion shall be met:

"Stuck Rod" Criterion: At every stage during loading and in the fully loaded configuration, the control rods must provide a shutdown control margin of at leat 0.01 Ak with any rod wholly out of the core and completely unavailable.

Revise item "3" of Section "E. <u>Refueling and Maintenance</u>" by deletion of the second sentence of said paragraph 3, and the addition of the following sentence:

> The loading procedures shall require verification that the reactor is safely subcritical by withdrawing and re-inserting a control rod in the vicinity of the refueling activity before and after each fuel addition.

8008250 829

Dr. Peter A. Morris

January 17, 1968

• The justification for this proposed change was submitted originally as the answer to Question 2 in Supplement A to the Description and Safety Evaluation Report for Proposed Change No. 14 to DPR-2; however, in the interest of continuity and clarity the answer to Question 2 of said report is restated below:

"The fact that the Type VI-I fuel assembly reactivity is greater than for previous Dresden fuel necessitated the re-examination of the refueling accident. The accident postulated is the lowering of a fuel assembly at the maximum design hoist rate into a near-critical core during refueling. The refueling accident has been hypothesized from a number of procedure violating circumstances and represents an accident of extremely low probability. Conservative assumptions for this analysis are as follows:

- Two control rods, next to the fuel position to be loaded, have inadvertently been withdrawn to give a near critical 2 x 4 fuel assembly array with one center fuel assembly missing. The members of the refueling crew fail to note that these two control rods are withdrawn and start to load a fuel assembly into the vacant position.
- 2. The reactor operator in the control room fails to notice the indications from his instruments that the control rods are out and that the reactor is near critical prior to loading. Procedures require him to observe this instrumentation and to be in communication with the members of the refueling crew during all fuel loading operations.
- The assembly is inserted into the vacant fuel position at the maximum design rate of the hoist, 12 in/sec.
- 4. The fuel assembly reactivity worth is 1.5% k. Analysis indicates that this is the maximum potential reactivity worth for Type VI-I fuel in the reload array shown in Fig. 2 of the Safety Evaluation Report.
- 5. The period scram circuitry fails.
- The initial fuel and moderator temperature is 68°F. The power level at initial criticality is 10°8 times rated power (i.e., 7 watts).
- 7. The calculational model includes no negative reactivity feedback effect from moderator or clad Leating or void formation. Only negative Doppler feedback is considered. Control rod motion is assumed not to start until 0.2 seconds after the scram signal of 120% of rated power.

.

Based on the above assumptions the calculations indicate that the maximum radially averaged fuel 'emperature in any fuel rod would be less than 2800°F, and the corresponding maximum central fuel temperature would be less than 3200°F. Clad temperatures will not exceed 2200°F. No fuel or clad melting is expected in this accident. The rapid power rise during the accident is terminated by the negative Doppler reactivity due to the fuel temperature rise, and the reactor is subsequently brought subcritical by the overpower scram. It will be noted that this accident is less severe than the one reported in the Cycle 4 Safety Evaluation Report for III-F fuel because a smaller number of fresh fuel assemblies are loaded into the core at BOC 6 than at BOC 4, and because of the higher exposure accumulated in the remaining assemblies.

Analysis of the equivalent accident, but without scram, indicates that bulk fuel melting would occur in several rods of two fuel assemblies, but that the peak fuel enthalpy rise would be insufficient to produce explosive fuel rod rupture."

Therefore, in consideration of the foregoing analysis, it is proposed that:

- The license requirement for "cocked rods" during refueling operations be eliminated.
- The fuel loading procedures be modified to require verification that the reactor is safely subcritical by withdrawing and re-inserting a control rod in the vicinity of the refueling activity before and after each fuel addition.
- 3. Control rod withdrawal during movement of the fuel ever/or into the reactor core be prohibited.

In our opinion Proposed Change No. 15 shall not result in hazards which are greater than or different from, those analyzed in the Hazards Summary Report, specifically there is (1) no increase in the probability of, or (2) no increase in the consequence of, Dr. Peter A. Morris

- 4 -

January 17, 1968

or (3) the creation of a credible probability of an accident different from, those accidents previous.y analyzed in the Hazards Summary Report as amended or in connection with the amendments and changes to Operating License DPR-2.

Very truly yours,

COMMONWEALTH EDISON COMPANY

esher BV

John H. Hughes Nuclear Licensing Administrator

Subscribed and sworn to before me this 17 day of anuary, 1968.

My Commission Expires October 14, 1969

votary Public

FROM: Constantealth Sdison Chicago, Ill. John H. Haghes To: Norris	DATE OF DOCUMENT	DATE	RECEIVED		NO.:	
	LTR. MEMO: REPORT: OTHER: X notarised 1-17-68					
	ORIG.: CC: OTHER:					
	ACTION NECESSARY	CONCU	CONCURRENCE DAT		DATE ANSWERED	ATE ANSWERED:
CLASSIF.: POST OFFICE REG. NO:	FILE CODE 50-10					
DESCRIPTION: (Must be Unclosefied) Ltr submitted as Proposed Change # 15 req Appendix A, of lie UPB-2 be change to allow the refueling of reactor with- out the use of cocked rods during referive fuel incertion as required Ref. Prosed Change # 11, 9-14-6	REFERRED TO		DATE	REC	EIVED BY	DATE
	INFO CTS TO H.Price & S	or act	1-10-00			
	Horris/Boye	1				
	Skovholt Dabe/Levine	•				
DISTIL - Formal	1					

☆ U. S. GOVERNMENT PRINTING OFFICE: 1966-235-519