

POWER AUTHORITY OF THE STATE OF NEW YORK
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATIONS DEPARTMENT STANDING ORDER

TITLE: INCOMPLETE FIRE MODIFICATIONS*

PROCEDURE NO. 15

REVIEWED BY: Plant Operations Review Committee

Meeting No. 81-016

Date 2/18/81

APPROVED BY:

B. J. M. G. R. G. G. G. G.
Operations Superintendent

Date 2/18/81

APPROVED BY:

R. J. M. G. R. G. G. G.
Resident Manager

Date 2/18/81

TELECOPIED

TO: Phil P. K.

FROM: R. Pasternak

DATE: 2-18-81

TIME:

NUMBER 3 of 8

(301) 492-8110

Rapicom

TELECOPIED

TO: Leo G. G. G. G.

FROM: R. Pasternak

DATE: 2-18-81

TIME: 2:15 p.m.

NUMBER 3 of 8

74-7618

Page No. 1 2 3

Rev. No. 1 0 1

Rev. No. 1

Date 2/18/81

8102250 218

Page 1 of 3
POOR ORIGINAL

POWER AUTHORITY OF THE STATE OF NEW YORK
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATIONS DEPARTMENT STANDING ORDER

TITLE: INCOMPLETE FIRE MODIFICATIONS*

PROCEDURE NO. 15

1.0 PURPOSE:

To ensure proper measures are taken to adequately protect the plant from fire situations while fire modifications are being completed.

2.0 APPLICABILITY:

This procedure applies until the inadequacies due to incomplete fire modifications are completed.

3.0 REFERENCES:

3.1 Letter J. P. Bayne (PASNY NYO) to T. A. Ippolito (NRC) dated February 11, 1981.

3.2 Operating Procedure F-OP-56, Relay Room Ventilation

3.3 Surveillance Test F-ST-400, Daily Surveillance Report

4.0 DEFINITIONS:

None.

5.0 RESPONSIBILITIES:

5.1 Each member of the fire brigade is responsible to ensure this procedure is carried out.

5.2 The Operations Department Superintendent is responsible to ensure training is complete on this standing order.

6.0 SPECIAL INSTRUCTIONS:

None.

7.0 PROCEDURE:

7.1 In the event of a fire in the relay room, the relay room ventilation will be immediately shut down in accordance with F-OP-56.

POWER AUTHORITY OF THE STATE OF NEW YORK
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATIONS DEPARTMENT STANDING ORDER

TITLE: INCOMPLETE FIRE MODIFICATIONS*

PROCEDURE NO. 15

- 7.2 In the event a fire alarm is received for RCIC or HPCI area, immediately initiate sprays to the associated area, also a foam cart shall be kept in reactor building 272' area.
- 7.3 New detector panels will be checked once per hour and any alarm investigated. The check shall also include power available light on. This will be added to surveillance test F-ST-400 (see Appendix A).
- 7.4 Fire doors will be checked once per shift. This will be signed off on F-ST-400 (see Appendix B).
- 7.5 Weekly, the ionization detector panel remote alarms will be tested by placing test/reset switch in test position and ensuring remote control room alarm is activated. This will be signed off on F-ST-400.

8.0 FIGURES:

None.

9.0 EXHIBITS:

None.

POOR ORIGINAL

4. Loads

The primary loads imposed on the block walls were due to seismic events. Two levels of earthquakes were used - Operating Basis Earthquake, OBE and the Design Basis Earthquake, DBE, (2 times OBE). The loads obtained for the DBE were reduced by 2/3 to account for the 50 percent increase in allowable stresses. No increase in allowable stresses were permitted for the OBE.

The seismic loads were computed using the following basis:

- 4.1. Damping of 0.5 percent for OBE and DBE. This is highly conservative by today's standards.
- 4.2. Cracked moment of inertia for frequency calculation.
- 4.3. One way action for frequency calculation.
- 4.4. Boundary conditions: Simply supported or fixed at bottom and simply supported or free at top depending on the construction details at the top and bottom. Fixity was assumed when reinforcement was doweled into supporting concrete element. Simple supports were assumed when the walls were supported by steel support angles on both sides and separation between the wall and structural element was achieved by a joint filler.
- 4.5. The accelerations obtained from the response spectra were further increased to account for overall torsional effects of the buildings. These multiplying factors were obtained from the John A. Blume & Associate Report for the Kewaunee Plant, December 1968.

5. Allowable Stresses

Working stress method has been used in the design of masonry walls.

The allowable stresses used were taken from the 1957 Edition of the Uniform Building Code, Table No. 24-H under the requirement of special inspection. The value of f_m' was taken equal to 1350 psi per UBC-67.

Compression flexural	$= 0.33 f_m'$	$= 450 \text{ psi}$
Bond		$= 140 \text{ psi}$
Shear (No shear reinforcement)		$= 50 \text{ psi}$

6. Analysis Method

The stresses in the block walls were computed using one way action of the walls (spanning vertically). Typical boundary conditions used were:

<u>Top</u>	<u>Bottom</u>
Free	Fixed
Simply Supported	Simply Supported
Simply Supported	Fixed

LOCAL FIRE PANELS

- 1) 76 CP-132 Location: Rx Building El. 272' N.E. Corner

ZONESDESCRIPTION

1	West Crescent Area
1A	RCIC Enclosure
2	East Crescent Area
2A	HPCI Enclosure
3	S.E. Rx Bldg. El. 272'
4	S.W. Rx Bldg. El. 272'
5	N.W. Rx Bldg. El. 272'
6	N.E. Rx Bldg. El. 272'
7	East RHR Hx. Room
8	Drywell Access Hatch Area
9	CRD Decon. Room
10	West RHR Hx. Room
12	Railroad Air Lock
13	Standby Gas Treatment
14	MCCs 151/132 & 161/142

NOTE: Zone 11 does not exist.

- 2) 76 CP-133 Location: Rx Bldg. El. 300' N.E. Corner

ZONESDESCRIPTION

15	S.E. Rx Bldg. El. 300'
16	S.W. Rx Bldg. El. 300'
17	N.W. Rx Bldg. El. 300'
18	N.E. Rx Bldg. El. 300'
20	RMCU Heat Exch. Room
21	Clean-up Decant Pump Room
25	S.E. Rx Bldg. El. 326'
26	S.W. Rx Bldg. El. 326'
27	N.W. Rx Bldg. El. 326'
28	N.E. Rx Bldg. El. 326'
31	Fuel Pool Hx. Room
32	Cont. Equip. Storage

- 3) 76 UV-1 Location: Recirc. MS Set Area S.E. Corner

ZONEDESCRIPTION

24	Fire at MS Set A or B
----	-----------------------

POOR ORIGINAL

APPENDIX A

Sheet 2 of 3

LOCAL FIRE PANELS

4) 76 CP-134

Location: Rx Bldg. Et. 344'-6" N.E. Corner

ZONES

DESCRIPTION

35	S.E. Rx Bldg. Et. 344'-6"
36	S.W. Rx Bldg. Et. 344'-6"
37	N.E. Rx Bldg. Et. 344'-6"
38	N.W. Rx Bldg. Et. 344'-6"
41	Change Room Et. 266'
43	S. LPCI Inverter Area Et. 344' ("B" Side)
44	N. LPCI Inverter Area Et. 344' ("A" Side)
47	S.E. Rx Bldg. Et. 369'-0"
48	S.W. Rx Bldg. Et. 369'-0"
49	N.W. Rx Bldg. Et. 369'-0"
50	N.E. Rx Bldg. Et. 369'-0"
61	Refuel Exhaust Duct

5) 76 CP-135

Location: Relay Room Et. 266' at North Wall Below Stair

ZONES

DESCRIPTION

74A	West Batt Room
74B	East Batt Room
75	West Batt Chrg Room
76	East Batt Chrg Room
77	Batt Room Corridor

6) 76 CP-137

Location: Operations Office

ZONES

DESCRIPTION

54	Control Room Air Intake
55	Control Room Chiller Area

7) 76 CP-2

Location: Foam Room Et. 272' T.S.

ZONES

DESCRIPTION

61	West Cable Tunnel
62	West Cable Tunnel
63	West Cable Tunnel
64	East Cable Tunnel
65	East Cable Tunnel
66	East Cable Tunnel
70	West Switchgear Room
71	East Switchgear Room
72	Emergency Swgr Room South
73	Emergency Swgr Room North
80	Diesel Fire Pump Room
81	Radwaste Sample Room

POOR ORIGINAL

LOCAL FIRE PANELS

8) 76 CP-136 Location: Foam Room E1. 272' T.B.

ZONESDESCRIPTION

78 S. Safety Pump Room
 79 N. Safety Pump Room

9) 76 CP-1 Location: Instrument Shop Admin. Bldg. E1: 300'

ZONESDESCRIPTION

42 Batt Room South
 43 Batt Room North
 53 Control Room & AC Equipment Room
 57 Relay Room E1. 284'
 58 Cable Spreading Room E1. 272'
 60 Cable Run Room South E1. 286'
 69 Cable Run Room North E1. 286'

POOR ORIGINAL

SUPERVISED FIRE DOORS

<u>DOOR NUMBER</u>	<u>DESCRIPTION OF LOCATION</u>
R227/1	West Wall of HPCI Enclosure
R227/2	East Wall of HPCI Enclosure
R227/3	West Wall of RCIC Enclosure
R227/4	East Wall of RCIC Enclosure
R272/15	Spiral Stairway Enclosure
R272/10	Door between SSGT & Track Bay
R300/4	Airlock Doors between Recirc MG Set Room and Reactor Building
HB272/2	A Side Batt Chgr Room
HB272/3	A Side Batt Room
HB272/4	B Side Batt Room
HB272/5	B Side Batt Chgr Room
D6256/1	North Entrance to West Cable Tunnel
D6272/2	Door Between Emerg Gwgr Rooms A & B
D6272/3	Diesel Gen. "D" Room
D6272/4	Diesel Gen. "B" Room
D6272/5	Diesel Gen. "C" Room
D6272/6	Diesel Gen. "A" Room
E286/3	Door Between A & B Elet. Bay Fan Rooms
A286/23	North Cable Run Room (Off Relay Room)
A286/24	South Cable Run Room (Off Relay Room)
A300/16	Control Room Stairs from Relay Room
TP255/2	Elec. Fire Pump Room to Elect. Tunnel
SP255/4	Fire Door Between A & B Service Water Pump Rooms
SP255/6	Fire Door Between Diesel Fire Pump Room and Screenwell

POOR ORIGINAL

ATTACHMENT TO F-ST-400

SEE OPS DEPARTMENT STANDING ORDER NO. 15, STEP 7.3

DATE _____

TIME

SIGNATURE

0100

0200

0300

0400

0500

0600

0700

0800

0900

1000

1100

1200

1300

1400

1500

1600

1700

1800

1900

2000

2100

2200

2300

2400

POOR ORIGINAL