

November 12, 1981

Docket No. 50-461

Illinois Power Company
ATTN: Mr. W. C. Gerstner
Executive Vice President
500 South 27th Street
Decatur, IL 62525



Gentlemen:

This refers to the routine safety inspection conducted by Mr. H. H. Livermore of this office on September 1-30, 1981, of activities at the Clinton Power Station, Unit 1, authorized by NRC Construction Permit No. CPPR-137 and to the discussion of our findings with Mr. M. C. Hollon and others of your staff at the conclusion of the inspection, and to the October 27, 1981 telephone conversation between Mr. R. C. Knop of this office with Mr. L. C. Koch of your staff in regard to the inspection findings.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in non-compliance with NRC requirements, as specified in the enclosed Appendix A. A written response, submitted under oath or affirmation is required.

With regard to Item No. 1 of Appendix A, we are concerned about the timeliness and effectiveness of your corrective action on this recurring item. In your response we request that you provide the following additional information: (1) a detailed timetable to assure that all installed equipment (i.e. electrical, mechanical, HVAC, etc.) will be inspected/surveyed to verify that nonsafety related installations do not pose a safety concern to safety related installations, (2) a program to assure that timely inspections/surveys are performed as equipment installation progresses, (3) acceptance criteria relating to system interaction for all equipment previously installed, and (4) documentation indicating that each item of safety related equipment has been inspected to verify that nonsafety related equipment will not interfere with safe plant operations during a postulated seismic event. Further, we request that you notify our Senior Resident Inspector of your plans concerning the disposition of discrepancies identified during the performance of this program.

Certain other activities, set forth in Appendix B to this letter, appear to be a deviation from commitments which you have made in previous correspondence with the Commission. Please advise us in writing within twenty-five days of the date of this letter of the corrective action you have taken

8111240708 811112
PDR ADDCK 05000461

JE01


OFFICE	KILL	KILL	RIII	RIII			
SURNAME	Reimann, Rl	Knop	Warnick	Speppard			1/1
DATE	11/10/81	11/9/81					

or plan to take, showing the estimated date of completion with regard to this deviation.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter, the enclosures and your response to this letter will be placed in the NRC's Public Document Room. If the enclosures contain any information that you or your contractors believe to be exempt from disclosure under 10 CFR 9.5(a)(4), it is necessary that you (a) notify this office by telephone within seven (7) days from the date of this letter of your intention to file a request for withholding; and (b) submit within twenty-five (25) days from the date of this letter a written application to this office to withhold such information. Section 2.790(b)(1) requires that any such application must be accompanied by an affidavit executed by the owner of the information which identifies the document or part sought to be withheld, and which contains a full statement of the reasons which are the bases for the claim that the information should be withheld from public disclosure. This section further requires the statement to address with specificity the considerations listed in 10 CFR 2.790(b)(4). The information sought to be withheld shall be incorporated as far as possible into a separate part of the affidavit. If we do not hear from you in this regard within the specified periods noted above, a copy of this letter, the enclosures, and your response to this letter will be placed in the Public Document Room.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,



R. L. Spessard, Director
Division of Resident and
Project Inspection

Enclosures:

- 1. Appendix A, Notice of Violation
- 2. IE Inspection Report No. 50-461/81-24

cc w/encls:

DMB Document Control Desk (RIDS)
Resident Inspector, RIII
Mary Jo Murray, Office of
Assistant Attorney General
Gary N. Wright, Manager
Nuclear Facility Safety

Randall L. Plant, Prairie
Alliance

OFFICE ▶	Randall L. Plant, Prairie Alliance				
SURNAME ▶					
DATE ▶					