

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

USNRC REGION II  
ATLANTA, GEORGIA

81 NOV 18 4 8: 03

November 16, 1981

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE  
REPORT SQRO-50-327/81127

The enclosed report provides details concerning the pressurizer pressure  
and level transmitters' instrument settings which were found to be less  
conservative than those established by the limiting condition for  
operation 2.2.1 due to instrument drift. This report is submitted in  
accordance with Sequoyah unit 1 Technical Specification 6.9.1.13.a.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*J. A. Green*  
J. J. Green  
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Director (40)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Records Center  
Institute of Nuclear Power Operations  
1820 Water Place  
Atlanta, Georgia 30339

NRC Inspector, Sequoyah

OFFICIAL COPY

*IE 22*  
*5*  
*1/1*

8111240776 811116  
PDR ADOCK 05000327  
S PDR