

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
1750 Chestnut Street Tower II
ATLANTA, GEORGIA

81 NOV 18 4 8:03

November 13, 1981

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET
NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE OCCURRENCE
REPORT BFRO-50-296/81039 REVISION 1

The enclosed report is a supplement to my letter dated September 14, 1981,
concerning turbine first-stage permissive switch 3-PS-1-81A which was
found to be 3 percent above the limits of Technical Specification 3.1.A.
This report is submitted in accordance with Browns Ferry unit 3 Technical
Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY


H. J. Green
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Records Center
Institute of Nuclear Power Operations
1820 Water Place
Atlanta, Georgia 30339

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry



OFFICIAL COPY

IE 22

8111240850 811112
PDR ADOCK 05000296
S PDR

An Equal Opportunity Employer