

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | F | L | T | P | S | 3 | 0 0 | - | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

CON T | 0 1 | R | E | P | O | R | T | S | O | U | R | C | E | L | 0 | 5 | 0 | 0 | 0 | 2 | 5 | 0 | 1 | 0 | 1 | 6 | 8 | 1 | 1 | 1 | 1 | 6 | 8 | 1 | 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | During a routine visual inspection pursuant to TS 4.15.4.a.1, an electrical
0 3 | penetration fire barrier on the west wall of the 3A 4160V Switchgear room
0 4 | was found to be non-functional. A fire watch patrol was established in
0 5 | accordance with the requirements of TS 3.14.4.a while repairs were completed.
0 6 | Similar LERs were reported as LER 250-81-011 and LER 250-80-007.
0 7 |
0 8 |

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP TURB CODE | VALVE SUBCODE
9 10 11 12 13 14 15 16 17 18 19 20
A B 11 | A 12 | E 13 | X X X X X X X 14 | Z 15 | Z 16
17 LER/RO REPORT NUMBER | 8 1 | 0 1 4 | 0 3 | L | 0
21 22 23 24 25 26 27 28 29 30
ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRO-4 FORM SUB | PRIME COMP SUPPLIER | COMPONENT MANUFACTURER
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
D 18 | Z 19 | Z 20 | Z 21 | 0 0 0 0 | N 23 | N 24 | Z 25 | Z 9 9 9 9 25

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | The root cause of the non-intact electrical penetration fire barrier was in-
1 1 | complete installation work. All electrical penetration fire barriers
1 2 | defined by TS 3.14.4.a are now functional. Both plant and contract maint-
1 3 | enance personnel will be re-instructed in the necessity for compliance
1 4 | with Maintenance Procedure 0725, Fire Stop and Cable Tray Fireproofing.

1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION
7 8 9 10 11 12 13 14 15 16 17 18 19 20
G 13 | 0 0 0 29 | NA | B 31 | Operator Observation 32
21 22 23 24 25 26 27 28 29 30
1 6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE
7 8 9 10 11 12 13 14 15 16 17 18 19 20
Z 33 | Z 34 | NA | NA 36

1 7 | PERSONNEL EXPOSURES | DESCRIPTION
7 8 9 10 11 12 13 14 15 16 17 18 19 20
0 0 0 37 | Z 38 | NA 39

1 8 | PERSONNEL INJURIES | DESCRIPTION
7 8 9 10 11 12 13 14 15 16 17 18 19 20
0 0 0 40 | NA 41

1 9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION
7 8 9 10 11 12 13 14 15 16 17 18 19 20
Z 43 | NA 43

2 0 | PUBLICITY ISSUED | DESCRIPTION | NRC USE ONLY
7 8 9 10 11 12 13 14 15 16 17 18 19 20
N 44 | NA 45

NAME OF PREPARER P. L. Pace PHONE (305) 552-3654

8111240861 811116
PDR ADOCK 05000250
S PDR