NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: N Y N M P 1 (2) LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE TYPE: 4 1 1 1 1 (4) CAT (5)
CON'T 0 1	REPORT SOURCE: L (6) DOCKET NUMBER: 0 5 0 0 0 2 2 0 (7) EVENT DATE: 0 7 1 5 8 1 (8) REPORT DATE: 1 1 2 5 8 1 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal operation No. 11 Reactor Building Ventilation Duct Radiation Monitor
0 3 experienced off-normal spiking which initiated the Emergency Ventilation System. This
0 4 is reported under Tech. Spec. 3.6.2, which requires initiating of the Emergency Ventila-
0 5 tion System upon a signal greater than the setpoint of 5 mr/hr. Because the system
0 6 operated as it was designed, safety consequences were minimal.
0 7
0 8

	SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
0 9	A A	E	E	I N S T R U	E	Z

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 5 0	/	0 3	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
A	Z	Z	Z	0 0 0 0	N	N	N	G 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 No. 11 Emergency Ventilation Monitor initiated the Emergency Ventilation System because
1 1 of a malfunctioning sensor - convertor unit. The unit was replaced and calibrated
1 2 with satisfactory results.
1 3
1 4

	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
1 5	E	0 9 8	NA	A	Operator Observation

	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z	Z	NA	NA

PERSONNEL EXPOSURES

	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
1 7	0 0 0	Z	NA

PERSONNEL INJURIES

	NUMBER (40)	DESCRIPTION (41)
1 8	0 0 0	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE (42)	DESCRIPTION
1 9	Z	NA

8112080303 811125
PDR ADOCK 05000220
S PDR

PUBLICITY

	ISSUED (44)	DESCRIPTION (45)	NRC USE ONLY
2 0	N	NA	

NAME OF PREPARER Kevin McLaughlin PHONE: (315)343-2110, X1595

GPO 917-926