NRC FORM 366 (7-77)

LICENSEE EVENT REPORT

3/30

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I L Z I S 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)

7 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

C

0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 0 4 (7) | 0 2 2 7 8 1 (8) | 0 3 2 7 8 1 (9)

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During routine surveillance of purge iodine rad monitor 2RT-PR09B, the

0 3 monitor was found reading low by a factor of almost 3. Since the rad

0 4 monitor is not the official quantitative value of activity released

0 5 (which is instead determined by grab sampling), this occurrence has no

0 6 effect on records nor data of previous Unit 2 purges. Thus there were

0 7 no safety implications and the health and safety of the public were not

0 8 affected.

7 8 9 80

0 9 | SYSTEM CODE B B (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE X (15) | VALVE SUBCODE Z (16)

7 8 9 10 11 12 13 18 19 20

(17) LER RO REPORT NUMBER | EVENT YEAR 8 1 | — | SEQUENTIAL REPORT NO. 0 0 2 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN B (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER N 3 0 5

33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The rad monitor was recalibrated to within tolerance. It is unknown

1 1 What caused the low reading but it was probably just normal electronic

1 2 variation. The monitor was placed back in service. This is not a

1 3 recurring problem. No further action is necessary.

1 4

7 8 9 80

1 5 | FACILITY STATUS E (28) | % POWER 0 8 9 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Instrument Re-calibration

7 8 9 10 12 13 44 45 46 80

1 6 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

7 8 9 10 11 44 45 80

1 7 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

7 8 9 11 12 13 80

1 8 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

7 9 11 12 80

1 9 | LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) | DESCRIPTION NA

7 8 9 10 80

8112090097 810327
PDR ADOCK 05000304
S PDR

2 0 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

7 8 9 10 68 69 80

Fred Ost 312 746-2084