

NOV 20 1981

Docket No. 99900757/81-01

Klockner-Moeller  
Atlanta Plant  
ATTN: Mr. H. P. Bearer  
Technical Manager  
1176 Franklin Road  
Marietta, GA 30067



Gentlemen:

This refers to the inspection conducted by H. W. Roberds of this office on September 29-30, 1981, of your facility at Marietta, Georgia, and to the discussions of our findings with you at the conclusion of the inspection.

This inspection was made as a result of the identification at the Grand Gulf Nuclear Station of: (1) 24-inch starter/breaker plug-in drawers installed in 480 volt Motor Control Centers not being seismically qualified; (2) electrical faults in size 3 starters; and (3) use of improper screw sizes in 480 volt Motor Control Center starter relays.

Areas examined during the inspection and our findings are discussed in the enclosed report. Within these areas, the inspection consisted of an examination of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of this inspection, we found no instance where you failed to meet NRC requirements.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room. If this report contains any information that you believe to be exempt from disclosure under 10 CFR 9.5(a)(4), it is necessary that you (a) notify this office by telephone within 10 days from the date of this letter of your intention to file a request for withholding; and (b) submit within 25 days from the date of this letter a written application to this office to withhold such information. If your receipt of this letter has been delayed such that less than seven days are available for your review, please notify this office promptly so that a new due date may be established. Consistent with Section 2.790(b)(1), any such application must be accompanied by an affidavit executed by the owner of the information which identifies the document or part sought to be withheld, and which contains a full statement of the reasons on the basis which it is claimed that the information should be withheld from public disclosure. This section further requires the statement to address with specificity the considerations listed in 10 CFR 2.790(b)(4). The information sought to be withheld shall be incorporated as far as possible into a separate part of the affidavit. If we do not hear from you in this regard within the specified periods noted above, the report will be placed in

OFFICE	RIS	RIS	VIB	DI	RA	
SURNAME	RIS /HRobertds	IBarnes	Uroshapovs	SEG	GUIN	STROTINS
DATE	11/06/81	11/06/81	11/08/81	11/16/81	11/20/81	
						8112090113 811120 PDR GA999 EMVKLOCK 99900757 PDR

11/09

5/1

OFFICIAL RECORD COPY

Klockner-Moeller

2

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Uldis Potapovs, Chief  
Vendor Inspection Branch

Enclosure:

1. Appendix A - Inspection Report No. 99900757/81-01
2. Appendix B - Inspection Data Sheets ( 2 Pages)

bcc:

IE/V&SPB (Reinmuth)

IE Files

AEOD

NMSS

NRC:PDR

QAB

Reg. Directors, I, II, III, V

JEGagliardo, RIV

OFFICE							
SURNAME							
DATE							