

Colt Industries



Fairbanks Morse
Engine Division
701 Lawton Avenue
Beloit, Wisconsin 53511
608/364-4411

50-483

November 30, 1981

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Ill. 60137



Attention: Mr. James G. Keppler, Director, Region III


Subject: Colt Industries-Fairbanks Morse Engine Division
Emergency Diesel Generators
SNUPPS Contract
May 2, 1980 Part 21 Report-Failed Engine Thrust Bearing
Supplemental No. 4-SNUPPS-Callaway Unit #1

Gentlemen:

We have completed our inspection of the two Colt-Pielstick Type PC-2 Diesel Generator Sets for SNUPPS-Callaway Unit #1. These inspections were made to written procedures utilizing the revised drawings mentioned in our May 2, 1980 report which provide adequate clearance. Both units are in compliance with the inspection procedure and are free of the reported potential defect.

A copy of this report is being forwarded to the utility involved.

Very truly yours,


J. M. Moriarty
MANAGER UTILITY SALES

JMM:jc

cc: Bechtel Power Corp.
P. O. Box 607
Gaithersburg, MD 20760
Attention: SNUPPS Project Engineer

U. S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D. C. 20555

8112100335 811130
PDR ADDCK 05000483
Q PDR

IE 195/10
A division of the Colt Industries Operating Corp.

DEC 3 1981