



Commonwealth Edison

DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
D-12-2-81-123				

PART 1 TITLE OF DEVIATION	OCCURRED
Failure of Core Spray Full Flow Test Valve M02-1402-48	11-19-81 0500
	DATE TIME

SYSTEM AFFECTED 1400	PLANT CONDITIONS
Core Spray	MODE Run PWR(MWT) 2487 LOAD(MWE) 816
	TESTING YES NO

DESCRIPTION OF EVENT
While completing core spray surveillance, couldn't maintain pressure through ECCS fill system. Upon investigation, found "B" core spray loop full flow test valve motor operator had fallen off preventing closure of the valve.

DESCRIPTION OF CAUSE
Failure occurred at the weld which attaches the motor operator mounting flange to the valve yoke.

OTHER APPLICABLE INFORMATION
The "A" core spray subsystem, both LPCI subsystems, and the Unit 2 and Unit 2/3 D/C surveillance were successfully completed.

EQUIPMENT FAILURE	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	DR NO.	WR NO.	K. L. Tupman	11-19-81
		N/A	17051	RESPONSIBLE SUPERVISOR	DATE

PART 2 OPERATING ENGINEERS COMMENTS
The "B" core spray subsystem was declared inoperable and isolated to allow pressurization of the remaining ECCS systems from the ECCS jockey pump.

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input type="checkbox"/> 10CFR21	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
<input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.b					

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION
81 - 69/-03L-0		R. M. Ragan 11-19-81 0600
		TITLE DATE TIME
		TITLE DATE TIME

24-HOUR NRC NOTIFICATION (courtesy)	PROMPT OFF-SITE NOTIFICATION
<input checked="" type="checkbox"/> TPH T. Tongue 11-19-81 0800	F. A. Palmer 11-19-81 1340
REGION III DATE TIME	TITLE DATE TIME
<input type="checkbox"/> TGM REGION III & DOL DATE TIME	TITLE DATE TIME

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC

REVIEW AND COMPLETED - John M. Almer OPERATING ENGINEER 11-19-81 DATE

ACCEPTANCE BY STATION REVIEW AS REQUIRED

DATE

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION

Jack Brunner 12/4/81
John M. Almer 12/4/81
Douglas Pitt 12/4/81
 STATION SUPERINTENDENT DATE