

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C B E P 2 0 0 - 0 0 0 0 0 - 0 0 0 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSL NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T 01 RPORT SOURCE L 0 5 0 - 0 3 2 4 7 1 1 1 8 8 1 8 1 2 0 4 8 1 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During routine surveillance it was discovered that suppression chamber water level
03 indicator, 2-CAC-LI-2601-3, was indicating a level which was 4" less than actual, as
04 shown by local indication. This event did not affect the health and safety of the
05 public.
06
07

Technical Specifications 3.3.5.3, 6.9.1.9b

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
I E 11 B 12 A 13 I N S T R U 14 T 15 Z 16
17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 1 1 2 4 0 3 L 0
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 C 19 Z 20 Z 21 0 0 0 0 Y 23 Y 24 N 25 B 0 4 C 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 A change in trickle flow to the wet reference leg of the recorder transmitter, 2-CAC-
11 LT-2601, Model No. B015221, caused the transmitter to function out of calibration
12 tolerances and send an incorrect input signal to the recorder. The trickle flow was
13 properly established, the transmitter was calibrated and returned to service and the
14 recorder was observed for proper operation and was returned to service.

15 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
E 28 0 7 9 NA A 31 Operator Surveillance

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
Z 33 Z 34 NA NA

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
0 0 0 Z NA

18 PERSONNEL INJURIES NUMBER DESCRIPTION
0 0 0 NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
Z NA

20 PUBLICITY ISSUED DESCRIPTION
N NA

8112140025 811204
PDR ADDCK 05000324
S PDR

NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr. PHONE 919-457-9521

LER ATTACHMENT - RO #2-81-124

Facility: BSEP Unit No. 2

Event Date: 11-18-81

As a result of an event involving this instrument on Unit No. 1, reported in LER 1-81-07 and a post-TMI requirement, a plant modification package (1-80-78 for Unit No. 1 and 2-80-99 for Unit No. 2) has been developed. This modification will install a condensing pot in the reference leg in order to increase the accuracy and reliability of this instrument, and remove the requirement to have flow in the reference leg to ensure that it is full.