December 11, 1981

Docket No. 50-295 Docket No. 50-304

Commonwealth Edison Company ATTN: Mr. Cordell Reed Vice President Post Office Box 767 Chicago, IL 60690

Gentlemen:

This refers to the telephone conversation between Messrs. C. Williams and D. Hayes and Mr. K. Graesser and others of our respective staffs on December 11, 1981, regarding Auxilliary Feedwater Pump operability at the Zion Station. With regard to the matters discussed we understand that the Zion Unit 2 reactor will remain in the shutdown condition until you have completed the following:

Identified the cause of the Auxilliary Feedwater Pumps not starting when required on December 11, 1981, and have corrected the problem; or provided assurance that the Auxilliary Feedwater Pumps will start when called upon to do so and this matter is concurred in by this office.

Please inform us immediately if you have any questions concerning this matter.

Sincerely,

James G. Keppler Regional Administrator

CC: Mr. Louis O. DelGeorge
Director of Nuclear Licensing
Nr. K. L. Graesser, Station
Superintendent
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Hary Jo Murray, Office of
Assistant Attorney General
Mayor John B. Spencer
City of Zion

