NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | W I K N P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)

LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T 0 1 REPORT SOURCE L (6) | 0 5 0 0 0 3 0 5 (7) | 1 1 1 3 8 1 (8) | 1 2 1 1 8 1 (9)

DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During surveillance testing on the Shield Building Vent System (SBV), check damper
0 3 SBV-10A failed shut. This train of SBV out of service placed the facility under
0 4 LCO T.S.3.6.b.1(one train of SBV may be out of service for up to 7 days) and thus
0 5 reportable per T.S.6.9.2.b(2). Since the redundant train of SBV was operable,
0 6 there was no effect on public safety or plant operation.
0 7
0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	S H (11)	E (12)	F (13)	V A L V O P (14)	C (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 3 8	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
A (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	A (25)	J 0 9 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The operator failure was the result of a ruptured diaphragm which separates the
1 1 motor from the oil reservoir. The motor was replaced, tested satisfactory, and
1 2 the system returned to service. No further action is required at this time. This
1 3 incident is similar to that reported in Kewaunee LER 81-029.
1 4

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	1 0 0 (29)	NA	B (31)	Surveillance testing

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

8112220383 811211
PDR ADOCK 05000305
S PDR

PUBLICITY ISSUED DESCRIPTION (45)

2 0 N (44) NA

NRC USE ONLY

NAME OF PREPARER C. S. Smoker PHONE (414) 388-2560