

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-344PORTLAND GENERAL ELECTRIC COMPANY ET AL.NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 69 to Facility Operating License No. NPF-1, issued to Portland General Electric Company, the City of Eugene, Oregon, and Pacific Power and Light Company (the licensees), which revised Technical Specifications for operation of Trojan Nuclear Plant (the facility) located in Columbia County, Oregon. The amendment is effective as of the date of issuance.

The amendment: (1) revises the operability requirements for fire detection instruments by identifying the minimum number required to be operable by fire detection zones within each safety-related area; (2) adds operability requirements for fire detection instruments in eight additional areas, and (3) modifies the visual inspection of fire hose stations in areas which are inaccessible during plant operation to require such inspections during each cold shutdown exceeding 24 hours in duration.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since this amendment does not involve a significant hazards consideration.


- 2 -

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated October 8, 1981, (2) Amendment No. 69 to License No. NPF-1 and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. 20555 and at the Multnomah County Library, Social Science and Science Department, 801 SW 10th Avenue, Portland, Oregon 97205. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 24th day of November, 1981.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing