## LICENSEE EVENT REPORT

EXHIBIT A

|       | CONTROL SECOCK:  |
|-------|--|
| 0 1   | C   A   D   C   P   1 3 0 0 0 - 0 0 0 0 0 - 0 0 0 0 0 0 0 0 0  |
| CON'T | SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80   |
| 0 2   | Prior to fuel load during a supervisor's review of surveillance require-   |
| 03    | ments, it was discovered that the Technical Specification Surveillance   |
| 0 4   | Requirement 4.11.2.4.1 to project doses due to gaseous releases from   |
| 0 5   | the plant had not been performed within the required time interval. No   |
| 0 6   | radioactive gaseous waste has been or is being discharged. This event  |
| 0 7   | Lin no way affects public health and safety. Reportable per Technical  |
| 7 8   | Specification Section 6.9.1.13.b.  |
| 0 9   | CODE SUBCODE S |
|       | LERINO EVENT YEAR SEQUENTIA OCCURRENCE REPORT TOPE TOPE TOPE SHUTDOWN NO. 121 22 23 24 26 27 28 29 30 31 32 COMPONENT TAKEN ACTION ON LANT SETHOD HOURS (22) SUBMITTED FORM SUB-SUPPLIER MANUEL CTUBER   |
|       | TAKEN ACTION ON LANT LETHOD HOURS (22) SUBMITTED FORM SUB. SUPPLIER MANUFACTURER  LX 18 X 19 Z 20 Z 21 1 9 9 9 26  |
|       | CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  |
| 110   | Because of personnel oversight, the projected dose calculation due on 10/22/81 was not performed until 11/25/81 when it was discovered during a 1  |
|       |  |
| 1 2   | management review. The dose projection was performed on 11/25/81 with  |
| 13    | satisfactory results. Surveillance requirement has been placed on the plant  |
| TA    | scheduling computer to prevent future occurrences.   |
|       | B 28 000 0 29 NA OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32  |
| R     | ELEASED OF RELEASE AMOUNT OF ACTIVITY 35   |
| , 6   | PERSONNEL EXPOSURES  A4  45  BO  BO  |
| 1 7   | NUMBER TYPE DESCRIPTION (39)  O   O   O   O   O   O   O   O    PERSONNEL INJURIES 13   |
| Э     | O O O O NA   |
| 1 9   | Z 42 NA PDR ADOCK 0500017  |
| 20    | SSUED DESCRIPTION 45 PDR NAC USE ONLY  |
|       | NAME OF PREPARES W. B. Kaefer PHONE 805-595-7351   |