

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

September 14, 1981

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Serial No. 534
NO/RMT:acm
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7

Dear Mr. O'Reilly:

We have reviewed your letter of August 21, 1981 in reference to the inspection conducted at North Anna Power Station between July 3-15, 1981 and reported in IE Inspection Report No. 50-338/81-19 and 50-339/81-16. Our response to the specific infraction is attached.

We have determined that no proprietary information is contained in the reports. Accordingly, the Virginia Electric and Power Company has no objection to these inspection reports being made a matter of public disclosure. The information contained in the attached pages is true and accurate to the best of my knowledge and belief.

Very truly yours,




R. H. Leasburg

Attachment

City of Richmond

Commonwealth of Virginia

Acknowledged before me this 14th day of Sept., 1981


Notary Public

My Commission expires: 2-26, 1985

SEAL

cc: Mr. Robert A. Clark, Chief
Operating Reactors Branch No. 3
Division of Licensing

8112300032 810925
PDR ADOCK 05000338
PDR
Q

RESPONSE TO NOTICE OF VIOLATION
ITEM REPORTED DURING NRC INSPECTION
CONDUCTED FROM JULY 6-9, 1981

NRC COMMENT

Technical Specification Section 6.8.1.f requires written procedures to be established, implemented and maintained covering the fire protection program implementation. The licensee's Fire Protection Plan contains the procedures for implementing the site fire protection program. Section 7.2.3 of the Fire Protection Plan requires at least one fire brigade drill to be held every 92 days for each brigade.

Contrary to the above, a fire brigade drill was not conducted each quarter during 1980 and 1981 for each brigade.

This is a Severity Level V Violation (Supplement I.E.).

A similar violation was brought to your attention in our letter dated March 12, 1980.

RESPONSE

1. ADMISSION OR DENIAL OF THE ALLEGED VIOLATION

The Notice of Violation is correct as stated.

2. REASON FOR THE VIOLATION

The failure of not meeting the required frequency of fire brigade drills per shift is a result of administrative error. Subsequent review of records shows that there was no method devised to keep track of drills in relationship to shift requirements.

3. CORRECTIVE STEPS TAKEN AND RESULTS ACHIEVED

When notified of this infraction, we standardized the forms used for recording the drills and included a method of identifying the security and operations shifts participating in the drills. We are also developing a schedule to insure that each Fire Brigade shift meets its required drills. We also reviewed our records and conducted drills to insure that our third quarter drill requirements have been met for all shifts.

4. CORRECTIVE STEPS WHICH WILL BE TAKEN TO AVOID FURTHER VIOLATIONS

To prevent recurrence of this item, we will implement a schedule which will identify when each shift fire brigade is required to participate in a drill.

5. DATE WHEN FULL COMPLIANCE WILL BE ACHIEVED

Complete compliance will be achieved on or about October 30, 1981.