

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER · DALLAS, TEXAS 75201

Log # TXX-3452
File # 10010

December 18, 1981

Mr. S. B. Burwell

Mr. S. B. Burwell
Licensing Project Manager
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555



Dear Mr. Burwell:

Please find attached a table providing the description of Amendment 29, dated December 21, 1981.

If you have any questions or comments, please call.

Sincerely,

J. S. Marshall

RWH/grr
Attachment

8112300071 811218
PDR ADOCK 03000445
A PDR

Boo!
S. J.

AMENDMENT 29 DESCRIPTION

December 21, 1981

<u>SECTION</u>	<u>DESCRIPTION OF CHANGE</u>
2.3	Provides definition of term used in X/Q equation (Editorial).
T3.2-2	Provides update to include all flow diagrams presently included within the FSAR.
3.9N	Provides clarification of active valve supports.
3.9B	Refer to section 3.9N.
EQR T4-1	Provides update to include recent Environmental Qualification information.
EQR T5-1	Refer to EQR T4-1.
6.3	Changes reference from T3.2-2 to T17A-1.
F6.3-1 (Sh. 1)	Provides update.
6.4	Provides update to add smoke detection signal to Control Room Emergency Pressurization System to prevent induction of smoke into the control room.
F7.2-1 (Sh. 8)	Refer to Q032.104.

<u>SECTION</u>	<u>DESCRIPTION OF CHANGE</u>
7.3	Refer to Q032.104.
9.3	Provides clarification of high level alarms for RMWST.
F9.4-1 (Sh. 1)	Provides update.
F9.4-11	Provides update.
F9.4-12	Provides update.
9.4C	Provides new system for air conditioning to the UPS room.
9.5	Provides update for fire protection assumptions so that the tray fill criteria refers to Chapter 8 in the FSAR.
	Provides update to eliminate reference of R. G. 1.26 to be in accordance with Chapter 1 (ANSI N18.2 [15]).
	Provides clarification of the manufacturing standards for the diesel generator.
	Also refer to Q040.14.
F10.4-3	Provides update of the main condenser flow diagram.
11.4	Provides update and changes reference from T3.2-1 and T3.2-2 to T17A-1.

SECTIONDESCRIPTION OF CHANGE

T11.5-1	Provides changes to reflect TMI requirements with respect to radiation monitoring as discussed with the appropriate NRC reviewer.
T11.5-2	Refer to T11.5-1.
12.1	Provides CFUR stipulation on ALARA for contention 9.
F12.1-1	Refer to Section 12.1.
T12.3-8	Refer to T11.5-1.
T12.3-9	Refer to T11.5-1.
T14.2-2 (Sh. 20)	Provides editorial clarification.
T14.2-2 (Sh. 30)	Clarifies that "Purging" includes hydrogen purging.
T14.2-2 (Sh. 30A)	Refer to T14.2-2 (Sh. 30).
17.1	Provides changes made by TUGCO QA that reflect current organizational status as previously discussed and approved with the appropriate NRC reviewer.
T17A-1	Provides update to incorporate comments on Q-list.
I.B	Provides update.

SECTION

DESCRIPTION OF CHANGE

II.B

Provides result of shielding study required by NUREG-0737 and SER as discussed with the appropriate NRC reviewer.

II.D

Indicates current position on block valve testing as discussed with appropriate NRC reviewer.

Q032.104

Provides update as a result of TXX-3427, transmitted to NRC October 21, 1981.

Q040.14

Corrects inconsistencies in description of emergency lighting and clarifies description with respect to fire protection as discussed with appropriate NRC reviewer.

Q112.18

Refer to Section 3.9N.

Q124.1

Provides response to question on turbine disk cracking as discussed with appropriate NRC reviewer.

Q260.1

Provides response to question which transmitted updated Q-list as discussed with appropriate NRC reviewer.

Q320.1

Refer to Section 11.4.