

Attachment

Millstone Nuclear Power Station, Unit No. 2

Proposed Revisions to Technical Specification

Supplement to Reference (1)

December, 1981

8112310377 811218
PDR ADOCK 05000336
P PDR

SURVEILLANCE REQUIREMENTS

4.9.8.1 At least one shutdown cooling loop shall be verified to be in operation and circulating reactor coolant at a flow rate consistent with decay heat removal requirements at least once per 12 hours.

4.9.8.2 Once per 7 days, the required shutdown cooling loops, if not in operation, shall be determined OPERABLE by verifying correct breaker alignments and indicated power availability for pump and shutdown cooling valves, or:

Verifying that the reactor vessel water level is at or above the vessel flange, the reactor vessel pit seal is installed, and greater than 370,000 gallons of water is available as a heat sink, as indicated by either:

- a. refuel pool level greater than 23 feet above the reactor vessel flange, or;
- b. the combined volume of the refuel pool and refueling water storage tank exceeds 370,000 gallons and a flow path is available from the refueling water storage tank to the refuel pool.

-
- * The shutdown cooling loop may be removed from operation for up to 1 hour per 8 hour period during the performance of CORE ALTERATIONS in the vicinity of the reactor pressure vessel hot legs.
 - ** The normal or emergency power source may be inoperable for each shutdown cooling loop.