




UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

December 14, 1981

Docket No. 50-409  
LS05-81-12-036

Mr. Frank Linder  
General Manager  
Dairyland Power Cooperative  
2615 East Avenue South  
La Crosse, Wisconsin 54601



DISTRIBUTION  
Docket  
NRC PDR  
Local PDR  
ORB Reading  
NSIC  
DCrutchfield  
HSmith  
RDudley  
RCaruso  
OELD  
OI&E (3)  
ACRS (10)  
SEPB  
JHegner

Dear Mr. Linder:

SUBJECT: RESOLUTION OF NUREG-0737 ITEM II.K.3.14, ISOLATION CONDENSER  
ISOLATION MODIFICATION

RE: LA CROSSE BOILING WATER REACTOR

We have completed our review and evaluation of your response dated September 3, 1980 regarding NUREG-0737 Item II.K.3.14, Isolation Condenser Isolation Modification. The results of our review are discussed in the enclosed Safety Evaluation. Based on those results, we conclude that your response to the item is acceptable and that the item is considered resolved.

Sincerely,

Original signed by  
Thomas V. Wambach for/

Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Enclosure:  
Safety Evaluation

cc w/enclosure:  
See next page

8201120263 811214  
PDR ADOCK 05000409  
P PDR

OFFICE	DL: ORB #5	DL: ORB #5	DL: ORB #5				
SURNAME	RDudley:cc	RCaruso	DCrutchfield				
DATE	12-14	12/14/81	12/14/81				



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

December 14, 1981

Docket No. 50-409  
LS05-81-12-036

Mr. Frank Linder  
General Manager  
Dairyland Power Cooperative  
2615 East Avenue South  
La Crosse, Wisconsin 54601

Dear Mr. Linder:

SUBJECT: RESOLUTION OF NUREG-0737 ITEM II.K.3.14, ISOLATION CONDENSER  
ISOLATION MODIFICATION

RE: LA CROSSE BOILING WATER REACTOR

We have completed our review and evaluation of your response dated September 3, 1980 regarding NUREG-0757 Item II.K.3.14, Isolation Condenser Isolation Modification. The results of our review are discussed in the enclosed Safety Evaluation. Based on those results, we conclude that your response to the item is acceptable and that the item is considered resolved.

Sincerely,

*for Thomas V. Wambach*  
Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Enclosure:  
Safety Evaluation

cc w/enclosure:  
See next page

Mr. Frank Linder

- 2 -

December 14, 1981

cc

Fritz Schubert, Esquire  
Staff Attorney  
Dairyland Power Cooperative  
2615 East Avenue South  
La Crosse, Wisconsin 54601

O. S. Heistand, Jr., Esquire  
Morgan, Lewis & Bockius  
1800 M Street, N. W.  
Washington, D. C. 20036

Mr. R. E. Shimshak  
La Crosse Boiling Water Reactor  
Dairyland Power Cooperative  
P. O. Box 135  
Genoa, Wisconsin 54632

Ms. Anne K. Morse  
Coulee Region Energy Coalition  
P. O. Box 1583  
La Crosse, Wisconsin 54601

La Crosse Public Library  
800 Main Street  
La Crosse, Wisconsin 54601

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Rural Route #1, Box 276  
Genoa, Wisconsin 54632

Town Chairman  
Town of Genoa  
Route 1  
Genoa, Wisconsin 54632

Chairman, Public Service Commission  
of Wisconsin  
Hill Farms State Office Building  
Madison, Wisconsin 53702

Alan S. Rosenthal, Esq., Chairman  
Atomic Safety and Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

U. S. Environmental Protection  
Agency  
Federal Activities Branch  
Region V Office  
ATTN: Regional Radiation Representative  
230 South Dearborn Street  
Chicago, Illinois 60604

Mr. John H. Buck  
Atomic Safety and Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Lawrence R. Quarles  
Kendal at Longwood, Apt. 51  
Kenneth Square, Pennsylvania 19348

Charles Bechhoefer, Esq., Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. George C. Anderson  
Department of Oceanography  
University of Washington  
Seattle, Washington 98195

Mr. Ralph S. Decker  
Route 4, Box 190D  
Cambridge, Maryland 21613

Thomas S. Moore  
Atomic Safety and Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

SAFETY EVALUATION REPORTAPPLICATION OF NUREG-0737 ITEM II.K.3.14 - "ISOLATION OF  
ISOLATION CONDENSERS" TO OPERATING BWRsINTRODUCTION

The requirements for automatic isolation of the isolation condensers on boiling water reactors was specified as a post-TMI requirement in NUREG-0737, which was transmitted to all licensees and applicants by letter dated October 31, 1980.

The position as stated in NUREG-0737 is:

"Isolation condensers have radiation monitors on their vents. These monitors provide alarms in the control room but do not isolate the isolation condensers. The isolation condensers are currently isolated on a high-radiation signal in the steam line leading to the isolation condensers. The design should be modified such that the isolation condensers are automatically isolated upon receipt of a high radiation signal at the vent rather than at the steam line. The purpose of the change is to increase the availability of the isolation condensers as heat sinks."

The six licensees for seven operating BWR units have responded to this item in References 1 - 3. This Safety Evaluation Report addresses the general need for the requirement for the seven operating units.

REGULATORY STAFF EVALUATION

The seven units covered by this review are Big Rock Point, Dresden 2/3, Millstone 1, Nine Mile Point, Oyster Creek and LaCrosse. All seven units have radiation monitors and alarms at the isolation condenser vents. Only the system design of Nine Mile Point Unit 1 incorporates the automatic isolation feature on high radiation at the vents. Nine Mile Point Unit 1 thus meets the requirements as stated and requires no further action. The remaining units require manual isolation of the IC if considered necessary by the operator, or in some cases utilize other signals as indicators to the operator that some action is required. In addition, some of the units do not have isolation on high radiation in the steam

lines as considered in the NUREG-0737 staff position.

In general, the licensees responses (Reference 1-6) have taken the position that the design modification is not necessary, either because the unit design is atypical or that more flexibility and system availability is attained by manual isolation.

Based on our review of individual licensee submittals, the staff concludes that since the subject plants do not have isolation condenser isolation on high radiation signals in the steam lines, the design modification as specified in NUREG-0737 Item II.K.3.14 is not relevant and does not increase the availability of the ICs as heat sinks. The staff also agrees with the position of one licensee that manual isolation allows the operator a greater amount of flexibility and system availability to cope with all anticipated and unanticipated operation transients.

#### REGULATORY POSITION

We have reviewed the responses by six utilities to the NUREG-0737 Item II.K.3.14 requirements for automatic isolation of the isolation condensers on a high radiation signal at the IC atmospheric vents. Based on the results of our review as discussed in the above staff evaluation, we conclude that the manual trip on high radiation levels at the vents is sufficient to provide the amount of flexibility and system availability intended by the NUREG-0737 requirement.

We conclude that the licensees' present positions, as stated in their respective submittals, are acceptable.