

LICENSEE EVENT REPORT

CONTROL BLOCK: [] (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0][1] [N][C][B][E][P][2] [2][0][C]-[0][0][0][0][0]-[0][0] [3][4][] [4] [5]

CON'T [0][1] REPORT SOURCE [L] [6][0][5][0]-[0][3][2][4] [7][1][2][0][4][8][1] [8][1][2][2][8][8][1][1] [9]

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0][2] [During plant operation, the channel functional test of the RCIC System steam line high
[0][3] differential pressure switches, PT 2.1.12P, was not performed by its required date of
[0][4] December 14, 1981, due to a problem with one of the switches' isolation valves. As a
[0][5] result, the RCIC System was declared inoperable due to failure to perform the required
[0][6] surveillance within the specified time interval. This event did not affect the health
[0][7] and safety of the public.

Technical Specifications 3.3.2, 3.7.4, 4.0.3, 6.9.1.9b

[0][9] [C][E] [11] [A] [12] [C] [13] [Z][Z][Z][Z][Z][Z] [14] [Z] [15] [Z] [16]
[17] LER/RO REPORT NUMBER [8][1] [21][22] [] [23] [1][2][9] [24][26] [] [27] [0][3] [28][29] [L] [30] [] [31] [0] [32]
ACTION TAKEN [H] [18] [Z] [19] [Z] [20] [Z] [21] [0][0][0][0] [22] [N] [23] [Y] [24] [Z] [25] [Z][9][9][9] [26]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1][0] [The responsible I&C PT foreman was unaware of technical specification requirements to
[1][1] declare a system inoperable when a system's required surveillance is not performed
[1][2] within the specified time interval. The PT was satisfactorily completed on December
[1][3] 7, 1981, and the RCIC System was declared operable and returned to normal service. The
[1][4] involved foreman has been counseled concerning the completion of required system sur-

[1][5] [E] [28] [0][7][7] [29] [NA] [30] [A] [31] Operational Event [32]

[1][6] [Z] [33] [Z] [34] [NA] [35] [NA] [36]

[1][7] [0][0][0] [37] [Z] [38] [NA] [39]

[1][8] [0][0][0] [40] [NA] [41]

[1][9] [Z] [42] [NA] [43]

[2][0] [N] [44] [NA] [45]

8201130173 811228
PDR ADOCK 05000324
S PDR