

# Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24506  
Telephone: (804) 384 5111

December 17, 1976

Mr. S. A. Varga, Chief  
LWR Branch No. 4  
Division of Project Management  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555


Dear Mr. Varga:

Attached is additional ECCS small break analysis for B&W's 177 Fuel Assembly Lowered-Loop NSS. This analysis is in accordance with the small break model as approved in BAW-10104A, Rev. 1, "B&W's ECCS Evaluation Model," March 1976.

This analysis was requested by letters from J. F. Stoltz to K. E. Suhrke, February 4, 1976, and from D. F. Ross to K. E. Suhrke, March 22, 1976 in connection with the review of BAW-10103, Rev. 2, "ECCS Analysis of B&W's 177-FA Lowered-Loop NSS." The other analysis (.5 ft<sup>2</sup> with large break model) requested in Mr. Stoltz's letter was submitted to you on October 8, 1976. This small break analysis predicts results well below the acceptance criteria of 10CFR50.46.

This submittal completes B&W's response to all the Staff's questions on BAW-10103, Rev. 2. Following your review, these analyses will be incorporated into BAW-10103. If you have questions concerning this matter, please feel free to contact Henry A. Bailey (Extension 2678) of my staff.

Very truly yours,



Kenneth E. Suhrke  
Manager, Licensing

KES:HAB:dc  
Attachment

cc: R. B. Borsum (B&W)(2)  
Thomas H. Novak  
Zoltan R. Rosztoczy (NRC)

82011B0589 810403  
PDR FOIA  
MADDENBO-515 PDR

## CONTENTS

### PAGE NO.

1. Introduction	1.1
2. Summary	2.1
3. Method of Analysis	3.1
4. Results of Small Leak Transients	4.1
4.1 Explanation of Curves	4.1
4.2 0.44 Ft <sup>2</sup> CFT Line Break	4.2
4.3 0.50 Ft <sup>2</sup> Split At Pump Discharge	4.3
4.4 0.04 Ft <sup>2</sup> Split At Pump Suction	4.3
5. Phase Distribution Multiplier For the CRAFT2 Wilson Separation Model	5.1
6. References	6.1

### LIST OF FIGURES

- 4.1 CRAFT2 Noding Diagram For Small Break
- 4.2 Core Power For CFT Line Break
- 4.3 Core Flow For CFT Line Break
- 4.4 Core Pressure History CFT Line Break
- 4.5 Leak Flow Vs. Time CFT Line Break
- 4.6 ECC Injection Rate CFT Line Break
- 4.7 Inner Vessel Fluid Inventory CFT Line Break
- 4.8 Core Power For 0.5 Ft<sup>2</sup> Break At Pump Discharge
- 4.9 Core Flow For 0.5 Ft<sup>2</sup> Break At Pump Discharge
- 4.10 Core Pressure History 0.5 Ft<sup>2</sup> Split At Pump Discharge
- 4.11 Leak Flow Vs Time 0.5 Ft<sup>2</sup> Split At Pump Discharge
- 4.12 ECC Injection Rate 0.5 Ft<sup>2</sup> Split At Pump Discharge
- 4.13 Inner Vessel Fluid Inventory 0.5 Ft<sup>2</sup> Split At Pump Discharge
- 4.14 Core Power For 0.04 Ft<sup>2</sup> Break At Pump Suction
- 4.15 Core Flow For 0.04 Ft<sup>2</sup> Break At Pump Suction
- 4.16 Core Pressure History 0.04 Ft<sup>2</sup> Split At Pump Suction
- 4.17 Leak Flow Vs. Time 0.04 Ft<sup>2</sup> Split At Pump Suction
- 4.19 Inner Vessel Fluid Inventory 0.04 Ft<sup>2</sup> Split At Pump Suction
- 5.1 FOAM - CRAFT2 Mixture Height Comparison

## 1. INTRODUCTION

Presented here are the results of an analysis of hypothetical loss-of-coolant accidents resulting from postulating small breaks in the reactor coolant system of B&W's 177FA lower loop plants. B&W's ECCS Evaluation Model as defined in BAW-10104<sup>5</sup> was used for the analysis. *See fig 5-4-71 diagram.*

Small breaks are defined as ruptures of the reactor coolant system with leak areas of 0.5 ft<sup>2</sup> or less. Break areas considered for this study are: (1) 0.44 ft<sup>2</sup> CFT line break since it has the minimum ECC system available to mitigate the LOCA, (2) 0.5 ft<sup>2</sup> break at the pump discharge as it represents the transition break between the small and large break models, (3) 0.04 ft<sup>2</sup> break at the pump suction which was shown to be the most limiting small break in BAW-10052.<sup>1</sup>

The current analysis of these breaks verifies the conservative nature of the cladding temperature calculations presented for the same breaks in BAW-10052 and BAW-10064<sup>4</sup>. Therefore, the analysis contained herein, coupled with the analyses of BAW-10052 and BAW-10064 provide an appropriate spectrum of breaks for the evaluation of the effects of small leaks and the demonstration of the ability of the ECCS to effectively control them.

BAW-10052 { .3 ft<sup>2</sup> @ Pump Sut - 780 °F-PCT  
.1 " " " " - 826 " "  
.1 " " " Disch - 780 " "  
.04 " " " Sut - 971 " "

*BAW-10052 - CFT line Rlk - 1220 °F PCT @ 10.25 ft-fa PA @ 95%*

## 2. SUMMARY AND CONCLUSIONS

The various breaks analyzed in Section 4 of this report show that the core remains covered throughout the transient. During the initial period when the transient is flow controlled, sufficient flow is maintained such that CHF does not occur and nucleate boiling heat transfer predominates. Since the core remains covered by a mixture, pool film boiling will be maintained during the quiescent period of the accident. This heat transfer mechanism is sufficient to maintain the cladding temperature within a few degrees of the fluid saturation temperature (Reference 4, BAW-10064). Therefore, for the maximum linear heat rate covered by BAW-10103,<sup>7</sup> the transient cladding surface temperature will never exceed its initial value of 660F, no metal water reaction will occur, and the core geometry will remain coolable as no cladding rupture will occur. Long term cooling is established as the HPI and LPI pumped injection systems provide fluid in excess of the boiloff rate due to core decay heat. Thus the five Acceptance Criteria in 10CFR50.46 are met.

The new modeling techniques used in the CRAFT<sup>2</sup> analyses for the present studies show improvement in the core performance when compared with the results of the same breaks reported in BAW-10052 and BAW-10064. Therefore, if all the breaks reported in BAW-10052 and BAW-10064 were re-analyzed with the present model, the same trend of improvement in core performance would be realized. Thus, the present analyses in conjunction with the analyses of BAW-10052 and BAW-10064 provide a suitable small break spectrum for demonstration of compliance of the ECC system with the five Acceptance Criteria in 10CFR50.46.

### 3. METHOD OF ANALYSIS

The analysis uses the CRAFT<sup>2</sup> code to develop the history of the reactor coolant system hydrodynamics. For small leak analysis it is sufficient to use smaller models than are used for large loss-of-coolant studies because hydrodynamic responses are slow enough for simpler models to describe them.<sup>1</sup> The CRAFT model uses 19 nodes to simulate the reactor coolant system, two nodes for the secondary system, and one node for the reactor building. A schematic diagram of the model is shown in Figure 4.1 along with the node descriptions. Control volumes (nodes) in and around the vessel are all connected by a pair of flow paths to allow the occurrence of counter-current flow. The break is located in the cold leg piping either at the lowest point in the pipe at the pump suction, or at a point opposed to the high-pressure injection nozzle at the pump discharge, or in the core flood line joining the CF nozzle. The Wilson, Grenda and Patterson<sup>3</sup> average bubble rise model is used for all nodes. Within the core region, however, a multiplier of 2.38 is applied to the calculated bubble rise velocity. Section 5 of this report demonstrates that a multiplier of 2.38 in CRAFT2 gives a mixture height within  $\pm$  2% of that predicted by FOAM<sup>4</sup>. Thus, no FOAM analysis will be needed if the CRAFT2 mixture level remains above the core by 2% of the active length.

The following assumptions are made for conditions and system responses during the accident:

1. The reactor is operating at 102% of the steady-state power level of 2772 Mwt.
2. The leak occurs instantaneously, and a discharge coefficient of 1.0 is used for the entire analysis. Bernoulli's equation was used for the subcooled portion of the transient while Moody's correlation was used in the two phase portion.
3. No offsite power is available.
4. The reactor trips on low pressure at 1900 psia.
5. The safety rods begin entering the core after a 0.5 second delay from the time the reactor trip signal is reached.

6. The reactor coolant pumps trip and coast down coincident with reactor trip.
7. One complete train of the emergency safeguards system fails to operate, leaving two CFTs and only one high-pressure injection and one low-pressure injection system available for pumped injection to mitigate the consequence of a cold leg break. For the CFT line break, only one CFT and one high pressure injection system is assumed available for providing ECC fluid to the vessel.
8. The auxilliary feedwater system is assumed to be available during the transient. It mainly removes heat from the upper half of the steam generator during the initial stages of the transient. When the secondary side of the steam generator becomes a source of heat to the primary system, the assumption of auxiliary feedwater maximizes the energy that must be relieved.
9. ESFAS signal error band is considered in the analysis to signal the actuation of the HPI.

The CRAFT2 results obtained from the present analysis are sufficient to meet the five Acceptance Criteria of 10CFR50.46 in that the core was always covered by a two-phase mixture, hence no separate thermal analysis is necessary for cladding temperatures during the transient. If required, as in the case of uncovering to within 0.25 feet above the active core (Ref. Section 5), the cladding heatup can be calculated by the procedure outlined in Section 5.2.3 of BAW-10104A.

#### 4. RESULTS OF SMALL LEAK TRANSIENTS

This section presents a detailed evaluation of the three breaks considered along with explanations of the phenomena involved.

##### 4.1 Explanation of Curves

The following categorical explanations are provided to aid in understanding the parameters illustrated in the curves:

Core Power: This curve indicates the normalized thermal power as calculated by CRAFT2.

Core Flow: This curve represents the total flow rates of core paths 1 and 2 of Figure 4.1. The curve shows flow rates mainly during the flow controlled part of the transient.

Pressure: This is the pressure at the top of the core node as calculated by CRAFT. The core node, in these analyses, includes the core, upper plenum, upper head, and the core bypass.

Boil-Off Due To Decay Heat: The liquid boil-off rate is given in terms of equivalent amount of HPI or HPI + LPI injection rate needed to dissipate the core decay heat. Mathematically:

$$\text{Boil-off rate} = (\text{core decay heat rate}) (h_g - h_{in})$$

Where:  $h_g$  = enthalpy of saturated steam at core pressure

$h_{in}$  = enthalpy of injected water

Inner Vessel Mixture Height: This curve shows the mixture height in the core node as calculated by the CRAFT code. The lines spanning the curve indicates the top of the active core, hot leg regions and the vent valve region.

Core Liquid Level: This curve, in contrast to that for the inner vessel mixture height shows the effective core liquid height and volume with the lower plenum filled with a mixture at the void fraction calculated by CRAFT2. This volume is representative of the liquid volume within the core node that would be used to calculate the mixture height within the core.

#### 4.2 0.44 Ft<sup>2</sup> CFT Line Break

The break is assumed to be at the CFT line nozzle joining the reactor vessel and is limited in area to 0.44 ft<sup>2</sup> by the nozzle insert in the CFT line. Node 13 in Figure 4.1 is the break node, and the analysis takes credit for one CFT and one HPI pump.

Figures 4.2 and 4.3 show core power and core flow rate respectively. Rapid initial depressurization (see Figure 4.4) causes reactor trip and start of reactor coolant pump coastdown within the first second. Flashing of system liquid slows the depressurization while the steam generator continues to remove energy from the primary coolant thereby helping to decrease the pressure. The lower pressure limit of the ESFAS setpoint error band is reached by about 10 seconds which initiates main feedwater and steam line isolation procedures and signals actuation of HPI. At about 40 seconds, the RCS pressure drops below the secondary steam generator pressure and heat removal to the secondary side drops off sharply and becomes a source of heat to the primary causing a slower depressurization. System flow has degraded such that core flow is predominately due to natural circulation and quiescent period of transient begins. HPI system provides makeup starting at about 50 seconds aiding depressurization. Core flood tank flow begins at 140 seconds aiding further depressurization but the diminishing leak flow (Figure 4.5) slows the depressurization rate. The core flood tanks are emptied by about 500 seconds after which the rate of depressurization is steady but very slow. Figure 4.6 is a plot of HPI and total ECC water flow. Long term cooling is assured in that by 850 seconds the HPI injection rate exceeds the boil-off due to core decay heat. Figure 4.7 is a plot of core liquid inventory and mixture height. It shows that while much of the core liquid inventory is depleted, the mixture level predicted by CRAFT remains at a level where it is able to spill into the hot legs and, for most of the time, through the vent valves. System oscillations are observed after 1120 seconds resulting in a decrease in core liquid volume and vessel mixture height. These reductions will soon be overcome as the boil-off rate is already exceeded by the injection rate and therefore will result in an increase in the core liquid volume. No cladding temperature transient will occur since the core is always covered with a mixture and the HPI injection rate has exceeded the boil-off assuring long term cooling capability.

#### 4.3 0.5 Ft<sup>2</sup> Split At Pump Discharge

The break is assumed to occur at the bottom of node 10 of Figure 4.1. The analysis takes credit for two CFTs, one HPI pump and one LPI pump.

The core power, flow rate, pressure, leak rate, ECC water flow and core fluid inventory history are shown in Figures 4.8 through 4.13 respectively. RC pumps and reactor trips occur in less than a second. The HPI actuation signal is received by about 10 seconds when the ESFAS setpoint on low pressure limit is reached. The secondary becomes a source of heat to the primary when, around 40 seconds, the SG primary pressure drops below the secondary pressure. The HPI and CFT flow begins by 45 and 109 seconds respectively. The salient features of system depressurization for this break are similar to those of CFT line break except in the present case, the initiation of LPI flow at 191 seconds results in a quicker termination of the transient. The combined HPI and LPI injection rate exceeds its boil-off due to decay heat by 195 seconds thus establishing long term cooling. No cladding temperature transient will occur since the core is always covered by a mixture.

#### 4.4 0.04 Ft<sup>2</sup> Split At Pump Suction

The break is assumed to be at the bottom of node 9 of Figure 4.1. The analysis takes credit for two CFTs, one HPI and one LPI pump.

Figures 4.14 through 4.19 show core power, flow rate, pressure, leak rate, HPI flow rates and core fluid inventory respectively. No CFT or LPI flow occurred by the end of the analysis since the system pressure remained higher than the CFT actuation pressure of 590 psi and remained higher than the dead head pressure of the LPI. The reactor and R.C. pump trip occurs by about 15 seconds. The depressurization is slower in this case compared to the breaks described previously due to very small size of the break resulting in a lower leak flow. ESFAS setpoint limit on low pressure is reached by 46 seconds and the HPI flow begins by 81 seconds aiding depressurization. The system pressure is still above the secondary pressure and subcooled liquid prevails in the steam generator primary side due to the heat removal by the secondary side of the steam generator. By 120 seconds, two phase mixture is realized in the SG primary side slowing the system depressurization. The slow rate of depressurization continues even after the primary side pressure drops below the secondary side pressure at 770 seconds. The steam generator primary side in the broken loop is filled with steam by 910 seconds. The pump suction nodes in the broken

loop contain very little liquid mass after 910 seconds hence the rate of depressurization increases due to the large volume of steam now discharging through the break. The HPI flow rate exceeds the boil-off rate due to decay heat by 1250 seconds, thereby establishing long term cooling. The core is always covered with a mixture hence no cladding temperature transient will occur.

In this particular transient, long term cooling is initially established by use of one HPI pump. No LPI or CFT injection took place since the system pressure was above the injection actuation pressures. Thus, it is concluded that for breaks less than or equal to  $0.04 \text{ ft}^2$  the HPI alone is capable of matching decay heat boil-off and maintaining a liquid inventory sufficient to preclude any cladding temperature excursions.

## 5. PHASE DISTRIBUTION MULTIPLIER FOR THE CRAFT2 WILSON SEPARATION MODEL


The phase separation model available in CRAFT2 includes the option of placing a multiplier on the bubble rise velocity calculated by the Wilson model. Although this velocity is based on the average mixture void fraction, the use of a proper multiplier corrects it for expected non-uniformity in phase distribution within the mixture. Because the mixture swelling is closely tied to the bubble separation rate, varying this multiplier effectively permits tuning the mixture height calculations. For small breaks then, this multiplier can be adjusted so that the mixture calculated by CRAFT2 in the core node matches that produced by the more detailed mixture swelling code, FOAM. This, of course, would preclude the necessity of doing a FOAM analysis as long as the mixture is above the core by an amount corresponding to the level uncertainty.

A series of FOAM calculations were made to determine the amount of liquid necessary to just cover the core with a froth using the axial power shape given in BAW-10074.<sup>6</sup> Results were obtained for pressures ranging from 200 to 1200 psia with a core power of 2.13% and 4.26% of 2772 Mwt. The core parameters used were those of 177 FA plants. Steady state CRAFT2 runs were made using several different bubble rise multipliers for each combination of power, pressure and associated FOAM core liquid volume. The equilibrium core mixture heights calculated by CRAFT2 were noted. Figure 5.1 shows a plot of difference in CRAFT2 and FOAM mixture height versus bubble rise multiplier in CRAFT2. A multiplier of 2.38 as seen in Figure 5.1, produces a CRAFT2 mixture level within + 1.8% and - 2% of that calculated by FOAM over the range of parameters most likely to exist when core uncovering is a possibility during a small break accident. Using a tolerance of  $\pm$  2%, it is concluded that no FOAM analysis is need if the mixture height exceeds the active core by three inches (0.25 feet). If mixture height drops to less than 0.25 feet above the core, the cladding heatup analysis using FOAM results will be done as outlined in Section 5.2.3 of BAW-10104.<sup>5</sup>

## 6. REFERENCES

1. C.E. Parks, B.M. Dunn, and R.C. Jones, "Multinode Analysis of Small Breaks for B&W's 2568 Mwt Nuclear Plants", BAW-10052, Rev. 1, Babcock & Wilcox, Lynchburg, Va., October 1975.
2. R.A. Hedrick, J.J. Cudlin and R.C. Foltz, "CRAFT2 - Fortran Program For Digital Simulation of a Multinode Reactor Plant During Loss of Coolant," BAW-10092, Rev. 2, Babcock & Wilcox, April 1975.
3. J.F. Wilson, R.J. Grenda, and J.F. Patterson, "The Velocity of Rising Steam in a Bubbling Two-Phase Mixture," ANS Transactions, 5 (1962).
4. B.M. Dunn, C.D. Morgan, and L.R. Cartin, "Multinode Analysis of Core Flooding Line Break for B&W's 2568 Mwt Internals Vent Valve Plants, BAW-10064, Rev. 1, Babcock & Wilcox, October 1975, (FOAM code is discussed in this reference).
5. B.M. Dunn, R.C. Jones, L.R. Cartin, C.E. Parks, and R.J. Salm, "B&W's ECCS Evaluation Model", BAW-10104A, Rev. 1, Babcock & Wilcox, Lynchburg, Va, March 1976.
6. R.C. Jones, B.M. Dunn, and C.E. Parks, "Multinode Analysis of Small Breaks for B&W's 205 Fuel Assembly Nuclear Plants With Internals Vent Valves", BAW-10074A, Rev. 1, Babcock & Wilcox, Lynchburg, Va., March 1976.
7. R.C. Jones, J.R. Biller, and B.M. Dunn, "ECCS Analysis of B&W's 177-FA Lowered Loop NSS", BAW-10103, Rev. 2, Babcock & Wilcox, Lynchburg, Va., April 1976.

FIGURE 4-1  
CRAFT Node Diagram For Small Break



Node No.	Identification	Path No.	Identification
1	Downcomer	1,2	Core
2	Lower Plenum	3,4,18,19	Hot Leg Piping
3	Core, Core Bypass, Upper Plenum, Upper Head	5,20	Hot Leg,Upper
4,14	Hot Leg Piping	6,21	SG Tubes
5,15	Steam Generator Upper Head, SG Tubes (Upper Half)	7,22	SG Lower Head
6,16	SG Tubes (Lower Half)	8	Core Bypass
8,18	SG Lower Head	9,13,24	Cold Leg Piping
9,11,19	Cold Leg Piping (Pump Suction)	10,14,25	Pumps
10,12,20	Cold Leg Piping (Pump Discharge)	11,12,15,16,26,27	Cold Leg Piping
13	Upper Downcomer (Above the Ⓛ of Nozzle Belt)	17,31	Containment
21	Pressurizer	23	LPI
22	Containment	28,29	Upper Downcomer
		30	Pressurizer
		32	Vent Valve
		33,34	Leak & Return Path
		35,36	HPI
		37	Containment Sprays

FIGURE - 4-2  
CAGE PRACTICE FOR LEFT LINE  
BREAK






FIGURE - 4.3  
CORE FLOW FOR CFT  
LINE BREAK









FIGURE A-6: ECC INJECTION RATE  
CFT LINE BREP






FIGURE - 1.5

COFF POWER FOR  $0.5 \text{ FT}^2$  BREATH  
AT PUMP DISCHARGE




FIGURE A-10: CFFE PRESSURE HISTORY  
0.5 FT<sup>2</sup> SPLIT AT PUMP DISCHARGE







FIGURE - 4.9

CORE FLOW FOR  $0.5 \text{ FT}^2$   
BREAK AT PUMP DISCHARGE










FIGURE - A-14

CORE POWER FOR  $0.04 \text{ FT}^2$  FREEAR  
AT PUMP SUCTION




FIGURE - 4-15

CORE FLOW FOR  $0.04 \text{ FT}^2$   
BREAK AT PUMP SUCTION




FIGURE 4-16: CORE PRESSURE HISTORY  
0.04 FT<sup>2</sup> SPLIT AT  
PUMP SUCTION




FIGURE - 4.17: LEAK FLOW VS TIME  
 $0.04 \text{ FT}^2$  SPLIT AT  
PUMP SUCTION





FIGURE - 4.18

ECC INJECTION RATE  
0.04 FT<sup>2</sup> SPLIT AT PUMP  
SUCTION





461510

10 X 10 TO THE CENTIMETER 10 X 25 CM  
KARL & ESSER CO. MARCH 1974


FIGURE 5.1: FOAM - CRAFT2  
MIXTURE HEIGHT  
COMPARISON

LEGEND

POWER %	PRESSURE
2.13	4.26
x	A
o	D
□	#
*	○
	▽
	H

$$100 \% \text{ POWER} = 1.02 \times 2772 \text{ MW}$$

$$\% \text{ ERROR} = \frac{L_{CRAFT2} - L_{FOAM}}{L_{FOAM}} \times 100$$



TO: G.R. Maynard

CONIENS

121-

RCOV

12/16/76

PAGE NO.

## RENE

1. Introduction	1.1
2. Summary	2.1
3. Method of Analysis	3.1
4. Results of Small Leak Transients	4.1
4.1 Explanation of Curves	4.1
4.2 0.44 Ft <sup>2</sup> CFT Line Break	4.2
4.3 0.50 Ft <sup>2</sup> Split At Pump Discharge	4.3
4.4 0.04 Ft <sup>2</sup> Split At Pump Suction	4.3
5. Phase Distribution Multiplier For the CRAFT2 Wilson Separation Model	5.1
6. References	6.1

Here is a better  
writeup. Use  
previous figures, if  
you can. I'm  
trying to get the  
get that goes  
with this writeup.

LIST OF FIGURES

- Jerry
- 4.1 CRAFT2 Noding Diagram For Small Break
  - 4.2 Core Power For CFT Line Break
  - 4.3 Core Flow For CFT Line Break
  - 4.4 Core Pressure History CFT Line Break
  - 4.5 Leak Flow Vs. Time CFT Line Break
  - 4.6 ECC Injection Rate CFT Line Break
  - 4.7 Inner Vessel Fluid Inventory CFT Line Break
  - 4.8 Core Power For 0.5 Ft<sup>2</sup> Break At Pump Discharge
  - 4.9 Core Flow For 0.5 Ft<sup>2</sup> Break At Pump Discharge
  - 4.10 Core Pressure History 0.5 Ft<sup>2</sup> Split At Pump Discharge
  - 4.11 Leak Flow Vs Time 0.5 Ft<sup>2</sup> Split At Pump Discharge
  - 4.12 ECC Injection Rate 0.5 Ft<sup>2</sup> Split At Pump Discharge
  - 4.13 Inner Vessel Fluid Inventory 0.5 Ft<sup>2</sup> Split At Pump Discharge
  - 4.14 Core Power For 0.04 Ft<sup>2</sup> Break At Pump Suction
  - 4.15 Core Flow For 0.04 Ft<sup>2</sup> Break At Pump Suction
  - 4.16 Core Pressure History 0.04 Ft<sup>2</sup> Split At Pump Suction
  - 4.17 Leak Flow Vs. Time 0.04 Ft<sup>2</sup> Split At Pump Suction
  - 4.19 Inner Vessel Fluid Inventory 0.04 Ft<sup>2</sup> Split At Pump Suction
  - 5.1 FOAM - CRAFT2 Mixture Height Comparison

## 1. INTRODUCTION

Presented here are the results of an analysis of hypothetical loss-of-coolant accidents resulting from postulating small breaks in the reactor coolant system of Crystal River 3. B&W's ECCS Evaluation Model as defined in BAW-10104<sup>5</sup> was used for the analysis.

Small breaks are defined as ruptures of the reactor coolant system with leak areas of  $0.5 \text{ ft}^2$  or less. Break areas considered for this study are: (1)  $0.44 \text{ ft}^2$  CFT line break since it has the minimum ECC system available to mitigate the LOCA, (2)  $0.5 \text{ ft}^2$  break at the pump discharge as it represents the transition break between the small and large break models, (3)  $0.04 \text{ ft}^2$  break at the pump suction which was shown to be the most limiting small break in BAW-10052.<sup>1</sup>

The current analysis of these breaks verifies the conservative nature of the cladding temperature calculations presented for the same breaks in BAW-10052 and BAW-10064<sup>4</sup>. Therefore, the analysis contained herein, coupled with the analyses of BAW-10052 and BAW-10064 provide an appropriate spectrum of breaks for the evaluation of the effects of small leaks and the demonstration of the ability of the ECCS to effectively control them.

## 2. SUMMARY AND CONCLUSIONS

The various breaks analyzed in Section 4 of this report show that the core remains covered throughout the transient. During the initial period when the transient is flow controlled, sufficient flow is maintained such that CHF does not occur and nucleate boiling heat transfer predominates. Since the core remains covered by a mixture, pool film boiling will be maintained during the quiescent period of the accident. This heat transfer mechanism is sufficient to maintain the cladding temperature within a few degrees of the fluid saturation temperature (Reference 4, BAW-10064). Therefore, for the maximum linear heat rate covered by BAW-10103,<sup>7</sup> the transient cladding surface temperature will never exceed its initial value of 660F, no metal water reaction will occur, and the core geometry will remain coolable as no cladding rupture will occur. Long term cooling is established as the HPI and LPI pumped injection systems provide fluid in excess of the boiloff rate due to core decay heat. Thus the five Acceptance Criteria in 10CFR50.46 are met.

The new modeling techniques used in the CRAFT<sup>2</sup> analyses for the present studies show improvement in the core performance when compared with the results of the same breaks reported in BAW-10052 and BAW-10064. Therefore, if all the breaks reported in BAW-10052 and BAW-10064 were re-analyzed with the present model, the same trend of improvement in core performance would be realized. Thus, the present analyses in conjunction with the analyses of BAW-10052 and BAW-10064 provide a suitable small break spectrum for demonstration of compliance of the ECC system with the five Acceptance Criteria in 10CFR50.46.

## METHOD OF ANALYSIS

The analysis uses the CRAFT2<sup>2</sup> code to develop the history of the reactor coolant system hydrodynamics. For small leak analysis it is sufficient to use smaller models than are used for large loss-of-coolant studies because hydrodynamic responses are slow enough for simpler models to describe them.<sup>1</sup> The CRAFT model uses 19 nodes to simulate the reactor coolant system, two nodes for the secondary system, and one node for the reactor building. A schematic diagram of the model is shown in Figure 4.1 along with the node descriptions. *Where?* Control volumes (nodes) in and around the vessel are all connected by a pair of flow paths to allow the occurrence of counter-current flow. The break is located in the cold leg piping either at the lowest point in the pipe at the pump suction, or at a point opposed to the high-pressure injection nozzle at the pump discharge, or in the core flood line joining the CF nozzle. The Wilson, Grenda and Patterson<sup>3</sup> average bubble rise model is used for all nodes. Within the core region, however, a multiplier of 2.38 is applied to the calculated bubble rise velocity. Section 5 of this report demonstrates that a multiplier of 2.38 in CRAFT2 gives a mixture height within  $\pm 2\%$  of that predicted by FOAM<sup>4</sup>. Thus, no FOAM analysis will be needed if the CRAFT2 mixture level remains above the core by 2% of the active length.

The following assumptions are made for conditions and system responses during the accident:

1. The reactor is operating at 102% of the steady-state power level of 2772 Mwt.
2. The leak occurs instantaneously, and a discharge coefficient of 1.0 is used for the entire analysis. Bernoulli's equation was used for the subcooled portion of the transient while Moody's correlation was used in the two phase portion.
3. No offsite power is available.
4. The reactor trips on low pressure at 1900 psia.
5. The safety rods begin entering the core after a 0.5 second delay from the time the reactor trip signal is reached.

6. The reactor coolant pumps trip and coast down coincident with reactor trip.
7. One complete train of the emergency safeguards system fails to operate, leaving two CFTs and only one high-pressure injection and one low-pressure injection system available for pumped injection to mitigate the consequence of a cold leg break. For the CFT line break, only one CFT and one high pressure injection system is assumed available for providing ECC fluid to the vessel.
8. The auxiliary feedwater system is assumed to be available during the transient. It mainly removes heat from the upper half of the steam generator during the initial stages of the transient. When the secondary side of the steam generator becomes a source of heat to the primary system, the assumption of auxiliary feedwater maximizes the energy that must be relieved.
9. ESFAS signal error band is considered in the analysis to signal the actuation of the HPI.

The CRAFI2 results obtained from the present analysis are sufficient to meet the five Acceptance Criteria of 10CFR50.46 in that the core was always covered by a two-phase mixture, hence no separate thermal analysis is necessary for cladding temperatures during the transient. If required, as in the case of uncovering to within 0.25 feet above the active core (Ref. Section 5), the cladding heatup can be calculated by the procedure outlined in Section 5.2.3 of BAW-10104A.

#### 4. RESULTS OF SMALL LEAK TRANSIENTS

This section presents a detailed evaluation of the three breaks considered along with explanations of the phenomena involved.

##### 4.1 Explanation of Curves

The following categorical explanations are provided to aid in understanding the parameters illustrated in the curves:

Core Power: This curve indicates the normalized thermal power as calculated by CRAFT2.

Core Flow: This curve represents the total flow rates of core paths 1 and 2 of Figure 4.1. The curve shows flow rates mainly during the flow controlled part of the transient.

Pressure: This is the pressure at the top of the core node as calculated by CRAFT. The core node, in these analyses, includes the core, upper plenum, upper head, and the core bypass.

Boil-Off Due To Decay Heat: The liquid boil-off rate is given in terms of equivalent amount of HPI or HPI + LPI injection rate needed to dissipate the core decay heat. Mathematically:

$$\text{Boil-off rate} = (\text{core decay heat rate}) (h_g - h_{in})$$

Where:  $h_g$  = enthalpy of saturated steam at core pressure

$h_{in}$  = enthalpy of injected water

Inner Vessel Mixture Height: This curve shows the mixture height in the core node as calculated by the CRAFT code. The lines spanning the curve indicates the top of the active core, hot leg regions and the vent valve region.

Core Liquid Level: This curve, in contrast to that for the inner vessel mixture height shows the effective core liquid height and volume with the lower plenum filled with a mixture at the void fraction calculated by CRAFT2. This volume is representative of the liquid volume within the core node that would be used to calculate the mixture height within the core.

#### 4.2 0.44 ft<sup>2</sup> CFT Line Br.

The break is assumed to be at the CFT joining the reactor vessel and is limited in area to 0.44 ft<sup>2</sup> by the nozzle insert in the CFT line. Node 13 in Figure 4.1 is the break node, and the analysis takes credit for one CFT and one HPI pump.

Figures 4.2 and 4.3 show core power and core flow rate respectively. Rapid initial depressurization (see Figure 4.4) causes reactor trip and start of reactor coolant pump coastdown within the first second. Flashing of system liquid slows the depressurization while the steam generator continues to remove energy from the primary coolant thereby helping to decrease the pressure. The lower pressure limit of the ESFAS setpoint error band is reached by about 10 seconds which initiates main feedwater and steam line isolation procedures and signals actuation of HPI. At about 40 seconds, the RCS pressure drops below the secondary steam generator pressure and heat removal to the secondary side drops off sharply and becomes a source of heat to the primary causing a slower depressurization. System flow has degraded such that core flow is predominately due to natural circulation and quiescent period of transient begins. HPI system provides makeup starting at about 50 seconds aiding depressurization. Core flood tank flow begins at 140 seconds aiding further depressurization but the diminishing leak flow (Figure 4.5) slows the depressurization rate. The core flood tanks are emptied by about 500 seconds after which the rate of depressurization is steady but very slow. Figure 4.6 is a plot of HPI and total ECC water flow. Long term cooling is assured in that by 850 seconds the HPI injection rate exceeds the boil-off due to core decay heat. Figure 4.7 is a plot of core liquid inventory and mixture height. It shows that while much of the core liquid inventory is depleted, the mixture level predicted by CRAFT remains at a level where it is able to spill into the hot legs and, for most of the time, through the vent valves. System oscillations are observed after 1120 seconds resulting in a decrease in core liquid volume and vessel mixture height. These reductions will soon be overcome as the boil-off rate is already exceeded by the injection rate and therefore will result in an increase in the core liquid volume. No cladding temperature transient will occur since the core is always covered with a mixture and the HPI injection rate has exceeded the boil-off assuring long term cooling capability.

#### 4.3 0.5 Ft<sup>2</sup> Split At Pump discharge

The break is assumed to occur at the bottom of node 10 of Figure 4.1. The analysis takes credit for two CFTs, one HPI pump and one LPI pump.

The core power, flow rate, pressure, leak rate, ECC water flow and core fluid inventory history are shown in Figures 4.8 through 4.13 respectively. RC pumps and reactor trips occur in less than a second. The HPI actuation signal is received by about 10 seconds when the ESFAS setpoint on low pressure limit is reached. The secondary becomes a source of heat to the primary when, around 40 seconds, the SG primary pressure drops below the secondary pressure. The HPI and CFT flow begins by 45 and 109 seconds respectively. The salient features of system depressurization for this break are similar to those of CFT line break except in the present case, the initiation of LPI flow at 191 seconds results in a quicker termination of the transient. The combined HPI and LPI injection rate exceeds its boil-off due to decay heat by 195 seconds thus establishing long term cooling. No cladding temperature transient will occur since the core is always covered by a mixture.

#### 4.4 0.04 Ft<sup>2</sup> Split At Pump Suction

The break is assumed to be at the bottom of node 9 of Figure 4.1. The analysis takes credit for two CFTs, one HPI and one LPI pump.

Figures 4.14 through 4.19 show core power, flow rate, pressure, leak rate, HPI flow rates and core fluid inventory respectively. No CFT or LPI flow occurred by the end of the analysis since the system pressure remained higher than the CFT actuation pressure of 590 psi and remained higher than the dead head pressure of the LPI. The reactor and R.C. pump trip occurs by about 15 seconds. The depressurization is slower in this case compared to the breaks described previously due to very small size of the break resulting in a lower leak flow. ESFAS setpoint limit on low pressure is reached by 46 seconds and the HPI flow begins by 81 seconds aiding depressurization. The system pressure is still above the secondary pressure and subcooled liquid prevails in the steam generator primary side due to the heat removal by the secondary side of the steam generator. By 120 seconds, two phase mixture is realized in the SG primary side slowing the system depressurization. The slow rate of depressurization continues even after the primary side pressure drops below the secondary side pressure at 770 seconds. The steam generator primary side in the broken loop is filled with steam by 910 seconds. The pump suction nodes in the broken

loop contain very little liquid mass after 910 seconds hence the rate of depressurization increases due to the large volume of steam now discharging through the break. The HPI flow rate exceeds the boil-off rate due to decay heat by 1250 seconds, thereby establishing long term cooling. The core is always covered with a mixture hence no cladding temperature transient will occur.

In this particular transient, long term cooling is initially established by use of one HPI pump. No LPI or GFT injection took place since the system pressure was above the injection actuation pressures. Thus, it is concluded that for breaks less than or equal to  $0.04 \text{ ft}^2$  the HPI alone is capable of matching decay heat boil-off and maintaining a liquid inventory sufficient to preclude any cladding temperature excursions.

## 5. PHASE DISTRIBUTION MULTIPLIER FOR THE CRAFT2 WILSON SEPARATION MODEL

The phase separation model available in CRAFT2 includes the option of placing a multiplier on the bubble rise velocity calculated by the Wilson model. Although this velocity is based on the average mixture void fraction, the use of a proper multiplier corrects it for expected non-uniformity in phase distribution within the mixture. Because the mixture swelling is closely tied to the bubble separation rate, varying this multiplier effectively permits tuning the mixture height calculations. For small breaks then, this multiplier can be adjusted so that the mixture calculated by CRAFT2 in the core node matches that produced by the more detailed mixture swelling code, FOAM. This, of course, would preclude the necessity of doing a FOAM analysis as long as the mixture is above the core by an amount corresponding to the level uncertainty.


A series of FOAM calculations were made to determine the amount of liquid necessary to just cover the core with a froth using the axial power shape given in BAW-10074.<sup>6</sup> Results were obtained for pressures ranging from 200 to 1200 psia with a core power of 2.13% and 4.26% of 2772 Mwt. The core parameters used were those of 177 FA plants. Steady state CRAFT2 runs were made using several different bubble rise multipliers for each combination of power, pressure and associated FOAM core liquid volume. The equilibrium core mixture heights calculated by CRAFT2 were noted. Figure 5.1 shows a plot of difference in CRAFT2 and FOAM mixture height versus bubble rise multiplier in CRAFT2. A multiplier of 2.38 as seen in Figure 5.1, produces a CRAFT2 mixture level within  $\pm$  1.8% and  $\pm$  2% of that calculated by FOAM over the range of parameters most likely to exist when core uncovering is a possibility during a small break accident. Using a tolerance of  $\pm$  2%, it is concluded that no FOAM analysis is need if the mixture height exceeds the active core by three inches (0.25 feet). If mixture height drops to less than 0.25 feet above the core, the cladding heatup analysis using FOAM results will be done as outlined in Section 5.2.3 of BAW-10104.

## 6. REFERENCES

1. C.E. Parks, B.M. Dunn, and R.C. Jones, "Multinode Analysis of Small Breaks for B&W's 2568 Mwt Nuclear Plants", BAW-10052, Rev. 1, Babcock & Wilcox, Lynchburg, Va., October 1975.
2. R.A. Hedrick, J.J. Cudlin and R.C. Foltz, "CRAFT2 - Fortran Program For Digital Simulation of a Multinode Reactor Plant During Loss of Coolant," BAW-10092, Rev. 2, Babcock & Wilcox, April 1975.
3. J.F. Wilson, R.J. Grenda, and J.F. Patterson, "The Velocity of Rising Steam in a Bubbling Two-Phase Mixture," ANS Transactions, 5 (1962).
4. B.M. Dunn, C.D. Morgan, and L.R. Cartin, "Multinode Analysis of Core Flooding Line Break for B&W's 2568 Mwt Internals Vent Valve Plants, BAW-10064, Rev. 1, Babcock & Wilcox, October 1975. (FOAM code is discussed in this reference).
5. B.M. Dunn, R.C. Jones, L.R. Cartin, C.E. Parks, and R.J. Salm, "B&W's ZCCS Evaluation Model", BAW-10104A, Rev. 1, Babcock & Wilcox, Lynchburg, Va., March 1976.
6. R.C. Jones, B.M. Dunn, and C.E. Parks, "Multinode Analysis of Small Breaks for B&W's 205 Fuel Assembly Nuclear Plants With Internals Vent Valves", BAW-10074A, Rev. 1, Babcock & Wilcox, Lynchburg, Va., March 1976.
7. R.C. Jones, J.R. Biller, and B.M. Dunn, "ECCS Analysis of B&W's 177-FA Lowered Loop NSS", BAW-10103, Rev. 2, Babcock & Wilcox, Lynchburg, Va., April 1976.

FIGURE 4-1

CFTRI Piping Diagram For Small Break



Node No.	Identification	Path No.	Identification
1	Downcomer	1,2	Core
2	Lower Plenum	3,4,18,19	Hot Leg Piping
3	Core, Core Bypass, Upper Plenum, Upper Head	5,20	Hot Leg, Upper
4,16	Hot Leg Piping	6,21	SC Tubes
3,15	Steam Generator Upper Head, SG Tubes (Upper Half)	7,22	SC Lower Head
6,16	SG Tubes (Lower Half)	8	Core Bypass
8,18	SG Lower Head	9,13,24	Cold Leg Piping
9,11,19	Cold Leg Piping (Pump Suction)	10,14,23	Pumps
10,22,20	Cold Leg Piping (Pump Discharge)	11,12,15,16,26,27	Cold Leg Piping
13	Upper Downcomer (Above the 6 of Nozzle Belt)	17,31	Downcomer
21	Pressurizer	23	LPI
22	Containment	28,29	Upper Downcomer
		30	Pressurizer
		32	Vent Valve
		33,34	Leak & Return Path
		35,36	LPI
		37	Containment Sprays

FIGURE - 4.2  
CORE POWER FOR CET LINE  
BREAK




FIGURE - 4-3  
CORE FLOW FOR CFT  
LINE BREAK




FIGURE - 4.8

CORE POWER FOR  $0.5 \text{ FT}^2$  BREAK  
AT PUMP DISCHARGE




FIGURE - 4.9

CORE FLOW FOR  $0.5 \text{ FT}^2$   
BREAK AT PUMP DISCHARGE




FIGURE - 4-14

CORE POWER FOR  $0.04 \text{ FT}^2$  BREAK  
AT PUMP SUCTION




FIGURE 4-15

CORE FLOW FOR  $0.04 \text{ FT}^2$   
BREAK AT PUMP SUCTION




FIGURE 5-1: FOAM-CRAFT 2  
MIXTURE HEIGHT  
COMPARISON





FIGURE 4.4: CORE PRESSURE HISTORY  
CFT LINE BREAK

INITIAL SYSTEM PRESSURE = 2200 PSIA







FIGURE - 4.18  
ECC INJECTION RATE

0.07 FT.<sup>3</sup>/SEC AT P<sub>4,2</sub>

SUCTION

120

100

80

60

FLOW RATE, CM/SEC

40

20

0

DECAY HEAT  
BOIL-OFF

HRI FLOW

0

500

1000

1500

2000

2500

TIME, SEC

FIGURE 4-17: LEAK FLOW VS TIME  
0.04 FT<sup>2</sup> SPLIT AT  
WALL INJECTION






FIGURE 4-16: CORE PRESSURE HISTORY







TEST NO. 1000, 1967


PUMP SUCTION





INN. VESSEL FLUID INVENTORY









FIGURE 4-10: CORE PRESSURE HISTORY

0.5 FT<sup>2</sup> SPLIT AT PUMP DISCHARGE






FIGURE 4.5 LEAK FLOW VS TIME  
CET LINE BREAK




FIGURE - 4.17: LEAK FLOW VS TIME  
0.01  $\text{ft}^2$  SPLIT AT  
PUMP SUCTION





FIGURE 4.6: ECC INJECTION RATE  
CFT LINE BREAK



LONGHAND MEMORANDUM

THE BABCOCK & WILCOX COMPANY

TO

G.R. Mayetis - NRC

FROM

Henry Bailey - BWB ext 2678

CUST.

SUBJ.

Small Break Analysis - BAW-10103

RCV'D  
part " 11/15/76  
part " 11/17/76

FILE NO. OR REF.

DATE

11/11/76

CRITICAL PATH ON CR-3

cc Zoltan R.  
11/19/76

JCP  
10/17/76

## SMALL BREAK ANALYSIS OF 177 FA LOWERED LOOP PLANTS

The CRAFT model used in these analyses is shown in Figure 1. The model is designed specifically to handle the small break LOCA. Control volumes in and around the vessel are all connected by a pair of flow paths to allow the occurrence of countercurrent flow. Phase separation within each control volume is computed using the Wilson, Grenda, and Patterson average bubble terminal velocity correlation. Within the core region, however, a multiplier of 2.38 is applied to the calculated bubble rise velocity. A comparison analysis has shown that a multiplier of 2.38 in CRAFT gives a mixture height within  $\pm 2\%$  of that predicted by FOAM. Thus no FOAM analysis will be needed if the CRAFT mixture level remains above the core by 2% of the active length.

Calculations were performed for the following breaks:

1. CFT Line Break ( $0.44 \text{ ft}^2$ ): This case results in minimum ECC system available to mitigate this relatively large, small LOCA.
2.  $0.5 \text{ ft}^2$  Split Type Break At Pump Discharge: This case was chosen as it represents the transition break between the small and the large break models.
3.  $0.04 \text{ ft}^2$  Split Type Break At Pump Suction: This case was reported as the most limiting small break in EAN-10052.

The system responses in each case have shown that during the initial period when the transient is flow controlled, sufficient flow is maintained such that CHF does not occur, and nucleate boiling heat transfer predominates.

Since the core remains covered by the mixture for the remainder of the transient, pool film boiling will be maintained. This heat transfer mechanism is sufficient to keep the cladding temperature within a few degrees of the fluid saturation temperature. Therefore, the transient clad temperature will never exceed its initial value, no metal water reaction will occur, and the core geometry will remain coolable as no cladding rupture will occur. Long term cooling is also established as the HPI injection rate is shown to eventually exceed the boil off due to core decay heat. Thus, the acceptance criteria of 10CFR50.46 are met.

A brief description of each case is now described below:

1. CFT Line Break:

The break is assumed to be at the CFT line nozzle joining one RV and is limited in area to  $0.44 \text{ ft}^2$  by the nozzle insert in the CFT line. Node 13 in Figure 1 is the break node, and the analysis takes account for one CFT and one HPI pump.

Figure 2 shows the system pressure history during the accident. Figure 3 shows leak rate thru the break, and Figure 4 is a plot of HPI and forced EOC water flow. Long term cooling is assured in that the boiloff due to core decay heat is exceeded by the HPI injection rate by 250 seconds. Figure 4 is a plot of core liquid inventory and mixture height. It shows that while much of the core liquid inventory is depleted, the mixture level predicted by CRAFT remains at a level where it is able to spill into the hot legs and, for most of the time, through the vent valves. System oscillations are observed after 1200

seconds resulting in a decrease in core liquid volume and vessel mixture height. These temporal perturbations will soon be overcome as the boil off rate is already exceeded by the injection rate and therefore will result in an increase in the core liquid volume. No clad temperature transient will occur since the core is always covered with a mixture and the HPI injection has exceeded the boil off assuring a long term cooling.

### 2. $0.05 \text{ ft}^2$ Split At Pump Discharge:

The break is assumed to be at the bottom of node 10. The analysis takes credit for two CFTs, one SPT pump and one LPI pump.

The system pressure, leak rate, SPC water flow and core fluid inventory history are shown in Figures 6,7,8 and 9 respectively. The core is always covered by a mixture and the boil off due to decay heat is exceeded by the HPI & LPI injection by 193 seconds thus establishing long term cooling.

### 3. $0.04 \text{ ft}^2$ Split At Pump Suction:

The break is assumed to be at the bottom of node 9. The analysis takes credit for two CFTs, one SPT and one LPI pump.

The Figure 10,11,12 & 13 shows system pressure, leak rate, core fluid inventory history and HPI water flow rates respectively. The core is always covered by a mixture and the boil off due to decay heat is exceeded by the HPI flow rate by 1250 seconds, indicating an establishment of long term cooling.

In this particular transient, long term cooling is initially established by use of one HPI pump alone. No LPI and/or CFT injection took place since the system pressure was above the injection actuation pressures. Thus for breaks less than or equal to  $0.04 \text{ ft}^2$  the HPI system alone is capable of matching decay heat boil off and maintaining a suitable liquid inventory to preclude any cladding temperature excursions.

# B&W Small Break Analysis (6NW-10103)

FIGURE 1

CRAFT Noding Diagram For Small Break





FIGURE -2 : CORE PRESSURE HISTORY  
CFT LINE BREAK







FIGURE 4 : LONG TFPM CORE COOLING  
CFT LINE BREAK



46 1320

K&E  
10 X 10 TO 14 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. NEW YORK







FIGURE 6: CORE PRESSURE HISTORY  
0.5 FT<sup>2</sup> SPLIT AT PUMP DISCHARGE

0.5 ft<sup>2</sup>










FIGURE 10 : CORE PRESSURE HISTORY  
0.04 FT<sup>2</sup> SPLIT AT  
PUMP SUCTION







0.04 ft<sup>2</sup>

FIGURE - 13

LONG TERM COOLING.  
0.04 FT<sup>2</sup> SPLIT AT PUMP  
SUCTION





Aust Rev, Vol 5, 1962  
q (351-357) 1961