LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	M I D C C 2 (2)	0 0 0 0 0 0 0 0 0 0 0 (3)	4 1 1 1 1 (4)	(5)
	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT

CON'T

0 1	REPORT SOURCE L (6)	0 5 0 0 0 3 1 6 (7)	1 2 1 5 8 1 (8)	0 1 1 3 8 2 (9)
		DOCKET NUMBER	EVENT DATE	REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 DURING THE PERFORMANCE OF A SURVEILLANCE TEST ON THE SOLID STATE PROTECTION SYSTEM

03 (TRAIN B), THREE LOGIC TEST POSITIONS TESTED UNSATISFACTORILY. THIS AFFECTED THE

04 CONTAINMENT PRESSURE HI-HI PORTION OF THE AUTOMATIC ACTUATION LOGIC, TECHNICAL SPEC-

05 IFICATION TABLE 3.3-3 ITEMS 2.b, 3.b.2, AND 4.b. THE REQUIREMENTS OF ACTION ITEM 13

06 WERE MET. SIMILAR OCCURRENCES INCLUDE: 050-315/78-067, 81-043 AND 050-316/78-076,

07 -080, 79-005.

08

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	I B (11)	E (12)	G (13)	I N S T R U (14)	X (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 7 4	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
A (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	N (25)	W 1 2 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 UNIVERSAL CARD A-209 (WESTINGHOUSE, PART NO. 6056D21G01) WAS FOUND TO HAVE FAILED.

11 THE LOGIC CARD WAS REPLACED, THE SURVEILLANCE TEST PROCEDURE WAS PERFORMED ON TRAIN

12 "B" TO VERIFY SYSTEM OPERABILITY. NO FURTHER ACTION IS PLANNED.

13

14

1 5	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	E (28)	1 0 0 (29)	NA	B (31)	SURVEILLANCE TEST

1 6	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

1 7	NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

1 8	NUMBER	DESCRIPTION (41)
	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE	DESCRIPTION
	Z (42)	NA

8201200637 820113
PDR ADOCK 05000316
S PDR

PUBLICITY

2 0	ISSUED	DESCRIPTION (45)	NRC USE ONLY
	N (44)	NA	

NAME OF PREPARER R. A. PALMER PHONE: 616-465-5901

GPO 917-926