



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

Docket No. 50-561

MAY 12 1978

MEMORANDUM FOR: Z. R. Rosztoczy, Chief, Analysis Branch, DSS  
FROM: T. M. Novak, Chief, Reactor Systems Branch, DSS  
SUBJECT: BSAR-205 TRANSIENT MD<sup>3</sup>R  
REFERENCES: 1. BSAR-205 Preliminary Safety Analysis Report  
2. Report to the ACRS in the Matter of B&W Reference Safety Analysis Report, BSAR-205, July 1977

Per your request, the minimum margin between minimum DNBR and the DNBR limit (1.30) for BSAR-205 is .011. This minimum DNBR occurs during the postulated feedwater temperature decrease event which is analyzed in Section 15.1.10 of reference 1 and discussed in Section 15.4.1 of reference 2.

A handwritten signature in cursive script, appearing to read "T M Novak".

Thomas M. Novak, Chief  
Reactor Systems Branch  
Division of Systems Safety

cc: D. Ross  
S. Israel  
G. Mazetis  
G. Kelly  
W. Hodges  
S. Newberry  
T. Cox  
L. Phillips

Contact: Scott Newberry, NRR  
49-27341