

50-395

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE BOX 764

COLUMBIA, S. C. 29218

January 19, 1982

Mr. Martin Virgilio
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, DC 20555



Subject: Virgil C. Summer Nuclear Station
Technical Specifications

Dear Mr. Virgilio:

In reference to Table 3.8-1, Containment Penetration Conductor Overcurrent Protective Device Test Setpoint Criteria, we asked our engineers to determine if there were any electrical penetrations to which the cables would fuse before damaging the penetration. Gilbert Associates, Inc. performed a study to determine the maximum cable size that would fuse before the penetration reached its thermal limit of 350°C. The approach of the analysis was to determine the energy required to raise the cable conductor temperature to its melting point taking into account ambient heat losses and comparing it with the energy required to raise the penetration conductor temperature to 350°C. The result of the analysis is that the cable sizes which will fuse before the penetration reaches its thermal limit are as follows:

250 MCM Penetration	# 1 Awg Cable or Smaller
#1/0 Penetration	# 4 Awg Cable or Smaller
#4 Awg Penetration	# 8 Awg Cable or Smaller

Based on the above, it is requested that the following items be eliminated from Table 3.8-1:

18-65, 67, 68, 71, 98-107, 109, 111, 113, 114, 117-119, 122-124,
126, 128-131, 133-137, 140, 141, 144-157, 159-163.

For these penetrations, the cable will fuse before the thermal limit of the penetration is reached eliminating the need for overcurrent protective devices.

It is also requested that the surveillance requirement for fuses be eliminated since the above analysis has eliminated all the electrical penetrations which were protected by fuses.

Enclosed are the corresponding corrections to the Technical Specifications. In addition to the changes above, please note that several corrections have also been made in the Table.

Cordially yours,

Ronald B. Clary

Ronald B. Clary, Manager
Nuclear Licensing

3001
3
1/1

8201250342 820119
PDR ADOCK 05000395
PDR
A

Mr. Martin Virgilio
January 19, 1982
Page 2

cc: D. A. Nauman
W. A. Williams, Jr.
R. B. Clary w/att.
O. S. Bradham
A. R. Koon w/att
W. R. Kane
L. D. Shealy w/att.
M. B. Whitaker, Jr.
W. R. Baehr w/att.
NPCF
File

ELECTRICAL POWER SYSTEMS

PROOF & REVIEW COPY

SURVEILLANCE REQUIREMENTS (Continued)

- (c) For each circuit breaker found inoperable during these functional tests, an additional representative sample of at least 10% of all the circuit breakers of the inoperable type shall also be functionally tested until no more failures are found or all circuit breakers of that type have been functionally tested.
2. By selecting and functionally testing a representative sample of at least 10% of each type of lower voltage circuit breakers. Circuit breakers selected for functional testing shall be selected on a rotating basis. Testing of these circuit breakers shall consist of injecting a current in excess of the breakers nominal setpoint and measuring the response time. The measured response time will be compared to the manufacturer's data to insure that it is less than or equal to a value specified by the manufacturer. Circuit breakers found inoperable during functional testing shall be restored to OPERABLE status prior to resuming operation. For each circuit breaker found inoperable during these functional tests, an additional representative sample of at least 10% of all the circuit breakers of the inoperable type shall also be functionally tested until no more failures are found or all circuit breakers of that type have been functionally tested.
3. By selecting and functionally testing a representative sample of each type of fuse on a rotating basis. Each representative sample of fuses shall include at least 10% of all fuses of that type. The functional test shall consist of a non-destructive resistance measurement test which demonstrates that the fuse meets its manufacturer's design criteria. Fuses found inoperable during these functional tests shall be replaced with OPERABLE fuses prior to resuming operation. For each fuse found inoperable during these functional tests, an additional representative sample of at least 10% of all fuses of that type shall be functionally tested until no more failures are found or all fuses of that type have been functionally tested.
- b. At least once per 60 months by subjecting each circuit breaker to an inspection and preventive maintenance in accordance with procedures prepared in conjunction with its manufacturer's recommendations.

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
<u>480 V SWGR.</u>				
1) XFN0067A-AH CRDM CLNG. SYS. FAN A	PRIMARY	XSWIA3/1C	LONG TIME 540 Amps SHORT TIME 2700 Amps INSTANT 3375 Amps 2025	³⁰ < 12 Sec. < 0.17 Sec. < 0.09 Sec.
XSWIA3 MAIN INCOMING	BACKUP	XSWIA3/4B	LONG TIME 4800 Amps SHORT TIME 7200 Amps INSTANT N/A	< 12 Sec. < 0.50 Sec. N/A
BUS TIE TO XSWIC3	BACKUP	XSWIA3/4C	LONG TIME 3000 Amps SHORT TIME 4500 Amps INSTANT N/A	< 12 Sec. < 0.32 Sec. N/A
2) XFN0067D-AH CDRM CLNG. SYS. FAN D	PRIMARY	XSWIA3/ ^{3A} BA	LONG TIME 540 Amps SHORT TIME 2700 Amps INSTANT 3375 Amps 2025	³⁰ < 12 Sec. < 0.17 Sec. < 0.09 Sec.
XSWIA3 MAIN INCOMING	BACKUP	XSWIA3/4B	LONG TIME 4800 Amps SHORT TIME 7200 Amps INSTANT N/A	< 12 Sec. < 0.50 Sec. N/A
BUS TIE TO XSWIC3	BACKUP	XSWIA3/4C	LONG TIME 3000 Amps SHORT TIME 4500 Amps INSTANT N/A	< 12 Sec. < 0.32 Sec. N/A
3) XCR0004-FH REACTOR BLDG POLAR CRANE	PRIMARY	XSWIA3/2C	LONG TIME 744 Amps SHORT TIME N/A INSTANT 4050 Amps	< 98 Sec. N/A < 0.09 Sec.
XSWIA3 MAIN INCOMING	BACKUP	XSWIA3/4B	LONG TIME 4800 Amps SHORT TIME 7200 Amps INSTANT N/A	< 12 Sec. < 0.50 Sec. N/A

PROCT
0-11-19
12:00 PM

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. -SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
3) CONTINUED:				
BUS TIE TO XSWIC3	BACKUP	XSWIA3/4C	LONG TIME 3000 Amps SHORT TIME 4500 Amps INSTANT N/A	< 12 Sec. ≤ 0.32 Sec. N/A
4) XFN0009A-AH R.B., REACTOR COMPART. CLNG FAN A	PRIMARY	XSWIA3/2A	LONG TIME 360 Amps SHORT TIME 1350 Amps INSTANT 1800 1350 Amps	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.
XSWIA3 MAIN INCOMING	BACKUP	XSWIA3/4B	LONG TIME 4800 Amps SHORT TIME 7200 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
BUS TIE TO XSWIC3	BACKUP	XSWIA3/4C	LONG TIME 3000 Amps SHORT TIME 4500 Amps INSTANT N/A	< 12 Sec. ≤ 0.32 Sec. N/A
5) XFN0067B-AH CRDM CLNG. SYS. FAN B	PRIMARY	XSWIB3/2D	LONG TIME 525 Amps SHORT TIME 2250 Amps INSTANT 3000 2250 Amps	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.
XSWIB3 MAIN INCOMING	BACKUP	XSWIB3/4B	LONG TIME 9000 Amps SHORT TIME 9000 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
EMERGENCY FEED FROM XSWIDB1	BACKUP	XSWIB3/3B	LONG TIME 4800 Amps SHORT TIME 6000 Amps INSTANT N/A	< 12 Sec. ≤ 0.32 Sec. N/A
6) XFN0009B-AH R.B., REACTOR COMPART. CLNG FAN B	PRIMARY	XSWIB3/3A	LONG TIME 525 Amps SHORT TIME 1125 Amps INSTANT 1500 Amps	< 12 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.

PROOF COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. -SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
6) CONTINUED:				
XSW1B3 MAIN INCOMING	BACKUP	XSW1B3/4B	LONG TIME 9000 Amps SHORT TIME 9000 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
EMERGENCY FEED FROM XSW1DB1	BACKUP	XSW1B3/3B	LONG TIME 4800 Amps SHORT TIME 6000 Amps INSTANT N/A	< 12 Sec. ≤ 0.32 Sec. N/A
7) XFN00067C-AH CDRM CLNG. SYSTEM FAN C	PRIMARY	XSW1C3/2D	LONG TIME 540 Amps SHORT TIME 2700 Amps INSTANT 3375 2025 Amps	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.
XSW1C3 MAIN INCOMING	BACKUP	XSW1C3/3B	LONG TIME 4800 Amps SHORT TIME 7200 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
BUS TIE TO XSW1A3	BACKUP	XSW1A3/4C	LONG TIME 3000 Amps SHORT TIME 4500 Amps INSTANT N/A	< 12 Sec. ≤ 0.32 Sec. N/A
8) MFN0097B-AH R.B. CLNG. UNIT FAN XFN64B EMERGENCY MOTOR	PRIMARY	XSW1DB1/6D	LONG TIME 525 Amps SHORT TIME 1500 Amps INSTANT 2250 Amps	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.
XSW1DB1 MAIN INCOMING	BACKUP	XSW1DB1/4B	LONG TIME 9000 6300 Amps SHORT TIME 9000 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
9) MFN0096B-AH R.B. CLNG. UNIT FAN XFN64B NORMAL MOTOR	PRIMARY	XSW1DB1/7B	LONG TIME 1260 Amps SHORT TIME 5400 Amps INSTANT 7200 5400 Amps	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.

PROOF COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
9) CONTINUED:				
XSWIDB1 MAIN INCOMING	BACKUP	XSWIDB1/4B	LONG TIME ⁶³⁰⁰ 9000 Amps SHORT TIME 9000 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
10) MFN0096C-AH R.B. CLNG. UNIT FAN XFN65A NORMAL MOTOR	PRIMARY	XSWIDA1/5B	LONG TIME 1260 Amps SHORT TIME 5400 Amps INSTANT 7200 Amps ⁵⁴⁰⁰	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.
XSWIDA1 MAIN INCOMING	BACKUP	XSWIDA1/4B	LONG TIME ⁶³⁰⁰ 9000 Amps SHORT TIME 9000 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
11) MFN0097C-AH R.B. CLNG. UNIT FAN XFN65A EMERGENCY MOTOR	PRIMARY	XSWIDA1/6C	LONG TIME 525 Amps SHORT TIME 1500 Amps INSTANT 2250 Amps	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.
XSWIDA1 MAIN INCOMING	BACKUP	XSWIDA1/4B	LONG TIME ⁶³⁰⁰ 9000 Amps SHORT TIME 9000 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
12) MFN0096A-AH R.B. CLNG. UNIT FAN XFN64A NORMAL MOTOR	PRIMARY	XSWIDA1/6B	LONG TIME 1260 Amps SHORT TIME 5400 Amps INSTANT 7200 Amps ⁵⁴⁰⁰	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.
XSWIDA1 MAIN INCOMING	BACKUP	XSWIDA1/4B	LONG TIME ⁶³⁰⁰ 9000 Amps SHORT TIME 9000 Amps INSTANT N/A	< 12 Sec. ≤ 0.17 Sec. N/A
13) MFN0097A-AH R.B. CLNG. UNIT FAN XFN64A EMERGENCY MOTOR	PRIMARY	XSWIDA1/5C	LONG TIME 525 Amps SHORT TIME 1500 Amps INSTANT 2250 Amps	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.

PROJECT 0077

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO.-SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
13) CONTINUED:				
XSWIDA1 MAIN INCOMING	BACKUP	XSWIDA1/4B	LONG TIME ⁶³⁰⁰ 9000 Amps SHORT TIME 9000 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
14) MFN0096D-AH R.B. CLNG. UNIT FAN XFN65B NORMAL MOTOR	PRIMARY	XSWIDB1/7C	LONG TIME 1260 Amps SHORT TIME 5400 Amps INSTANT 7200 ⁵⁴⁰⁰ Amps	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.
XSWIDB1 MAIN INCOMING	BACKUP	XSWIDB1/4B	LONG TIME ⁶³⁰⁰ 9000 Amps SHORT TIME 9000 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
15) MFN0097D-AH R.B. CLNG. UNIT FAN XFN65B EMERGENCY MOTOR	PRIMARY	XSWIDB1/6C	LONG TIME 525 Amps SHORT TIME 1500 Amps INSTANT 2250 Amps	< 30 Sec. ≤ 0.17 Sec. ≤ 0.09 Sec.
XSWIDB1 MAIN INCOMING	BACKUP	XSWIDB1/4B	LONG TIME ⁶³⁰⁰ 9000 Amps SHORT TIME 9000 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
16) XHR0004A-HR H ₂ RECOMBINER PWR. PNL. TO RECOMBINER FEED	PRIMARY	XSWIDA2/5C	LONG TIME 315 Amps SHORT TIME N/A INSTANT 900 Amps	< 12 Sec. N/A ≤ 0.09 Sec.
XSWIDA2 MAIN INCOMING	BACKUP	XSWIDA2/4B	LONG TIME 4800 Amps SHORT TIME 7200 Amps INSTANT N/A	< 12 Sec. ≤ 0.50 Sec. N/A
17) XHR0004B-HR H ₂ RECOMBINER PWR. PNL. TO RECOMBINER FEED	PRIMARY	XSWIDB2/5C	LONG TIME 315 Amps SHORT TIME N/A INSTANT 900 Amps	< 12 Sec. N/A ≤ 0.09 Sec.

FOR REVIEW ONLY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
17) CONTINUED:				
XSWIDB2 MAIN INCOMING	BACKUP	XSWIDB2/4B	LONG TIME 4800 Amps SHORT TIME 7200 Amps INSTANT N/A	< 12 Sec. < 0.50 Sec. N/A
440 Vac CDRM PWR. CAB. 1AC, CONTROL BANK A,				
18) MECHANISM 1 -				
XCA1A-CR A59-Fu13	PRIMARY	XCA1A	> 18 Milliohms	N/A
XCA1A-CR A59-Fu17	BACKUP	XCA1A	> 18 Milliohms	N/A
XCA1A-CR A51-Fu1	PRIMARY	XCA1A	> 1.4 Milliohms	N/A
XCA1A-CR A57-Fu1	BACKUP	XCA1A	> 1.4 Milliohms	N/A
XCA1A-CR A59-Fu21	PRIMARY	XCA1A	> 18 Milliohms	N/A
XCA1A-CR A61-Fu45	BACKUP	XCA1A	> 18 Milliohms	N/A
19) MECHANISM 2 -				
XCA1A-CR A59-Fu14	PRIMARY	XCA1A	> 18 Milliohms	N/A
XCA1A-CR A59-Fu18	BACKUP	XCA1A	> 18 Milliohms	N/A
XCA1A-CR A51-Fu2	PRIMARY	XCA1A	> 1.4 Milliohms	N/A
XCA1A-CR A57-Fu2	BACKUP	XCA1A	> 1.4 Milliohms	N/A
XCA1A-CR A59-Fu22	PRIMARY	XCA1A	> 18 Milliohms	N/A
XCA1A-CR A61-Fu46	BACKUP	XCA1A	> 18 Milliohms	N/A

PROTECTANT 377

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

EQUIP NO.-SYS/DESCRIPTION		DEVICE	LOCATION	TEST SETPOINT	RESPONSE TIME
CRDM PWR. CAB. 1AC, CONTINUED:					
20) MECHANISM 3 -					
XCA1A-CR	A59-Fu15	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A59-Fu19	BACKUP	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A52-Fu1	PRIMARY	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A58-Fu1	BACKUP	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A59-Fu23	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A61-Fu47	BACKUP	XCA1A	≥ 18 Milliohms	N/A
21) MECHANISM 4 -					
XCA1A-CR	A59-Fu16	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A59-Fu20	BACKUP	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A52-Fu2	PRIMARY	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A58-Fu2	BACKUP	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A59-Fu24	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A61-Fu48	BACKUP	XCA1A	≥ 18 Milliohms	N/A
440 Vac CRDM POWER CABINET 1AC, CONTROL BANK C, GROUP 1					
22) MECHANISM 1 -					
XCA1A-CR	A60-Fu25	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A60-Fu29	BACKUP	XCA1A	≥ 18 Milliohms	N/A

PHOTO COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>		<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
CRDM PWR. CAB. IAC, CONTINUED:					
XCA1A-CR	A53-Fu1	PRIMARY	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A57-Fu1	BACKUP	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A60-Fu33	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A61-Fu45	BACKUP	XCA1A	≥ 18 Milliohms	N/A
23) MECHANISM 2 -					
XCA1A-CR	A60-Fu26	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A60-Fu30	BACKUP	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A53-Fu2	PRIMARY	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A57-Fu2	BACKUP	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A60-Fu34	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A61-Fu46	BACKUP	XCA1A	≥ 18 Milliohms	N/A
24) MECHANISMS 3 -					
XCA1A-CR	A60-Fu27	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A60-Fu31	BACKUP	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A54-Fu1	PRIMARY	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A58-Fu1	BACKUP	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A60-Fu35	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A61-Fu47	BACKUP	XCA1A	≥ 18 Milliohms	N/A

PHOTO COPY
 10/10/2007

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

EQUIP NO. - SYS/DESCRIPTION		DEVICE	LOCATION	TEST SETPOINT	RESPONSE TIME	
CRDM PWR. CAB. 1AC, CONTINUED:						
25)	MECHANISM 4 -					
	XCA1A-CR	A60-Fu28	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
	XCA1A-CR	A60-Fu32	BACKUP	XCA1A	≥ 18 Milliohms	N/A
	XCA1A-CR	A54-Fu2	PRIMARY	XCA1A	≥ 1.4 Milliohms	N/A
	XCA1A-CR	A58-Fu2	BACKUP	XCA1A	≥ 1.4 Milliohms	N/A
	XCA1A-CR	A60-Fu36	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
	XCA1A-CR	A61-Fu48	BACKUP	XCA1A	≥ 18 Milliohms	N/A
440 VAC CRDM POWER CABINET 1AC, SHUTDOWN BANK A, GROUP 1						
26)	MECHANISM 1 -					
	XCA1A-CR	A61-Fu41	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
	XCA1A-CR	A60-Fu37	BACKUP	XCA1A	≥ 18 Milliohms	N/A
	XCA1A-CR	A55-Fu1	PRIMARY	XCA1A	≥ 1.4 Milliohms	N/A
	XCA1A-CR	A57-Fu1	BACKUP	XCA1A	≥ 1.4 Milliohms	N/A
	XCA1A-CR	A61-Fu49	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
	XCA1A-CR	A61-Fu45	BACKUP	XCA1A	≥ 18 Milliohms	N/A
27)	MECHANISM 2 -					
	XCA1A-CR	A61-Fu42	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
	XCA1A-CR	A60-Fu38	BACKUP	XCA1A	≥ 18 Milliohms	N/A

POST
CLOSING
COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

EQUIP NO.-SYS/DESCRIPTION		DEVICE	LOCATION	TEST SETPOINT	RESPONSE TIME
CRDM PWR. CAB. 1AC, CONTINUED:					
XCA1A-CR	A55-Fu2	PRIMARY	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A57-Fu2	BACKUP	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A61-Fu50	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A61-Fu46	BACKUP	XCA1A	≥ 18 Milliohms	N/A
28) MECHANISM 3 -					
XCA1A-CR	A61-Fu43	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A60-Fu39	BACKUP	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A56-Fu1	PRIMARY	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A58-Fu1	BACKUP	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A61-Fu51	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A61-Fu47	BACKUP	XCA1A	≥ 18 Milliohms	N/A
29) MECHANISMS 4 -					
XCA1A-CR	A61-Fu44	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A60-Fu40	BACKUP	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A56-Fu2	PRIMARY	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A58-Fu2	BACKUP	XCA1A	≥ 1.4 Milliohms	N/A
XCA1A-CR	A61-Fu52	PRIMARY	XCA1A	≥ 18 Milliohms	N/A
XCA1A-CR	A61-Fu48	BACKUP	XCA1A	≥ 18 Milliohms	N/A

PROOF OF REVIEW 2007

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
440 VAC CRM POWER CABINET 2AC, SHUTDOWN BANK A, GROUP 2				
30) MECHANISM 1 -				
XCA2A-CR A59-Fu13	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A59-Fu17	BACKUP	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A51-Fu1	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A57-Fu1	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A59-Fu21	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A61-Fu45	BACKUP	XCA2A	≥ 18 Milliohms	N/A
31) MECHANISM 2 -				
XCA2A-CR A59-Fu14	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A59-Fu18	BACKUP	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A51-Fu2	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A57-Fu2	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A59-Fu15	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A59-Fu19	BACKUP	XCA2A	≥ 18 Milliohms	N/A
32) MECHANISM 3 -				
XCA2A-CR A59-Fu15	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A59-Fu19	BACKUP	XCA2A	≥ 18 Milliohms	N/A

RECEIVED
 12/11/04

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
CRDM PWR. CAB. 2 AC, CONTINUED:				
XCA2A-CR A52-Fu11	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A58-Fu1	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A59-Fu23	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A61-Fu47	BACKUP	XCA2A	≥ 18 Milliohms	N/A
33) MECHANISM 4 -				
XCA2A-CR A59-Fu16	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A59-Fu20	BACKUP	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A52-Fu2	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A58-Fu2	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A59-Fu24	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A61-Fu45	BACKUP	XCA2A	≥ 18 Milliohms	N/A
440 VAC CRDM POWER CABINET 2 AC, CONTROL BANK C, GROUP 2				
34) MECHANISM 1-				
XCA2A-CR A60-F25	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A60-Fu29	BACKUP	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A53-Fu1	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A57-Fu1	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A

PROTECTIVE DEVICE TEST SETPOINT CRITERIA

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. -SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>	
CRDM PWR. CAB. 2 AC, CONTINUED:					
XCA2A-CR	A60-Fu33	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR	A61-Fu45	BACKUP	XCA2A	≥ 18 Milliohms	N/A
35) MECHANISM 2 -					
XCA2A-CR	A60-Fu26	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR	A60-Fu30	BACKUP	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR	A53-Fu2	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR	A57-Fu2	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR	A60-Fu34	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR	A60-Fu46	BACKUP	XCA2A	≥ 18 Milliohms	N/A
36) MECHANISM 3 -					
XCA2A-CR	A60-Fu27	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR	A60-Fu31	BACKUP	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR	A54-Fu1	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR	A58-Fu1	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR	A60-Fu35	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR	A61-Fu47	BACKUP	XCA2A	≥ 18 Milliohms	N/A

SECRET

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
CRDM POW. CAB. 2AC, CONTINUED:				
37) MECHANISM 4 -				
XCA2A-CR A60-Fu28	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A60-Fu32	BACKUP	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A54-Fu2	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A58-Fu2	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A60-Fu36	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A61-Fu48	BACKUP	XCA2A	≥ 18 Milliohms	N/A
440 VAC CRDM POWER CABINET 2AC, SHUTDOWN BANK A, GROUP 2				
38) MECHANISM 1 -				
XCA2A-CR A61-Fu41	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A60-Fu37	BACKUP	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A55-Fu1	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A57-Fu2	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A61-Fu49	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A61-Fu45	BACKUP	XCA2A	≥ 18 Milliohms	N/A
39) MECHANISM 2 -				
XCA2A-CR A61-Fu42	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A60-Fu38	BACKUP	XCA2A	≥ 18 Milliohms	N/A

PHOTO COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
CRDM PWR. CAB. 2 AC, CONTINUED:				
XCA2A-CR A55-Fu2	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A57-Fu2	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A61-Fu50	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A61-Fu46	BACKUP	XCA2A	≥ 18 Milliohms	N/A
40) MECHANISM 3 -				
XCA2A-CR A61-Fu43	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A60-Fu39	BACKUP	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A56-Fu1	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A58-Fu1	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A61-Fu51	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A61-Fu47	BACKUP	XCA2A	≥ 18 Milliohms	N/A
41) MECHANISM 4-				
XCA2A-CR A61-Fu44	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A60-Fu40	BACKUP	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A56-Fu2	PRIMARY	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A58-Fu2	BACKUP	XCA2A	≥ 1.4 Milliohms	N/A
XCA2A-CR A61-Fu52	PRIMARY	XCA2A	≥ 18 Milliohms	N/A
XCA2A-CR A61-Fu48	BACKUP	XCA2A	≥ 18 Milliohms	N/A

P07-00000000

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

EQUIP NO. -SYS/DESCRIPTION	DEVICE	LOCATION	TEST SETPOINT	RESPONSE TIME	
440 VAC CRDM POWER CABINET 1BD, SHUTDOWN BANK B, GROUP 1					
42) MECHANISM 1 -					
XCA1B-CR	A59-Fu13	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A59-Fu17	BACKUP	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A51-Fu1	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR	A57-Fu1	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR	A59-Fu21	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A61-Fu45	BACKUP	XCA1B	≥ 18 Milliohms	N/A
43) MECHANISM 2 -					
XCA1B-CR	A59-Fu14	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A59-Fu18	BACKUP	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A51-Fu2	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR	A57-Fu2	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR	A59-Fu22	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A61-Fu46	BACKUP	XCA1B	≥ 18 Milliohms	N/A
44) MECHANISM 3 -					
XCA1B-CR	A59-Fu15	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A59-Fu19	BACKUP	XCA1B	≥ 18 Milliohms	N/A

1950

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
CRDM PWR. CAB. 1BD, CONTINUED:				
XCA1B-CR A52-Fu1	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A58-Fu1	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A59-Fu23	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A61-Fu47	BACKUP	XCA1B	≥ 18 Milliohms	N/A
45) MECHANISM 4 -				
XCA1B-CR A59-Fu16	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A59-Fu20	BACKUP	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A52-Fu2	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A58-Fu2	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A59-Fu24	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A61-Fu48	BACKUP	XCA1B	≥ 18 Milliohms	N/A
440 VAC CRDM POWER CABINET, CONTROL BANK D, GROUP 1				
46) MECHANISM 1 -				
XCA1B-CR A60-Fu25	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A60-Fu29	BACKUP	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A53-Fu1	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A57-Fu1	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A

1007605270027

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>	
CRDM PWR. CAB. 1BD, CONTINUED:					
XCA1B-CR	A60-Fu33	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A61-Fu45	BACKUP	XCA1B	≥ 18 Milliohms	N/A
47) MECHANISM 2 -					
XCA1B-CR	A60-Fu26	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A60-Fu30	BACKUP	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A53-Fu2	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR	A57-Fu2	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR	A60-Fu34	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A61-Fu46	BACKUP	XCA1B	≥ 18 Milliohms	N/A
48) MECHANISM 3 -					
XCA1B-CR	A60-Fu27	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A60-Fu31	BACKUP	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A54-Fu1	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR	A58-Fu1	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR	A60-Fu35	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR	A61-Fu47	BACKUP	XCA1B	≥ 18 Milliohms	N/A

[illegible]

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. -SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
CRDM PWR. CAB. 1BD, CONTINUED:				
49) MECHANISM 4 -				
XCA1B-CR A60-Fu28	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A60-Fu32	BACKUP	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A54-Fu2	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A58-Fu2	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A60-Fu36	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A61-Fu48	BACKUP	XCA1B	≥ 18 Milliohms	N/A
440 VAC CRDM POWER CABINET 1BD, SHUTDOWN BANK B, GROUP 1				
50) MECHANISM 1 -				
XCA1B-CR A61-Fu41	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A60-Fu37	BACKUP	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A55-Fu1	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A57-Fu1	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A61-Fu49	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A61-Fu45	BACKUP	XCA1B	≥ 18 Milliohms	N/A
51) MECHANISM 2 -				
XCA1B-CR A61-Fu42	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A60-Fu38	BACKUP	XCA1B	≥ 18 Milliohms	N/A

PROOF OF REVIEW COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
CRDM PWR. CAB. 1BD, CONTINUED:				
XCA1B-CR A55-Fu2	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A57-Fu2	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A61-Fu50	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A61-Fu46	BACKUP	XCA1B	≥ 18 Milliohms	N/A
52) MECHANISM 3 -				
XCA1B-CR A61-Fu43	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A60-Fu39	BACKUP	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A56-Fu1	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A58-Fu1	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A61-Fu51	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A61-Fu47	BACKUP	XCA1B	≥ 18 Milliohms	N/A
53) MECHANISM 4 -				
XCA1B-CR A61-Fu44	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A60-Fu40	BACKUP	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A56-Fu2	PRIMARY	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A58-Fu2	BACKUP	XCA1B	≥ 1.4 Milliohms	N/A
XCA1B-CR A61-Fu52	PRIMARY	XCA1B	≥ 18 Milliohms	N/A
XCA1B-CR A61-Fu48	BACKUP	XCA1B	≥ 18 Milliohms	N/A

PROOF & CHECKED COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. -SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
440 VAC CRDM POWER CABINET 2 BD, CONTROL BANK B, GROUP 2				
54) MECHANISM 1 -				
XCA2B-CR A59-Fu13	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A59-Fu17	BACKUP	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A51-Fu1	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A57-Fu1	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A59-Fu21	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu45	BACKUP	XCA2B	≥ 18 Milliohms	N/A
55) MECHANISM 2 -				
XCA2B-CR A59-Fu14	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A59-Fu18	BACKUP	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A51-Fu2	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A57-Fu2	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A59-Fu22	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu46	BACKUP	XCA2B	≥ 18 Milliohms	N/A
56) MECHANISM 3 -				
XCA2B-CR A59-Fu15	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A59-Fu19	BACKUP	XCA2B	≥ 18 Milliohms	N/A

PROOF COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
CRDM PWR. CAB. 2 BD, CONTINUED:				
XCA2B-CR A52-Fu1	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A58-Fu1	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A59-Fu23	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu47	BACKUP	XCA2B	≥ 18 Milliohms	N/A
57) MECHANISM 4 -				
XCA2B-CR A59-Fu16	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A59-Fu20	BACKUP	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A52-Fu2	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A58-Fu2	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A59-Fu24	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu48	BACKUP	XCA2B	≥ 18 Milliohms	N/A
440 VAC CRDM POWER CABINET 2BD, CONTROL BANK D, GROUP 2				
58) MECHANISM 1 -				
XCA2B-CR A60-Fu25	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A60-Fu29	BACKUP	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A53-Fu1	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A57-Fu1	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A

PROTECTIVE COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
CRDM PWR. CAB. 2 BD, CONTINUED:				
XCA2B-CR A60-Fu33	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu45	BACKUP	XCA2B	≥ 18 Milliohms	N/A
59) MECHANISM 2 -				
XCA2B-CR A60-Fu26	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A60-Fu30	BACKUP	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A53-Fu2	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A57-Fu2	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A60-Fu34	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu46	BACKUP	XCA2B	≥ 18 Milliohms	N/A
60) MECHANISM 3 -				
XCA2B-CR A60-Fu27	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A60-Fu31	BACKUP	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A54-Fu1	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A58-Fu1	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A60-Fu35	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu47	BACKUP	XCA2B	≥ 18 Milliohms	N/A

P003 0 27000 0000

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO.-SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
CRDM PWR. CAB. 2 BD, CONTINUED:				
61) MECHANISM 4 -				
XCA2B-CR A60-Fu28	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A60-Fu32	BACKUP	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A54-Fu2	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A58-Fu2	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A60-Fu36	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu4B	BACKUP	XCA2B	≥ 18 Milliohms	N/A
440 VAC CRDM POWER CABINET 2BD, SHUTDOWN BANK D, GROUP 2				
62) MECHANISM 1-				
XCA2B-CR A61-Fu41	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A60-Fu37	BACKUP	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A55-Fu1	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A57-Fu1	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A61-Fu49	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu45	BACKUP	XCA2B	≥ 18 Milliohms	N/A
63) MECHANISM 2 -				
XCA2B-CR A61-Fu42	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A60-Fu38	BACKUP	XCA2B	≥ 18 Milliohms	N/A

PROOF COPY

TABLE 3.8-1 (continued)

CONTAINMENT/PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
GRDM PWR. CAB. 2 BD, CONTINUED:				
XCA2B-CR A55-Fu2	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A57-Fu2	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A61-Fu50	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu46	BACKUP	XCA2B	≥ 18 Milliohms	N/A
64) MECHANISM 3 -				
XCA2B-CR A61-Fu43	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A60-Fu39	BACKUP	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A56-Fu1	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A58-Fu1	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A61-Fu51	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu47	BACKUP	XCA2B	≥ 18 Milliohms	N/A
65) MECHANISM 4 -				
XCA2B-CR A61-Fu44	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A60-Fu40	BACKUP	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A56-Fu2	PRIMARY	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A58-Fu2	BACKUP	XCA2B	≥ 1.4 Milliohms	N/A
XCA2B-CR A61-Fu48	PRIMARY	XCA2B	≥ 18 Milliohms	N/A
XCA2B-CR A61-Fu48	BACKUP	XCA2B	≥ 18 Milliohms	N/A

PROOF & REVIEW COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

EQUIP NO. -SYS/DESCRIPTION	DEVICE	LOCATION	TEST SETPOINT	RESPONSE TIME
18 125 VAC				
66) DPN8007C-ED Emergency LTG. PNL. 7	PRIMARY	DPN1HX/14	120 Amps	≤ 30 sec.
	BACKUP	DPN1HX/M2	1500 Amps	≤ 250 Sec.
120 VAC MISC.				
67) XBJ0002-IC/INCORE THERMOCOUPLE REF. JUNCT. BOX 2	PRIMARY	APN1FX1/25	45 Amps	≤ 45 Sec.
	BACKUP	APN1FX1/27	450 Amps	≤ 150 Sec.
68) XBJ0002-IC/INCORE THERMOCOUPLE REF. JUNCT. BOX 1	PRIMARY	APN1FX1/24	45 Amps	≤ 45 Sec.
	BACKUP	APN1FX1/27	450 AMPS	≤ 150 Sec.
19 69) XPN7060-CR/ROD POSITION INDICATION PNL. 1	PRIMARY	APN1FC1/2	120 Amps	≤ 30 Sec.
	BACKUP	APN1FA/25 (Normal Feed)	450 Amps	≤ 150 Sec.
	BACKUP	APN1FB/25 (Emerg. Feed)	450 Amps	≤ 150 Sec.
20 70) XPN7061-CR/ROD POSITION INDICATION PNL. 2	PRIMARY	APN1FC1/4	120 Amps	≤ 30 Sec.
	BACKUP	APN1FA/25 (Normal Feed)	450 Amps	≤ 150 Sec.
	BACKUP	APN1FB/25 (Emerg. Feed)	450 Amps	≤ 150 Sec.
71) APN5915-EV/TRANSMITTER PWR. SUPPLY CAB. NO. 3	PRIMARY	APN5906/25	60 Amps	≤ 45 Sec.
	BACKUP	X1T5906 (Normal Feed)	Later	
	BACKGGROUND	APN1FX/25 (Emerg. Feed)	375 Amps	≤ 150 Sec.

PHOTO COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. -SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
²¹ 72) 460 VAC MISC.				
72) PRESS. HTR. GROUP 23, 49, 50 -RC	PRIMARY	APN4101/1	270 Amps	≤ 75 Sec.
	BACKUP	APN4101/MN.	2400 Amps	≤ 350 Sec.
²² 73) PRESS. HTR. GROUP 28, 55, 56 -RC	PRIMARY	APN4101/2	270 Amps	≤ 75 Sec.
	BACKUP	APN4101/MN.	2400 Amps	≤ 350 Sec.
²³ 74) PRESS. HTR. GROUP 29, 57, 58 -RC	PRIMARY	APN4101/3	270 Amps	≤ 75 Sec.
	BACKUP	APN4101/MN.	2400 Amps	≤ 350 Sec.
²⁴ 75) PRESS. HTR. GROUP 26, 53, 54 -RC	PRIMARY	APN4101/4	270 Amps	≤ 75 Sec.
	BACKUP	APN4101/MN.	2400 Amps	≤ 350 Sec.
²⁵ 76) PRESS. HTR. GROUP 21, 47, 48 -RC	PRIMARY	APN4101/5	270 Amps	≤ 75 Sec.
	BACKUP	APN4101/MN.	2400 Amps	≤ 350 Sec.
²⁶ 77) PRESS. HTR. GROUP 1, 2, 22 - RC	PRIMARY	APN4101/6	270 Amps	≤ 75 Sec.
	BACKUP	APN4101/MN.	2400 Amps	≤ 350 Sec.
²⁷ 78) PRESS. HTR. GROUP 5, 6, 27 -RC	PRIMARY	APN4101/7	270 Amps	≤ 75 Sec.
	BACKUP	APN4101/MN.	2400 Amps	≤ 350 Sec.
²⁸ 79) PRESS. HTR. GROUP 3, 4, 35 -RC	PRIMARY	APN4101/8	270 Amps	≤ 75 Sec.
	BACKUP	APN4101/MN.	2400 Amps	≤ 350 Sec.

PROOF OF REVIEW 0077

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO.-SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
29 80) 460 VAC MISC. CONTINUED: PRESS. HTR. GROUP 7, 8, 30 -RC	PRIMARY	APN4101/9	270 Amps	≤ 75 Sec.
	BACKUP	APN4101/MN.	2400 Amps	≤ 350 Sec.
30 81) PRESS. HTR. GROUP 24, 51, 52 -RC	PRIMARY	APN4101/10	270 Amps	≤ 75 Sec.
	BACKUP	APN4101/MN.	2400 Amps	≤ 350 Sec.
31 82) PRESS. HTR. GROUP 17, 18, 42 -RC	PRIMARY	APN4102/1	270 Amps	≤ 75 Sec.
	BACKUP	APN4102/MN.	1500 Amps	≤ 200 Sec.
32 82) PRESS. HTR. GROUP 19, 20, 45 -RC	PRIMARY	APN4102/2	270 Amps	≤ 75 Sec.
	BACKUP	APN4102/MN.	1500 Amps	≤ 200 Sec.
33 83) PRESS. HTR, GROUP 38, 67, 68 -RC	PRIMARY	APN4102/3	270 Amps	≤ 75 Sec.
	BACKUP	APN4102/MN.	1500 Amps	≤ 200 Sec.
34 84) PRESS. HTR. GROUP 39, 69, 70 - RC	PRIMARY	APN4102/4	270 Amps	≤ 75 Sec.
	BACKUP	APN4102/MN.	1500 Amps	≤ 200 Sec.
35 85) PRESS. HTR. GROUP 44, 75, 76 -RC	PRIMARY	APN4102/5	270 Amps	≤ 75 Sec.
	BACKUP	APN4102/MN.	1500 Amps	≤ 200 Sec.
36 86) PRESS. HTR. GROUP 41, 71, 72 -RC	PRIMARY	APN4102/6	270 Amps	≤ 75 Sec.
	BACKUP	APN4102/MN.	1500 Amps	≤ 200 Sec.

PROJECT REVIEW 03/27

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
37 460 VAC MISC. CONTINUED:				
87) PRESS. HTR. GROUP 43, 73, 74 -RC	PRIMARY	APN4102/7	270 Amps	≤ 75 Sec.
	BACKUP	APN4102/MN.	1500 Amps	≤ 200 Sec.
38 88) PRESS. HTR. GROUP 15, 16, 40 -RC	PRIMARY	APN4102/8	270 Amps	≤ 75 Sec.
	BACKUP	APN4102/MN.	1500 Amps	≤ 200 Sec.
39 89) PRESS. HTR. GROUP 46, 77, 78 -RC	PRIMARY	APN4102/9	270 Amps	≤ 75 Sec.
	BACKUP	APN4102/MN.	1500 Amps	≤ 200 Sec.
40 90) PRESS. HTR. GROUP 9, 10, 32 -RC	PRIMARY	APN4103/1	270 Amps	≤ 75 Sec.
	BACKUP	APN4103/MN.	2400 Amps	≤ 350 Sec.
41 91) PRESS. HTR. GROUP 11, 12, 35 -RC	PRIMARY	APN4103/2	270 Amps	≤ 75 Sec.
	BACKUP	APN4103/MN.	2400 Amps	≤ 350 Sec.
42 92) PRESS. HTR. GROUP 31, 59, 60 - RC	PRIMARY	APN4103/3	270 Amps	≤ 75 Sec.
	BACKUP	APN4103/MN.	2400 Amps	≤ 350 Sec.
43 93) PRESS. HTR. GROUP 36, 65, 66 -RC	PRIMARY	APN4103/4	270 Amps	≤ 75 Sec.
	BACKUP	APN4103/MN.	2400 Amps	≤ 350 Sec.
44 94) PRESS. HTR. GROUP 13, 14, 37 -RC	PRIMARY	APN4103/5	270 Amps	≤ 75 Sec.
	BACKUP	APN4103/MN.	2400 Amps	≤ 350 Sec.

RECEIVED
 10/10/03

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
45 460 VAC MISC. CONTINUED:				
95) PRESS. HTR. GROUP 33, 61, 62 -RC	PRIMARY	APN4103/6	270 Amps	≤ 75 Sec.
	BACKUP	APN4103/MN.	2400 Amps	≤ 350 Sec.
46 96) PRESS. HTR. GROUP 34, 63, 64 -RC	PRIMARY	APN4103/7	270 Amps	≤ 75 Sec.
	BACKUP	APN4103/MN.	2400 Amps	≤ 350 Sec.
47 480 VAC MOTOR CONTROL CENTERS				
97) XFN0066A-AH/RB CHARCOAL CLEANUP UNIT FAN A	PRIMARY	XMC1A3X/10GK	1500 Amps	N/A
	BACKUP	XMC1A3X/10GK	210 Amps	≤ 200 Sec. ≤ 95 Sec.
98) XPP0138-ND/LEAK DETECTION SUMP PUMP	PRIMARY	XMC1A3X/41L	225 Amps	N/A
	BACKUP	XMC1A3X/41L	45 Amps	≤ 100 Sec.
99) XDO 0001-IC/TERM. BOX FOR INCORE NEUTRON DETECTOR DRIVES A,B,C,D,E	PRIMARY	XMC1A3X/3EG	45 Amps	≤ 100 Sec.
	BACKUP	XMC1A3X/3EG	45 Amps	≤ 100 Sec.
100) XVG9593A-CC/MOV REACT. COOL Pump A THERMAL Barrier	PRIMARY	XMC1A3X/9IM	33 Amps	N/A
	BACKUP	XMC1A3X/9IM	45 Amps	≤ 30 Sec.

PROOF OF REVIEW COPY

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
480 VAC MISC. CONTINUED:				
101) XPP0149-SW/DRPI COOLING UNIT BSTR. PUMP	PRIMARY	XMC1A3X/11AD	225 Amps	N/A
	BACKUP	XMC1A3X/11AD	45 Amps	≤ 100 Sec.
102) XFN0068A-AA/SECONDARY COMPT. (LOOP A) CLG. FAN A	PRIMARY	XMC1A3X/11EH	720 Amps	N/A
	BACKUP	XMC1A3X/11EH	150 Amps	≤ 200 Sec.
103) XFN0069A-AH/SECONDARY COMPT. (LOOP B) CLG. FAN A	PRIMARY	XMC1A3X/10CF	720 Amps	N/A
	BACKUP	XMC1A3X/10CF	150 Amps	≤ 200 Sec.
104) XFN0070A-AH/SECONDARY COMPT. (LOOP C) CLG. FAN A	PRIMARY	XMC1A3X/9AD	720 Amps	N/A
	BACKUP	XMC1A3X/9AD	150 Amps	≤ 200 Sec.
105) XPP0051A-WL/R.C. DRAIN TANK - PUMP A	PRIMARY	XMC1A3X/6CG	720 Amps	N/A
	BACKUP	XMC1A3X/6CG	210 Amps	≤ 200 Sec.
106) XPP0059A-ND/INCORE INSTR. CHASE SUMP PUMP A	PRIMARY	XMC1A3X/4AD	225 Amps	N/A
	BACKUP	XMC1A3X/4AD	45 Amps	≤ 100 Sec.
107) XPP0115A-ND/R.B. SUMP PUMP A	PRIMARY	XMC1A3X/4EH	87 Amps	N/A
	BACKUP	XMC1A3X/4EH	45 Amps	≤ 100 Sec.

PROOF COPY
 100-000000-0001

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
48 480 VAC MCC*, CONTINUED: 108) XTF9003-EM/RECEPTACLE TRANSFORMER 3	PRIMARY	XMC1A3X/1AC	240 Amps	≤ 200 Sec.
	BACKUP	XMC1A3X/1AC	240 Amps	≤ 200 Sec.
109) XVG9576-CC/MOV, ISOLATION RCDT	PRIMARY	XMC1B2X/5IM	225 Amps	N/A
	BACKUP	N/A	60 Amps	≤ 100 Sec.
49 110) XVG9583-CC/MOV, GATE EXCESS LETDOWN HX	PRIMARY	XMC1B2X/3AE	225 Amps	N/A
	BACKUP	XMC1B2X/3AE	45 Amps	≤ 100 Sec.
111) XFN0007B-AH/REFUELING WATER SURFACE SUPPLY FAN B	PRIMARY	XMC1B3X/9AD	87 Amps	N/A
	BACKUP	XMC1B3X/9AD	45 Amps	≤ 100 Sec.
50 110) XFN0066B-AN/R.B. CHARCOAL CLEANUP UNIT FAN B	PRIMARY	XMC1B3X/10FJ	1,500 Amps	N/A
	BACKUP	XMC1B3X/10FJ	210 Amps	≤ 200 Sec.
113) XXP0059B-ND/INCORE INSTR. CHASE SUMP PUMP B	PRIMARY	XMC1B3X/3EH	225 Amps	N/A
	BACKUP	XMC1B3X/3EH	45 Amps	≤ 100 Sec.
114) XPP0115B-ND/R.B. SUMP PUMP B	PRIMARY	XMC1B3X/3IL	87 Amps	N/A
	BACKUP	XMC1B3X/3IL	45 Amps	≤ 100 Sec.

FOOTNOTES
 SEE
 114

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. -SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
51 480 VAC MCC, CONTINUED: 115) APN4005-EM/480 VAC POWER PNL.-FEEDER	PRIMARY	XMC1B3X/5CE	270 Amps	≤ 200 Sec.
	BACKUP	XMC1B3X/5CE	270 Amps	≤ 200 Sec.
52 116) XTF8009-EM/TRANSFORMER FOR LIGHTING PNL. 9 (NORMAL LTG.)	PRIMARY	XMC1B3X/5HJ	240 Amps	≤ 200 Sec.
	BACKUP	XMC1B3X/5HJ	240 Amps	≤ 200 Sec.
117) XFN0068B-AH/SECONDARY COMPT. (LOOP A) CLG FAN B	PRIMARY	XMC1B3Y/3AD	720 Amps	N/A
	BACKUP	XMC1B3Y/3AD	180 Amps	≤ 200 Sec.
118) XFN0069B-AH/SECONDARY COMPT. (LOOP B) CLG FAN B	PRIMARY	XMC1B3Y/3EH	720 Amps	N/A
	BACKUP	XMC1B3Y/3EH	180 Amps	≤ 200 Sec.
119) XFN0070B-AH/SECONDARY COMPT. (LOOP C) CLG. FAN B	PRIMARY	XMC1B3Y/3IL	720 Amps	N/A
	BACKUP	XMC1B3Y/3IL	180 Amps	≤ 200 Sec.
53 120) APN4012-EM/WELDING RECEPT. PWR. PNL.	PRIMARY	XMC1B3Y/7GL	600 Amps	≤ 300 Sec.
	BACKUP	XMC1B3Y/7GL	600 Amps	≤ 300 Sec.
54 121) APN4013-EM/WELDING RECEPT. PWR. PNL.	PRIMARY	XMC1B3Y/9GL	600 Amps	≤ 300 Sec.
	BACKUP	XMC1B3Y/9GL	600 Amps	≤ 300 Sec.

PHOTO COPY

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. -SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
480 VAC MCC, CONTINUED:				
122) R.C. PUMP C HEATER-RC	PRIMARY	XMC1B3Y/5AD	225 Amps	N/A
	BACKUP	XMC1B3Y/5AD	45 Amps	≤ 100 Sec.
123) R.C. PUMP C, OIL LIFT PMP -RC	PRIMARY	XMC1B3Y/5EH	450 Amps	N/A
	BACKUP	XMC1B3Y/5EH	75 Amps	≤ 100 Sec.
124) XPP0051B-WL/R.C. DRAIN TANK PUMP B	PRIMARY	XMC1B3Y/8GK	720 Amps	N/A
	BACKUP	XMC1B3Y/8GK	210 Amps	≤ 95 Sec.
55 125) XTF8008-EM/TRANSFORMER FOR LTG. PNL. 8, UNDERWATER LIGHTING	PRIMARY	XMC1B3Y/4HI	240 Amps	≤ 200 Sec.
	BACKUP	XMC1B3Y/4HJ	240 Amps	≤ 200 Sec.
126) XVB9593B-CC/MOV, RC PUMP B THERMAL BARRIER	PRIMARY	XMC1B3Y/4AE	225 Amps	N/A
	BACKUP	XMC1B3Y/4AE	45 Amps	≤ 100 Sec.
56 127) XFN0068C-AH/SECONDARY COMPT. (LOOP A) CLG FAN C	PRIMARY	XMC1C3X/8AE	1500 Amps	N/A
	BACKUP	XMC1C3X/8AE	210 Amps	≤ 200 Sec.
128) R.C. PUMP B HEATER -RC	PRIMARY	XMC1C3X/5EH	225 Amps	N/A
	BACKUP	XMC1C3X/5EH	45 Amps	≤ 100 Sec.

[illegible]

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
480 VAC MCC, CONTINUED:				
129) R.C. PUMP B OIL LIFT PUMP - RC	PRIMARY	XMC1C3X/6EH	450 Amps	N/A
	BACKUP	XMC1C3X/6EH	75 Amps	≤ 100 Sec.
130) XFN0069C-AH/SECONDARY COMPT. (LOOP B) CLG. FAN C	PRIMARY	XMC1C3X/2EH	720 Amps	N/A
	BACKUP	XMC1C3X/2EH	150 Amps	≤ 200 Sec.
131) XFN0070C-AH/SECONDARY COMPT. (LOOP C) CLG FAN C	PRIMARY	XMC1C3X/2IL	720 Amps	N/A
	BACKUP	XMC1C3X/2IL	150 Amps	≤ 200 Sec.
132) XTF8006-EM/TRANSFORMER FOR LTG. PNL. 6, NORMAL LIGHTING	PRIMARY	XMC1C3X/4CE	240 Amps	≤ 200 Sec.
	BACKUP	XMC1C3X/4CE	240 Amps	≤ 200 Sec.
133) XVG9593C-CC/MOV, R.C. PUMP C THERMAL BARRIER	PRIMARY	XMC1C3X/4IM	225 Amps	N/A
	BACKUP	XMC1C3X/4IM	45 Amps	≤ 100 Sec.
134) XFN0107-VL/CONTROL ROD POSIT. DATA CAB. CLG FAN	PRIMARY	XMC1C3X/2AD	450 Amps	N/A
	BACKUP	XMC1C3X/2AD	75 Amps	≤ 100 Sec.
135) R.C. PUMP A HEATER - RC	PRIMARY	XMC1C3X/5AD	225 Amps	N/A
	BACKUP	XMC1C3X/5AD	45 Amps	≤ 100 Sec.

FILED
MAR 7 1977
FBI - NEW YORK

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. -SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
480 VAC MCC, CONTINUED:				
136) R.C. PUMP A OIL LIFT PUMP -RC	PRIMARY	XMC1C3X/6AD	450 Amps	N/A
	BACKUP	XMC1C3X/6AD	75 Amps	≤ 100 Sec.
137) XFN0007A-AH/REFUELING WATER SURFACE SUPPLY FAN A	PRIMARY	XMC1C3X/3EH	87 Amps	N/A
	BACKUP	XMC1C3X/3EH	45 Amps	≤ 100 Sec.
59-139) XFN0008-AH/REFUELING WATER SURFACE EXHAUST FAN	PRIMARY	XMC1C3X/3IL	720 Amps	N/A
	BACKUP	XMC1C3X/3IL	150 Amps	≤ 200 Sec.
140) XVG9605-CC/MOV - R.B.	PRIMARY	XMC1DA2X/3IM	45 Amps	≤ 100 Sec.
	BACKUP	XMC1DA2X/3IM	45 Amps	≤ 100 Sec.
141) XVG8701A-RH/RHR LOOP 1 INLET ISOLATION VLV.	PRIMARY	XMC1DA2X/7FJ	225 Amps	N/A
	BACKUP	XMC1DA2X/7FJ	45 Amps	≤ 100 Sec.
59-142) XVG8808A-SI/ACCUMULATOR A ISOLATION VLV.	PRIMARY	XMC1DA2X/8AE	300 Amps	≤ 200 Sec.
	BACKUP	XMC1DA2X/8AE	300 Amps	≤ 200 Sec.

RECEIVED
10/10/07

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
480 VAC MCC, CONTINUED:				
60 143) XVG8808C-SI/ACCUMULATOR C ISOLATION VLV.	PRIMARY	XMC1DA2X/8FS	300 Amps	≤ 200 sec.
	BACKUP	XMC1DA2X/8FJ	300 Amps	≤ 200 sec.
144) XVG8000B-RC/PRESS. RELIEF ISOLATION VLV.	PRIMARY	XMC1DA2X/6IM	225 Amps	N/A
	BACKUP	XMC1DA2X/6IM	45 Amps	≤ 100 sec.
145) XVG3108A-SW/R.B. Recirc. Unit A - Isolation Vlv.	PRIMARY	XMC1DA2Y/16IM	45 Amps	≤ 100 sec.
	BACKUP	XMC1DA2Y/16IM	45 Amps	≤ 100 sec.
146) XVG3108B-SW/R.B. Recirc. Unit B - Isolation Vlv.	PRIMARY	XMC1DA2Y/15CG	45 Amps	≤ 100 sec.
	BACKUP	XMC1DA2Y/15CG	45 Amps	≤ 100 sec.
147) XVG3109A-SW/R.B. Recirc. Unit A - Isolation Vlv.	PRIMARY	XMC1DA2Y/15HL	45 Amps	≤ 100 sec.
	BACKUP	XMC1DA2Y/15HL	45 Amps	≤ 100 sec.
148) XVG3109B-SW/R.B. Recirc. Unit B - Isolation Vlv.	PRIMARY	XMC1DA2Y/14CG	45 Amps	≤ 100 sec.
	BACKUP	XMC1DA2Y/14CG	45 Amps	≤ 100 sec.

NOT TO BE USED

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. - SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
480 VAC MCC, CONTINUED:				
149) XVT8112-CS/SEAL WATER RETURN ISOLATION VLV.	PRIMARY	XMC1DA2Y/3IM	45 Amps	≤ 100 Sec.
	BACKUP	XMC1DA2Y/3IM	45 Amps	≤ 100 Sec.
150) XVG8701B-RH/RNR LOOP 3 INLET ISOLATION VLV.	PRIMARY	XMC1DA2Y/18IM	225 Amps	N/A
	BACKUP	XMC1DA2Y/18IM	45 Amps	≤ 100 Sec.
151) XVG8000C-RC/PRESS. RELIEF ISOLATION VLV.	PRIMARY	XMC1DB2X/8DH	225 Amps	N/A
	BACKUP	XMC1DB2Y/8DH	45 Amps	≤ 100 Sec.
152) XVG3108C-SW/R.B. RECIRC UNIT C ISOLATION VLV.	PRIMARY	XMC1DB2Y/18IM	45 Amps	≤ 100 Sec.
	BACKUP	XMC1DB2Y/18IM	45 Amps	≤ 100 Sec.
153) XVG3108D-SW/R.B. RECIRC. UNIT D ISOLATION VLV.	PRIMARY	XMC1DB2Y/19IM	45 Amps	≤ 100 Sec.
	BACKUP	XMC1DB2Y/19IM	45 Amps	≤ 100 Sec.
154) XVG3109C-SW/R.B. RECIRC UNIT C ISOLATION VLV.	PRIMARY	XMC1DB2Y/20 IM	45 Amps	≤ 100 Sec.
	BACKUP	XMC1DB2Y/20IM	45 Amps	≤ 100 Sec.

PROOF OF REVIEW 03/17

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

EQUIP NO. - SYS/DESCRIPTION	DEVICE	LOCATION	TEST SETPOINT	RESPONSE TIME
480 VAC MCC, CONTINUED:				
155) XVG 3109D-SW/R.B. RECIRC. UNIT D ISOLATION VLV.	PRIMARY	XMC1DB2Y/21IM	45 Amps	≤ 100 Sec.
	BACKUP	XMC1DB2Y/21IM	45 Amps	≤ 100 Sec.
156) XVG 8702A-RH/RHR LOOP 1 INLET ISOLATION VLV.	PRIMARY	XMC1DB2Y/4AE	225 Amps	N/A
	BACKUP	XMC1DB2Y/4AE	45 Amps	≤ 100 Sec.
157) XVG 87028-RH/RHR LOOP 3 INLET ISOLATION VLV.	PRIMARY	XMC1DB2Y/4FS	225 Amps	N/A
	BACKUP	XMC1DB2Y/4FS	45 Amps	≤ 100 Sec.
6 / 158) XVG 8808B-ST/ACCUMULATOR B ISOLATION VLV.	PRIMARY	XMC1DB2Y/16IM	300 Amps	≤ 200 Sec.
	BACKUP	XMC1DB2Y/16IM	300 Amps	≤ 200 Sec.
159) XVG 8000A-RC/PRESS. RELIEF ISOLATION VLV.	PRIMARY	XMC1DB2Y/31IM	45 Amps	N/A
	BACKUP	XMC1DB2Y/31IM	45 Amps	≤ 100 Sec.
160) XVG 8095A-RC/REACTOR HEAD VENT VLV. TO PRESS. RELIEF TANK	PRIMARY	XMC1DA2X/5IM	225 Amps	N/A
	BACKUP	XMC1DA2X/5IM	45 Amps	≤ 100 Sec.

PROF. A. H. C. 1071

TABLE 3.8-1 (continued)

CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICE TEST SETPOINT CRITERIA

<u>EQUIP NO. -SYS/DESCRIPTION</u>	<u>DEVICE</u>	<u>LOCATION</u>	<u>TEST SETPOINT</u>	<u>RESPONSE TIME</u>
480 VAC MCC, CONTINUED:				
161) XVG 8095B-RC/REACTOR HEAD VENT VLV. TO PRESS. RELIEF TANK	PRIMARY	XMC1DB2Y/23FJ	45 Amps	≤ 100 Sec.
	BACKUP	XMC1DB2Y/23FJ	60 Amps	≤ 100 Sec.
162) XVG 8096A-RC/REACTOR HEAD VENT VLV. TO PRESS. RELIEF TANK	PRIMARY	XMC1DA2X/7AE	225 Amps	N/A
	BACKUP	XMC1DA2X/7AE	60 Amps	≤ 100 Sec.
163) XVG 8096B-RC/REACTOR HEAD VENT VLV. TO PRESS. RELIEF TANK	PRIMARY	XMC1DB2Y/12IM	225 Amps	N/A
	BACKUP	XMC1DB2Y/12IM	60 Amps	≤ 100 Sec.

PROT & REVISED 2007