

CONFIRMATION OF ACTION

Docket No. 50-266

Docket No. 50-301

Wisconsin Electric Power Company
ATTN: Mr. C. W. Fay
Assistant Vice President
231 West Michigan
Milwaukee, WI 53201



Gentlemen:

This letter is to confirm the agreements reached between you and other members of your staff, and Messrs. S. Schwartz, Headquarters NRC, W. Axelson, Region III, and other members of the Nuclear Regulatory Commission staff on January 14, 1982, during the management exit interview following the NRC Emergency Preparedness Appraisal of Point Beach Nuclear Plant, Units 1 and 2.

Immediate corrective actions are required for the significant Appraisal findings. The exact nature of the required actions, as well as the agreed upon dates for such actions, are as follows:

1. Onsite Emergency Organization

A. Required Action

The licensee shall provide a description of how they intend to meet the minimum shift staffing guidance of NUREG-0654, Table B-1. This description shall clearly indicate how each major functional area and task will be implemented at all times. Alternate measures shall be described for those major functional areas not maintained 24 hours per day. Further, the licensee shall provide a description of a timely shift augmentation system meeting the goals of Table B-1. The description of the minimum shift staffing and augmentation system shall clearly indicate dates for implementation. (266/82-02-01; 301/82-02-01)

B. Agreed Upon Dates for Completion

This shall be completed by February 18, 1982.

8201260013 820120
PDR ADOCK 05000266
G PDR

CONFIRMATION OF ACTION

JB35
2/10

CONFIRMATION OF ACTION

Wisconsin Electric Power Company - 2 -

2. Emergency Plan Training/Retraining

A. Required Action

The licensee shall provide a schedule for developing and documenting an approved emergency plan training/retraining program to include formal lesson plans with clearly stated performance objectives and provisions for student performance evaluation. (266/82-02-02; 301/82-02-02)

B. Agreed Upon Date of Completion

This shall be completed and sent to the NRC by February 18, 1982.

3. Implementing Instructions

A. Required Action

The licensee shall (1) modify the PBNP Emergency Plan and Implementing Procedure EAL's to agree with those given in NUREG-0654, Appendix 1, and (2) have the capability to notify the State and local governmental agencies within 15 minutes of declaration of an emergency. This shall include delegation of authority to the Shift Supervisor to promptly (15 minutes) notify responsible State and county agencies of an emergency if he cannot reach the Duty and Call Supervisor. Training shall be provided to all Shift Supervisors relevant to this authority. This delegation of authority shall be formalized in a procedure. (266/82-02-03; 301/82-02-03)

B. Agreed Upon Date of Completion

This shall be completed by March 18, 1982.

4. Meteorological Instrumentation

A. Required Action

The licensee shall establish a meteorological measurements program in accordance with RG 1.23 (February 17, 1972) and identify techniques to be incorporated into dose calculational methodology to compensate for potential uncertainties associated with plume trajectories. This shall include procedures to accommodate lake effect. (266/82-02-04; 301/82-02-04)

B. Agreed Upon Date of Completion

This shall be completed by May 18, 1982, depending on equipment procurement problems. If these problems arise, the licensee shall

CONFIRMATION OF ACTION

CONFIRMATION OF ACTION

Wisconsin Electric Power Company - 3 -

notify the NRC-Region III within 5 working days. Procedure corrections shall be incorporated within 60 days of the date of this letter including dose assessment methodology described above.

In addition to the above agreements, the licensee shall provide to the NRC by February 18, 1982, the State and counties' position regarding prompt notification to them for an Unusual Event emergency at Point Beach.

If our understanding of the actions as described in this letter are not correct, you should contact this office within 24 hours.

Further, please provide our office written notification upon completion of your corrective actions.

Sincerely,

Original signed by
James G. Keppler

James G. Keppler
Regional Administrator

cc: G. A. Reed, Manager
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
John J. Duffy, Chief Boiler
Inspector
Peter Anderson, Wisconsin's
Environmental Decade
Stanley York, Chairman
Public Service Commission

RIII
JRP
Pagliaro/so
1/19/82

RIII
JRP
Januska
for

RIII
Anderson

RIII
CP
Paperiello
1/20/82

RIII RIII
RFW
Hind Warnick
1/20/82 1/20/82 1/20/82

RIII
Spessard
1/20

RIII
Davis
1/20

RIII
Keppler
1/20/82

CONFIRMATION OF ACTION