| (7-77) | LICENSEE EVENT REPORT |
|------------|---|
| 1 | CONTROL BLOCK |
| | N J S G S 2 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 6 57 CAT 58 5 |
| CON'T | REPORT L 6 0 5 0 0 0 3 1 1 0 1 2 2 8 1 8 0 1 1 3 8 2 9 SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80 |
| 02 | EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) |
| | |
| 0 3 | levels dropped to a 10% reading due to loss of nitrogen header pressure, caused by |
| 0 4 | depletion of the low pressure nitrogen supply. At 1415 hours No. 21 and 22 BAST |
| 0 5 | were declared inoperable and Action Statements 3.1.2.6.a and 3.3.3.7.b were |
| 06 | entered. |
| 0 7 | L |
| 08 | L |
| 7 8 | 9 SYSTEM CAUSE CAUSE COMPONENT CODE COMP VALVE SUBCODE SUBCODE |
| 0 9 7 8 | $ \begin{array}{c c c c c c c c c c c c c c c c c c c $ |
| | Image: The second se |
| | ACTION FUTURE EFFECT SHUTDOWN TAKEN ACTION ON PLANT METHOD HOURS (22) ATTACHMENT FORM SUB H 18 2 19 2 20 2 2 2 10 0 0 0 0 0 0 0 0 0 0 0 0 0 |
| | CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) |
| 10 | The shift supervisor switched the supply to the backup tank which had a pressure of |
| 111 | 50 PSIG. The BAST level indicators were restored, but due to the low nitrogen |
| 12 | pressure, were considered unreliable. The high pressure nitrogen backup supply was |
| 13 | then connected through a regulator to the indicator bubblers. At 1835 hours, proper |
| 14 | BAST level indication was restored, the BAST's were declared operable, and Action 9 Statements 3.1.2.6.a and 3.3.3.7 b were terminated. 80 |
| | ACILITY STATUS & POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32 |
| 7 8 | E (25) 0 8 9 (29) NA A (31) Loss of Indication 9 10 12 13 44 45 46 80 CTIVITY CONTENT 0 80 80 |
| | 2 33 2 34 NA |
| 7 8 | 9 10 11 44 45 80 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39) |
| 17 | |
| | 9 PERSONNEL INJURIES NUMBER DESCRIPTION (41) |
| 1 8 | 9 1: 12 80 LOSS OF OR DAMAGE TO FACILITY (43) |
| 119 | Z (42) NA |
| 7 8 | 9 10 B201260037 B20113 B0 |
| 20 | |
| , 8 | 9 10 68 69 80 5 NAME OF PREPARER Frank Dickey PHONE 609-935-0998 3 |