

SSINS 50-321
50-366

RECEIVED
JAN 26 1982
U.S. NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C.

Subject: Confirmation of Action

With regard to matters discussed, it is our understanding that you have undertaken or will undertake the following actions to resolve apparent deficiencies in your emergency preparedness program:

1. Reassess the Plant Manager's role with respect to command and control functional responsibilities within the onsite emergency organization.
2. Assign onshift responsibility for emergency notifications and provide enhanced training for the assigned individuals to include actions to be taken to verify message receipt when the Emergency Notification Network (ENN) system fails to operate.
3. Clarify the command and control functions of the Technical Support Center (TSC) in accordance with the criteria of NUREG-0654 and guidance in NUREG-0696. Increase TSC staffing to relieve engineering support personnel from communications functions.
4. Assign management supervisor to the Operational Support Center (OSC) who will be readily available to assume control of OSC functions, and provide staffing to include health physics support personnel at the OSC. Additionally, equip the OSC with appropriate emergency equipment and supplies, such as survey instruments, protective clothing, etc.

IE30

[illegible]

NOV 3 1981

5. Resolve differences between the State of Georgia and Georgia Power Company's offsite dose calculational models and strengthen the interface between the State and Georgia Power with respect to Georgia Power Company's role in providing information necessary for protective action decision making.
6. Submit a written report to the Director, Region II, by December 1, 1981, describing actions taken in the above areas and, for those actions not complete, providing the completion dates. It is our understanding that these actions will be completed prior to March 1, 1982.

Please inform this office immediately if your understanding of this matter is different from that stated above.

Sincerely,

JSI

James P. O'Reilly
Director

cc: J. T. Beckham, Vice President
and General Manager, Nuclear
Generation
M. Manry, Plant Manager
C. E. Belflower, Site QA
Supervisor

bcc: NRC Senior Resident Inspector
Document Management Branch
State of Georgia
B. K. Grimes, DEP:IE

OFFICE	EPOS:RII	EPOS:RII	EPOS:RII	RRPI:RII	RRPI:RII	OD:RII
SURNAME	GTGibson:mh	GRJenkins	JPStohr	VBrownlee	RCLewis	RDMartin
DATE	11/3/81	11/3/81	11/3/81	11/3/81	11/3/81	11/3/81