

Revision 1
January 15, 1982

ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS 1E EQUIPMENT
FOR
SHOREHAM NUCLEAR POWER STATION - UNIT 1
LONG ISLAND LIGHTING COMPANY

STONE & WEBSTER ENGINEERING CORPORATION

8201290116 820125
PDR ADDCK 05000322
E PDR

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
SUMMARY		S-1
1 INTRODUCTION		1-1
1.1 PURPOSE		1-1
1.2 SCOPE		1-1
1.3 SHOREHAM POSITION		1-3
2 DEFINITION OF SAFETY-RELATED ELECTRICAL EQUIPMENT		2-1
2.1 METHODOLOGY		2-1
2.2 SPECIFICATIONS WITH EQUIPMENT REQUIRING ENVIRONMENTAL QUALIFICATION		2-2
2.3 MISCELLANEOUS COMPONENTS AND ACCESSORIES		2-4
2.4 SYSTEMS REVIEWED		2-5
2.5 EQUIPMENT SAFETY FUNCTIONS		2-6
3 ENVIRONMENT APPLICABLE UNDER ACCIDENT CONDITIONS		3-1
3.1 METHODOLOGY		3-1
3.2 ENVIRONMENTAL ZONE MAPS		3-1
3.3 SERVICE CONDITONS		3-2
3.3.1 Normal Service Conditions		3-2
3.3.2 Postulated Accident Conditions		3-2
3.3.2.1 Loss of Coolant Accident		3-2
3.3.2.2 Pipe Break Outside Containment		3-3
3.3.2.3 Radiation		3-4
3.3.2.4 Sprays		3-4
3.3.2.5 Flooding		3-5
3.4 METHODOLOGY FOR AGING CONSIDERATIONS		3-5
3.4.1 Introduction		3-5
3.4.2 Radiation		3-5
3.4.3 Cycle Aging		3-5
3.4.4 Thermal Aging		3-6
3.4.5 Arrhenius Methodology		3-6
3.4.6 10°C Rule Methodology		3-7
3.5 MARGINS		3-8
4 DETERMINATION OF QUALIFICATION STATUS		4-1
4.1 EQUIPMENT STATUS		4-1
4.2 METHODOLOGY FOR EQUIPMENT QUALIFICATION		4-1
4.3 ENVIRONMENTAL QUALIFICATION DOCUMENTS		4-3
4.4 EQUIPMENT QUALIFICATION ACCEPTANCE CRITERIA		4-3
4.5 EQUIPMENT LIST UPDATE		4-4
4.6 ENVIRONMENTAL QUALIFICATION STATUS REPORT		4-4
5 SURVEILLANCE AND MAINTENANCE		5-1
6 REFERENCES		6-1

TABLE OF CONTENTS (Cont)

<u>Section</u>	<u>Title</u>
APPENDIX A	ENVIRONMENTAL QUALIFICATION REPORT EVALUATION FORM
APPENDIX B	ENVIRONMENTAL QUALIFICATION SUMMARY SHEETS
APPENDIX C	ENVIRONMENTAL ZONE MAPS
APPENDIX D	RADIATION, TEMPERATURE, AND PRESSURE DATA
APPENDIX E	ENVIRONMENTAL PROFILE CALCULATIONS
APPENDIX F	ENVIRONMENTAL QUALIFICATION STATUS REPORT
APPENDIX G	EQUIPMENT WITH INCOMPLETE QUALIFICATION DOCUMENTATION
APPENDIX H	LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE

SUMMARY

This report is produced for NRC review of environmental qualification of safety-related electrical equipment at the Shoreham Nuclear Power Station - Unit 1.

Section 1 discusses the purpose and scope of the program, and the Shoreham position on environmental qualification.

Section 2 defines the methodology for determining the safety-related electrical equipment requiring qualification for a harsh environment. The systems and safety functions reviewed to make this determination are also given.

Section 3 presents the environment considered as applicable under accident conditions. Because specific areas of the plant will be subject to different environmental conditions during an accident, the plant has been divided into "zones" as shown in Appendix C. The bases for the determination of particular environmental conditions are also given. The environment calculated for each zone is given in Appendix D. Appendix E contains the description of calculations which provide the bases for the selection of appropriate environmental conditions.

Section 4 discusses the methodology used for determining the qualification status of equipment. The equipment is listed in Appendix F, the Environmental Qualification Status Report (EQSR), with the qualification status of each piece of equipment and data which provide the requirements for that qualification. Equipment from the EQSR for which qualification documentation is considered deficient is listed in Appendix G. Appendix G also presents additional information and/or proposed resolution for the deficiencies in qualification documentation. Appendix H provides a list of the abbreviations used in the EQSR and in Appendix G.

Section 5 describes qualification aspects of the surveillance and preventive maintenance program for the station.

Based on the information contained herein, this report provides the assurance that the Shoreham Nuclear Power Station - Unit 1 can be brought to safe shutdown following a LOCA, HELB, or MELB without harm to the environment or public health and safety.

SECTION 1
INTRODUCTION

1.1 PURPOSE

The purpose of the Environmental Qualification (EQ) Program for the Shoreham Nuclear Power Station is to provide assurance that all electrical equipment (safety-related Class 1E equipment and equipment required by Regulatory Guide 1.97) located in potential harsh environments maintain functional operability when required to mitigate the consequences of a postulated accident or to bring the plant to a cold shutdown condition afterwards. This assurance is provided by comparing environmental information contained in electrical equipment qualification documents against the postulated environment to which the equipment may be subjected. This review results in one of the following:

- a. documentation of environmental qualification of equipment to demonstrate that requirements are adequately met, or
- b. upgrading of qualification or requalification of equipment which does not meet minimum requirements, or
- c. modification of design to meet the applicable requirements, or
- d. replacement of any equipment which lacks sufficient evidence of qualification with qualified equipment.

1.2 SCOPE

The equipment identified for environmental qualification include:

- a. safety-related Class 1E Electrical Equipment (hereafter referred to as equipment) located in potentially harsh environments, and required to operate during or after such an environment,
- b. sensing devices located in potentially harsh environments for display instruments which monitor the condition of the plant during and after postulated accidents as required by Regulatory Guide 1.97, (these are designated with "RG" in the rightmost column of the Equipment Qualification Status Report (EQSR) in Appendix F), and
- c. Three Mile Island (TMI) Lessons Learned modifications to safety-related systems including control and monitoring devices located in potentially harsh environments.

Environmental conditions to which the above equipment may be subjected consist of the following:

- a. pressure
- b. temperature
- c. relative humidity
- d. radiation
- e. flooding/submergence
- f. fluid spray

Equipment qualification documents are reviewed with respect to the following:

- a. service conditions to which equipment is subjected,
- b. design basis events (LOCA, MELB, HELB) which equipment is to mitigate,
- c. operating time, or the time during which the equipment is required to perform a function so as to mitigate the consequences of the design basis event, and
- d. qualification methodology based on the Operating Codes defined in Appendix E of NUREG-0588
- e. aging considerations
- f. margins

The review is documented on the Environmental Qualification Report Evaluation Form (EQREF), the Environmental Qualification Summary Sheet (EQSS), and tabulated in the computerized Environmental Qualification Status Report (EQSR).

Equipment successfully tested for an environmental profile which meets or exceeds postulated service conditions satisfies the qualification conditions and the qualification report is approved.

If a qualification report does not provide sufficient evidence of qualification, then alternative qualification methods are evaluated, including:

- a. obtain additional qualification documentation,
- b. perform additional environmental testing or analysis,
- c. modify the equipment design or material selection,

- d. further analyze the equipment's environment and/or its function to refine the adverse service conditions that pertain to the actual location and use of the component,
- e. provide enclosure or shielding,
- f. relocate in a less severe environmental zone,
- g. include considerations of potential equipment degradation in the plant preventive maintenance program to provide a basis for extension of equipment qualified life,
- h. establish a limited qualified life and a schedule for future replacement, or
- i. select better qualified equipment as replacement.

Qualification programs for specific equipment, such as cables, valves, motors, and electrical penetrations, that are designed to conform with the requirements of daughter standards of IEEE-323, are acceptable for demonstrating compliance with the objectives of IEEE Std. 323. The daughter standards include IEEE Std. 383 for cables, IEEE Std. 382 for motor operated valves, IEEE Std. 334 for electric motors, and IEEE Std. 317 for electrical penetrations.

Dynamic qualification of equipment is performed in accordance with the requirements of IEEE Std. 344 and is addressed in separate documentation.

LILCO maintains primary responsibility for the Environmental Qualification Program for the Shoreham Nuclear Power Station. LILCO is also responsible for the performance of those organizations who have been assigned specific tasks, and imposes upon them the requirements of the LILCO Quality Assurance Program. The review of Balance of Plant (BOP) equipment has been assigned to the Stone & Webster Engineering Corp. (SWEC) and the review of Nuclear Steam Supply System (NSSS) equipment to EDS Nuclear Inc. Both these organizations have acceptable Quality Assurance Programs which meet the requirements of 10CFR50 Appendix B, and implementation of the respective programs specific to the assigned tasks is monitored by LILCO.

1.3 SHOREHAM POSITION

Shoreham Nuclear Power Station Class 1E electrical equipment are qualified as follows:

- a. Equipment purchased through May 23, 1980 is evaluated and considered environmentally qualified if it satisfies IEEE Standard 323-1971 and NUREG-0588 Category II positions as a minimum.

- b. Equipment purchased after May 23, 1980 is evaluated and accepted to IEEE Standard 323-1974 and NUREG-0588 Category I positions, where possible. If such equipment is not available and cannot be made available, equipment is evaluated and considered environmentally qualified if it satisfies IEEE Standard 323-1971 and NUREG-0588, Category II positions as a minimum.

In some cases, the DOR Guidelines may be used to clarify the requirements of IEEE Standard 323 and NUREG-0588.

SECTION 2

DEFINITION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

2.1 METHODOLOGY

The identification of equipment for environmental qualification requires the examination of the applicable project documents. These documents include flow diagrams, electrical one-line diagrams, logic diagrams, elementary diagrams, and instrument loop diagrams. Examination of these documents entails the following:

- a. Review of electrical one-line diagrams to identify electrical equipment which distributes safety-related power to safety-related electrical systems.
- b. Review of system flow diagrams, related system descriptions, and FSAR system function sections (including Chapter 15 - accident analysis and Appendix 3C - pipe failure outside primary containment) to identify the electrical equipment within each system, analyze and tabulate emergency events for each equipment item and the corresponding safety function required to mitigate the emergency event, derive operating codes as referenced in Appendix E of NUREG-0588, and determine the amount of time required for performance of the operability requirement.
- c. Review of elementary and loop diagrams for each Class 1E electrical equipment item on marked-up flow diagrams to identify miscellaneous safety-related equipment required to control or monitor the equipment.

Equipment identified in this manner is listed on the Environmental Qualification Status Report (EQSR), and is cross-referenced against the Project Equipment System (PES) computer listing to confirm the identification and location of the equipment, and to aid in the location of applicable procurement documents.

To provide additional assurance that all required electrical equipment is identified, the plant Emergency Operating Procedures will be reviewed against the computerized report (EQSR).

2.2 SPECIFICATIONS WITH EQUIPMENT REQUIRING ENVIRONMENTAL QUALIFICATION

Using the procedure outlined in Section 2.1 and discussed in detail in the following sections, a list of BOP safety-related Class IE electrical equipment located in a potentially harsh environment has been developed. The specifications listed below are applicable to this equipment.

SPECIFICATIONS FOR SAFETY-RELATED ELECTRICAL EQUIPMENT LOCATED IN A HARSH ENVIRONMENT

<u>Specification Number</u>	<u>Title</u>
SH1-39	4,160 V Metal Clad Switchgear
SH1-62G	Centrifugal Pumps
SH1-88AD	Carbon Steel MOVs
SH1-88V	Carbon Steel MOVs
SH1-102	Centrifugal Fans
SH1-105	Charcoal Filter Trains
SH1-111	Ventilation Butterfly Valves
SH1-115	480 V Motor Control Centers
SH1-124	Miscellaneous AC and DC Distribution Panelboards
SH1-127	5 KV Power Cable
SH1-128	600 V Power Cable
SH1-129	300 V and 600 V Fire-Resistant Control and Instrument Cable
SH1-130	Instrument Cable
SH1-131	Thermocouple Extension Wire
SH1-134	Reactor Containment Electrical Penetrations
SH1-159	Electrical Work

<u>Specification Number</u>	<u>Title</u>
SH1-168	DC Motor Control Centers
SH1-172	Primary Containment Isolation Valves
SH1-175	Drywell Floor Relief Valves
SH1-197	Motor Operated Butterfly Valves
SH1-203	Manually Operated Diaphragm Valves - Carbon Steel
SH1-214	Manually Operated Stainless Steel Valves
SH1-232	Special Check Valves
SH1-235	Loop Level Pumps
SH1-248	Miscellaneous Transformers
SH1-253	Motor Operated Steel Valves
SH1-270	Axial Flow Fans
SH1-276	Unit Coolers
SH1-281	Bronze Valves
SH1-289	Hydrogen Recombiner Units
SH1-310	Electric Motor Operated Controls Valves
SH1-318	Air Operated Control Valves
SH1-319	Automatic Temperature Control Systems for HVAC
SH1-332	Radiation Monitors
SH1-344	Primary Containment Gas Analyzers
SH1-348	Pressure and Temperature Switches
SH1-406	Electronic Transmitters and RTDs
SH1-406A	RTDs

<u>Specification Number</u>	<u>Title</u>
SH1-407	Level Switches
SH1-423	Air Operated Butterfly Valves ASME III
SH1-438	Automatic Transfer Switches
SH1-439	480 V Motor Generator Set
SH1-455	Low Capacitance Fire-Resistant Instrument Cable
SH1-456	Reactor Containment Electrical Penetrations
SH1-457	Leakage Return Pump
SH1-473	Level Transmitters
SH1-475	Post Accident Radiation Monitoring
SH1-484	Control & Instrument Cable
SH1-485	Thermocouple Extension Wire
15.54	Valcor Solenoid Valves

The equipment items within the NSSS scope of supply are included under Specification SH1-003.

2.3 MISCELLANEOUS COMPONENTS AND ACCESSORIES

The environmental qualification of miscellaneous electrical components and accessories is addressed in the same manner as the equipment which is identified from the review of project drawings. Examples of miscellaneous components include control stations, terminal lugs, splicing materials, and internal panel wire. These components are not identified with a specific equipment identification number but, instead, are documented on a separate list attached to the Environmental Qualification Status Report (EQSR) in Appendix F. Most of the miscellaneous electrical components and accessories have been procured under Specification SH1-159.

2.4 SYSTEMS REVIEWED

The systems reviewed to identify the equipment requiring environmental qualification are presented below. In parentheses alongside the systems are alternate names to describe the system or portions thereof.

<u>SYSTEM</u>	<u>SYSTEM CODE</u>
Nuclear Boiler (Includes Some Safeguards Activation)	1B21
Reactor Water Recirculation (Reactor Coolant)	1B31
Control Rod Drive Hydraulic Control	1C11
Standby Liquid Control	1C41
Neutron Monitoring	1C51
Reactor Plant Remote Shutdown	1C61
Reactor Protection	1C71
Process Radiation Monitoring	1D11
Area Radiation Monitoring	1D21
Residual Heat Removal (Includes Containment Spray)	1E11
Core Spray	1E21
MSIV Leakage Control	1E32
High Pressure Coolant Injection	1E41
Reactor Core Isolation Cooling	1E51
Radwaste	1G11
Reactor Water Cleanup	1G33
Fuel Pool Cooling and Cleanup	1G41
Main Control Room Panels	1H11
Local Panels and Racks	1H21
RBSVS & Control Room Chilled Water	1M50
Main Steam	1N11
Condensate and Feedwater	1N21
Miscellaneous Drains	1N23
Condensate Transfer and Storage	1P11
Demineralized & Makeup Water	1P21
Sample	1P33
Service Water	1P41
Reactor Building Closed Loop Cooling Water	1P42
Compressed Air	1P50
Metal Clad Switchgear	1R22
Unit Substations	1R23
Motor Control Centers	1R24
Power Cable & Wire	1R31
Control Cable & Wire	1R32
AC Control and Instrument Power	1R35
AC Uninterruptible Power	1R36
DC Instrument Power	1R41
Battery Power (125V D-C)	1R42
Diesel Emergency Power	1R43
Reactor Building Superstructure	1T22
Reactor Primary Containment	1T23
Primary Containment Inerting	1T24
Reactor Building Ventilation	1T41
Reactor Building Standby Ventilation (Standby	1T46

Gas Treatment)	
Primary Containment Cooling	1T47
Primary Containment Atmospheric Control (Combustible Gas Control)	1T48
Miscellaneous HVAC	1X41
Diesel Generator Ventilation	1X60
Control Room HVAC	1X61
Excess Flow Check Valves	1Z92
Post Accident Monitoring	1Z93
Post Accident Sampling	1Z96
(Emergency Condenser not applicable to Shoreham)	

2.5 EQUIPMENT SAFETY FUNCTIONS

Safety-related electrical equipment in this qualification program perform safety functions required to mitigate the consequences of a Loss of Coolant Accident (LOCA), a High Energy Line Break (HELB), or a Moderate Energy Line Crack (MELB). The equipment also performs safety functions required to maintain the reactor in a safe shutdown condition. Safety functions and their abbreviations are listed below.

SAFETY FUNCTIONS

<u>SAFETY FUNCTION</u>	<u>ABBREVIATION</u>
Automatic Depressurization	ATDP
Component Auxiliary Cooling	CAUC
Containment Isolation	CISL
Core Spray	CSPR
Emergency Power	EMPO
Feedwater Isolation	FISL
Fuel Pool Cooling	FLCL
Post Accident Hydrogen Control	HCNT
HELB Mitigation	HELB
High Pressure Coolant Injection	HPCI
Residual Heat Removal	HTRM
Safety-Related HVAC	HVAC
Leakage Control	LCNT
Low Pressure Coolant Injection	LHSI
MELB Mitigation	MELB
Post Accident Monitoring	PACM
Reactivity Control	RCCL
Reactor Core Isolation Cooling	RCIC
Regulatory Guide 1.97 Criteria	REGG
Reactor Trip Protection	RTRP
Engineered Safety Function	SAFE
Main Steam Isolation	SISL
Suppression Pool Pump Back	SPPB
Service Water	SWAT
Ultimate Cooling	ULCL

To determine which equipment is safety-related, it is useful to assign specific safety functions to the systems. This is done most easily by regrouping, under larger system headings, the systems listed in Section 2.4.

Safety functions for applicable systems are listed below:

SYSTEM SAFETY FUNCTIONS

<u>SYSTEM</u>	<u>SAFETY FUNCTIONS</u>
Main & Auxiliary Steam Nuclear Boiler (1B21)	CISL, SISL, HTRM, ATDP, LHSI, CSPR, HELB, MELB, SAFE, LCNT, REGG
Feedwater (1B21, 1N21)	LCNT, CISL, FISL, HPCI, RCIC
Reactor Building Sampling (1B31, 1P33)	CISL, LCNT
Reactor Water Recirculation (1B31)	SAFE, HTRM, LHSI
Radiation Monitoring (1D11)	PACM, REGG, LCNT, RTRP, SAFE, CISL
Control Rod Drive (1C11)	RTRP, LCNT, REGG
Standby Liquid Control (1C41)	RCCL, CISL, REGG
Neutron Monitoring (1C51, 1C61)	CISL, REGG
Residual Heat Removal (1E11)	LHSI, HTRM, CISL, SAFE, LCNT, ATDP, REGG, HCNT
Core Spray (1E21)	CSPR, CISL, LCNT, SAFE, ATDP, REGG
Main Steam Isolation Valve Leakage Control (1E32)	CISL, SISL, LCNT
Reactor Core Isolation Cooling (1E51)	RCIC, REGG, LCNT, CISL, HELB, MELB
Reactor Building Vents and Drains (1G11)	CISL, LCNT, SPPB, HELB, REGG
Reactor Water Cleanup (1G33)	CISL, HELB, LCNT
Fuel Pool Cooling and Cleanup (1G41)	CISL, FLCL, ULCL, REGG

SYSTEMSAFETY FUNCTIONS

Local Panels and Racks (1H21)	SAFE
Main Steam-Turbine Side of Main Steam Isolation Valves (1N11, 1B21, 1C71)	LCNT, SISL, SAFE
Secondary Plant Drains (1N23)	LCNT, SISL
Metal Clad Switchgear (1R22)	EMPO, SAFE
Motor Control Centers (1R24)	EMPO, SAFE
Power Cable and Wire (1R31)	EMPO, SAFE
Control Cable and Wire (1R32)	EMPO, SAFE
AC Control and Instrument Power (1R35)	EMPO, SAFE, REGG
125 V DC Battery Power (1R42)	EMPO, SAFE
Fuel Oil Transfer (1R43)	EMPO, SAFE
High Pressure Coolant Injection (1E41, 1Z93)	REGG, HPCI, HELB, CISL, LCNT
Drywell Floor Seal Pressure Monitoring (1T23)	CISL
Demineralized and Make- Up Water (1P11, 1P21)	HPCI, SAFE
Service Water (1P41)	SWAT, PACM, HTRM, FLCL, SAFE
Reactor Building Closed Loop Cooling Water (1P42)	CISL, CAUC
Instrument and Service Air (1P50)	CISL, SAFE
Reactor Primary Containment (1T23)	CISL, SAFE, EMPO
Reactor Building Normal & RBSVS Ventilation (1T41, 1T46, 1T47)	SAFE, CISL, HVAC

SYSTEM

SAFETY FUNCTIONS

Primary Containment
Atmospheric Control and
Inerting (1T48, 1T24)

CISL, SAFE, HCNT, REGG

The system safety functions for equipment items identified are documented in the S&W Engineering Files and will be provided in a report to LILCO.

SECTION 3

ENVIRONMENT APPLICABLE UNDER ACCIDENT CONDITIONS

3.1 METHODOLOGY

In order to determine what safety-related electrical equipment is located in a harsh environment, it is necessary to establish the environmental conditions experienced in the areas of the plant in which the equipment is located.

Environmental profiles are determined for defined spatial zones both inside and outside the primary containment. Radiation source terms are developed in accordance with the requirements of NUREG-0737. Temperature, pressure, and humidity data are based upon applicable sections of the FSAR including Appendix 3C (Pipe Failure Outside Primary Containment). The following environmental parameters are included in the analyses of equipment environmental qualification:

a. Normal Environment

1. Radiation - 40 year integrated dose
2. Temperature - expected range
3. Humidity - expected range
4. Pressure - expected range

b. Postulated Accident Environment

1. Radiation - radiation dose received from the accident environment for the time period of interest.
2. Temperature - temperature expressed as a function of time for the duration of the accident transient.
3. Humidity - highest relative humidity levels during the accident transient, conservatively assumed at 100 percent for both the primary and secondary containments of the Reactor Building.
4. Pressure - maximum levels postulated for the accident transient.

3.2 ENVIRONMENTAL ZONE MAPS

Environmental zone maps illustrating the harsh environmental spatial zones are shown in Appendix C. The harsh environmental

service conditions experienced by each zone are given in Appendix D.

3.3 SERVICE CONDITIONS

The environmental parameters for each zone are determined for the normal and postulated accident service conditions. These parameters are the specific qualification requirements for the equipment to be qualified. The normal and accident profiles (temperature, pressure, and radiation) for each zone are illustrated as a function of time in Appendix D.

3.3.1 Normal Service Conditions

Normal service conditions are the environmental conditions in each zone which are maintained during normal plant operations. This includes all levels of power generation, start-up, hot standby, shutdown, and refueling. For equipment qualification, normal service conditions are assumed continuous over the 40 year life of the plant. Pressure, temperature, and humidity values are based on normally operating HVAC systems and are shown on Table 3-1. Radiation values are based on normal radionuclide inventory and are cumulative during the 40 year plant life.

3.3.2 Postulated Accident Conditions

Accident conditions generate the most severe environmental parameters for the environmental qualification of equipment. Values of temperature, pressure, humidity, and radiation are postulated to occur at the end of the 40 year plant life. Specific environmental parameters are determined by investigating the postulated accident conditions discussed below:

3.3.2.1 Loss of Coolant Accident

- a. The method of analysis for pressure and temperature response for Loss of Coolant Accident (LOCA) within the primary containment is described in Section 6.2 of the FSAR.
- b. The pressure and temperature for the secondary containment are defined in Appendix D as taken from Section 6.2.3 of the FSAR. The pressure transient in the secondary containment due to a LOCA is also shown in Figure D-43 as taken from FSAR Figure 6.2.3-2.
- c. The Turbine and Control Buildings do not experience extremes of temperature and/or pressure due to LOCA within the Reactor Building.

3.3.2.2 Pipe Break Outside Containment

a. Short-Term Response to High Energy Line Breaks (HELB)

High energy line breaks have been selected and analyzed in accordance with the specific criteria outlined in Appendix 3C of the FSAR. Achieving cold shutdown during a HELB event is discussed in FSAR Appendix 3C together with the required systems and postulated conditions. The analysis described in Appendix E, Section E.2 provides further detail of particular HELBs and their effect upon additional areas of the plant through the use of more refined temperature zones.

b. Short-term Response to Moderate Energy Line Cracks (MELB)

The following moderate energy line failure is considered and represents the limiting design condition for temperature effects due to MELBs: Twenty-four inch RHR pipe crack in the Reactor Building, elevation 40 ft. Calculations are described in Appendix E, Section E.3. This failure and other MELBs are listed in Appendix 3C of the FSAR and are analyzed with the applicable criteria of that section.

c. Long-Term Response

The long-term response analysis for all breaks is a determination of the elapsed time from the moment the break occurs to the time the building environment returns to the initial starting temperature (generally 104°F).

The Reactor Building secondary containment is considered one volume.

The amount of energy in BTU's discharged into the secondary containment by the break is determined based on a reference of 104°F.

Heat is removed from the building by one of two trains of RBSVS coolers and by air exchange with the atmosphere.

The elapsed time is calculated by dividing the total energy discharged by the sum of the RBSVS cooler and atmospheric air exchange heat removal rates.

No credit is taken for heat sinks and the entire secondary containment is assumed to cool down uniformly.

d. Summary of Conservatism Used in the Analyses

1. Frictionless flow is assumed for blowdowns.
2. No credit is taken for air coolers during the short-term analyses of Section a.
3. No automatic closure signals for isolation valves occur until the entire zone rises to the setpoint temperature.
4. Metal heat sinks are neglected.
5. The Reactor Building remains isolated to mass and energy transfer out of the building until the sheet metal roof panels relieve during the short-term analyses.
6. No credit is taken for radwaste sump pumps.
7. No credit is taken for passive heat sinks in the long-term analyses.

3.3.2.3 Radiation

The accident radiation sources and integrated radiation doses are derived as discussed in Appendix E, Section E.4 in accordance with NUREG 0737, Section II. B.2.

3.3.2.4 Sprays

The only equipment subject to spray is that equipment within the primary containment during the post accident containment cooling mode of RHR (refer to FSAR Section 6.2). The design of this system causes a uniform mist within the containment, which is bounded by the 100 percent humidity/saturated steam conditions specified for the qualification of equipment. Refer to Appendix 3C of the FSAR for the detailed analysis of HELB and MELB fluid effects outside the primary containment.

An analysis was performed to evaluate the effects of containment spray due to the drywell and wetwell spray nozzles. The impinging effect is assumed to be considerable only when the spray droplet velocity has a horizontal component. This is a conservative assumption because the horizontal component of the velocity in some areas can be larger than the terminal velocity of the droplets. The area outside the spray impingement zone is assumed to be equivalent to 100 percent humidity due to the small size of the droplets and gravity as the only driving force. Based on these assumptions, qualification of equipment in the following areas requires consideration of the spray impingement effect:

Drywell: An annular volume from 10' above to 10' 11" below elevation 109' 9" (elevation 98' to 120') and radially 33' outward from the location of nozzles on elevation 109' 9".

Wetwell: An annular volume from elevation 41' to 54' (2' 1" above and 10' 2" below elevation 51' 9") and radially 17' 2" outward from the location of nozzles on elevation 51' 9".

3.3.2.5 Flooding

Equipment required for accident mitigation is not subject to submergence in the Shoreham design. A detailed evaluation of possible flooding effects outside the primary containment due to HELBs and MELBs is presented in Appendix 3C of the FSAR.

3.4 METHODOLOGY FOR AGING CONSIDERATIONS

3.4.1 Introduction

The intent of aging in the qualification process is to bring the tested equipment to the equivalent of its "end of life" condition prior to subjecting it to the conditions of the Design Basis Event (DBE). The time period corresponding to this "end of life" condition becomes the "qualified life" of the tested equipment when the equipment demonstrates operability when subjected to its required service conditions.

The aging mechanisms that equipment are exposed to during qualified life are: radiation, cycling, and heat.

3.4.2 Radiation

The determination of qualified life includes assurance that the equipment was radiation aged to an amount equivalent to its 40 year plus accident integrated radiation dose. The preferred method for this type of qualification is type-testing. However, in some cases, type-testing was insufficient to qualify the device for its required radiation dose. In these cases, an analysis of the materials used in the tested equipment has been performed to determine the sensitivity of these materials (based on previous testing experience) to its applicable radiation environment. The radiation tolerance of the most sensitive material was assumed to be the radiation tolerance of the entire tested equipment.

3.4.3 Cycle Aging

For devices which have moving parts or function in some repeatable manner, the devices are cycle aged for the number of postulated operations that can be expected during the installed life. In the qualification test process, cycle aging is typically performed prior to initiation of the thermal and design basis accident tests.

3.4.4 Thermal Aging

Thermal aging is the deterioration of equipment components when subjected to elevated temperatures over a period of time. During qualification testing, this process is intended to produce the actual installed end-of-life condition of the equipment prior to application of the accident environment. In the case of thermal aging, analysis may be used to augment actual type testing.

One of the methods used in consideration of thermal aging is the determination that the materials in the equipment are not sensitive to thermal degradation. This determination may include either recognizing that the materials are metallic or utilizing the Arrhenius parameters for each material to determine an "expected life." Expected life can be defined as the amount of time a material can be expected to retain a certain property in a purely thermal environment without the imposition of other aging mechanisms. When this time is much greater than the 40 yr plant life, it can be concluded that thermal degradation is insignificant in relation to other harsh environmental effects and the DBE, and thus the component may be exempted from the artificial thermal pre-aging.

When the expected life does not greatly exceed the 40 year plant life, accelerated thermal aging may be included in the qualification test program. Arrhenius parameters are utilized to determine the time and temperature of the accelerated aging required to bring the equipment to an equivalent age of 40 years at normal service temperatures. When the accelerated aging parameters are less than those required for a 40-year equivalent, a determination is made of the actual equivalent. This equivalent age is the "qualified life" of the equipment, if it successfully completes other applicable aging tests and the accident simulation.

3.4.5 Arrhenius Methodology

Section 4.4 of NUREG 0588 and Paragraph 5.2.4 of the DOR guidelines defines Arrhenius techniques as an acceptable method for aging determinations. This methodology allows the relative thermal life of nonmetallic materials to be determined by the extrapolation of an Arrhenius plot of the natural log of life as a function of reciprocal absolute temperature for that particular material.

For many nonmetallic materials, it is known that the degradation process can be defined by a single temperature-dependent reaction that follows the Arrhenius equation:

$$k = A \exp \left(-\frac{E_a}{k_B T} \right) \quad (1)$$

where:

k = reaction rate
 A = frequency factor
 exp = exponent to base e
 E_a = activation energy
 k_B = Boltzmann's Constant
 T = absolute temperature

It is further noted, that for many reactions, the activation energy can be considered to be constant over the applicable temperature range. That is, that a single aging mechanism or reaction, is controlling the rate of thermal degradation.

Equation (1) can be transformed into a form which yields a time compression factor.

The equation is:

$$t_1/t_2 = \exp \left((E_a/k_B) (1/T_1 - 1/T_2) \right) \quad (2)$$

where:

t₁ = accelerated aging time at temperature T₁
 t₂ = normal service time at temperature T₂
 exp = exponent to base e
 E_a = activation energy (eV)
 k_B = Boltzmann's Constant (8.617 x 10⁻⁵ eV/°K)
 T₁ = accelerated aging temperature (°K)
 T₂ = normal service temperature (°K)

It is this equation which is used to provide a qualified life of devices at T₂ (normal service temperatures) when the activation energy of the most temperature sensitive material in the device can be determined by material textbook references or actual type testing.

3.4.6 10°C Rule Methodology

The qualified life for certain equipment was determined by the 10°C rule, rather than Arrhenius techniques. The 10°C rule (each 10°C rise shortens life by one-half) was the state of the art for aging prior to the development of Arrhenius techniques. Where the 10°C rule was used as the qualification basis, the results

are verified by obtaining activation energies from published data and calculating service life via the Arrhenius method as discussed above or by demonstrating that application of the 10°C rule yields a more conservative qualified life than the Arrhenius methodology for the equipment involved.

3.5 MARGINS

The analyses used to determine environmental parameters for normal and accident service conditions include various conservative assumptions as described previously. Therefore, the postulated values of pressure, temperature, humidity, and radiation for each environmental zone are in excess of the values that would be realistically expected for the conditions analyzed. Equipment which is required to operate must be qualified to an environmental profile which envelopes the postulated profile and results in a supplemental margin. In addition, equipment is qualified for time periods in excess of that required to provide the equipment's safety function. The operability time requirement listed in the EQSR includes a margin of at least one hour or 10 percent, whichever is greater, in excess of the time duration required by the accident analyses.

SECTION 4

DETERMINATION OF QUALIFICATION STATUS

4.1 EQUIPMENT STATUS

The qualification status of safety-related electrical equipment located in harsh environments is listed in the attached computer listing (EQ Status Report) in Appendix F. Appendix G addresses the equipment with deficient qualification documentation, along with resolution plans and, if needed, justification for interim operation.

4.2 METHODOLOGY FOR EQUIPMENT QUALIFICATION

The environmental qualification documents for the equipment are typically obtained for engineering evaluation from equipment vendors, equipment manufacturers and/or testing facilities. These documents in the form of qualification procedures, reports, and supplementary information are evaluated in accordance with NUREG-0588, IEEE Std. 323, and the associated daughter standards included in Section 6. Review of these documents includes assurance that they are technically adequate and conform to the environmental qualification requirements of the applicable emergency conditions, operability times, and service conditions.

Each equipment item is assigned an operability code in accordance with the categories discussed in Appendix E of NUREG-0588, and the qualification entails the following:

- a. Equipment assigned an operability code "A" must have acceptable documentation which demonstrates that the equipment performs its required safety function(s) in the environment dictated by the zone in which the equipment is located.
- b. Equipment assigned an operability code "B" does not have an active safety function. Essentially, "B" coded equipment is the equipment identified as connected to Category 1E power systems but not required to operate during the postulated accident condition. Therefore, this equipment is evaluated to ensure that the accident exposure does not result in any equipment failure which would alter the state of the 1E power system.
- c. Equipment assigned an operability code "C" does not have a safety function and does not fail in any manner that would affect the safe shutdown of the plant. This equipment is not included in this report unless determined to be operability code "A" or "B" for a time less than the 180 day post accident duration and

operability code "C" for the remaining duration of the accident.

When this equipment operability code is determined, the length of time (operability time) into an accident during which the equipment must function or must not fail is also ascertained. The designation of this operability time is based on:

- a. The system operating requirements for accident mitigation.
- b. The function of each required equipment item in the system during and after accident mitigation.

All equipment is designated to be qualified for a maximum of 180 day post-accident duration. Equipment identified as operability code "A" for less than 180 days is designated operability code "B" for the remainder of the accident duration. However, if, at some time during the accident duration, it is determined that no postulated failure will be detrimental to the safe shutdown of the plant, an operability time of less than 180 days may be designated.

The methods of qualifying equipment are testing and analysis. Testing is the principal method of qualification used in this program. The evaluation of equipment testing includes the following considerations:

- a. Acceptance criteria are established prior to the evaluation of test reports.
- b. The environmental profiles for the applicable accident conditions and zones are examined for comparison to the environment simulated in the test report.
- c. Continuous or discrete monitoring results are reviewed where relevant.
- d. Margins are verified for the environmental parameters.
- e. Documentation is reviewed to ensure that adequate information with respect to the equipment performing its required safety functions during the postulated service conditions is presented in a format that is verifiable in an independent audit.

For cases where test documentation is unavailable or incomplete, the services of reputable independent engineering testing laboratories or engineering consulting firms are contracted. These testing facilities or engineering consultants are selected based on their cognizance of the applicable standards and their experience in environmental equipment qualification. Qualification documentation may then be upgraded and reevaluated

based on additional test information, retesting, or analysis based on adequate data using acceptable engineering models.

4.3 ENVIRONMENTAL QUALIFICATION DOCUMENTS

As each qualification document is reviewed and assessed, a "Test Report Number" is assigned. This test report identification is prefixed with the letters "TR-" and suffixed with the digits of the equipment's procurement specification identification to facilitate future information retrieval. These digits of the specification identification are also used to identify the other forms of documentation used in the environmental qualification (EQ) review process. When one or more components or groups of components are addressed under one specification, additional digits are added to the identification code.

The actual review of the equipment qualification reports is documented on the Environmental Qualification Report Evaluation Form (EQREF), described more fully in Appendix A. This document identifies the equipment by system, vendor, manufacturer, and model number, while providing a review format that addresses the applicable zone service conditions as required per NUREG-0588. Upon completion of the qualification document review, final comments are recorded on the EQREF including justification for EQ acceptance, recommendations to rectify qualification document deficiencies, and limitations or conditions required in order to preserve qualification, as applicable.

The results of the EQREF review are summarized on the Environmental Qualification Summary Sheet (EQSS), described in more detail in Appendix B. Information including equipment description, IEEE Standards referenced, test sequence, environmental zones, and test parameters as described in the qualification report(s) is entered on this document. The test parameters recorded on the EQSS are compared to the required zone parameters for adequacy. Any discrepancies are noted on the applicable EQREF. A separate EQSS is generated for each specification or group of devices. Documentation packages which include the qualification reports, EQREF and EQSS are transmitted to LILCO and incorporated into the Shoreham permanent record file.

4.4 EQUIPMENT QUALIFICATION ACCEPTANCE CRITERIA

The information collected on the EQSS and EQSR provides the EQ status of each Class 1E electrical equipment. The equipment is considered qualified if the following requirements are met:

- a. Acceptable documentation to all applicable referenced requirements.
- b. Environmental tests and/or analyses are performed and meet all applicable referenced requirements for the

postulated conditions to which the equipment is subjected.

- c. Acceptable performance characteristics in an environment as severe as the postulated zone environment is demonstrated.
- d. A qualified life is determined and supported by qualification documents.

Equipment that does not satisfy the above criteria is not considered fully qualified and is addressed in Appendix G. The resolution of EQ deficiencies may include one or more of the alternatives listed in Section 1.1.

4.5 EQUIPMENT LIST UPDATE

As additional environmental qualification (EQ) reports and/or procedures are obtained, the appropriate EQ review and evaluation documents are revised to reflect changes in the qualification status of each piece of equipment. Evaluation of these documents is performed as previously described in this text. If changes in the qualification information occur, the appropriate EQSS is revised with a revision number to indicate the revision. Each revised EQSS supersedes, in entirety, all previous EQSSs with the same number. New data is entered into the master list (EQSR) to indicate changes and additional qualification documentation is added to the Shoreham records file as the changes are implemented.

4.6 ENVIRONMENTAL QUALIFICATION STATUS REPORT (EQSR)

The EQSR is a computerized report which summarizes the qualification status of each equipment item. The current issue of the EQSR is included in Appendix F.

MAINTENANCE

SECTION 5

SURVEILLANCE AND MAINTENANCE

The Shoreham surveillance and maintenance programs include documented program plans, procedures, and results to assure that the safety-related equipment is maintained in a state of readiness and operability so that it will perform its intended safety function upon demand.

The results of the Equipment Qualification Program are directly input to the Shoreham maintenance and spare parts programs to ensure timely device or parts replacement as needed due to identified qualified life limitations and to ensure timely performance of any other identified maintenance activities required to preserve the applicability of the qualification.

SECTION 6

REFERENCES

<u>Abbreviation</u>	<u>Year of Issue</u>	<u>Sponsor Organization, Document Title</u>
IEEE 308	1971	Institute of Electrical and Electronics Engineers, Standard Criteria for Class 1E Electric Systems for Nuclear Power Generating Stations
IEEE 317	1972	Institute of Electrical and Electronics Engineers, Electrical Penetration Assemblies in Containment Structures for Nuclear Power Generating Stations.
IEEE 323	1971, 1974	Institute of Electrical and Electronics Engineers, General Guide for Quality- ing Class I Electric Equipment for Nuclear Power Generating Stations
IEEE 334	1971	Institute of Electrical and Electronics Engineers, Trial-Use Guide for Type Tests of Continuous-duty Class I Motors Installed Inside the Containment of Nuclear Power Generating Stations
IEEE 344	1971, 1975	Institute of Electrical and Electronics Engineers, Trial-Use Guide for Seismic Qualification of Electronic Equipment for Nuclear Power Generating Stations
IEEE 382	1972	Institute of Electrical and Electronic Engineers, Trial-Use Guide for Type Test of Class I Electric Valve Operators for Nuclear Power Generating Stations

<u>Abbreviation</u>	<u>Year of Issue</u>	<u>Sponsor Organization, Document Title</u>
IEEE 383	1974	Institute of Electrical and Electronic Engineers, Type Test of Class I Electric Cables, Field Splices, and Connections for Nuclear Power Generating Power Stations
NUREG 0588 Rev. 1	1979 1981	Nuclear Regulatory Commission, Interim Staff Position on Environmental Qualification of Safety-related Electrical Equipment
NUREG 0737	1980	Nuclear Regulatory Commission, Clarification of Three Mile Island Action Plan Requirements

APPENDIX A

ENVIRONMENTAL QUALIFICATION
REPORT EVALUATION FORM

APPENDIX A

ENVIRONMENTAL QUALIFICATION REPORT EVALUATION FORM (EQREF)

This form (a blank copy of which is included after this description) provides a summary of EQ document assessment and consists of four (4) pages. Each EQREF is numbered by specification number preceded by the letters TR. The first page includes data entries entitled EQUIPMENT IDENTIFICATION and QUALIFICATION DOCUMENTATION which are self-explanatory. The entry for "SQRT Form I.D.:" is not entered but the seismic qualifications for the equipment are filed separately. The assessment results (whether the EQ document is acceptable or not) are summarized under the REVIEWER'S CONCLUSION section where any exceptions, special conditions or correctable deficiencies are entered.

On Page 2, data entries include TEST FACILITY - name and location of testing firm, and the APPLICABLE ZONE NUMBERS, for the environmental zones in which the tested equipment is installed.

The information that follows is a list of questions that pertain to the equipment. The response to these questions is either "YES", "NO", or "N/A" - not applicable. The technical content of these questions is intended to satisfy the requirements of IEEE Std 323-1971, 1974 and NUREG-0588, and addresses the following:

1. Equipment identification
2. Test Program Description and Procedure
3. Qualification and Performance of Tested Equipment.
4. Thermal Aging including mechanical wear and radiation exposure.
5. Post test inspection

On the final page of this form, the appropriate COMMENTS and RECOMMENDATIONS on all aspects of the qualification reports are entered. Additional pages may be attached to record any additional comments required to summarize the evaluation process.

ENVIRONMENTAL QUALIFICATION REPORT EVALUATION FORM
FOR SHOREHAM NUCLEAR POWER STATION - UNIT 1

NRC NUREG-0588 Category I* and II Positions

TR- _____

(Please type or print)

EQUIPMENT IDENTIFICATION

Equipment Type: _____
Vendor : _____
Specification No.: _____
Purchase (P.O.) No.: _____
Manufacturer: _____
Model No.: _____
Serial No.: _____

QUALIFICATION DOCUMENTATION

Title: _____
Author (Organization): _____
Identification No.: _____
Date: _____
SQRT Form I.D.: _____

REVIEWER'S CONCLUSION

Acceptable? YES NO

If YES, any limitation, exceptions, special conditions: _____

If NO, what specific deficiencies could be corrected in order to achieve acceptability? _____

REVIEWED BY: _____ VERIFIED BY: _____
Signature Date Signature Date

(*) Applicable to NUREG Category 1 positions only.

TEST FACILITY

Name: _____
 City: _____
 State: _____

APPLICABLE ZONE NUMBERS

Rad. Zones: _____
 Temp./Pres. Zones: _____

1. TEST CONDITIONS

See Environmental Qualification Summary Sheet No.: _____

- | | | | |
|---|-----|----|-----|
| 2. Does the model number of the component(s) tested coincide with the model number of the component(s) being reviewed? | YES | NO | |
| A. If not, is adequate justification provided showing that the component(s) tested adequately represent(s) component(s) being reviewed? | YES | NO | N/A |
| 3. Does the Test Program Outline include: | | | |
| A. Test Objectives | YES | NO | |
| B. Test Sample Description | YES | NO | |
| C. Number of units to be tested | YES | NO | |
| D. Mounting requirements | YES | NO | N/A |
| 1. If yes, is mounting justified? | YES | NO | N/A |
| 2. If no, has justification been provided showing that equipment performance is not altered by the manner or position in which it is mounted? | YES | NO | N/A |
| E. Aging Simulation Procedure | YES | NO | |
| F. Parameters to be measured | YES | NO | |
| 1. Accuracy | YES | NO | N/A |
| 2. Response time | YES | NO | N/A |
| G. The range, sequence, and combination of environments to simulate DBA conditions? | YES | NO | N/A |
| H. Acceptance Criteria | YES | NO | |
| 1. Are the acceptance criteria adequate to verify the ability of the equipment to perform its required safety function? | YES | NO | N/A |
| 4. Are the tests methods in accordance with following: | | | |
| A. Does the test demonstrate that the equipment satisfies the acceptance criteria? | YES | NO | |
| B. Do the parameters in the qualification documentation at least meet accident requirements? | YES | NO | |
| 1. If not, are deviations justified? | YES | NO | N/A |

- C. Have adequate margins been allowed in accordance with NUREG-0588, Section 3 (Cat. I or II)? YES NO
- (Circle appropriate Category)
- D. If the qualification uses analysis, are the basis, supporting data, and method for analysis included? YES NO N/A
- *E. Is test sequence justified as per IEEE 323-1974 Section 6.3.2 and NUREG-0588 Category I position? YES NO
- F. Is the test sequence justified as per IEEE 323-1971 and NUREG-0588 Category II position? YES NO
- G. Were performance characteristics verified before, during, and after testing? YES NO
- H. Were temperature readings obtained by thermocouple location on, or as near as practical to the surface of the component? YES NO
1. If not, is adequate justification provided showing that the component was exposed to the specified temperature environment? YES NO N/A
5. Does the test report address thermal aging? YES NO
- A. Was a qualified life and/or replacement schedule established? YES NO
- *B. Was test sample thermally aged by an acceptable method? YES NO
- *C. Did thermal aging simulate design life at normal conditions (temperature)? YES NO
- *D. Was test sample operated to simulate expected mechanical wear over design life? (electromechanical equipment only) YES NO N/A
- *E. Was test sample irradiated to the normal service life dosage before seismic and DBA testing? YES NO
- *F. Was test sample irradiated to the combined normal service life dosage plus DBA dosage before and during DBA testing? YES NO
6. Was equipment inspected after type testing? YES NO
- A. Are the results of the inspection recorded? YES NO N/A
7. Were any failures identified during environmental qualifications? YES NO
- A. Are failures justified? YES NO N/A
8. Is the test facility (set-up) described? YES NO N/A
9. Is a description of the instrumentation provided? YES NO
10. Are test conclusions consistent with test objectives and supported by test results? YES NO

11. A. Operability time demonstrated _____

B. Accuracy demonstrated _____

C. Response time demonstrated _____

12. Does the report have an approval signature? YES NO N/A

13. Is this report acceptable? YES NO

COMMENTS: _____

Multiple horizontal lines for writing comments.

RECOMMENDATIONS _____

Multiple horizontal lines for writing recommendations.

APPENDIX B
ENVIRONMENTAL QUALIFICATION
SUMMARY SHEET

APPENDIX B

ENVIRONMENTAL QUALIFICATION SUMMARY SHEET (EQSS)

The EQSS is a one page summary (a blank copy of which is included after this description) of the qualification document(s) to record the test or analysis results.

The data entered on the EQSS is, for the most part, self-explanatory. Each EQSS is numbered by specification number, succeeded by a number to sequentially identify each component or group of components. When an EQSS is revised, a revision number is added beginning with "1".

Data entries include procurement document references and test report identifications with applicable IEEE standards and the qualified life of the equipment.

The TEST SEQUENCE entry details the specific steps performed during the environmental qualification test in the sequence that they were performed.

The TEST ENVIRONMENT data tabulates the temperature, pressure and humidity test parameters, and their duration. In addition, the reviewer must ascertain whether the operability time and the equipment accuracy performance is acceptable.

Other entries include the APPLICABLE ENVIRONMENT ZONES in which the equipment must be qualified, and RADIATION AGING, THERMAL AGING, and mechanical CYCLE AGING data from the test report.

Completed EQSS copies are indexed and included following the blank copy for those qualification documents which have been evaluated. Each EQSS is referenced in the Equipment Qualification Status Report (EQSR). The EQSR also gives the qualification status for the equipment items.

INDEX
 ENVIRONMENTAL QUALIFICATION STATUS SUMMARY
 (EQSS)

<u>EQSS NO.</u>	<u>EQUIPMENT TITLE</u>	<u>VENDOR</u>	<u>DATE REVIEWED</u>
003-01	Limiterque Valve Actuators SMB2, SMB3	GE-NED	12/29/81
124-01	120VAC Distribution	Systems	6/29/81
124-01A	Panel	Controls	6/29/81
124-01B			6/29/81
127-01	5KV Power Cable	kerite	1/4/82
128-01	600V Power Cable	Okonite	11/20/81
129-01	Instrument Cable	Rockbestos	11/27/81
129-02			12/31/81
130-01	Instrument Cable	Raychem	10/26/81
134-01	Electrical Penetration Series 200 Low Voltage	GE	11/30/81
134-02	Electrical Penetration Series 100 Medium Voltage	GE	11/06/81
159-01	Splicing Tapes T35, T95	Okonite	5/19/81
159-02	Lugs & Splices 52900 thru 53900	AMP	8/4/81
159-03	Switchboard Wire SIS 157279	GE	12/2/81
159-04	Switchboard Wire A830___6	Rockbestos	8/25/81
159-05	Raychem WCSF-N Splice & Termination	Raychem	11/7/81
197-01	Motor Operated Valve Actuators, Limitorque	Henry Pratt ITT Grinnell Contramatics	12/11/81
214-01	Motor Operated Valve	Velan	11/30/81
214-02	Actuators, Limitorque		12/11/81
232-01	Solenoid Valve	Velan	8/18/81

<u>EQSS NO.</u>	<u>EQUIPMENT TITLE</u>	<u>VENDOR</u>	<u>DATE REVIEWED</u>
	ASCO WJKX-		
248-01	Miscellaneous Transformer	Magnetics	12/01/81
253-01	Motor Operated Valve	Velan	11/30/81
253-02	Actuators, Limitorque		12/01/81
253-02			12/08/81
276-01	Fan Motor 143TCZ Westinghouse	Buffalo Forge	1/13/82
289-01	Hydrogen Recombiner Unit	Atomics International	12/11/81
289-02	Limitorque	(Rockwell)	12/11/81
289-03	Hydrogen Recombiner Blower Motor Reliance Electric Co.		1/6/82
310-01	Electric Motor Operated Control Valves Harold Beck & Sons	Fisher Controls	1/4/82
318-01	Solenoid Valve, ASCO NP-8320	Copes Vulcan	8/18/81
318-02	Solenoid Valve, ASCO HVA-206	Copes Vulcan	8/18/81
319-01	Veltron 800, Centerline 32046, Dwyer 1627, Powers 331-2792, Raymond MASR-49	MCC Powers	9/21/81
319-02	ITT General NH-91	MCC Powers	4/29/81
319-03	Solenoid Valve, ASCO WJHXX-	MCC Powers	9/1/81
344-01	Gas Analyzer	Comsip	12/3/81
344-01A			12/3/81
406-01	Pressure Transmitter, 1153 Series	Rosemount	9/09/81
406-02	Pressure Transmitter, 1152 Series E	Rosemount	12/22/81
406-03	RID, 88-149	Rosemount	1/5/82
407-01	Level Switch 291-	Magnetrol	1/9/82

<u>EQSS NO.</u>	<u>EQUIPMENT TITLE</u>	<u>VENDOR</u>	<u>DATE REVIEWED</u>
423-01	Solenoid Valve ASCO WJHXX-	Fisher Controls	
439-01	480V MG Set Panel	Louis Allis	
439-01A			6/25/81
439-01B			1/6/82
439-01C			1/6/82
439-01D			1/6/82
439-01E			6/25/81
439-02			1/5/82
455-01	Instrument Cable	Brand Rex	4/5/81
456-01	Electrical Penetration	Conax	9/23/81
456-02	Electrical Penetrations, Adapter Module	Conax	9/29/81
15.54-01	Solenoid Valve, Valcor V526	Valcor	8/17/81
88AD-01	Motor Operated Valve	Anchor	11/30/81
88AD-02	Actuator, Limitorque	Darling	12/11/81
88V-01	Motor Operated Valve	Velan	11/30/81
88V-02	Actuator, Limitorque		12/1/81
88V-03			12/03/81
88V-04			12/21/81

ENVIRONMENTAL QUALIFICATION SUMMARY SHEET (EQSS) INDEX

<u>EQSS NO.</u>	<u>EQUIPMENT TITLE</u>	<u>VENDOR</u>	<u>DATE REVIEWED</u>
3018	Barksdale B1T Pressure Switch	GE-NED	12/31/81
3021	Barksdale D2H Pressure Switch	GE-NED	12/23/81
3025	Barksdale P1H Pressure Switch	GE-NED	12/31/81
3027	ITT Barton 288A and 2898 Differential Pressure Indicating Switches	GE-NED	1/11/82
3032	Static-O-Ring 5N and 6N Series Pressure Switches	GE-NED	12/31/81
3037	Yarway 4418C Level Indicator	GE-NED	12/30/81
3040	Fenwal Temperature Switch	GE-NED	12/30/81
3048	Rosemount 1151 Differential Pressure Transmitter	GE-NED	12/31/81
3096	ASCO HTX-8320A20 Solenoid Valve	GE-NED	12/28/81
3110	Pyco/California Alloy/ NECI Temperature Element	GE-NED	12/31/81
3111	General Electric ECCS Motors	GE-NED	12/23/81

ENVIRONMENTAL QUALIFICATION SUMMARY SHEET (EQSS) INDEX
(Continued)

<u>EQSS NO.</u>	<u>EQUIPMENT TITLE</u>	<u>VENDOR</u>	<u>DATE REVIEWED</u>
3143	Magnetrol 3.5-751X-MPG-M14HY Level Switch	GE-NED	12/31/81
3146	Conax 1832-159-01 Explosive Valve	GE-NED	1/11/82
3902	General Electric 47D518673 Electric Heater	GE-NED	12/31/81
3903	General Electric 2CH6-041-1U Blower	GE-NED	12/31/81
3904	Target Rock 1/2 SMS-A-01 Solenoid Valve	GE-NED	12/31/81
3906	PYCo 102-3171 Temperature Element	GE-NED	12/31/81
3909	ASCO NP8316C37 Solenoid Valve	GE-NED	12/29/81
3915	Rosemount 1152 Differential Pressure Transmitter	GE-NED	1/6/82

ENVIRONMENTAL QUALIFICATION SUMMARY NO. _____
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE _____
 SPEC. NO. _____ P.O. _____ VENDOR _____
 TEST ITEM DESC. _____
 MAKE _____ MODEL _____
 APPLICABLE STANDARDS _____ TEST REPORT NO. _____
 IEEE _____ TEST METHOD _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____
 NUREG 0588 CAT. _____ QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)

1. _____	6. _____
2. _____	7. _____
3. _____	8. _____
4. _____	9. _____
5. _____	10. _____

TEST ENVIRONMENT (R: _____)	APPLICABLE ENV. ZONES
TIME _____	- - - -
TEMP. °F _____	- - - -
PRES. PSIG _____	- - - -
OP. TIME DEMO _____ ACC/PERF DEMO _____	- - - -

RADIATION AGING (R: _____)	THERMAL AGING (R: _____)
DOSE RATE _____ RAD/HR	AGED TO SIMULATED LIFE OF _____ YRS.
DOSE PRIOR TO ENV. TEST _____ RADS	BASED ON AMBIENT TEMP OF _____ °F
DOSE DURING ENV. TEST _____ RADS	AGING TEMP./ DURATION _____ / _____
TOTAL DOSE _____ RADS	REL. HUMIDITY _____ %

CYCLE AGING (R: _____)	NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.
CYCLES REQUIRED _____	
CYCLES PERFORMED _____ (Electro-Mechanical Equip. only)	

REVIEWER: _____ DATE: _____

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 003-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE NUCLEAR STEAM SUPPLY SYSTEM
 SPEC. NO. SHL-003 P.O. 370010/31001 VENDOR GENED
 TEST ITEM DESC. MOTOR OPERATED VALVE
 MAKE SMB-0 MODEL AC RELIANCE, H-INSULATION
 VENDOR TEST REPORT NO. 600198, F-C2232-01 + APP 1, 600376A (RAD ONLY)
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE - 323-1971 TEST METHOD SEQUENTIAL TESTING
 IEEE - 344 DOCUMENTATION ACCEPTABILITY NOT ACCEPTABLE
 IEEE - 382-1972
 NUREG 0588 CAT. II QUALIFIED LIFE NOT GIVEN

- TEST SEQUENCE (R: pg 3-7 600198)
- | | |
|--|---|
| 1. <u>PRELIMINARY HEAT TEST ON COMPONENT PARTS</u> | 4. <u>HEAT AGING TEST - MOTOR - MOTOR WITH BRAKES</u> |
| 2. <u>PRELIMINARY HEAT TESTS ON ACTUATOR</u> | 5. <u>SHOCK + VIBRATION TEST OF ACTUATOR</u> |
| 3. <u>PRE-LIVE STEAM TEST ON ACTUATOR</u> | 6. <u>150 CYCLE TEST</u> |
| | 7. <u>POST-ACCIDENT STEAM + CHEMICAL ENVIRONMENT TEST</u> |

TEST ENVIRONMENT (R: pg 11 + App I FC2232-01)

TIME	0-1hr	1-3hr	3-5hrs	5-24hrs	24hr-7days	
AVG TEMP. °F	829	313.5	287	264	249	
PRES. PSIG	90	70	40	20	5	
R.H.	<u>100</u>					
OP. TIME DEMO	<u>7 days</u>					ACC/PERF DEMO _____

APPLICABLE ENV. ZONES
 RAD 0
 T/P 22

RADIATION AGING (R: pg 4, 600376A *)
 DOSE RATE 1 x 10⁶ RAD/HR
 DOSE PRIOR TO ENV. TEST 204. x 10⁶ RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 204. x 10⁶ RADS

THERMAL AGING (R: pg 5 600198)
 AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF NOT GIVEN °F
 AGING TEMP./ DURATION 180° / 100
 REL. HUMIDITY NOT GIVEN

CYCLE AGING (R: pg 6 600198)
 CYCLES REQUIRED 2000 (IEEE-382)
 CYCLES PERFORMED 150
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.

REVIEWER: [Signature] * ACTUATOR ONLY - MOTOR FILES MUST BE REVIEWED DATE: 7/2/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 124-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Miscellaneous AC and DC Distribution Boards
 SPEC. NO. 124 P.O. 310713 VENDOR Systems Control
 TEST ITEM DESC. See Attached EQS sheets 124-01A+B
 MAKE _____ MODEL _____
 VENDOR TEST REPORT NO. _____
 APPLICABLE STANDARDS _____ TEST REPORT NO. _____
 IEEE 323-1974 TEST METHOD _____
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY _____
 IEEE _____
 NUREG 0588 CAT. _____ QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)
 1. _____ 6. _____
 2. _____ 7. _____
 3. _____ 8. _____
 4. _____ 9. _____
 5. _____ 10. _____

TEST ENVIRONMENT (R: _____)	APPLICABLE ENV. ZONES
TIME _____	RAD _____
TEMP. °F _____	_____
PRES. PSIG _____	T/P _____
R.H. _____	_____
OP. TIME DEMO _____ ACC/PERF DEMO _____	_____

RADIATION AGING (R: _____)	THERMAL AGING (R: _____)
DOSE RATE _____ RAD/HR	AGED TO SIMULATED LIFE OF _____ YRS.
DOSE PRIOR TO ENV. TEST _____ RADS	BASED ON AMBIENT TEMP OF _____ °F
DOSE DURING ENV. TEST _____ RADS	AGING TEMP./ DURATION _____ / _____
TOTAL DOSE _____ RADS	

CYCLE AGING (R: _____)	REL. HUMIDITY _____
CYCLES REQUIRED _____	NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.
CYCLES PERFORMED _____ (Electro-Mechanical Equip. only)	

REVIEWER: Ren M Snyder DATE: 6-24-81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 124-01A
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Miscellaneous AC and DC Distribution Boards
 SPEC. NO. 124 P.O. 310713 VENDOR Systems Control
 TEST ITEM DESC. Magnetic Molded Case Circuit Breakers
 MAKE Westinghouse MODEL See Attachment 1
 VENDOR TEST REPORT NO. 16295
 APPLICABLE STANDARDS TEST REPORT NO. 124-01
 IEEE 323-1974 TEST METHOD Test/Analysis
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY Unacceptable, further supporting data, and analysis required
 IEEE _____ QUALIFIED LIFE >40 years
 NUREG 0588 CAT. I

TEST SEQUENCE (R: Appendix II)

- | | |
|-------------------------------------|---|
| 1. <u>Functional Test</u> | 6. <u>Vibration Test</u> |
| 2. <u>Radiation Aging</u> | 7. <u>Calibration Test</u> |
| 3. <u>Functional Test</u> | 8. <u>1200 HRS Temp Aging 150°C</u> |
| 4. <u>1200 HRS Temp Aging 150°C</u> | 9. <u>Calibration + Dielectric Test</u> |
| 5. <u>Calibration Test</u> | 10. <u>Vibration + Calibration Test</u> |

TEST ENVIRONMENT (R: N/A, No DBA test performed)

APPLICABLE ENV. ZONES

TIME _____
 TEMP. °F _____
 PRES. PSIG _____
 R.H. N/A
 OP. TIME DEMO N/A ACC/PERF DEMO N/A

RAD N
 T/P 21

RADIATION AGING (R: Sec 4.1.1 + App IV)

THERMAL AGING (R: Sec 4.1.3 + App IV)

DOSE RATE Not provided RAD/HR
 DOSE PRIOR TO ENV. TEST N/A RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE 1.1 x 10⁵ RADS

AGED TO SIMULATED LIFE OF * 10 YRS.
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION 302°F / 2400 HRS

CYCLE AGING (R: Sec 4.1.2 + App IV)

REL. HUMIDITY Not Addressed

CYCLES REQUIRED 10,000 *
 CYCLES PERFORMED 4,000
 (Electro-Mechanical Equip. only)
 * See note 2 on attachment 1

NOT AGED-JUSTIFIED BY ANALYSIS TO 89 YRS.

* See note 1 on attachment 1

REVIEWER: Ron M Snyder

DATE: 6/29/81

Attachment 1 to EQS-124-01A

The following types of circuit breakers are addressed by EQS-124-01A

Thermal-Magnetic Circuit Breakers

QBH
QPH
QCH
EB
EHB
FB
HFB
FB Tri-Pac

Magnetic Trip Only Circuit Breakers

FB
MCP
HFB

Notes

1. (See thermal aging section of EQS-124-01A)
The thermal aging time and temp used simulated at least 40 years at 25°C (87°F) for all parts of the breaker except molded, polyester-glass bases which were aged to the equivalent of 10 years. Subsequent analysis based on the activation energy of the weak link material (glass tape) showed equivalent aging of 89 years at 40°C (104°F)
2. (See cycle aging section of EQS-124-01A)
The test report references UL standard 489 for their cycle aging requirement. The standard calls for 6000 load operations, 4000 No load operations for a total of 10,000 operations.

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 124-013
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Miscellaneous AC and DC Distribution Boards
 SPEC. NO. 124 P.O. 310713 VENDOR Systems Control
 TEST ITEM DESC. Ground Bus Insulator and Bus Support/Insul. Barrier
 MAKE Fenn Custom Moldings MODEL Pienco-466
 VENDOR TEST REPORT NO. Acton 16295
 APPLICABLE STANDARDS _____ TEST REPORT NO. 124-01
 IEEE 323-1974 TEST METHOD Analysis
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY Unacceptable,
 IEEE _____ radiation analysis not
 NUREG 0588 CAT. I sufficiently documented
 QUALIFIED LIFE 740 years

TEST SEQUENCE (R: N/A)

- | | |
|----------|-----------|
| 1. _____ | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: N/A, No DBA test performed)

APPLICABLE ENV. ZONES

TIME _____

RAD N

TEMP. °F _____

PRES. PSIG _____

T/P 21

R.H. N/A

OP. TIME DEMO N/A ACC/PERF DEMO N/A

RADIATION AGING (R: Section 4.2.2)

THERMAL AGING (R: Section 4.2.1)

DOSE RATE N/A by analysis RAD/HR

AGED TO SIMULATED LIFE OF N/A YRS.

DOSE PRIOR TO ENV. TEST N/A RADS

BASED ON AMBIENT TEMP OF 104 °F

DOSE DURING ENV. TEST N/A RADS

AGING TEMP./ DURATION N/A / N/A

TOTAL DOSE 2 × 10⁷ RADS

REL. HUMIDITY Not Addressed

CYCLE AGING (R: Not required)

NOT AGED-JUSTIFIED BY ANALYSIS TO 225.15 YRS.

CYCLES REQUIRED _____

CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

REVIEWER: Ron M Snyder

DATE: 6-29-81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 127-01 Rev 1
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE 5 KV Power Cable
 SPEC. NO. 127 P.O. 310561 VENDOR Kerite Company
 TEST ITEM DESC. Single Conductor, 6AWG, 5KV, Power Cable
 MAKE Kerite Company MODEL HTK(N-98) insulation, FR(HC-711) jacket
 VENDOR TEST REPORT NO. None issue date May 14, 1981
 APPLICABLE STANDARDS TEST REPORT NO. 127-01
 IEEE 383-1974 TEST METHOD Sequential Test Analysis
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: Section A, page 1, para 4, + Section B, page 13, para 5+6)

- | | |
|-----------------------------------|--|
| 1. <u>Thermal Aging</u> | 6. <u>Insulation resistance checks</u> |
| 2. <u>Radiation Aging</u> | 7. <u>High Voltage AC test</u> |
| 3. <u>Simulated LOCA (6 day)</u> | 8. _____ |
| 4. <u>Inspection, Hi-pot test</u> | 9. _____ |
| 5. <u>Simulated LOCA (94 day)</u> | 10. _____ |

TEST ENVIRONMENT (R: Section B, page 14, figure 3)
 * Op. time demo extended by Wyle Analysis 17464-3502 Sec 6.0

TIME	<u>4 HRS</u>	<u>7 HRS</u>	<u>86 HRS</u>	<u>2304 HRS</u>
TEMP. °F	<u>340</u>	<u>320</u>	<u>250</u>	<u>200</u>
PRES. PSIG	<u>95.5</u>	<u>60</u>	<u>Atmos</u>	<u>Atmos</u>
R.H. <u>100 (Spray)</u>				
OP. TIME DEMO <u>>180 Days*</u>	ACC/PERF DEMO <u>N/A</u>			

APPLICABLE ENV. ZONES

RAD ALL

T/P ALL

RADIATION AGING (R: Sec. B App. A)

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^8 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 2×10^8 RADS

THERMAL AGING (R: Sec. A, page 1, para 4)

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF * 194 °F
 AGING TEMP./ DURATION 302°F / 100 HRS
 REL. HUMIDITY Uncontrolled *

CYCLE AGING (R: _____)

CYCLES REQUIRED Not Required
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.
 * Aging based on 194°F (90°C) conductor temp with 181.4° (83°C) surface temp.

REVIEWER: Ron M Snyder

DATE: 1/4/82

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 128-01 Rev A
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE 600 Volt Power Cable
 SPEC. NO. 128 P.O. 310557 VENDOR Okonite Company
 TEST ITEM DESC. 600 volt #12 7X TC .030" Okonite (EPR) insulation
 MAKE Okonite Company MODEL N/A
 VENDOR TEST REPORT NO. NQRN-1
 APPLICABLE STANDARDS TEST REPORT NO. 128-01
 IEEE 383-1974 TEST METHOD Sequential Test/Analysis/historical Data
 IEEE 323-1974 DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ Acceptable for customer if position of NUREG 0588
 NUREG 0588 CAT. II QUALIFIED LIFE 40 years

TEST SEQUENCE (R: Section 1.4.1-5)

- | | |
|----------------------------|--|
| 1. <u>Electrical Test</u> | 6. <u>Voltage Withstand Test (50 V/mil AC)</u> |
| 2. <u>Thermal Aging</u> | 7. <u>100 Day LOCA Test</u> |
| 3. <u>Irradiation</u> | 8. <u>Voltage Withstand Test (20 V/mil AC)</u> |
| 4. <u>Electrical Test</u> | 9. <u>Electrical Test</u> |
| 5. <u>30 Day LOCA test</u> | 10. <u>Dielectric Strength Test</u> |

TEST ENVIRONMENT (R: Section 1.4.1-3, App 5, Wire Analysis)
17464-1802 section 6.0

APPLICABLE ENV. ZONES

TIME	3 HRS	2 HRS	3 HRS	3 HRS	4 HRS	8 HRS	26 DYS	100 DYS
TEMP. °F	34.5	190	34.5	33.5	31.5	26.5	21.2	21.2
PRES. PSIG	114	^{NOT} STATED	114	101	74	26	0	0
R.H.	<u>100 (SPRAY)</u>							
OP. TIME DEMO	<u>130 DAYS</u>		ACC/PERF DEMO	<u>N/A</u>				

RAD ALL
 T/P ALL

RADIATION AGING (R: Appendix 1)

THERMAL AGING (R: Section 1.4.1.3, App 2)

DOSE RATE .67 to .75 RAD/HR
 DOSE PRIOR TO ENV. TEST 2.01×10^3 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 2.01×10^3 RADS

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 167 °F
 AGING TEMP./ DURATION 302°F / 504 HRS
 REL. HUMIDITY Not Addressed

CYCLE AGING (R: _____)

CYCLES REQUIRED Not Required
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.
 * Analysis and historical data is used to establish 40 year qualified life

REVIEWER: Ron W. Knudsen DATE: 7/1/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 129-01 Rev 1
 SHOREHAM NUCLEAR POWER STATION-UNIT 1 Page 1

SPEC. TITLE 300V and 600V Fire Resistant Control and Instrumentation Cable
 SPEC. NO. 129 P.O. 310553 VENDOR Rockbestos Company
 TEST ITEM DESC. See Attachment 1
 MAKE See Attachment 1 MODEL See Attachment 1
 VENDOR TEST REPORT NO. Firewall III Chemically Crosslinked 7-7-77, Rev. 12-8-80
 APPLICABLE STANDARDS TEST REPORT NO. 129-01
 IEEE 383-1974 TEST METHOD Sequential Test
 IEEE DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE NUREG 0588 Category II
 NUREG 0588 CAT. II POSITIONS Positions
 QUALIFIED LIFE 40 years

TEST SEQUENCE (R: Pages 5 thru 7)

- | | |
|----------------------------------|----------------------------------|
| 1. <u>Thermal Aging</u> | 6. <u>Voltage Withstand Test</u> |
| 2. <u>Radiation Aging</u> | 7. <u>365 Day Post LOCA Test</u> |
| 3. <u>Voltage Withstand Test</u> | 8. <u>Voltage Withstand Test</u> |
| 4. <u>Radiation Aging</u> | 9. _____ |
| 5. <u>30 Day LOCA Test</u> | 10. _____ |

TEST ENVIRONMENT (R: Page 11 and Page 7)

APPLICABLE ENV. ZONES

TIME	3 HRS	2 HRS	3 HRS	3 HRS	4 HRS	8 HRS	26 DAYS	14R
TEMP. °F	346	140	346	335	315	265	212	200
PRES. PSIG	113	NOT GIVEN	113	93	69	28	0	NOT GIVEN
R.H.	<u>100 (Spray)*</u>							
OP. TIME DEMO	<u>395 Days</u>							
ACC/PERF DEMO	<u>N/A</u>							

RAD All
 T/P All

RADIATION AGING (R: Sec III pg 5, Sec V, pg 6)

THERMAL AGING (R: Sec II pg 5)

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^8 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 2×10^8 RADS

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 176 °F
 AGING TEMP./ DURATION 302 °F, 1300 HRS

CYCLE AGING (R: _____)

REL. HUMIDITY Uncontrolled*

CYCLES REQUIRED Not Required
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

REVIEWER: Ron M. Smyth

DATE: 11/27/81

SPEC. TITLE 300v and 600v Fire Resistant Control and Instrumentation Cable
 SPEC. NO. 129 P.O. 310553 VENDOR Rockbestos Company
 TEST ITEM DESC. See Attachment 2
 MAKE See Attachment 2 MODEL See Attachment 2
 VENDOR TEST REPORT NO. Firewall III Irradiation Crosslinked Insulation, Rev. 12-880
 APPLICABLE STANDARDS TEST REPORT NO. 129-01
 IEEE 383-1974 TEST METHOD Sequential Test
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable,
 IEEE _____ NUREG 0588 Category II
 NUREG 0588 CAT. II positions
 QUALIFIED LIFE 40 years

TEST SEQUENCE (R: pages 16 thru 18)

- | | |
|----------------------------------|----------------------------------|
| 1. <u>Thermal Aging</u> | 6. <u>Voltage Withstand Test</u> |
| 2. <u>Radiation Aging</u> | 7. <u>365 Day post LOCA Test</u> |
| 3. <u>Voltage Withstand Test</u> | 8. <u>Voltage Withstand Test</u> |
| 4. <u>Radiation Aging</u> | 9. _____ |
| 5. <u>30 Day LOCA Test</u> | 10. _____ |

TEST ENVIRONMENT (R: Page 22 and page 18)

TIME	3HRS	2 HRS	3HRS	4 HRS	4HRS	81HRS	26D43	14R
TEMP. °F	346	140	346	335	315	265	212	200
PRES. PSIG	113	NOT GIVEN	113	93	69	28	0	NOT GIVEN
R.H.	<u>100 (Spray)</u>							
OP. TIME DEMO	<u>395 Days</u>							
ACC/PERF DEMO	<u>N/A</u>							

APPLICABLE ENV. ZONES

RAD All

T/P All

RADIATION AGING (R: See III p.16, See V p.17)

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^8 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 2×10^8 RADS

THERMAL AGING (R: See II p.16)

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 176 °F
 AGING TEMP./ DURATION 302° / 1300 HRS

CYCLE AGING (R: _____)

CYCLES REQUIRED Not Required
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Uncontrolled

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

REVIEWER: Ron M. Smyth

DATE: 11/27/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 129-02 Rev 0
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE 300V and 600V Fire Resistant Control and Instrumentation Cable
 SPEC. NO. 129 P.O. 310553 VENDOR Rockbestos Company
 TEST ITEM DESC. Adverse Service Coaxial Cable
 MAKE Rockbestos Company MODEL BSS 6-102 and BSS 6-113
 VENDOR TEST REPORT NO. Qualification of Firewall III Coaxial Constructions
 APPLICABLE STANDARDS TEST REPORT NO. 129-02
 IEEE 383-1974 TEST METHOD Sequential Test
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ NUREG 0588 Category II
 NUREG 0588 CAT. II Positions
 QUALIFIED LIFE 40 years

TEST SEQUENCE (R: Pages 1, 2, 3)

- | | |
|---------------------------------------|--|
| 1. <u>Thermal Aging</u> | 6. <u>Insulation Resistance Check</u> |
| 2. <u>Radiation Aging</u> | 7. <u>365 Day Post LOCA Simulation</u> |
| 3. <u>30 Day LOCA Test</u> | 8. <u>Insulation Resistance Check</u> |
| 4. <u>Insulation Resistance Check</u> | 9. <u>Dielectric Test</u> |
| 5. <u>Dielectric Test</u> | 10. _____ |

TEST ENVIRONMENT (R: Page 7)

APPLICABLE ENV. ZONES

TIME	3 HRS	3 HRS	3 HRS	4 HRS	105 HRS	391 DYS
TEMP. °F	340	340	320	370	250	200
PRES. PSIG	104	104	75	52	15	0
R.H.	<u>100 (Spray)*</u>					
OP. TIME DEMO	<u>395 Days</u> ACC/PERF DEMO <u>N/A</u>					

RAD All

T/P All

RADIATION AGING (R: Page 2 + 8)

THERMAL AGING (R: Page 2 Sec II)

DOSE RATE 5×10^5 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^8 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 2×10^5 RADS

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 167 °F
 AGING TEMP./ DURATION 302°F / 1169 HRS

CYCLE AGING (R: _____)

REL. HUMIDITY Not Addressed*

CYCLES REQUIRED Not Required
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

REVIEWER: Ron M Lynch

DATE: 12/4/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 130-01 Rev A
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Instrument Cable
 SPEC. NO. 130 P.O. 310587 VENDOR Raychem
 TEST ITEM DESC. See Attachments
 MAKE Raychem MODEL Flametro
 VENDOR TEST REPORT NO. 5058, F-C4033-1, EM 1237, + EM 1403
 APPLICABLE STANDARDS TEST REPORT NO. 130-01
 IEEE 383-1974 TEST METHOD Sequential Test/Analysis
 IEEE 323-1974 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. II (cat I in RBS) QUALIFIED LIFE 40 years

TEST SEQUENCE (R: App XI pg 6, Report EM 1403 pg 1 & 2)

- | | |
|--|----------------------------------|
| 1. <u>Combined Radiation + Thermal Aging</u> | 6. <u>Voltage Withstand Test</u> |
| 2. <u>Insulation Resistance Checks</u> | 7. _____ |
| 3. <u>30 Day LOCA exposure</u> | 8. _____ |
| 4. <u>Bend & High Potential Test</u> | 9. _____ |
| 5. <u>LOCA continuation</u> | 10. _____ |

TEST ENVIRONMENT (R: App XI pg 6, App XIII, Report EM 1403)

TIME	<u>10 HRS</u>	<u>82 HRS</u>	<u>26 DYS</u>	<u>121 DYS</u>	<u>185 DYS</u>
TEMP. °F	<u>357</u>	<u>275</u>	<u>212</u>	<u>200</u>	<u>155</u>
PRES. PSIG	<u>70</u>	<u>31</u>	<u>10</u>	<u>10</u>	<u>—</u>
R.H.	<u>100</u>				
OP. TIME DEMO	<u>336 DYS</u>		ACC/PERF DEMO <u>N/A</u>		

APPLICABLE ENV. ZONES

RAD ALL Reactor Bldg
 T/P ALL Reactor Bldg

RADIATION AGING (R: App XI sec 3.5.3.4, + App D)

DOSE RATE Not Stated RAD/HR
 DOSE PRIOR TO ENV. TEST 5×10^7 RADS
 DOSE DURING ENV. TEST 1.5×10^8 RADS
 TOTAL DOSE 2.0×10^8 RADS

CYCLE AGING (R: _____)

CYCLES REQUIRED Not Required
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

THERMAL AGING (R: App XI sec 3.5, App XIII, Wyle Anal 17464-1102)

AGED TO SIMULATED LIFE OF (>40 yrs in RBS) 31 YRS.
 BASED ON AMBIENT TEMP OF 194 °F
 AGING TEMP./DURATION 302 / 32 days
 REL. HUMIDITY Not addressed
 NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.

REVIEWER: Ron M Lynch

DATE: 10-26-81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 134-01 Rev 1
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Reactor Containment Electrical Penetrations
 SPEC. NO. 134 P.O. 310578 VENDOR General Electric
 TEST ITEM DESC. Electrical Containment Penetrations
 MAKE General Electric MODEL Series 200, low voltage
 VENDOR TEST REPORT NO. 924-7a-018
 APPLICABLE STANDARDS TEST REPORT NO. 134-01
 IEEE 317-1972 TEST METHOD Sequential Test
 IEEE _____ DOCUMENTATION ACCEPTABILITY Not
 IEEE _____ Acceptable
 NUREG 0588 CAT. II QUALIFIED LIFE Not Determined

TEST SEQUENCE (R: page 3)

- | | |
|--------------------------|-------------------------------|
| 1. <u>Thermal Cycle</u> | 6. <u>Long Term Post LOCA</u> |
| 2. <u>Gamma Exposure</u> | 7. _____ |
| 3. <u>Overcurrent</u> | 8. _____ |
| 4. <u>LOCA Test</u> | 9. _____ |
| 5. <u>Seismic Test</u> | 10. _____ |

TEST ENVIRONMENT (R: page 32)

TIME	<u>4.5 HRS</u>	<u>3.5 HRS</u>	<u>17.5 HRS</u>	<u>12 DAYS</u>	<u>6.5 HRS</u>
TEMP. °F	<u>340</u>	<u>328</u>	<u>275</u>	<u>210</u>	
PRES. PSIG	<u>103</u>	<u>30</u>	<u>20</u>	<u>20</u>	
R.H.	<u>100 %</u>				
OP. TIME DEMO	<u>13 HRS</u>	ACC/PERF DEMO	<u>N/A</u>		

APPLICABLE ENV. ZONES

RAD D
 T/P 22

RADIATION AGING (R: page 9)

DOSE RATE Not Stated RAD/HR
 DOSE PRIOR TO ENV. TEST 1 x 10⁻⁵ RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 1 x 10⁻⁵ RADS

THERMAL AGING (R: Not Addressed)

AGED TO SIMULATED LIFE OF _____ YRS.
 BASED ON AMBIENT TEMP OF _____ °F
 AGING TEMP./ DURATION _____ / _____
 REL. HUMIDITY _____ %

CYCLE AGING (R: Not Required)

CYCLES REQUIRED _____
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.

REVIEWER: Ken W. [Signature]

DATE: 11/30/81

B

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 134-02
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Reactor Containment Electrical Penetrations
 SPEC. NO. 134 P.O. 310578 VENDOR General Electric
 TEST ITEM DESC. Electrical Containment Penetration
 MAKE General Electric MODEL 100 Series, 5 KV, Medium Voltage
 VENDOR TEST REPORT NO. 74-502-2
 APPLICABLE STANDARDS TEST REPORT NO. 134-02
 IEEE 317-1972 TEST METHOD Sequential Test
 IEEE _____ DOCUMENTATION ACCEPTABILITY Not Acceptable,
 IEEE _____ Further test or analysis required
 NUREG 0588 CAT. II QUALIFIED LIFE Not determined

TEST SEQUENCE (R: Page 2-3)

- | | |
|------------------------------|---|
| 1. <u>Gamma exposure</u> | 6. <u>(Thermal Cycle) (performed independ-
ently)</u> |
| 2. <u>Electrical testing</u> | 7. _____ |
| 3. <u>LOCA</u> | 8. _____ |
| 4. <u>Post LOCA test</u> | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: Page 2-3)

TIME	<u>4 HRS</u>	<u>6 HRS</u>	<u>240 HRS</u>
TEMP. °F	<u>340</u>	<u>320</u>	<u>260</u>
PRES. PSIG	<u>103</u>	<u>81</u>	<u>20</u>
R.H. (%)	<u>100</u>		
OP. TIME DEMO	<u>10 Days</u>	ACC/PERF DEMO	<u>N/A</u>

APPLICABLE ENV. ZONES

RAD D
 T/P 22

RADIATION AGING (R: App B)

DOSE RATE 3.7×10^5 RAD/HR
 DOSE PRIOR TO ENV. TEST 1×10^2 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 1×10^8 RADS

THERMAL AGING (R: Not Addressed)

AGED TO SIMULATED LIFE OF _____ YRS.
 BASED ON AMBIENT TEMP OF _____ °F
 AGING TEMP./ DURATION _____ / _____
 REL. HUMIDITY _____ %
 NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.

CYCLE AGING (R: App A Thermal Cycle)

CYCLES REQUIRED 100
 CYCLES PERFORMED 120
 (Electro-Mechanical Equip. only)

REVIEWER: Ron M. ...

DATE: 11-6-81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 159-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE ELECTRICAL INSTALLATION
 SPEC. NO. SHI-159 P.O. VARIOUS VENDOR VARIOUS
 TEST ITEM DESC. OKOGUARD INSULATED CABLES W/T-95 & T-35 TAPES
 MAKE OKONITE MODEL T-35, T-95 SPLICE TAPES
 VENDOR TEST REPORT NO. NQRN-3
 APPLICABLE STANDARDS TEST REPORT NO. TR-128-01
 IEEE 383-1974 TEST METHOD SEQUENTIAL
 IEEE 323-1974 DOCUMENTATION ACCEPTABILITY - NOT
 IEEE _____ APPLICABLE TO 600V
 NUREG 0588 CAT. - CABLES USED @ SHOREHAM
 QUALIFIED LIFE _____

TEST SEQUENCE (R: Pg 3)

- | | |
|---------------------------------------|-----------------------------------|
| 1. <u>Sample selection + pre test</u> | 6. <u>Loca Profile</u> |
| 2. <u>Prepare Splices + check</u> | 7. <u>Post loca Withstand</u> |
| 3. <u>Thermal Aging</u> | 8. <u>Add 100 DAY Environment</u> |
| 4. <u>Irradiation</u> | 9. <u>Final check</u> |
| 5. <u>Pre-Loca check</u> | 10. _____ |

TEST ENVIRONMENT (R: App 4)

TIME	<u>3HRS</u>	<u>3HRS</u>	<u>3HRS</u>	<u>4HRS</u>	<u>8HRS</u>	<u>26DYS</u>	<u>100DYS</u>
TEMP. °F	<u>345</u>	<u>345</u>	<u>335</u>	<u>315</u>	<u>265</u>	<u>212</u>	
PRES. PSIG	<u>114</u>	<u>114</u>	<u>101</u>	<u>74</u>	<u>26</u>	<u>0-2</u>	<u>0</u>
R.H.	<u>100</u>						
OP. TIME DEMO	<u>130 DYS ACC/PERF DEMO</u>					<u>N/A</u>	

APPLICABLE ENV. ZONES
 RAD ALL
 ZONES
 T/P _____

RADIATION AGING (R: App 3)

DOSE RATE 0.7×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2.01×10^8 RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 2.01×10^8 RADS

CYCLE AGING (R: N/A)

CYCLES REQUIRED _____
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

THERMAL AGING (R: Pg 3)

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 192 °F
 AGING TEMP./ DURATION 302°F, 3 WEEKS

REL. HUMIDITY N/A

NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.

REVIEWER: William R. Fisher

DATE: 5/19/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 159-02
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE ELECTRICAL INSTALLATION
 SPEC. NO. SHI-159 P.O. VARIOUS VENDOR VARIOUS
 TEST ITEM DESC. LUGS & SPLICES
 MAKE AMP MODEL 534-- , 539-- , 529--
 VENDOR TEST REPORT NO. 110-11516
 APPLICABLE STANDARDS TEST REPORT NO. 159-02
 IEEE 323 - 1974 TEST METHOD SEQUENTIAL TEST/ANALYSIS
 IEEE 383 - 1974 DOCUMENTATION ACCEPTABILITY ACCEPTABLE
 IEEE P572 / D6A
 NUREG 0588 CAT. 1 QUALIFIED LIFE 40 YRS

TEST SEQUENCE (R: Pg 4 of 14)

- | | |
|--------------------------------|----------------------------|
| 1. <u>EXAMINE PRODUCT</u> | 6. <u>SPRAY</u> |
| 2. <u>TEMP RISE</u> | 7. <u>TENSILE STRENGTH</u> |
| 3. <u>HEAT AGE</u> | 8. _____ |
| 4. <u>DIELECTRIC WITHSTAND</u> | 9. _____ |
| 5. <u>RAD EXPOSURE</u> | 10. _____ |

TEST ENVIRONMENT (R: Pg 5 of 14)

TIME	0 TO 7 MIN	7 TO 9 MIN	9 TO 11 MIN	11 TO 17.5 MIN	19.5 MIN TO 2.3 HRS	9.8 HRS TO 52.2 HRS	54.3 HRS TO 384 HRS
TEMP. °F	370	370	350	350	302	268	240
PRES. PSIG	60	60	60	60	55	26	13-14
R.H.	100%						
OP. TIME DEMO	16 DAYS ACC/PERF DEMO N/A						

APPLICABLE ENV. ZONES
 RAD All
 T/P All

RADIATION AGING (R: Pg 5 of 14)

DOSE RATE 0.75 MEGA RAD/HR
 DOSE PRIOR TO ENV. TEST 2.06 x 10⁸ RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 2.06 x 10⁸ RADS

THERMAL AGING (R: Pg 5 of 14)

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 89°C (INCLUDES TEMP RISE) °F
 AGING TEMP./ DURATION 150°C / 7 DAYS *

CYCLE AGING (R: Not REQD)

CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

REL. HUMIDITY UNCONTROLLED

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

* ADDITIONAL COMPONENTS AGED FURTHER

REVIEWER: William R Shosh

DATE: 8-4-81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 159-03
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE ELECTRICAL INSTALLATION
 SPEC. NO. SHI-159 P.O. VARIOUS VENDOR VARIOUS
 TEST ITEM DESC. GENERAL ELECTRIC YULKENE SUPREME SI 57279
 MAKE GENERAL ELECTRIC MODEL SI 57279 SWITCHBOARD WIRE
 VENDOR TEST REPORT NO. FRANKLIN INSTITUTE #F-C4497-2 & GE. #PD-80
 APPLICABLE STANDARDS _____ TEST REPORT NO. TR-159-03
 IEEE STD 383-1974 TEST METHOD SEQUENTIAL TEST
 IEEE STD 323-1974 DOCUMENTATION ACCEPTABILITY NOT ACCEPTABLE,
 IEEE _____ FURTHER ANALYSIS REQ'D.
 NUREG 0588 CAT. I QUALIFIED LIFE NOT INDICATED

TEST SEQUENCE (R: Pg. 3-1,2,3 ; 4-1 of report # F-C4497-2)

- | | |
|---|------------------------------------|
| 1. <u>THERMAL AGING</u> | <u>NOTE: INSULATION RESISTANCE</u> |
| 2. <u>GAMMA RADIATION EXPOSURE</u> | <u>MEASUREMENTS MADE @ EACH</u> |
| 3. <u>STEAM/CHEMICAL SPRAY EXPOSURE</u> | <u>TEST STAGE.</u> |
| 4. <u>MANDREL BEND TEST</u> | _____ |
| 5. <u>HIGH POTENTIAL TEST</u> | _____ |

TEST ENVIRONMENT (R: Pg C-5 of report #F-C4497-2)

TIME	0 TO .35 HR	.35 HR TO 34 DAYS	0 TO 3 HR	4 HR TO 6.5 HR	6.5 HR TO 9.5 HR	9.5 HR TO 12.5 HR	12.5 HR TO 16.5 HR	16.5 HR TO 4 DAYS
TEMP. °F	348	TEST STOPPED	346	140	345	335	315	265
PRES. PSIG	124		124	0	122	95	69	28
R.H.	100%							
OP. TIME DEMO	110 DAYS			ACC/PERF DEMO	N/A			

* FROM 4 DAYS + 1.5 HR TO 110 DAYS, 212°F @ 5 PSIG

APPLICABLE ENV. ZONES
 RAD All
 T/P All

RADIATION AGING (R: Page 3-1)

DOSE RATE 0.54 MEGA RAD/HR
 DOSE PRIOR TO ENV. TEST 220 MEGA RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 220 MEGA RADS

THERMAL AGING (R: Pg 4 of PD-80)

AGED TO SIMULATED LIFE OF 350,000 HRS (40 YRS.)
 BASED ON AMBIENT TEMP OF 90°C (194 °F)
 AGING TEMP./ DURATION 165°C, 125 HRS

CYCLE AGING (R: N/A)

CYCLES REQUIRED _____
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NOT ADDRESSED

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

REVIEWER: William R. Shook

DATE: 12-02-81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 159-04
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE ELECTRICAL INSTALLATION
 SPEC. NO. SHI-159 P.O. VARIOUS VENDOR VENDOR
 TEST ITEM DESC. SWITCHBOARD WIRE TYPE A 830--6
 MAKE ROCKBESTOS MODEL FIREWALL III
 VENDOR TEST REPORT NO. -
 APPLICABLE STANDARDS TEST REPORT NO. TR-129-01
 IEEE 383-1974 TEST METHOD SEQUENTIAL TEST
 IEEE _____ DOCUMENTATION ACCEPTABILITY ACCEPTABLE
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 YEARS

TEST SEQUENCE (R: SECTIONS I → VI)

- | | |
|--|--|
| 1. <u>THERMAL AGING</u> | 6. <u>VOLTAGE WITHSTAND</u> |
| 2. <u>RADIATION AGING (5×10^7)</u> | 7. <u>365 DAY POST LOCA (SAMPLE B)</u> |
| 3. <u>VOLT. WITHSTAND</u> | 8. _____ |
| 4. <u>RADIATION AGING (1.5×10^8)</u> | 9. _____ |
| 5. <u>30 DAY LOCA</u> | 10. _____ |

TEST ENVIRONMENT (R: PROFILE ON Pg 8, * ON Pg 4)

TIME	3HR	2HR	3HR	3HR	4HR	81HR	26DYS	*365
TEMP. °F	346	140	346	335	315	265	212	200
PRES. PSIG	113	-	113	93	69	28	0	-
R.H.	100							
OP. TIME DEMO	365		ACC/PERF DEMO		N/A			

APPLICABLE ENV. ZONES
 RAD ALL
 T/P ZONES

RADIATION AGING (R: SECT III, VI)
 DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^8 RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 2×10^8 RADS

THERMAL AGING (R: Pg 2, SECT II)
 AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 176 °F
 AGING TEMP./ DURATION 302°F / 1300HRS

CYCLE AGING (R: _____)
 CYCLES REQUIRED N/A
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NOT ADDRESSED
 NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.

REVIEWER: William R. Shuler DATE: 8-25-81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 159-05
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Electrical Installation
 SPEC. NO. SH-159 P.O. Various VENDOR Various
 TEST ITEM DESC. Heat Shrinkable Insulating Sleeves [Splices]
 MAKE Raychem MODEL WCSE-N
 VENDOR TEST REPORT NO. _____
 APPLICABLE STANDARDS TEST REPORT NO. 2049
 IEEE -323-1974 TEST METHOD Sequential Tests
 IEEE -323-1974 DOCUMENTATION ACCEPTABILITY NO-
 IEEE _____ See comments on
 NUREG 0588 CAT. I QUALIFIED LIFE 40 yrs
EQREF-159-05

TEST SEQUENCE (R: _____)

- | | |
|---------------------------------------|-------------------------------------|
| 1. <u>Functional Test</u> | 6. <u>Additional Radiation Exp.</u> |
| 2. <u>Aging Simulation</u> | 7. _____ |
| 3. <u>Nuclear Radiation</u> | 8. _____ |
| 4. <u>LOCA Simulation</u> | 9. _____ |
| 5. <u>Post LOCA Test (Functional)</u> | 10. _____ |

TEST ENVIRONMENT (R: page 5)

TIME	3hr	5hr	5hr 5min	8hr	11hr	15hrs	4dys	30dys
TEMP. °F	340	340-140	140-240	340	320	300	250	200
PRES. PSIG	103	-	-	103	75	02	45	0
R.H.	<u>100%</u>							
OP. TIME DEMO	<u>30dys</u>		ACC/PERF	DEMC <u>N/A</u>				

APPLICABLE ENV. ZONES
 RAD ALL
 T/P ZONES

RADIATION AGING (R: pgs 2, 10)

DOSE RATE: .381 Mega RAD/HR
 DOSE PRIOR TO ENV. TEST 163.3 Mega RADS
 DOSE DURING ENV. TEST 50 Mega RADS
 TOTAL DOSE 213.3 Mega RADS

THERMAL AGING (R: pg 2)

AGED TO SIMULATED LIFE OF 40 yrs YRS.
 BASED ON AMBIENT TEMP OF 194 °F
 AGING TEMP./ DURATION 302°F / 168 hrs
 REL. HUMIDITY 100%

CYCLE AGING (R: _____)

CYCLES REQUIRED N/A
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.

REVIEWER: Kent W. Smith DATE: 11/7/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 197-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE MOTOR OPERATED / MANUALLY OPERATED / BRONZE VALVES
BUTTERFLY VALVE / DIAPHRAGM VALVES / 3in + 3 SMALLER

SPEC. NO. 197/203/28 P.O. 310546 VENDOR Henry Pratt/ITT GRINELL/Contramatics
310538
310744

TEST ITEM DESC. Limit torque MOV

MAKE Limitorque MODEL MOTOR+ACTUATOR-SMB-0-25

VENDOR TEST REPORT NO. B0058+AppD-80003 MOTORS (ALONG- 25+40 ft-lb start torq
Reliance, AC, class B [ALL MOTORS]

APPLICABLE STANDARDS TEST REPORT NO. _____

IEEE - 382-1972 TEST METHOD Sequential Testing

IEEE - 323-1971 DOCUMENTATION ACCEPTABILITY Acceptable
See comments + special

IEEE _____ conditions - EQREF-88V-3

NUREG 0588 CAT. II QUALIFIED LIFE 40 yrs

TEST SEQUENCE (R: pg 7-10 (80003))

- | | |
|------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Seismic Aging</u> | 9. _____ |
| 5. <u>Environmental Test</u> | 10. _____ |

TEST ENVIRONMENT (R: pg 10 (80003))

TIME	0-.5hr	.5-2hr	2-24hr	24-25hr	25hr-16days
TEMP. °F	250	250+120	250	250-200	200
PRES. PSIG	25	-	25	-	10
R.H.	<u>100</u>				
OP. TIME DEMO	<u>16 days</u> ACC/PERF DEMO _____				

APPLICABLE ENV. ZONES

RAD 7, 5

T/P 1, 18

RADIATION AGING (R: pg 8 (80003))

DOSE RATE 1×10^6 RAD/HR

DOSE PRIOR TO ENV. TEST 2×10^7 RADS

DOSE DURING ENV. TEST _____ RADS

TOTAL DOSE 2×10^7 RADS

THERMAL AGING (R: pg 7 (80003) (80058-p12))

AGED TO SIMULATED LIFE OF 232 days

BASED ON AMBIENT TEMP OF 104 °F

AGING TEMP./ DURATION 165 °F / 200 [199.8] HRS

CYCLE AGING (R: pg 7-8 (80003))

CYCLES REQUIRED 500

CYCLES PERFORMED 1993
 (Electro-Mechanical Equip. only)

REL. HUMIDITY 100

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.
 [pg 12-15 80058]
 Eq. Age at 104 °F obtained by proportioning to thermal life figures

REVIEWER: David W. Smith DATE: 12/11/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 214-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Manually Operated Stainless Steel Valves
 SPEC. NO. SH-214 P.O. 310512 VENDOR Velan
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL AC/SMB-0-25 Belliance Class BH
 VENDOR TEST REPORT NO. 80058 + App B - 600376A
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE -323-71 TEST METHOD Sequential Testing
 IEEE -382-72 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ See comments + special conditions
 NUREG 0588 CAT. II QUALIFIED LIFE > 40yrs
EQREF-88V-1

TEST SEQUENCE (R: pp 3-5 (600376A))

- | | |
|---------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Seismic Qualification</u> | 9. _____ |
| 5. <u>Accident Simulation</u> | 10. _____ |

TEST ENVIRONMENT (R: Franklin Institute Report; FC3441)
pg 3-5

APPLICABLE ENV. ZONES

TIME	0-2hr	3-6hr	6-9hr	9-12hr	12-13hr	13hr-30days
TEMP. °F	340	con	340	320	320-252	251
PRES. PSIG	105	down	105	77	19	15
R.H.	100 *					
OP. TIME DEMO	30 days					
ACC/PERF DEMO	_____					

RAD D

T/P 22

RADIATION AGING (R: pg 4 (600376A))

DOSE RATE 1×10^6 RAD/HR

DOSE PRIOR TO ENV. TEST 204×10^6 RADS

DOSE DURING ENV. TEST _____ RADS

TOTAL DOSE 204×10^6 RADS

CYCLE AGING (R: pg 3,4 (600376A))

CYCLES REQUIRED 500

CYCLES PERFORMED 500
(Electro-Mechanical Equip. only)

THERMAL AGING (R: pg 3; 80058-pg 10, 11)

Only the motor/stator aged
AGED TO SIMULATED LIFE OF 48 YRS.

BASED ON AMBIENT TEMP OF 158 °F

AGING TEMP./DURATION 180°C / 100 HRS

REL. HUMIDITY Not Given *

ACTUATOR NOT AGED-JUSTIFIED BY ANALYSIS TO 240 YRS.

Equiv. age at 158°F is determined by proportioning to thermal life figures given in 80058

REVIEWER Gene W. Smith

DATE: 11/30/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 214-02
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Manually Operated Stainless Steel valves
 SPEC. NO. SHI-214 P.O. 310512 VENDOR Velan
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL MOTOR+ACTUATOR-SMB-0-25
 VENDOR TEST REPORT NO. B0058+AppD-B0003 MOTORS (ALONE) - 2.5+40 ft-lb start torq
 APPLICABLE STANDARDS TEST REPORT NO. Reliance, AC, class B [ALL MOTORS]
 IEEE - 382-1972 TEST METHOD Sequential Testing
 IEEE - 323-1971 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE See comments + special
 NUREG 0588 CAT. II QUALIFIED LIFE 40 yrs
conditions - EQREF-88V-3

TEST SEQUENCE (R: pg 7-10 (B0003))

- | | |
|------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Siesmic Aging</u> | 9. _____ |
| 5. <u>Environmental Test</u> | 10. _____ |

TEST ENVIRONMENT (R: pg 10 (B0003))

TIME	0-.5hr	.5-2hr	2-24hr	24-25hr	25hr-16days
TEMP. °F	250	250+120	250	250-200	200
PRES. PSIG	25	-	25	-	10
R.H.	<u>100</u>				
OP. TIME DEMO	<u>16 days</u>				
ACC/PERF DEMO	_____				

APPLICABLE ENV. ZONES

RAD G, L
 T/P 1, 2, 12

RADIATION AGING (R: pg 8 (B0003))

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^7 RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 2×10^7 RADS

THERMAL AGING (R: pg 7 (B0003) (B0058-p12))

AGED TO SIMULATED LIFE OF 232 days
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION 165°F / 200 [199.8] HRS
 REL. HUMIDITY 100

CYCLE AGING (R: pg 7-8 (B0003))

CYCLES REQUIRED 500
 CYCLES PERFORMED 1993
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.
 [pg 12-15 B0058]
 Equiv. Age at 104°F obtained by proportioning to thermal life figures

REVIEWER: David W. Smith

DATE: 12/1/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 232-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Special Check Valves
 SPEC. NO. 232 P.O. 310595 VENDOR Velan
 TEST ITEM DESC. Solenoid Valve
 MAKE ASCO MODEL NP8320A184E
 VENDOR TEST REPORT NO. AQS-21678/TR Rev A, Wyle report 17464-1202
 APPLICABLE STANDARDS _____ TEST REPORT NO. 232-01
 IEEE 323-1974 TEST METHOD Sequential Test/Analysis
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years - coil + elastomer change every 4 years

- TEST SEQUENCE (R: Pages 3-1, 3-2)
- | | |
|---|------------------------------|
| 1. <u>Baseline/Functional</u> | 6. <u>Accident Radiation</u> |
| 2. <u>Thermal Aging</u> | 7. <u>LOCA Simulation</u> |
| 3. <u>Radiation</u> | 8. _____ |
| 4. <u>Wear Aging</u> | 9. _____ |
| 5. <u>Seismic Simulation/Vibration End.</u> | 10. _____ |
- * Before and After each Type Test phase

TEST ENVIRONMENT (R: <u>Pages 4-4, 4-5 and Fig 2 page 4-21</u>)					APPLICABLE ENV. ZONES	
TIME	<u>3 HRS</u>	<u>3 HRS</u>	<u>3 HRS</u>	<u>85 HRS</u>	<u>26 DYS</u>	RAD <u>B, D, G, H</u> T/P <u>1, 13, 22</u>
TEMP. °F	<u>346</u>	<u>346</u>	<u>320</u>	<u>250</u>	<u>200</u>	
PRES. PSIG	<u>110</u>	<u>110</u>	<u>75</u>	<u>15</u>	<u>10</u>	
R.H.	<u>100</u>					
OP. TIME DEMO	<u>180 DYS *</u>		ACC/PERF DEMO	<u>N/A</u>		

* Analysis for 180 DAY OP TIME IN WYLE REPORT 17464-1202

RADIATION AGING (R: Pages 4-2, 4-4 and Appendix D)

DOSE RATE $.51 \times 10^6$ and $.8 \times 10^6$ RAD/HR

DOSE PRIOR TO ENV. TEST 2.013×10^8 RADS

DOSE DURING ENV. TEST None RADS

TOTAL DOSE 2.013×10^8 RADS

THERMAL AGING (R: Pages 4-1, 4-3, 4-4)

AGED TO SIMULATED LIFE OF Zone 22 only 494 * 55 YRS.

BASED ON AMBIENT TEMP OF Zone 22 only 150 * 104 °F

AGING TEMP./DURATION 268 °F / 12 Days

REL. HUMIDITY Uncontrolled

CYCLE AGING (R: Page 4-3)

CYCLES REQUIRED 40,000

CYCLES PERFORMED 40,000
(Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

* See Wyle Lab. Thermal Aging Analysis Wyle Rep + 17464-1202 page 2

REVIEWER: Ron M Snyder DATE: 8/11/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 248-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE MISCELLANEOUS TRANSFORMERS
 SPEC. NO. SHI-248 P.O. 310739 VENDOR MAGNETICS
 TEST ITEM DESC. 480-120/240V TRANSFORMER
 MAKE MAGNETICS MODEL L-12514
 VENDOR TEST REPORT NO. -NONE-
 APPLICABLE STANDARDS TEST REPORT NO. -NONE-
 IEEE 323-1971 TEST METHOD _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY NA
 IEEE _____
 NUREG 0588 CAT. II QUALIFIED LIFE SEE WYLE ANALYSIS 17464-1302

TEST SEQUENCE (R: _____)

1. _____
2. _____
3. _____
4. _____
5. _____
6. _____
7. _____

TEST _____ APPLICABLE ENV. ZONES _____
 TIME _____ RAD _____
 TEMP. °F _____ N
 PRES. PSIG _____ T/P 21
 R.H. _____
 OP. TIME DEMO _____ / PERF DEMO _____

RADIATION AGING (R: _____) THERMAL AGING (R: WYLE ANALYSIS 17464-1302)
 DOSE RATE _____ RAD/HR AGED TO _____ YRS.
 DOSE PRIOR TO ENV. TEST _____ RADS BASED ON AMBIENT _____ °F
 DOSE DURING ENV. TEST _____ RADS TEMPERATURE _____ °F
 TOTAL DOSE _____ RADS DURATION _____

CYCLE AGING (R: _____) REL. HUMIDITY _____
 CYCLES REQUIRED _____ NOT ASED-JUSTIFIED BY ANALYSIS TO 40 YRS.
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. onl;)

REVIEWER: WR Stroscher DATE: 12-1-81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 253-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Motor Operated Carbon Steel Valves (Cat. I)
 SPEC. NO. SHI-253 P.O. 310512 VENDOR Velan
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL ACISMB-0-25 Reliance Class BH
 VENDOR TEST REPORT NO. B0058 + App B - 600376A
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE -323-71 TEST METHOD Sequential Testing
 IEEE -382-72 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ See comments + special conditions
 NUREG 0588 CAT. II EQREF -88V-1
 QUALIFIED LIFE > 40yrs

- TEST SEQUENCE (R: pp 3-5 (600376A))
- | | |
|---------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Seismic Qualification</u> | 9. _____ |
| 5. <u>Accident Simulation</u> | 10. _____ |

TEST ENVIRONMENT (R: <u>Franklin Institute Report; FC3441</u>)						APPLICABLE ENV. ZONES	
<u>pg 3-5</u>							
TIME	<u>0-3hr</u>	<u>3-6hr</u>	<u>6-9hr</u>	<u>9-12hr</u>	<u>12-13hr</u>	<u>13hr-30 days</u>	RAD <u>B, D, G, T</u>
TEMP. °F	<u>340</u>	<u>Cool</u>	<u>340</u>	<u>320</u>	<u>320-252</u>	<u>251</u>	_____
PRES. PSIG	<u>105</u>	<u>Down</u>	<u>105</u>	<u>77</u>	<u>19</u>	<u>15</u>	T/P <u>6, 8, 22</u>
R.H.	<u>100</u>						_____
OP. TIME DEMO	<u>30 days</u>		ACC/PERF DEMO _____				_____

RADIATION AGING (R: pg 4 (600376A))

DOSE RATE 1×10^6 RAD/HR

DOSE PRIOR TO ENV. TEST 204×10^6 RADS

DOSE DURING ENV. TEST — RADS

TOTAL DOSE 204×10^6 RADS

THERMAL AGING (R: pg 3; (B0058-pg 10, 11))

Only the motor stator aged

AGED TO SIMULATED LIFE OF 48 YRS.

BASED ON AMBIENT TEMP OF 158 °F

AGING TEMP./ DURATION 180°C / 100 HRS

CYCLE AGING (R: pg 3, 4 (600376A))

CYCLES REQUIRED 500

CYCLES PERFORMED 500
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Not Given

Actuator

NOT AGED-JUSTIFIED BY ANALYSIS TO > 40 YRS.

Equiv. age at 158°F is determined by proportioning to thermal life figures given in B0058

REVIEWER: Gene W. Smith DATE: 11/30/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 253-02
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE MOTOR OPERATED CARBON STEEL VALVES
 SPEC. NO. SHI-253 P.O. 310512 VENDOR VELAN
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL SMB-0-25 Beliance, DC, class H
 VENDOR TEST REPORT NO. B0058 + App E - B0009
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE - 382 - 72 TEST METHOD Sequential Testing
 IEEE - 323 - 71 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE - See comments and special
conditions EQREF-88V-2
 NUREG 0588 CAT. II QUALIFIED LIFE 240 yrs

TEST SEQUENCE (R: pg 6-9 (B0009))

1. Thermal Aging 6. _____
2. Mechanical Aging 7. _____
3. Radiation Aging 8. _____
4. Seismic Testing 9. _____
5. Environmental Test 10. _____

TEST ENVIRONMENT (R: pg 10 (B0009))

TIME	<u>0-1hr</u>	<u>1-2hr</u>	<u>2-4hr</u>	<u>4-7hr</u>	<u>7-25hrs</u>
TEMP. °F	<u>120-340</u>	<u>340</u>	<u>330</u>	<u>310</u>	<u>212</u>
PRES. PSIG	<u>0-68</u>	<u>68-104</u>	<u>104-86</u>	<u>86-63</u>	<u>0</u>
R.H.	<u>100</u>				
OP. TIME DEMO	<u>25 hrs</u>		ACC/PERF DEMO _____		

APPLICABLE ENV. ZONES
 RAD L, T
 T/P 5.8

RADIATION AGING (R: pg 7 (B0009))

DOSE RATE _____ RAD/HR
 DOSE PRIOR TO ENV. TEST 1x10⁷ RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 1x10⁷ RADS

THERMAL AGING (R: pg 6 + App III (B0009))

Motor Stator Only
 AGED TO SIMULATED LIFE OF 13.5 YRS.
 BASED ON AMBIENT TEMP OF 140 (60°C) °F
 AGING TEMP./ DURATION 180°C / 100 HRS

CYCLE AGING (R: pg 7 (B0009))

CYCLES REQUIRED 500
 CYCLES PERFORMED 2004
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Not Given
 Actuator
 NOT AGED-JUSTIFIED BY ANALYSIS TO 40 [B0058] [pg 13-15] YRS.

Equiv. Age derived by proportioning to thermal life figures [pg 10-11 B0058]

REVIEWER: Gene W. Smith DATE: 12/1/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 289-02
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE HYDROGEN RE

SPEC. NO. _____ P.O. _____ VENDOR _____

TEST ITEM DESC. Limitorque MOV

MAKE Limitorque MODEL MOTOR+ACTUATOR-SMB-0-25

VENDOR TEST REPORT NO. B0058+AppD-B0003 MOTORS (ALONET-25+40 ft-lb start torq
Reliance, AC, class B [ALL MOTORS]

APPLICABLE STANDARDS TEST REPORT NO. _____

IEEE - 382-1972 TEST METHOD Sequential Testing

IEEE - 323-1971 DOCUMENTATION ACCEPTABILITY Acceptable

IEEE _____ See comments + special

NUREG 0588 CAT. II conditions - EQREF-88V-3
 QUALIFIED LIFE 4.0 yrs

TEST SEQUENCE (R: pg 7-10 (B0003))

- | | |
|------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Siesmic Aging</u> | 9. _____ |
| 5. <u>Environmental Test</u> | 10. _____ |

TEST ENVIRONMENT (R: pg 10 (B0003))

APPLICABLE ENV. ZONES

TIME	0-.5hr	.5-2hr	2-24hr	24-25hr	25hr-16days
TEMP. °F	250	250+120	250	250-200	200
PRES. PSIG	25	-	25	-	10
R.H. _____ %	_____				
OP. TIME DEMO <u>16 days</u>	ACC/PERF DEMO _____				

RAD J
 T/P 15

RADIATION AGING (R: pg 8 (B0003))

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^7 RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 2×10^7 RADS

THERMAL AGING (R: pg 7 (B0003) (B0058-p12))

AGED TO SIMULATED LIFE OF 232 days
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION 165 °F, 200 [199.8] HRS
 REL. HUMIDITY 100 %

CYCLE AGING (R: pg 7-8 (B0003))

CYCLES REQUIRED 500
 CYCLES PERFORMED 7993
 (Electro-Mechanical Equip. only)

~~NOT AGED~~-JUSTIFIED BY ANALYSIS TO 40 YRS.
[pg 12-15 B0058]
 Equiv. Age at 104°F obtained by proportioning to thermal life figures

REVIEWER: Gene W. Smith

DATE: 12/11/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 253-03
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Motor Operated Carbon Steel Valves
 SPEC. NO. SHI-253 P.O. 310512 VENDOR Velan
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL MOTOR+ACTUATOR-SMB-0-25
 VENDOR TEST REPORT NO. B0058+AppD-80093 MOTORS (ALONET-25+40 ft-lb start torq, Reliance, AC, class B [ALL MOTORS])
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE - 382-1972 TEST METHOD Sequential Testing
 IEEE - 323-1971 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ See comments + special
 NUREG 0588 CAT. II conditions - EQREF-88V-3
 QUALIFIED LIFE 40 yrs

- TEST SEQUENCE (R: pg 7-10 (80003))
1. Thermal Aging 6. _____
 2. Mechanical Aging 7. _____
 3. Radiation Aging 8. _____
 4. Siesmic Aging 9. _____
 5. Environmental Test 10. _____

TEST ENVIRONMENT (R: pg 10 (80003))

TIME	<u>0-.5hr</u>	<u>.5-2hr</u>	<u>2-24hr</u>	<u>24-25hr</u>	<u>25hr-16days</u>	APPLICABLE ENV. ZONES RAD <u>7, L, T</u> T/P <u>2, 6, 8</u>
TEMP. °F	<u>250</u>	<u>250+120</u>	<u>250</u>	<u>250-200</u>	<u>200</u>	
PRES. PSIG	<u>25</u>	<u>-</u>	<u>25</u>	<u>-</u>	<u>10</u>	
R.H. %	<u>100</u>					
OP. TIME DEMO	<u>16 days</u> ACC/PERF DEMO _____					

RADIATION AGING (R: pg 8 (80003))

DOSE RATE 1×10^6 RAD/HR

DOSE PRIOR TO ENV. TEST 2×10^7 RADS

DOSE DURING ENV. TEST _____ RADS

TOTAL DOSE 2×10^7 RADS

THERMAL AGING (R: pg 7 (80003) (80058-p12))

AGED TO SIMULATED LIFE OF 232 days

BASED ON AMBIENT TEMP OF 104 °F

AGING TEMP./ DURATION 165°F / 200 [199.8] HRS

REL. HUMIDITY 100 %

CYCLE AGING (R: pg 7-8 (80003))

CYCLES REQUIRED 500

CYCLES PERFORMED 1993
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.
[pg 12-15 80058]
 Equiv. Age at 104°F obtained by proportioning to thermal life figures

REVIEWER: Scott W. Smith DATE: 12/8/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 276-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE UNIT COOLERS
 SPEC. NO. SHI-276 P.O. 310556 VENDOR BUFFALO FORGE Co.
 TEST ITEM DESC. MOTORETTE + MOTOR TESTING
 MAKE WESTINGHOUSE MODEL FRAME 365T
 VENDOR TEST REPORT NO. DO-146F
 APPLICABLE STANDARDS TEST REPORT NO. TR-276-01
 IEEE 323-1974 TEST METHOD SEQUENTIAL
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY ACCEPTABLE
 IEEE 334-1974
 NUREG 0588 CAT. I QUALIFIED LIFE 40 YEARS w/
IEEE 117-1974 BEARING + LUBE MAINTENANCE

- TEST SEQUENCE (R: Pg 5)
- | | |
|----------------------------|---------------------------------|
| 1. <u>SEISMIC (CALC)</u> | 6. <u>DBE TEST</u> |
| 2. <u>FACTORY TESTS</u> | 7. <u>ELEC. INSULATION TEST</u> |
| 3. <u>THERMAL AGING</u> | 8. <u>FINAL INSPECTION</u> |
| 4. <u>IRRADIATION</u> | 9. _____ |
| 5. <u>MECHANICAL AGING</u> | 10. _____ |

TEST ENVIRONMENT (R: APP 8, Pg 4)

TIME 30 DAYS
 TEMP. °F 227°
 PRES. PSIG 3.3
 R.H. 100
 OP. TIME DEMO 30 DAYS ACC/PERF DEMO N/A

APPLICABLE ENV. ZONES

RAD L
 T/P 02

RADIATION AGING (R: Pg 3)

DOSE RATE _____ RAD/HR
 DOSE PRIOR TO ENV. TEST _____ RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 1x10⁸ RADS

THERMAL AGING (R: Pg 5)

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 266 °F
 AGING TEMP./ DURATION 410°F, 1370 HRS

CYCLE AGING (R: _____)

CYCLES REQUIRED N.R.
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NOT ADDRESSED
 NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.

REVIEWER: William R. [Signature] DATE: 1/13/82

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 289-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Hydrogen Recombiner Units
 SPEC. NO. SH1-289 P.O. 310624 VENDOR Rockwell
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL ACSM8-0-25 Reliance Class BH
 VENDOR TEST REPORT NO. B0058 + App B - 600376A
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE -323-71 TEST METHOD Sequential Testing
 IEEE -382-72 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ See comments + special conditions
 NUREG 0588 CAT. II EQREF-88V-1
 QUALIFIED LIFE > 40yrs

TEST SEQUENCE (R: pp 3-5 (600376A))

- | | |
|---------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Seismic Qualification</u> | 9. _____ |
| 5. <u>Accident Simulation</u> | 10. _____ |

TEST ENVIRONMENT (R: Franklin Institute Report; EC3441)
pg 3-5

APPLICABLE ENV. ZONES

TIME	0-3hr	3-6hr	6-9hr	9-12hr	12-13hr	13hr-30days
TEMP. °F	340	<u>Con</u>	340	320	320-252	251
PRES. PSIG	105	<u>Down</u>	105	77	19	15
R.H.	<u>100</u>					
OP. TIME DEMO	<u>30 days</u> ACC/PERF DEMO _____					

RAD 5
T/P 15

RADIATION AGING (R: pg 4 (600376A))

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 204×10^6 RADS
 DOSE DURING ENV. TEST — RADS
 TOTAL DOSE 204×10^6 RADS

THERMAL AGING (R: pg 3; (80058-pg 10, 11))

Only the motor stator aged
 AGED TO SIMULATED LIFE OF 48 YRS.
 BASED ON AMBIENT TEMP OF 158 °F
 AGING TEMP./DURATION 180°C / 100 HRS

CYCLE AGING (R: pg 3, 4 (600376A))

CYCLES REQUIRED 500
 CYCLES PERFORMED 500
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Not Given
 Actuator
 NOT AGED-JUSTIFIED BY ANALYSIS TO > 40 YRS.
 Equiv. age at 158°F is determined by proportioning to thermal life figures given in 80058

REVIEWER: Gene W. Smith

DATE: 12/11/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 289-02
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE HYDROGEN RECOMBINER UNITS
 SPEC. NO. SH-289 P.O. 310624 VENDOR ATOMICS INTERNATIONAL (ROCKWELL)
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL MOTOR+ACTUATOR-SMB-0-25
 VENDOR TEST REPORT NO. B0058+AppD-80003 MOTORS (ALONE)- 25+40 ft-lb start torq
 APPLICABLE STANDARDS TEST REPORT NO. Reliance, AG, class B [ALL MOTORS]
 IEEE - 382-1972 TEST METHOD Sequential Testing
 IEEE - 323-1971 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE See comments + special
 NUREG 0588 CAT. II QUALIFIED LIFE 40 yrs
conditions - EQ REF-88V-3

TEST SEQUENCE (R: pg 7-10 (80003))

- | | |
|------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Seismic Aging</u> | 9. _____ |
| 5. <u>Environmental Test</u> | 10. _____ |

TEST ENVIRONMENT (R: pg 10 (80003))

TIME	0-.5hr	.5-2hr	2-24hr	24-25hr	25hr-16days
TEMP. °F	250	250+20	250	250-200	200
PRES. PSIG	25	-	25	-	10
R.H.	<u>100</u>				
OP. TIME DEMO	<u>16 days</u>				
ACC/PERF DEMO	_____				

APPLICABLE ENV. ZONES

RAD 5
 T/P 15

RADIATION AGING (R: pg 8 (80003))

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^7 RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 2×10^7 RADS

THERMAL AGING (R: pg 7 (80003) (80058-p12))

AGED TO SIMULATED LIFE OF 232 days
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION 165 °F / 200 [199.8] hrs
 REL. HUMIDITY 100

CYCLE AGING (R: pg 7-8 (80003))

CYCLES REQUIRED 500
 CYCLES PERFORMED 1993
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.
 [pg 12-15 80058]
 Equiv. Age at 104°F obtained by proportioning to thermal life figures

REVIEWER: David W. Smith

DATE: 12/11/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 289-03
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Hydrogen Recombiner
 SPEC. NO. 289 P.O. 310624 VENDOR Reliance Electric Company
 TEST ITEM DESC. Recombiner Blower Motors
 MAKE Reliance Electric Company MODEL 324T
 VENDOR TEST REPORT NO. Reliance Electric company Report No. NUC-9
 APPLICABLE STANDARDS TEST REPORT NO. Limitorque project #600456
 IEEE 323-1974 TEST METHOD Standard Qualification Test
 IEEE 334-1974 DOCUMENTATION ACCEPTABILITY Must be used
 IEEE 344-1975 in conjunction with Reliance
 NUREG 0588 CAT. _____ report No. NUC-9
 QUALIFIED LIFE 40 years

TEST SEQUENCE (R: I, page 3-11)

- | | |
|------------------------------|---------------------------------------|
| 1. <u>Thermal Aging</u> | 6. <u>LOCA Test</u> |
| 2. <u>Mechanical Aging</u> | 7. <u>Visual Inspection</u> |
| 3. <u>Radiation Aging</u> | 8. <u>Post LOCA Load Cycling Test</u> |
| 4. <u>Seismic Testing</u> | 9. <u>Final Inspection</u> |
| 5. <u>Radiation Exposure</u> | 10. _____ |

TEST ENVIRONMENT (R: I, page 10, 14)

TIME	<u>33 min.</u>	<u>24 min.</u>	<u>92 Hours</u>	<u>26 Days</u>		
TEMP. °F	<u>295</u>	<u>310</u>	<u>250</u>	<u>200</u>		
PRES. PSIG	<u>70</u>	<u>70</u>	<u>30</u>	<u>10</u>		
R.H.	<u>100 % Steam/chemical spray</u>					
OP. TIME DEMO	<u>30 Days</u>		ACC/PERF DEMO	<u>N/A</u>		

APPLICABLE ENV. ZONES
 RAD J
 T/P 15

RADIATION AGING (R: I, page 6)

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2.04×10^8 RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE 2.04×10^8 RADS

THERMAL AGING (R: I, page 3, II, p. 3)

AGED TO SIMULATED LIFE OF Greater than 40 YRS.
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION 355°F, 100 Hours

CYCLE AGING (R: I, page 11)

CYCLES REQUIRED -
 CYCLES PERFORMED 1208
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Not controlled
 NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

REVIEWER: M. Grinshteyn

DATE: 1-6-82

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 310-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Electric Motor Operated Control Valves
 SPEC. NO. 310 P.O. 310736 VENDOR Fisher Controls
 TEST ITEM DESC. Electric Motor Operated Valve Actuator
 MAKE Harold Beck and Sons MODEL 14-101-023645
 VENDOR TEST REPORT NO. Not Assigned
 APPLICABLE STANDARDS TEST REPORT NO. 310-01
 IEEE 382-1972 TEST METHOD Sequential Test
 IEEE 323-1974 DOCUMENTATION ACCEPTABILITY Not Acceptable
 IEEE _____
 NUREG 0588 CAT. N/A QUALIFIED LIFE Not Established

TEST SEQUENCE (R: Page R-7)

- | | |
|----------------------------|-----------|
| 1. <u>Mechanical Aging</u> | 6. _____ |
| 2. <u>Radiation Aging</u> | 7. _____ |
| 3. <u>Functional Test</u> | 8. _____ |
| 4. <u>Seismic Test</u> | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: Not Performed)

TIME _____
 TEMP. °F _____
 PRES. PSIG _____
 R.H. Not Addressed
 OP. TIME DEMO None ACC/PERF DEMO N/A

APPLICABLE ENV. ZONES

RAD G, H, K, N
 T/P 1, 2, 15, 16, 19, 20

RADIATION AGING (R: Attach 1 to Wyle Report 17464-1402)

DOSE RATE 1x10⁷ RAD/HR
 DOSE PRIOR TO ENV. TEST N/A RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE * 1x10⁷ for ESR Board
2.2x10⁸ for remainder RADS

THERMAL AGING (R: Wyle Report 17464-1402 Section 3.0)

AGED TO SIMULATED LIFE OF N/A YRS.
 BASED ON AMBIENT TEMP OF 185 °F
 AGING TEMP./ DURATION 0/0
 REL. HUMIDITY Not Addressed

CYCLE AGING (R: Page R-7)

CYCLES REQUIRED 500
 CYCLES PERFORMED 16,588
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 740 YRS.
 * Thermal Aging data not available on oil materials

REVIEWER: Ron M. Snyder

DATE: 1/4/82

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 318-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Air Operated Control Valves
 SPEC. NO. 318 P.O. 310735 VENDOR Copes Vulcan
 TEST ITEM DESC. Solenoid Valve
 MAKE ASCO MODEL NP8320A184E
 VENDOR TEST REPORT NO. AQS-21678/TR Rev A, Wyle report 17464-1202
 APPLICABLE STANDARDS TEST REPORT NO. 232-01
 IEEE 323-1974 TEST METHOD Sequential Test/Analysis
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years - coil & elastomer change every 4 years

TEST SEQUENCE (R: Pages 3-1, 3-2)

- | | |
|---|------------------------------|
| 1. <u>* Baseline/Functional</u> | 6. <u>Accident Radiation</u> |
| 2. <u>Thermal Aging</u> | 7. <u>LOCA Simulation</u> |
| 3. <u>Radiation</u> | 8. _____ |
| 4. <u>Wear Aging</u> | 9. _____ |
| 5. <u>Seismic Simulation/Vibration Ends</u> | 10. _____ |
- * Before and After each Type Test phase

TEST ENVIRONMENT (R: Pages 4-4, 4-5 and Fig 2 page 4-21)

TIME	<u>3 HRS</u>	<u>3 HRS</u>	<u>3 HRS</u>	<u>85 HRS</u>	<u>26 DYS</u>
TEMP. °F	<u>346</u>	<u>346</u>	<u>320</u>	<u>250</u>	<u>200</u>
PRES. PSIG	<u>110</u>	<u>110</u>	<u>75</u>	<u>15</u>	<u>10</u>
R.H.	<u>100</u>				
OP. TIME DEMO	<u>180 DYS *</u>		ACC/PERF DEMO	<u>N/A</u>	

* Analysis for 180 DAY OP. TIME IN WYLE REPORT 17464-1202

APPLICABLE ENV. ZONES
 RAD G, H, K
 T/P 1, 3, 7, 15, 18

RADIATION AGING (R: Pages 4-2, 4-4 and Appendix B)

DOSE RATE .51 x 10⁶ and .8 x 10⁶ RAD/HR
 DOSE PRIOR TO ENV. TEST 2.013 x 10⁸ RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 2.013 x 10⁸ RADS

THERMAL AGING (R: Pages 4-1, 9-3, 9-4)

AGED TO SIMULATED LIFE OF * 55 YRS.
 BASED ON AMBIENT TEMP OF * 104 °F
 AGING TEMP./ DURATION 268 °F / 12 Days
 REL. HUMIDITY Uncontrolled
 NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.
 * See Wyle Lab. Thermal Aging Analysis, Wyle Report 17464-1202 page 2

CYCLE AGING (R: Page 4-3)

CYCLES REQUIRED 40,000
 CYCLES PERFORMED 40,000
 (Electro-Mechanical Equip. only)

REVIEWER: Ron M Snyder DATE: 8/18/91

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 318-02
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Air Operated Control Valves
 SPEC. NO. 318 P.O. 310735 VENDOR Copes Vulcan
 TEST ITEM DESC. Solenoid Valve
 MAKE ASCO MODEL HVA 206-380-3RF
 VENDOR TEST REPORT NO. ADS-21673/TR Rev A, Wyle Reports 17464-06 & 17464-0602
 APPLICABLE STANDARDS _____ TEST REPORT NO. 232-01
 IEEE 323-1974 TEST METHOD Sequential Test/Analysis
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years - coil & elastomer change every 4 years

TEST SEQUENCE (R: Pages 3-1, 3-2)

- | | |
|---|------------------------------|
| 1. <u>*Baseline/Functional</u> | 6. <u>Accident Radiation</u> |
| 2. <u>Thermal Aging</u> | 7. <u>LOCA Simulation</u> |
| 3. <u>Radiation</u> | 8. _____ |
| 4. <u>Wear Aging</u> | 9. _____ |
| 5. <u>Seismic Simulation/Vibration End.</u> | 10. _____ |
- * Before and after each Type Test phase

TEST ENVIRONMENT (R: Pages 4-4, 4-5, and Fig 2 page 4-21)

TIME	<u>3 HRS</u>	<u>3 HRS</u>	<u>3 HRS</u>	<u>85 HRS</u>	<u>26 DYS</u>
TEMP. °F	<u>346</u>	<u>346</u>	<u>320</u>	<u>250</u>	<u>200</u>
PRES. PSIG	<u>110</u>	<u>110</u>	<u>75</u>	<u>15</u>	<u>10</u>
R.H.	<u>100</u>				
OP. TIME DEMO	<u>180 DYS * ACC/PERF DEMO N/A</u>				

* Analysis for 180 Day Op time in Wyle Report 17464-0602

APPLICABLE ENV. ZONES

RAD G
 T/P 2,6,12

RADIATION AGING (R: Pages 4-2, 4-4 and Appendix D)

DOSE RATE 5.7×10^6 and 3×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2.013×10^5 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 2.013×10^5 RADS

THERMAL AGING (R: Pages 4-1, 4-3, 4-4)

AGED TO SIMULATED LIFE OF 55 YRS.
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION 263°F / 12 Days
 REL. HUMIDITY Uncontrolled

CYCLE AGING (R: Page 4-3)

CYCLES REQUIRED 40,000
 CYCLES PERFORMED 40,000
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.
 * See Wyle Lab Thermal Aging Analysis, Wyle report 17464-0602 page 2

REVIEWER: Ron M. Snyder DATE: 8/15/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 319-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE AUTOMATIC TEMPERATURE CONTROL SYSTEMS FOR HVAC
 SPEC. NO. SHI-319 P.O. 310738 VENDOR MCC POWERS
 TEST ITEM DESC. SEE ATTACHMENT #1
 MAKE SEE ATTACHMENT #1 MODEL SEE ATTACHMENT #1
 VENDOR TEST REPORT NO. WYLE # 44540-1
 APPLICABLE STANDARDS _____ TEST REPORT NO. TR-319-01
 IEEE 323-1971, 1974 TEST METHOD TYPE TEST
 IEEE _____ DOCUMENTATION ACCEPTABILITY SEE
 IEEE _____ ATTACHMENT #1
 NUREG 0588 CAT. SEE ATTACHMENT #1 QUALIFIED LIFE SEE ATTACHMENT #1

TEST SEQUENCE (R: Pg. No. ILL, LV, V, VI)

1. INITIAL FUNCTION TEST
2. SERVICE CONDITION SIMULATION + AGING
3. POST AGING OPERATIONAL CHECK
4. RADIATION EXPOSURE
5. POST RADIATION OPERATIONAL CHECK
6. SEISMIC TEST
7. POST SEISMIC OPERATIONAL CHECK
8. SIMULATED POST ACCIDENT CONDITIONS
9. FINAL FUNCTIONAL TEST
10. _____

TEST ENVIRONMENT (R: SECTION VIII-1)

APPLICABLE ENV. ZONES

TIME	1HR	1DAY	9DAYS	1HR	20DAYS
TEMP. °F	170	122	122	200	122
PRES. PSIG	1	0	0	1	0
R.H. %	100	90	60	100	60

OP. TIME DEMO 722 HRS ACC/PERF DEMO SEE ATTACHMENT #1

RAD _____
 T/P _____

RADIATION AGING (R: SECT IV-1)

THERMAL AGING (R: SECTION II-1)

DOSE RATE 1000 RAD/HR
 DOSE PRIOR TO ENV. TEST 1 x 10⁷ RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 1 x 10⁷ RADS

AGED TO SIMULATED LIFE OF 5YRS THERMAL, 5YRS OPER-TWICE 10 YEARS TOTAL
 BASED ON AMBIENT TEMP OF 75°F (SECTION XI-6) °F
 AGING TEMP./ DURATION 180°F / 1344 HRS

CYCLE AGING (R: SECTION II-16,17)

REL. HUMIDITY 50 TO 90 %

CYCLES REQUIRED NOT ADDRESSED
 CYCLES PERFORMED SEE ATTACHMENT #1
 (Electro-Mechanical Equip. only)

~~NOT AGED~~ JUSTIFIED BY ANALYSIS TO SEE ATTACHMENT #1

REVIEWER: William R. Shado

DATE: 9/21/81

- A. TEST ITEM: DWYER INSTRUMENTS INC / #1627-1
NOT QUALIFIED / SWITCH DIFFERENTIAL PRESSURE EXCEEDED
ALLOWABLE LIMIT AFTER COMPLETION OF TESTING / QUAL. LIFE
& ACCURACY PERFORMANCE NOT DEMONSTRATED / CYCLED
7400 TIMES / QUALIFIED LIFE AT 104°F NOT DETERMINED
- B. TEST ITEM: AIR MONITOR CORP (VALIDYNE) / VELTRON 800
NOT QUALIFIED / DURING D.E.A. TEST WIRE INSULATION
FAILED / QUAL. LIFE & ACCURACY PERFORMANCE
NOT DEMONSTRATED / CYCLED 7400 TIMES / QUAL LIFE
AT 104°F NOT DETERMINED
- C. TEST ITEM: RAYMOND CONTROL SYSTEMS / MASR - 9,49
NOT QUALIFIED / FAILED AFTER THERMAL AGING
AND DURING CYCLE AGING / QUAL. LIFE & ACCURACY
PERFORMANCE NOT DEMONSTRATED / CYCLING INCOMPLETE,
QUAL. LIFE AT 104°F NOT DETERMINED
- D. TEST ITEM: CENTERLINE / 32046-6
QUALIFIED / TO NUREG CAT I / QUALIFIED LIFE
8 YEARS PER ATTACHED WYLE REPORT 17464-1002 /
ACC PERF NOT APPLICABLE / CYCLED 7400 TIMES /
THERMAL AGING ANALYSIS PER WYLE REPORT 17464-
1002.

ATTACHMENT #1 TO EQSS-319-01

- E. TEST ITEM: MCC POWERS / 331-2792
QUALIFIED / NUTREG CAT I / QUALIFIED 15 YEARS
PER WYLE REPORT 17464-0402 / ACC PERF
NOT REQ'D / CYCLED 7400 TIMES / THERMAL
AGING ANALYSIS PER WYLE REPORT 17464-0402.
- F. TEST ITEM: ASCO / WJHKX832089E
SEE EQSS #319-03 (QUALIFIED)
- G. TEST ITEM: NAMCO / EA750
NOT QUALIFIED, SEE EQSS #319-04

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 319-02
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

4/1/81

SPEC. TITLE Auto Temp Control System for HVAC

SPEC. NO. SH-319 P.O. 310738 VENDOR M.C.C. Powers

TEST ITEM DESC. Damper Actuator

MAKE ITT General Controls MODEL NH91

APPLICABLE STANDARDS

IEEE 323-74

IEEE 344-75

IEEE

NUREG 0588 CAT. I

TEST REPORT NO. 377-80.010-A

TEST METHOD

DOCUMENTATION ACCEPTABILITY

QUALIFIED LIFE 10 yrs

TEST SEQUENCE (R: pg no. 2-5)

- | | |
|--|--|
| 1. <u>Initial Insp and Functional Test</u> | 6. <u>Final Insp. + Functional Test</u> |
| 2. <u>Service Cond. Simulation + Aging</u> | 7. _____ |
| 3. <u>Irradiation Test</u> | 8. <u>(Functional Test was performed</u> |
| 4. <u>Seismic Vibration Test</u> | 9. <u>after each test)</u> |
| 5. <u>Simulated LCCA Cond. Test</u> | 10. _____ |

TEST ENVIRONMENT (R: pg no 5)

TIME	<u>30 days</u>	<u>100 days</u>
TEMP. °F	<u>122 °F</u>	<u>150 °F</u>
PRES. PSIG	<u>Not</u>	<u>addressed</u>
% R.H.	<u>90%</u>	<u>95%</u>
OP. TIME DEMO	_____ ACC/PERF DEMO _____	

APPLICABLE ENV. ZONES

H Rad zone	-
LO Tot. Rad zone	-
-	-
-	-
-	-
-	-

RADIATION AGING (R: pg No 3)

DOSE RATE 1.6×10^4 RAD/HR
 DOSE PRIOR TO ENV. TEST 4×10^5 RADS
 DOSE DURING ENV. TEST 0 RADS
 TOTAL DOSE 4×10^5 RADS

CYCLE AGING (R: pg no 3)

CYCLES REQUIRED _____
 CYCLES PERFORMED 87,360
 (Electro-Mechanical Equip. only)

THERMAL AGING (R: pg no 3)

AGED TO SIMULATED LIFE OF 10 YRS.
 BASED ON AMBIENT TEMP OF 175 °F
 AGING TEMP./ DURATION 185 °F / 100 days
 REL. HUMIDITY 50%

NOT AGED—JUSTIFIED BY ANALYSIS TO _____ YRS.

REVIEWER: Keom J. Muller

DATE: 4-27-81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 319-03
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE AUTO TEMPERATURE CONTROL SYSTEMS FOR HVAC
 SPEC. NO. SHI-319 P.O. 310738 VENDOR MCC POWERS
 TEST ITEM DESC. SOLENOID VALVE
 MAKE ASCO MODEL WJKHX8320A89E
 VENDOR TEST REPORT NO. AQS-21678/TR REVA. WYLE REPORT 17464-1202
 APPLICABLE STANDARDS _____ TEST REPORT NO. 232-01
 IEEE 323-1974 TEST METHOD SEQUENTIAL TEST/ANALYSIS
 IEEE _____ DOCUMENTATION ACCEPTABILITY ACCEPTABLE
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 YEARS - CHANGE COIL + ELASTOMER @ 4 YEAR INTERVAL

- TEST SEQUENCE (R: Pages 3-1, 3-2)
1. *BASELINE / FUNCTIONAL
 2. THERMAL AGING
 3. RADIATION
 4. WEAR AGING
 5. SEISMIC SIMULATION/VIBRATION
 6. ACCIDENT RADIATION
 7. LOCA SIMULATION
 8. _____
 9. _____
- * BEFORE + AFTER EACH TYPE TEST PHASE

TEST ENVIRONMENT (R: Pg. 4-4, 4-5, FIG. 2 Pg. 4-21)

TIME	<u>3HRS</u>	<u>3HRS</u>	<u>3HRS</u>	<u>35HRS</u>	<u>26DAYS</u>
TEMP. °F	<u>346</u>	<u>346</u>	<u>320</u>	<u>250</u>	<u>200</u>
PRES. PSIG	<u>110</u>	<u>110</u>	<u>75</u>	<u>15</u>	<u>10</u>
R.H.	<u>100</u>				
OP. TIME DEMO	<u>70 MIN</u>		ACC/PERF DEMO	<u>N/A</u>	

APPLICABLE ENV. ZONES
RAD H, K
T/P 15, 18

<p>RADIATION AGING (R: <u>Pg 4-2, 44, APP D</u>)</p> <p>DOSE RATE <u>.51 x 10⁶ & .8 x 10⁶</u> RAD/HR</p> <p>DOSE PRIOR TO ENV. TEST <u>2.013 x 10⁸</u> RADS</p> <p>DOSE DURING ENV. TEST <u>NONE</u> RADS</p> <p>TOTAL DOSE <u>2.013 x 10⁸</u> RADS</p>	<p>THERMAL AGING (R: <u>Pg 4-1, 9-3, 9-4</u>)</p> <p>AGED TO SIMULATED LIFE OF <u>* 55</u> YRS.</p> <p>BASED ON AMBIENT TEMP OF <u>* 150</u> °F</p> <p>AGING TEMP./ DURATION <u>268, 12 DAYS</u></p> <p>REL. HUMIDITY <u>UNCONTROLLED</u></p> <p>NOT AGED-JUSTIFIED BY ANALYSIS TO <u>N/A</u> YRS.</p> <p><u>* SEE WYLE LAB THERMAL AGING ANALYSIS #17464-1202</u></p>
<p>CYCLE AGING (R: <u>Pg 4-3</u>)</p> <p>CYCLES REQUIRED <u>40,000</u></p> <p>CYCLES PERFORMED <u>40,000</u> (Electro-Mechanical Equip. only)</p>	

REVIEWER: WR Shoho DATE: 9-1-81

SPEC. TITLE Primary Containment Gas Analyzer
 SPEC. NO. 344 P.O. 310737 VENDOR Comsip Inc.
 TEST ITEM DESC. Hydrogen Analyzer System
 MAKE Comsip Delphi MODEL K-IV
 VENDOR TEST REPORT NO. Project 1035-1 Rev. 1, Sept 1981
 APPLICABLE STANDARDS _____ TEST REPORT NO. 344-01
 IEEE 323-1974 TEST METHOD Sequential Test/Analysis
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable,
 IEEE _____ provided deficiencies list on page 1
 _____ of EOREF 344-01 are justified
 NUREG 0588 CAT. I QUALIFIED LIFE See Attachment 1

- TEST SEQUENCE (R: Page 2 section 4.1.1)
1. Inspection and Operational Test
 2. Thermal Aging
 3. Mechanical Cycling
 4. Irradiation
 5. Seismic Vibration
 6. Simulated Past Accident Condition
 7. Final Inspection and Operational Test
 8. _____
 9. *(Functional Test were performed
 10. after each test)

TEST ENVIRONMENT (R: Table F-I Page 69, Attach 2 sec 4*)

	LOCA ENV.		Sample Gas Env.			APPLICABLE ENV. ZONES
TIME	100 DYS		9.75 HRS	106 HRS	96 DYS	RAD <u>J</u>
TEMP. °F	150°		300°	210°	167°	
PRES. PSIG	0		70	40	5	T/P <u>15, 16</u>
R.H.	<u>90 IS</u>					
OP. TIME DEMO	<u>180 DYS *</u>		ACC/PERF DEMO <u>1% Full Scale</u>			

* Analysis for 180 Day Op. time provided in Comsip letter July 20, 1981

RADIATION AGING (R: Table D-III pg 37)

DOSE RATE $<1 \times 10^6$ (pg 6) RAD/HR

DOSE PRIOR TO ENV. TEST 1×10^6 RADS

DOSE DURING ENV. TEST None RADS

TOTAL DOSE 1×10^6 RADS

THERMAL AGING (R: Table D-I pg 29)

AGED TO SIMULATED LIFE OF See Attach 1 YRS.

BASED ON AMBIENT TEMP OF See Attach 1 °F

AGING TEMP./DURATION See Attach 1

REL. HUMIDITY Not addressed

CYCLE AGING (R: Table D-II pg 33)

CYCLES REQUIRED Undetermined

CYCLES PERFORMED See Attach 2
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

REVIEWER: Ron M Snyder DATE: 12/3/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 344-01A
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Primary Containment Gas Analyzer
 SPEC. NO. 344-01 P.O. 310737 VENDOR Comsip Inc.
 TEST ITEM DESC. Moturette
 MAKE Reliance MODEL RN and RH insulation
 VENDOR TEST REPORT NO. NUC-9
 APPLICABLE STANDARDS TEST REPORT NO. 344-01A
 IEEE 323-1974 TEST METHOD Type Test/Analysis
 IEEE 334-1974 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: Section II, pages 5+6)

- | | |
|--------------------------------|-----------|
| 1. <u>Temperature Exposure</u> | 6. _____ |
| 2. <u>Mechanical Vibration</u> | 7. _____ |
| 3. <u>Moisture Exposure</u> | 8. _____ |
| 4. <u>Voltage Checks</u> | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: LOCA Test not required)

APPLICABLE ENV. ZONES

TIME _____
 TEMP. °F _____
 PRES. PSIG _____
 R.H. N/A
 OP. TIME DEMO 180 Days ACC/PERF DEMO N/A

RAD J
 T/P 15, 16

RADIATION AGING (R: Section III pg 14)

THERMAL AGING (R: Section 2)

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST N/A RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE 2.04×10^9 RADS

AGED TO SIMULATED LIFE OF N/A YRS.

BASED ON AMBIENT TEMP OF 338 °F

AGING TEMP./ DURATION N/A, N/A

CYCLE AGING (R: Not performed)

REL. HUMIDITY 100 %

CYCLES REQUIRED _____
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.

REVIEWER: Ron M Snyder

DATE: 12/3/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 406-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE ELECTRONIC TRANSMITTERS AND RTD's
 SPEC. NO. SHI-406 P.O. 310773 VENDOR ROSEMOUNT
 TEST ITEM DESC. PRESSURE TRANSMITTER
 MAKE ROSEMOUNT MODEL 1153 SERIES B
 VENDOR TEST REPORT NO. 108025, 108026 (2 VOLUMES, 4 APPENDICES)
 APPLICABLE STANDARDS TEST REPORT NO. 406-01
 IEEE 323-1974 TEST METHOD SEQUENTIAL TEST
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY ACCEPTABLE
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 3.9 YEARS @ 104°F

TEST SEQUENCE (R: Appendix II of 108026 (ROSEMOUNT Procedure # 1802))

- | | |
|--|---|
| 1. <u>Acceptance Test Verification</u> | 6. <u>Radiation Aging & Abnormal</u> |
| 2. <u>Design Verification Test</u> | 7. <u>Seismic Aging</u> |
| 3. <u>Accelerated Aging Thermal</u> | 8. <u>Seismic Abnormal</u> |
| 4. <u>Accelerated Aging Functional</u> | 9. <u>Steam / Temperature Test</u> |
| 5. <u>Baseline Check</u> | 10. <u>Post Accident Operation & Base Check</u> |

TEST ENVIRONMENT (R: VOLUME I of 108026)

APPLICABLE ENV. ZONES

TIME	<u>25.5 min</u>	<u>8 Hrs 17.5 min</u>	<u>57 Hrs</u>
TEMP. °F	<u>318</u>	<u>318</u>	<u>265</u>
PRES. PSIG	<u>72</u>	<u>73</u>	<u>24</u>
R.H. <u>100%</u>			
OP. TIME DEMO _____	ACC/PERF DEMO _____		

RAD G, J
 T/P 1, 2, 7, 10, 15

RADIATION AGING (R: Pg 56, VOLUME I)

THERMAL AGING (R: Pg 37, Report 108026)

DOSE RATE 2×10^6 to 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2.62×10^7 TO 2.88×10^7 RADS
 DOSE DURING ENV. TEST 0 RADS
 TOTAL DOSE 2.62×10^7 to 2.88×10^7 RADS

AGED TO SIMULATED LIFE OF 2 YRS.

BASED ON AMBIENT TEMP OF 120 °F

AGING TEMP./ DURATION 203°F, 1,110 HRS

CYCLE AGING (R: Pg 32, Appendix II)
INPUT PRESSURE

REL. HUMIDITY NOT ADDRESSED

CYCLES REQUIRED _____
 CYCLES PERFORMED 8030
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO _____ YRS.

REVIEWER: William R. Smith

DATE: 9-7-81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 406-02
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE ELECTRONIC TRANSMITTERS AND RESISTANCE TEMPERATURE DETECTORS
 SPEC. NO. SHI-406 P.O. 310773 VENDOR ROSEMOUNT
 TEST ITEM DESC. PRESSURE TRANSMITTER
 MAKE ROSEMOUNT MODEL 1152, OUTPUT CODE "E"
 VENDOR TEST REPORT NO. _____
 APPLICABLE STANDARDS _____ TEST REPORT NO. 38019, 57820, 117415 REV B
 IEEE 323 - 1971 TEST METHOD SEPARATE TESTS / ANALYSIS
 IEEE 344 - 1975 DOCUMENTATION ACCEPTABILITY YES - WITH
 IEEE _____ SEQUENTIAL TEST SUPPORTING
 NUREG 0588 CAT. II DATA _____
 QUALIFIED LIFE 1 YEAR, 4.78 MOS.

TEST SEQUENCE (R: SEPARATE TESTS, temp Pg 10 of 117415, radiation on)
RMT 8805A, 98022C

1. THERMAL TEST (ACCIDENT) 6. _____
2. LOW LEVEL RADIATION TEST 7. _____
3. SUPPLEMENTARY RADIATION TEST II 8. _____
4. _____ 9. _____
5. _____ 10. _____

TEST ENVIRONMENT (R: <u>Pg 9, #117415</u>)					APPLICABLE ENV. ZONES	
TIME, duration	<u>5min</u>	<u>10min</u>	<u>1hour</u>	<u>7hours</u>	<u>42hours</u>	RAD _____ T/P _____
TEMP. °F	<u>↑ 350°F</u>	<u>350°F</u>	<u>316°F</u>	<u>303°F</u>	<u>230°F</u>	
PRES. PSIG	<u>↑ 60</u>	<u>60</u>	<u>70</u>	<u>55.4</u>	<u>6</u>	
R.H.	<u>100%</u>					
OP. TIME DEMO	ACC/PERF DEMO <u>0.75% ACC AFTER TESTING</u>					

RADIATION AGING (R: Pg 7, 98022C)

DOSE RATE 0.2 to 1.0 x 10⁶ RAD/HR

DOSE PRIOR TO ENV. TEST 6.9 x 10⁶ RADS

DOSE DURING ENV. TEST _____ RADS

TOTAL DOSE 6.9 x 10⁶ RADS

THERMAL AGING (R: INCLUDED IN HEAT/ ACCIDENT TEST)

AGED TO SIMULATED LIFE OF _____ YRS.

BASED ON AMBIENT TEMP OF 104° F

AGING TEMP./ DURATION _____

REL. HUMIDITY _____

NOT AGED-JUSTIFIED BY ANALYSIS TO 1 YEAR, 4.78 MOS *

* SEE WYLE ASSESSMENT 17464-0902

CYCLE AGING (R: N/A)

CYCLES REQUIRED _____

CYCLES PERFORMED _____
(Electro-Mechanical Equip. only)

REVIEWER: William R Skasho DATE: 12/22/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 406-03
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE RTD Assemblies
 SPEC. NO. 406 P.O. 310773 VENDOR Rosemount Inc.
 TEST ITEM DESC. Resistance Temperature Detector
 MAKE Rosemount Inc. MODEL 88-51-50
 VENDOR TEST REPORT NO. Rosemount test report No. 2767 Rev. B
 APPLICABLE STANDARDS TEST REPORT NO. 2767, Rev. B.
 IEEE 323-1971 TEST METHOD Sequential test Analysis
 IEEE 323-1974 DOCUMENTATION ACCEPTABILITY Must be used
 IEEE 344-1971 in conjunction with Wyle reports
 NUREG 0588 CAT. II No 17464-1501 1502.
 QUALIFIED LIFE 4.78y. (Refer. 3)

TEST SEQUENCE (R: 1, page 5-13)
 1. Initial inspection and calibration 6. _____
 2. Gamma radiation 7. _____
 3. Seismic vibration 8. _____
 4. Steam chemical exposure 9. _____
 5. Final inspection and calibration 10. _____

TEST ENVIRONMENT (R: 1, page 8-11)
 TIME 7 min. 17 min 8 Hours 50 Hours 51 Hours
 TEMP. °F 340 340 303 228 Ambient
 PRES. PSIA 125 125 70 20 Ambient
 R.H. 80 % steam/chemical spray
 OP. TIME DEMO 50 Hours ACC/PERF DEMO ±.04°C

APPLICABLE ENV. ZONES
 RAD G, H, K
E, F
 T/P 1, 2, 15, 16, 19, 20, 23

RADIATION AGING (R: 1, page 8, Append. B)
 DOSE RATE 1x10⁶ RAD/HR
 DOSE PRIOR TO ENV. TEST 2x10⁸ RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE 2x10⁸ RADS

THERMAL AGING (R: 3, p. 6)
 AGED TO SIMULATED LIFE OF N/A YRS.
 BASED ON AMBIENT TEMP OF N/A °F
 AGING TEMP./ DURATION N/A, N/A

CYCLE AGING (R: _____)
 CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Not controlled
 NOT AGED-JUSTIFIED BY ANALYSIS TO (secondary side) 4.78 YRS.
(Primary side) less 1 year.

REVIEWER: M. Grinshteyn DATE: 1-5-82

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 407-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Level Switch
 SPEC. NO. 407 P.O. 10042 VENDOR Magnetrol International
 TEST ITEM DESC. Level Switch
 MAKE Magnetrol Internat MODEL 291-MPG-X-M14DC
 VENDOR TEST REPORT NO. Type Test Program on Liquid Level controls (Wyle Labor.)
 APPLICABLE STANDARDS TEST REPORT NO. 43235-1
 IEEE 323-1974 TEST METHOD Sequential Test, Analysis
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY Must be used
 IEEE _____ In conjunction with Wyle reports
 NUREG 0588 CAT. I No. 17464-0101, 0102
 QUALIFIED LIFE 7.6 years (Ref. 3)

TEST SEQUENCE (R: I, p. 2)

1. Nuclear Radiation Damage
2. Regression Analyses
3. Baseline Functional and Hydrostatic
4. Nuclear Radiation Aging
5. Elevated Temperature/Humidity
6. 75Hz Plant Induced Vibration Test
7. Seismic Qualification
8. Functional Test Following
9. Seismic
10. _____

TEST ENVIRONMENT (R: _____)

TIME No accident test was performed.
 TEMP. °F _____
 PRES. PSIG _____
 R.H. _____
 OP. TIME DEMO _____ ACC/PERF DEMO _____

APPLICABLE ENV. ZONES

RAD G; H
 T/P 03; 10; 18

RADIATION AGING (R: I, p. 140)

DOSE RATE 5.8×10^2 RAD/HR
 DOSE PRIOR TO ENV. TEST 4.4×10^4 RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE 4.4×10^4 RADS

THERMAL AGING (R: I, p. 146; 3, p. 3)

AGED TO SIMULATED LIFE OF N/A YRS.
 BASED ON AMBIENT TEMP OF N/A °F
 AGING TEMP./ DURATION 300°F, 149 Hours
 *REL. HUMIDITY 95 to 100 %

CYCLE AGING (R: I; p. 147)

CYCLES REQUIRED N/A
 CYCLES PERFORMED 10,040
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 7.6 YRS.

*The humidity was performed for a total of 480 hours at 95-100% RH and 100°F after thermal aging test.

REVIEWER: M. Grinshteyn

DATE: 1-9-82

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 423-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Air Operated Butterfly Valves
 SPEC. NO. 423 P.O. 310772 VENDOR Fisher Controls
 TEST ITEM DESC. Solenoid Valve
 MAKE ASCO MODEL NP8320A184E
 VENDOR TEST REPORT NO. AQS-21678/TR Rev A, Wyle report 17464-1202
 APPLICABLE STANDARDS _____ TEST REPORT NO. 232-01
 IEEE 323-1974 TEST METHOD Sequential Test/Analysis
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years - coil + elastomer change every 4 years

TEST SEQUENCE (R: Pages 3-1, 3-2)

- | | |
|---|------------------------------|
| 1. <u>Baseline/Functional</u> | 6. <u>Accident Radiation</u> |
| 2. <u>Thermal Aging</u> | 7. <u>LOCA Simulation</u> |
| 3. <u>Radiation</u> | 8. _____ |
| 4. <u>Wear Aging</u> | 9. _____ |
| 5. <u>Seismic Simulation/Vibration Ende</u> | 10. _____ |
- * Before and After each Type Test phase

TEST ENVIRONMENT (R: Pages 4-4, 4-5 and Fig 2 page 4-21)

TIME	<u>3 HRS</u>	<u>3 HRS</u>	<u>3 HRS</u>	<u>85 HRS</u>	<u>26 DYS</u>
TEMP. °F	<u>346</u>	<u>346</u>	<u>320</u>	<u>250</u>	<u>200</u>
PRES. PSIG	<u>110</u>	<u>110</u>	<u>75</u>	<u>15</u>	<u>10</u>
R.H.	<u>100</u>				
OP. TIME DEMO	<u>180 DYS</u>		* ACC/PERF DEMO	<u>N/A</u>	

* Analysis for 180 DAY OP TIME IN WYLE REPORT 17464-1202

APPLICABLE ENV. ZONES
 RAD G
 T/P 1

RADIATION AGING (R: Pages 4-2, 4-4 and Appendix D)

DOSE RATE $.51 \times 10^6$ and $.8 \times 10^6$ RAD/HR
 DOSE PRIOR TO ENV. TEST 2.013×10^8 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 2.013×10^8 RADS

CYCLE AGING (R: Page 4-3)

CYCLES REQUIRED 40,000
 CYCLES PERFORMED 40,000
 (Electro-Mechanical Equip. only)

THERMAL AGING (R: Pages 4-1, 9-3, 9-4)

AGED TO SIMULATED LIFE OF 55 YRS.
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP DURATION E 112 Days
 REL. HUMIDITY Uncontrolled

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.
 * See Wyle Lab. Thermal Aging Analysis, Wyle Report 17464-1202 page 2

REVIEWER: Ron M Snyder DATE: 8/18/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 439-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE 480 V Motor Generator Set
 SPEC. NO. 439 P.O. 310950 VENDOR Louis Allis
 TEST ITEM DESC. See Attached EOS nos. 439-01A, B, C, D, and E
 MAKE _____ MODEL _____
 VENDOR TEST REPORT NO. Louis Allis 9-129576
 APPLICABLE STANDARDS _____ TEST REPORT NO. 439-01
 IEEE _____ TEST METHOD _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ when supplemented by Wyle Lab
 _____ report 17464-3902
 NUREG 0588 CAT. _____ QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)

- | | |
|----------|-----------|
| 1. _____ | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: _____)

TIME _____
 TEMP. °F _____
 PRES. PSIG _____
 R.H. _____ %
 OP. TIME DEMO _____ ACC/PERF DEMO _____

APPLICABLE
 ENV. ZONES

RAD N

 T/P 21

RADIATION AGING (R: _____)

DOSE RATE _____ RAD/HR
 DOSE PRIOR TO ENV. TEST _____ RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE _____ RADS

THERMAL AGING (R: _____)

AGED TO SIMULATED LIFE OF _____ YRS.
 BASED ON AMBIENT TEMP OF _____ °F
 AGING TEMP./ DURATION _____ / _____
 REL. HUMIDITY _____ %

CYCLE AGING (R: _____)

CYCLES REQUIRED _____
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

NOT ACED-JUSTIFIED BY ANALYSIS TO _____ YRS.

REVIEWER: Ron M Snyder

DATE: 1/6/82

1R24W191

REPORT NO. PES-800 JOB 1160002 12/18/81

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

REPORT DATE 12/18/81 PAGE 66

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

RESET NO. 003

JOB NAME SHOREMAN - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET DATE 07/01/81

JOB CLIENT LILCO

SORTED BY - EQS / /

EQUIPMENT ID	EQUIPMENT DESCRIPTION	APPLIC DNG	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT	
VENDOR ID	VENDOR NAME	CAC	ZONE	MODEL / CATALOG NO	QUAL STAT	OSTG ITEM	OSTG ITEM	ENG CND
	PO NUMBER	PO RESP	SPEC	BLDG ELEV	SAFETY FUNCTIONS	SUBMG		OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP EQS = QS-439-01

.1R24W1111	480V MOTOR GENERATOR (RED)			LOUIS ALLIS	*QS-439-01	180 DYS	NA	
	LOUIS ALLIS	1E	N-21	COGSF	*EQ			ALL
	310950	439	RBS	150				A
.1R24W1112	480V MOTOR GENERATOR (BLUE)			LOUIS ALLIS	*QS-439-01	180 DYS	NA	
	LOUIS ALLIS	1E	N-21	COGSF	*EQ			ALL
	310950	439	RBS	150				A
.1R24W1113A	480V MOTOR GENERATOR (ORANGE)			LOUIS ALLIS	*QS-439-01	180 DYS	NA	
	LOUIS ALLIS	1E	N-21	COGSF	*EQ			ALL
	310950	439	RBS	150				A
.1R24W1113B	480V MOTOR GENERATOR (ORANGE)			LOUIS ALLIS	*QS-439-01	180 DYS	NA	
	LOUIS ALLIS	1E	N-21	COGSF	*EQ			ALL
	310950	439	RBS	150				A

ATTACHMENT TO
EQSS 439-01

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 439-01A
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE 480V Motor Generator Sets
 SPEC. NO. 439 P.O. 310950 VENDOR Louis Allis
 TEST ITEM DESC. Winding Insulation Systems
 MAKE See Attachment 1 MODEL See Attachment 1
 VENDOR TEST REPORT NO. Louis Allis 9-129576
 APPLICABLE STANDARDS _____ TEST REPORT NO. 439-01
 IEEE 323-1974 TEST METHOD Test/Analysis
 IEEE 117-1974 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE 334-1974 _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: N/A All test were performed independently)
 1. _____ 6. _____
 2. _____ 7. _____
 3. _____ 8. _____
 4. _____ 9. _____
 5. _____ 10. _____

TEST ENVIRONMENT (R: N/A, DBA test not required)
 TIME _____
 TEMP. °F _____
 PRES. PSIG _____
 R.H. N/A
 OP. TIME DEMO 180 Days ACC/PERF DEMO N/A

APPLICABLE ENV. ZONES
 RAD N
 T/P 21

RADIATION AGING (R: Section H)
 DOSE RATE 4.9×10^5 RAD/HR
 DOSE PRIOR TO ENV. TEST N/A RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE 1.1×10^9 RADS

THERMAL AGING (R: Section H)
 AGED TO SIMULATED LIFE OF N/A YRS.
 BASED ON AMBIENT TEMP OF * 109 °F
 AGING TEMP./ DURATION N/A / N/A
 REL. HUMIDITY 100 %

CYCLE AGING (R: Not Required)
 CYCLES REQUIRED _____
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.
 * See note 1 on pages 1 thru 6 of attachment 1

REVIEWER: Ron M Snyder DATE: 6-25-81

ENGINEERING REPORT

Attachment 1 for EQS-439-01A
page 1 of 7

DATE OF TEST ---

MANUFACTURER'S
ORDER NO. 9-129576

PURCHASER Long Island Lighting Co.

PURCHASER'S
ORDER NO. 310950

P4-9061 INSULATION SYSTEM
ALTERNATOR ARMATURE

- Magnet Wire - Single Glass Heavy Polyimide Film
- Slot Cell - Silicone, Glass-Mica-Glass
- Top Wedge - Aramid U-Wedge
- Silicone Resin Glass Laminate Flat Wedge
- Center Wedge - Silicone Resin Glass Laminate
- End Coil Insulation - Silicone, Glass-Mica-Glass
- Sleeving - Polyimide Coated Glass
- Connection Insulation - Glass
- Polyimide Coated Glass Sleeving
- Lacing - Woven Glass
- Tape - Woven Glass
- Varnish - Silicone
- Lead Cable - Aramid
- Polyimide Coated Glass

Notes:

1. Refer to item 25, par A, pg 14 of test report for data showing basis of 109°F (43°C) ambient temp

Written By

M. J. Shaw

Sheet 1 of 7



LOUIS ALLIS

Litton

APPROVED BY

L. M. ...

CODE IDENT. NO.

DOCUMENT NUMBER

DATE

5-15-81

01425

SECTION G-1

M 3126 10/79

ENGINEERING REPORT

page 2 of 7

DATE OF TEST ---
 MANUFACTURER'S ORDER NO. 9-129576
 PURCHASER'S ORDER NO. 310950

PURCHASER Long Island Lighting Co.

P4-9135 INSULATION SYSTEM ALTERNATOR ROTATING FIELD

- Magnet Wire - Heavy Polyimide Film (H220F)
- Pole - Silicone, Glass-Mica-Glass
- Pole End Radius Block - Silicone Resin Glass Laminate
- Pole Washers - Silicone Resin Glass Laminate
- Washer Tape - Woven Glass
- Bonding Resin - Epoxy Resin
- Sleeving - Polyimide Coated Glass
- Tie Tape - Woven Glass
- Crossover Insulation - Silicone, Glass-Mica-Glass
- Connection Tape - Silicone, Glass-Mica-Glass
- Woven Glass
- Banding Tape - Epoxy Resin Glass Filament Reinforced
- Varnish - Silicone
- Lead Cable - Aramid
- Polyimide Coated Glass

Notes:

1. Refer to item 25, para B, pg 15 of test report for data showing basis of 104°F (43°C) ambient temp

Written By W.D. Stone

Sheet 2 of 7



APPROVED BY W.D. Stone

CODE IDENT. NO.

DOCUMENT NUMBER

DATE 5-15-81

01425

SECTION G-1

M 3186 10/79

ENGINEERING REPORT

page 3 of 7

DATE OF TEST ---
 MANUFACTURER'S ORDER NO. 9-129576
 PURCHASER'S ORDER NO. 310950

PURCHASER Long Island Lighting Co.

P4-9144 INSULATION SYSTEM
 ALTERNATOR EXCITER ROTATING ARMATURE

ARMATURE

- Magnet Wire - Heavy Polyimide Film (H220F)
- Slot Cell - Silicone, Glass-Mica-Glass
- Top Wedge - Silicone Resin Filled Glass Laminate
- Center Wedge - Silicone Resin Filled Glass Laminate
- End Coil Insulation - Silicone, Glass-Mica-Glass
- Sleeving - Polyimide Coated Glass
- Connection Tape - Silicone, Glass-Mica-Glass
- Woven Glass
- Lacing - Woven Glass
- Banding Tape - Epoxy Resin Glass Filament Reinforced
- Resin - Epoxy
- Varnish - Silicone
- Lead Cable - Aramid
- Polyimide Coated Glass

Notes:

1. Refer to item 25, para. C, pg 12, of test report for data showing basis of 109°F (43°C) ambient temp.

Written By *M. J. ...*

Sheet 3 of 7



LOUIS ALLIS

APPROVED BY *L. May & P. ...*
 DATE 5-15-81

CODE IDENT. NO.

01425

DOCUMENT NUMBER

SECTION G-1

M 3186 10/75

ENGINEERING REPORT

page 4 of 7

PURCHASER Long Island Lighting Co.

DATE OF TEST ---
 MANUFACTURER'S ORDER NO. 9-129576
 PURCHASER'S ORDER NO. 310950

P4-9144 INSULATION SYSTEM
 ALTERNATOR EXCITER STATIONARY FIELD

FIELDS

- Magnet Wire - Heavy Polyimide Film (H220F)
- Ground Insulation - Silicone, Glass-Mica-Glass
- Conductor Splice - Polyimide Coated Glass
- Coil Leads - Aramid
- Polyimide Coated Glass
- Connection Insulation - Woven Glass
- Polyimide Coated Glass
- Start & Finish Leads - Polyimide Coated Glass
- Buffer Insulation - Polyimide Coated Glass
- Coil Insulation Tape - Silicone, Glass-Mica-Glass
- Woven Glass
- Varnish - Silicone

Notes:

1. Refer to item 25, para D, pg 21 of test report for data showing basis of 104°F (43°C) ambient temp.

Written By

M. J. Shaver

Sheet 4 of 7



LOUIS ALLIS

Litton

APPROVED BY

L. M. 2-1-81

CODE IDENT. NO.

DOCUMENT NUMBER

DATE

5-15-81

01425

SECTION G-1

M 3186 10/75

ENGINEERING REPORT

page 5 of 7

PURCHASER Long Island Lighting Co.

DATE OF TEST ---
 MANUFACTURER'S ORDER NO. 9-129576
 PURCHASER'S ORDER NO. 310950

P4-9128 INSULATION SYSTEM
 A.C. MOTOR STATOR AND
 PERMANENT MAGNET PILOT EXCITER STATOR


- | | |
|-----------------------|--------------------------------------|
| Magnet Wire | - Heavy Polyimide Film |
| Slot Cell | - Silicone, Glass-Mica-Glass |
| Top Wedge | - Aramid U-Wedge |
| | - Silicone Glass Laminate Flat Wedge |
| Center Wedge | - Silicone Glass Laminate |
| End Coils | - Silicone, Glass-Mica-Glass |
| Sleeving | - Polyimide Coated Glass |
| Connection Insulation | - Woven Glass |
| | - Polyimide Coated Glass |
| Lacing | - Woven Glass |
| Lead Cable | - Aramid |
| | - Polyimide Coated Glass |
| Varnish | - Silicone |

Notes:

i. Refer to item 25, para. E, pg 22 of test report for data showing basis of 109°F (43°C) ambient temp.

Written By *mg. Shaver*

Sheet 5 of 7



APPROVED BY *Louis Allis*

CODE IDENT. NO.

DOCUMENT NUMBER

DATE 5-15-81

01425

SECTION G-1

M 3186 10/79

ENGINEERING REPORT

page 6 of 7

DATE OF TEST ---
MANUFACTURER'S ORDER NO. 9-129576
PURCHASER'S ORDER NO. 310950

PURCHASER Long Island Lighting Co.

09P00057-0000
INSULATION SYSTEM
FEEDBACK CURRENT TRANSFORMER

Magnet Wire	- Heavy Polyimide Film
Terminals	- Tin Plated Brass
Terminal and Bracket Insulation	- Flexible Plate Mica
Tape	- Woven Glass
Varnish	- Silicone

VARNISH TREATMENT

Preheat followed by multiple dips and bakes in silicone varnish.

Notes:

1. Refer to item 15, para F, pg 23, of test report for data showing basis of 104°F (40°C) ambient temp.

Written By

M. J. Shaver

Sheet 6 of 7



LOUIS ALLIS

Litton

APPROVED BY

L. May 2/81

CODE IDENT. NO.

01425

DOCUMENT NUMBER

SECTION G-1

DATE

5-15-81

M 3106 10/79

ENGINEERING REPORT

DATE OF TEST ---
 MANUFACTURER'S ORDER NO. 9-129576
 PURCHASER'S ORDER NO. 310950

PURCHASER Long Island Lighting Co.

VARNISH TREATMENTS
 P4-400-115
 A.C. STATORS

Preheat followed by multiple dips and bakes in silicone varnish.

P4-400-125
 ALTERNATOR ROTATING FIELD COILS

Varnish treatment for coils, wet wound with epoxy resin and baked. Varnish treatment for coil assembly, preheat followed by multiple dips and bakes in a silicone varnish.

P4-400-126
 BRUSHLESS EXCITER ARMATURE


Preliminary varnish treatment is a preheat followed by one VPI and bake in epoxy resin before installing leads.

Final varnish treatment after leads are installed is multiple dips and bakes in silicone varnish.

P4-400-127
 EXCITER FIELDS

Preliminary varnish treatment is a preheat followed by one dip and bake in silicone varnish before forming and taping operating.

Final varnish treatment is a preheat followed by multiple dips and bakes in silicone varnish after forming and taping operation.

Written By <u>W. G. Shaw</u>		Sheet 7 of 7		 LOUIS ALLIS Litton
APPROVED BY <u>L. King</u>	DATE <u>5-15-81</u>	CODE IDENT. NO. <u>01425</u>	DOCUMENT NUMBER <u>SECTION G-1</u>	

3186 10/79

SPEC. TITLE 480 V Motor Generator Sets
 SPEC. NO. 439 P.O. 310950 VENDOR Louis Allis
 TEST ITEM DESC. Bearing Related Elements
 MAKE See Attachment MODEL See Attachment 1
 VENDOR TEST REPORT NO. Louis Allis 9-129576
 APPLICABLE STANDARDS _____ TEST REPORT NO. 439-01
 IEEE 323-1974 TEST METHOD Test/Analysis
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: N/A All test were performed independently)

- | | |
|----------|-----------|
| 1. _____ | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: DBA test not required)
 TIME _____
 TEMP. °F _____
 PRES. PSIG _____
 R.H. N/A
 OP. TIME DEMO 180 Days ACC/PERF DEMO N/A

APPLICABLE ENV. ZONES
 RAD N
 T/P 21

RADIATION AGING (R: Section J)
 * See note 1 on attachment
 DOSE RATE Not Given RAD/HR
 DOSE PRIOR TO ENV. TEST N/A RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE 1 x 10⁷ RADS

THERMAL AGING (R: Section J)
 AGED TO SIMULATED LIFE OF N/A YRS.
 BASED ON AMBIENT TEMP OF * 109 °F
 AGING TEMP./ DURATION N/A / N/A

CYCLE AGING (R: Section J-1)
 CYCLES REQUIRED 100,000 HRS
 CYCLES PERFORMED > 40 years *
 (Electro-Mechanical Equip. only)
 * See note 2 on attachment

REL. HUMIDITY Not Addressed
 NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.
 * See note 3 on attachment

REVIEWER: Ron Malnych DATE: 1/6/82

ENGINEERING REPORT Attachment 1 for EQS 439-01B

DATE OF TEST ---
MANUFACTURER'S ORDER NO. 9-129576
PURCHASER'S ORDER NO. 310950

PURCHASER Long Island Lighting Co.

BEARING RELATED ELEMENTS

A. BEARING SIZE AND TYPE:

1. Motor

Drive End - 218 SF Deep Groove Conrad Ball (1 Shield)
Non Drive End - 216 SF Deep Groove Conrad Ball (1 Shield)

2. Alternator

Drive End - 318SF Deep Groove Conrad Ball (1 Shield)
Non Drive End - 318 SF Deep Groove Conrad Ball (1 Shield)

B. BEARING INSULATION:

1. Motor

Insulating Washers - Canvas Base Phenolic
Insulating Tape - Epoxy Resin Glass Filament Reinforced

2. Alternator

Insulating Washers - Polyester Glass Laminate
Insulating Tape - Epoxy Resin Glass Filament Reinforced

C. BEARING LUBRICATION: Dow Corning (R)
FS-3451 Grease
NGLI #2

Notes:

1. Limiting Component is bearing lubricant
2. The bearing life of >40 years established by analysis
3. Refer to page 25 of test report for data showing basis of 109°F (43°C) ambient temp

Written by M.G. Shaver

Sheet 1 of 1



LOUIS ALLIS

APPROVED BY Louis J. Allis

CODE IDENT. NO.

DOCUMENT NUMBER

DATE 5-15-81

01425

SECTION G-2

M 3185 10/87

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 439-01C Rev 1
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE 480 V Motor Generator Set
 SPEC. NO. 439 P.O. 310950 VENDOR Louis Allis
 TEST ITEM DESC. Rotating Rectifier Assembly
 MAKE See Attachment MODEL See Attachment
 VENDOR TEST REPORT NO. Louis Allis 9-129576
 APPLICABLE STANDARDS _____ TEST REPORT NO. 439-01
 IEEE 323-1974 TEST METHOD Test/Analysis
 IEEE 650-1979 DOCUMENTATION ACCEPTABILITY Acceptable,
 IEEE _____ when supplemented by Wyle Lab
 _____ report 17464-3901
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: N/A All test were performed independently)
 1. _____ 6. _____
 2. _____ 7. _____
 3. _____ 8. _____
 4. _____ 9. _____
 5. _____ 10. _____

TEST ENVIRONMENT (R: <u>DBA test not required</u>)	APPLICABLE ENV. ZONES
TIME _____	RAD <u>N</u>
TEMP. °F _____	_____
PRES. PSIG _____	T/P <u>21</u>
R.H. <u>N/A</u>	_____
OP. TIME DEMO <u>180 days</u> ACC/PERF DEMO <u>N/A</u>	_____

RADIATION AGING (R: Section K & Wyle)
Report 17464-3902
 DOSE RATE Not Given RAD/HR
 DOSE PRIOR TO ENV. TEST N/A RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE 1 x 10⁷ ^{See note 1 on attach.} RADS

THERMAL AGING (R: Section K)
 AGED TO SIMULATED LIFE OF N/A YRS.
 BASED ON AMBIENT TEMP OF * 109 °F
 AGING TEMP./DURATION N/A / N/A

CYCLE AGING (R: Not Required)
 CYCLES REQUIRED _____
 CYCLES PERFORMED _____
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Not Addressed
 NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.
 * See note 2 on attachment

REVIEWER: Ron M Snyder DATE: 1/6/82

ENGINEERING REPORT Attachment 1 for EQS-439-01C

DATE OF TEST _____

MANUFACTURER'S ORDER NO. 9-129576

PURCHASER Long Island Lighting Co.

PURCHASER'S ORDER NO. 310950

ROTATING RECTIFIER ASSEMBLY


- A. Diodes: "General Electric" Part No. 1N1190 (Forward) and 1N1190R (Reverse)
- B Diode Support: Canvas Base Phenolic
- C. Shaft Insulation: Glass-Micapaper-Glass Lamine Silicon Bonded
- D. Cable: Aramid

Notes:

1. 1×10^7 RADS based on limiting component (Diodes) Support^m
2. Refer to item 25, para. ii, pg 26 of test report for data giving basis for 109°F (43°C) ambient temp.
- 3 The effects of radiation on diodes was ~~not~~ addressed by ~~the report~~^m Wyle Lab report 17464-3902

Written By *M. J. [Signature]*

Sheet 1 of 1



APPROVED BY *L. King [Signature]*
DATE 5-15-81

CODE IDENT. NO. **01425**

DOCUMENT NUMBER SECTION G-3

M 3186 10/79

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 439-01D Rev 1
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE 480 V Motor Generator Set
 SPEC. NO. 439 P.O. 310950 VENDOR Louis Allis
 TEST ITEM DESC. Static Rectifier Control Board Circuit
 MAKE See Attachment MODEL See Attachment
 VENDOR TEST REPORT NO. Louis Allis 9-129576
 APPLICABLE STANDARDS TEST REPORT NO. 439-01
 IEEE 323-1974 TEST METHOD Test/Analysis
 IEEE 650-1979 DOCUMENTATION ACCEPTABILITY Acceptable,
 IEEE _____ when supplemented by Wyle Lab.
 _____ report 17464-3901
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: N/A All test were performed independently)

- | | |
|----------|-----------|
| 1. _____ | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: <u>DBA test is not required</u>)	APPLICABLE ENV. ZONES
TIME _____	RAD <u>N</u>
TEMP. °F _____	_____
PRES. PSIG _____	T/P <u>21</u>
R.H. <u>N/A</u>	_____
OP. TIME DEMO <u>180 Days</u> ACC/PERF DEMO <u>N/A</u>	_____

RADIATION AGING (R: <u>Section L & Wyle report 17464-3902</u>)	THERMAL AGING (R: <u>Section L</u>)
DOSE RATE <u>Not Given</u> RAD/HR	AGED TO SIMULATED LIFE OF <u>N/A</u> YRS.
DOSE PRIOR TO ENV. TEST <u>N/A</u> RADS	BASED ON AMBIENT TEMP OF <u>* 109</u> °F
DOSE DURING ENV. TEST <u>N/A</u> RADS	AGING TEMP./ DURATION <u>N/A / N/A</u>
TOTAL DOSE <u>4.17 x 10⁶</u> <small>See note 1 on attach.</small> RADS	REL. HUMIDITY <u>Not Addressed</u>

CYCLE AGING (R: <u>Not Required</u>)	NOT AGED-JUSTIFIED BY ANALYSIS TO <u>40</u> YRS.
CYCLES REQUIRED _____	* <u>See note 2 on attachment</u>
CYCLES PERFORMED _____ (Electro-Mechanical Equip. only)	

REVIEWER: Ron M Snyder DATE: 1/6/82

ENGINEERING REPORT

Attachment 1 for EQS-439-01D

DATE OF TEST ---

MANUFACTURER'S
ORDER NO. 9-129576

PURCHASER Long Island Lighting Co.

PURCHASER'S
ORDER NO. 310950

STATIC RECTIFIER CONTROL BOARD CIRCUIT

- A. Diodes: "General Electric" Part No. IN1190 (Forward) and IN1190R (Reverse)
- B. Insulated Diode Support: Canvas Base Phenolic
- C. Cable: Aramid
- D. Resistors:
 - 1. 10 OHM - "OHMITE" Type 210
 - 2. 21 OHM (^{25 Watt}_{Tapped}) - "Milwaukee Resistor Corp."
- E. Terminal Board: General Purpose Black Phenolic
- F. Poly Crystalline Varistor: "General Electric" Part No. V320LA40B

Notes:

1. 4.17×10^6 RADS based on limiting component (Poly Crystalline Varistor)
2. Refer to item 25, para J, pg 29 of test report for data giving basis for 109°F (43°C) ambient temp
3. The effects of radiation on the diodes, resistors and Poly Crystalline Varistor is addressed by ~~the report in~~ Wyle Laboratories report 17464-3901

Written By:

M. J. Shaver

Sheet 1 of 1



LOUIS ALLIS

Lifton

APPROVED BY

L. Roy M. Paris

CODE IDENT NO

DOCUMENT NUMBER

DATE

5-15-81

01425

SECTION G-4

7/01 3016 H 3106 10/7

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 439-01E
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE 480V Motor Generator Set
 SPEC. NO. 439 P.O. 310950 VENDOR Louis Allis
 TEST ITEM DESC. Rotating Field Clamping
 MAKE See Attachment 1 MODEL See Attachment 1
 VENDOR TEST REPORT NO. Louis Allis 9-129576
 APPLICABLE STANDARDS _____ TEST REPORT NO. 439-01
 IEEE 323-1974 TEST METHOD Test/Analysis
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: N/A All test were performed independently)

- | | |
|----------|-----------|
| 1. _____ | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: N/A DBA test not required)

APPLICABLE ENV. ZONES

TIME _____

RAD N

TEMP. °F _____

PRES. PSIG _____

T/P 21

R.H. N/A

OP. TIME DEMO N/A

ACC/PERF DEMO N/A

RADIATION AGING (R: Section M)

THERMAL AGING (R: Section M)

* See note 1 on attachment 1

DOSE RATE Not Given RAD/HR

AGED TO SIMULATED

LIFE OF N/A YRS.

DOSE PRIOR TO ENV. TEST N/A RADS

BASED ON AMBIENT

TEMP OF * 109 °F

DOSE DURING ENV. TEST N/A RADS

AGING TEMP./

DURATION N/A / N/A

TOTAL DOSE 2x10⁷ RADS

REL. HUMIDITY N/A

CYCLE AGING (R: Not Required)

NOT AGED-JUSTIFIED

BY ANALYSIS TO 40 YRS.

CYCLES REQUIRED _____

CYCLES PERFORMED _____
(Electro-Mechanical Equip. only)

* See note note 2 on attachment 1

REVIEWER: Ron M Snyder

DATE: 6-25-81

ENGINEERING REPORT Attachment. 1 for EQS-439-01E

DATE OF TEST ---
MANUFACTURER'S ORDER NO. 9-129576
PURCHASER'S ORDER NO. 310950

PURCHASER Long Island Lighting Co.

ROTATING FIELD CLAMPING


- A. Coil Clamps: Canvas Base Phenolic
- B. Bolt Insulation: Polyimide Resin Coated Glass

Notes:

1. 2×10^7 RADS based on limiting component (Coil Clamps)
2. Refer to item 25, para. K, pg 34, of test report for data giving basis for 109°F (43°C) ambient temp.

Written By M. J. Shaver

Sheet 1 of 1



APPROVED BY [Signature]
DATE 5-15-81

CCDE IDENT. NO. 01425

DOCUMENT NUMBER
SECTION G-5

M 3185 10/79

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 439-02 Rev 1
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE 480 Volt Motor Generator Sets
 SPEC. NO. 439 P.O. 310950 VENDOR Louis Allis Inc.
 TEST ITEM DESC. Motor Control Panel for 480V MG Set
 MAKE Gould MODEL 5600 Series
 VENDOR TEST REPORT NO. CC-323.74-83 Rev 0
 APPLICABLE STANDARDS _____ TEST REPORT NO. 439-02
 IEEE 323-1974 TEST METHOD Summary Report
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ provided the information requested on
 NUREG 0588 CAT. I EQREF 439-02 is provided
 QUALIFIED LIFE See Attachment

TEST SEQUENCE (R: N/A)
 1. _____ 6. _____
 2. _____ 7. _____
 3. _____ 8. _____
 4. _____ 9. _____
 5. _____ 10. _____

TEST ENVIRONMENT (R: <u>N/A, DBA test not required</u>)	APPLICABLE ENV. ZONES
TIME _____	RAD <u>N</u>
TEMP. °F _____	T/P <u>21</u>
PRES. PSIG _____	
R.H. <u>N/A</u>	
OP. TIME DEMO <u>N/A</u> ACC/PERF DEMO <u>N/A</u>	

RADIATION AGING (R: Page 7)
 DOSE RATE See Attachment RAD/HR
 DOSE PRIOR TO ENV. TEST N/A RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE See Attachment RADS

THERMAL AGING (R: Page 7)
 AGED TO SIMULATED LIFE OF See Attachment YRS.
 BASED ON AMBIENT TEMP OF See Attachment °F
 AGING TEMP./DURATION See Attachment
 REL. HUMIDITY See Attachment

CYCLE AGING (R: Page 7)
 CYCLES REQUIRED _____
 CYCLES PERFORMED See Attachment
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO See Attachment YRS.

REVIEWER: Ross M. Snyder DATE: 1/5/82

Attachment to EC S 439-02

SEP / 1981

No.	Item	Cycle, Aging	Radiation Total Dose	Aging Simulated Yrs at °F	Aging Temp/Duration
1.	Cabinet Structure (MGS)	N/A	1×10^8 RADS	40 yrs at 122°	230°F / 670.1 HRS
2.	Relay (86) HEA	Not performed	1×10^5 RADS	Not determined	—
3.	Relay (74) 7024	27,500	2×10^5 RADS	10 yrs at 70°-104°	212°F / 42 DYS
4.	Circuit Breaker KM	4000	1×10^7 RADS	10 yrs at 104°	212°F / 1074 HRS
5.	Contactors S/S A103G	1×10^6	1×10^7 RADS	10 yrs at 104°	212°F / 1074 HRS
6.	Terminal BIK. EB-25	N/A	1×10^8 RADS	40 yrs at 104°	Analysis.
7.	Relay (59) NGV	Not performed	1×10^5 RADS	40 yrs at 104°	Analysis
8.	Current Transformer JCS-O	N/A	1×10^7 RADS	40 yrs at 140°	212°F / 26 weeks
9.	Potential Transformer JVA-O	N/A	1×10^7 RADS	40 yrs at 140°	212°F / 26 weeks
10.	Relay (87) HFC	Not performed	1×10^5 RADS	40 yrs at 104°	Analysis
11.	Switch (43) C77	50,000	1×10^6 RADS	40 yrs at 104°	Analysis
12.	Switch (CCS) H33	1.2×10^4	1×10^6 RADS	40 yrs at 104°	230°F / 808.7 HRS
13.	Control Transformer 750 VA	N/A	1×10^9 RADS	40 yrs at 104°	Analysis
14.	Fuse (Form 600) A6Y	N/A	1×10^7 RADS	10 yrs at 104°	212°F / 1074 HRS
15.	Control Wire Vulkene Supreme	N/A	2.2×10^8	40 yrs at 194°	329°F / 125 HRS
16.	Power Wire Okalon	N/A	2×10^8 RADS	40 yrs at 194°	302° / 21 DYS

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 455-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Low Capacitance Fire Resistant Instrument Cable
 SPEC. NO. 455 P.O. 310965 VENDOR Brand Rex Co.
 TEST ITEM DESC. Coaxial Instrument Cable, XPLE insulation
 MAKE Brand Rex Co. MODEL RG-11A/u ; RG-59 B/u
 VENDOR TEST REPORT NO. F-C5120-2 (Brand Rex Co./Franklin Research Ctr.)
 APPLICABLE STANDARDS TEST REPORT NO. 455-01
 IEEE 323-1974 TEST METHOD Sequential Test/Analysis
 IEEE 323-1974 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: Section 4, pages 4.1 thru 4.4)

- | | |
|---|---|
| 1. <u>Functional Test</u> | 6. <u>Final Inspection</u> |
| 2. <u>Thermal Aging</u> | 7. <u>High Potential Withstand Test</u> |
| 3. <u>Insulation Resistance Check</u> | 8. _____ |
| 4. <u>Gamma Irradiation</u> | 9. _____ |
| 5. <u>Steam/Chemical Spray Exposure</u> | 10. _____ |

TEST ENVIRONMENT (R: Page 4.3 *EOREF 455-01 ^{page 4} comment 3)

APPLICABLE ENV. ZONES

TIME HRS	.2	2.8	.2	2.8	4.9	19.2	47.4	RAD	<u>A4</u>
TEMP. °F	385	346	385	346	317	280	230		
PRES. PSIG	66	113	66	113	70	35	10	T/P	<u>A4</u>
R.H. (SPRAY)	<u>100</u>								
OP. TIME DEMO	<u>180 Days*</u>				ACC/PERF DEMO	<u>N/A</u>			

RADIATION AGING (R: Page 4.1, & App B)

THERMAL AGING (R: Pages 4.1, 5.1, & Attach 1)

DOSE RATE 6.3×10^{-5} RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^8 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 2×10^8 RADS

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 194 °F
 AGING TEMP./ DURATION 277° / 168 HRS

CYCLE AGING (R: Not Required)

REL. HUMIDITY Uncontrolled
 NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

REVIEWER: Ron M Snyder

DATE: 4/5/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 456-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Reactor Containment Electrical Penetrations
 SPEC. NO. 456 P.O. 310967 VENDOR Conax Corporation
 TEST ITEM DESC. Instrument Penetration Assembly
 MAKE Conax MODEL Instrument Penetration Assembly
 VENDOR TEST REPORT NO. IPS-583
 APPLICABLE STANDARDS TEST REPORT NO. 456-01
 IEEE 317-1976 TEST METHOD Sequential Test, Analysis
 IEEE 323-1974 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: Table 4.2, page 5; Figure 4.1 page 5A)

- | | |
|----------------------------------|-----------------------------------|
| 1. <u>Design Validation Test</u> | 6. <u>Validation Tests</u> |
| 2. <u>Storage Simulation</u> | 7. <u>Seismic Tests</u> |
| 3. <u>Thermal Cycle</u> | 8. <u>Validation Tests</u> |
| 4. <u>Thermal Aging</u> | 9. <u>Design Basis Event Test</u> |
| 5. <u>Radiation Exposure</u> | 10. <u>Validation Tests</u> |

TEST ENVIRONMENT (R: Section 5.8, pg 17, Fig 5.8.1 pg 13A)

TIME	<u>1 Min. Transient</u>	<u>10 min</u>	<u>1.8 HRS</u>	<u>6 HRS</u>	<u>4 HRS</u>	<u>343 HRS</u>
TEMP. °F	<u>375° Peak temp</u>	<u>320°</u>	<u>350°</u>	<u>340°</u>	<u>320°</u>	<u>300°</u>
PRES. PSIG	<u>30</u>	<u>-</u>	<u>78</u>	<u>70</u>	<u>35</u>	<u>35</u>
R.H.	<u>100 %</u>					
OP. TIME DEMO	<u>1 year</u>		ACC/PERF DEMO	<u>N/A</u>		

APPLICABLE ENV. ZONES

RAD D, G, H
T/P 10, 11, 22

RADIATION AGING (R: Sec. 5.6.1 para 5)

DOSE RATE 7.7×10^5 RAD/HR
 DOSE PRIOR TO ENV. TEST 1.8×10^3 RADS
 DOSE DURING ENV. TEST N/A RADS
 TOTAL DOSE 1.8×10^8 RADS

THERMAL AGING (R: Section 5.6.2.3 page 10)

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 248 °F
 AGING TEMP./DURATION 302° F / 100 HRS

CYCLE AGING (R: Sec 5.6.1 para 3, pg 7)

CYCLES REQUIRED 120
 CYCLES PERFORMED 120
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Not Controlled
 NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

* Thermal Cycle test required by IEEE 317

REVIEWER: Russ M. [Signature]

DATE: 4/23/91

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 456-02
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Reactor Containment Electrical Penetrations
 SPEC. NO. 456 P.O. 310967 VENDOR Conax Corporation
 TEST ITEM DESC. Penetration Adapter Module
 MAKE Conax MODEL Viton "A" 2-Ring Seal
 VENDOR TEST REPORT NO. IPS-631
 APPLICABLE STANDARDS TEST REPORT NO. 456-02
 IEEE 317-1976 TEST METHOD Sequential Test
 IEEE 323-1974 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: Figure 3.3 page 3)

- | | |
|------------------------------|---|
| 1. <u>Gas Leak Rate Test</u> | 6. <u>Irradiation *</u> |
| 2. <u>Thermal Cycling</u> | 7. <u>Seismic *</u> |
| 3. <u>Storage Simulation</u> | 8. <u>DBE Environmental Test *</u> |
| 4. <u>Age Conditioning *</u> | 9. <u>(* Evaluation Test performed</u> |
| 5. <u>Shipping</u> | 10. <u>after that phase of testing)</u> |

TEST ENVIRONMENT (R: Fig 6.10.2, page 11A)

TIME	<u>2 min</u>	<u>1 min</u>	<u>7 min</u>	<u>6 HRS</u>	<u>425 HRS</u>
TEMP. °F	<u>300°</u>	<u>350°</u>	<u>360°</u>	<u>350°</u>	<u>266°</u>
PRES. PSIG	<u>55</u>	<u>55</u>	<u>55</u>	<u>55</u>	<u>25</u>
R.H.	<u>100 %</u>				
OP. TIME DEMO	<u>180 Days</u>		ACC/PERF DEMO	<u>N/A</u>	

APPLICABLE ENV. ZONES

RAD D, G, H
 T/P 10, 11, 22

RADIATION AGING (R: Section 6.6 pg 7)

DOSE RATE 1.5×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 1.5×10^8 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 1.5×10^8 RADS

THERMAL AGING (R: Section 6.4 pg 6 and Attachment 1)

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 161 °F
 AGING TEMP./DURATION 302° / 168 HRS
 REL. HUMIDITY Uncontrolled %

CYCLE AGING (R: Section 6.3 pg 6)

CYCLES REQUIRED 120
 CYCLES PERFORMED 120
 (Electro-Mechanical Equip. only)
 Thermal Cycle test required by IEEE 317

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

REVIEWER: Ron M. Albrecht

DATE: 7/27/81

B

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 15.54-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Safety Related Solenoid Valves
 SPEC. NO. 15.54 P.O. 310979 VENDOR Valcor Engineering Corp
 TEST ITEM DESC. Solenoid Valve
 MAKE Valcor MODEL V52600-515
 VENDOR TEST REPORT NO. QR 52600-5940-2
 APPLICABLE STANDARDS TEST REPORT NO. 15.54-01
 IEEE 323-1974 TEST METHOD Sequential Test/Analysis
 IEEE _____ DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____
 NUREG 0588 CAT. I QUALIFIED LIFE 40 years

TEST SEQUENCE (R: Appendix VII page 4.5)

- | | |
|---|--|
| 1. <u>Initial Acceptance Test</u> | 6. <u>Seismic Simulation/Acceptance Test</u> |
| 2. <u>Thermal Aging/Acceptance Test</u> | 7. <u>LOCA Test/Acceptance Test</u> |
| 3. <u>Cyclic Aging/Acceptance Test</u> | 8. <u>Disassembly and Inspection</u> |
| 4. <u>Radiation</u> | 9. _____ |
| 5. <u>Dielectric and Insulation Resist.</u> | 10. _____ |

TEST ENVIRONMENT (R: App IV of App XII page 4-16)
* R: App XII Sec 4.2.6, page 30, Wyle Report 17464-4802

TIME	2 HRS	2 HRS	2 HRS	3 HRS	4 HRS	8 HRS	25 DYS
TEMP. °F	346	140	346	335	315	265	245
PRES. PSIG	113		113	95	69	28	13
R.H.	<u>100</u>						
OP. TIME DEMO	<u>1 year</u>			ACC/PERF DEMO	<u>N/A</u>		

APPLICABLE ENV. ZONES
 RAD G
 T/P 1, 2, 9, 10, 12

RADIATION AGING (R: App XII Sec 4.2.4)
App III & App XII

DOSE RATE 7.5×10^5 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^8 RADS
 DOSE DURING ENV. TEST None RADS
 TOTAL DOSE 2×10^8 RADS

THERMAL AGING (R: App XII Sec 4.2.2)
Wyle Report 17464-4802

AGED TO SIMULATED LIFE OF 40 YRS.
 BASED ON AMBIENT TEMP OF 120 °F
 AGING TEMP./DURATION 313°F / 172 HRS

CYCLE AGING (R: App XII Sec 4.2.3)

CYCLES REQUIRED _____
 CYCLES PERFORMED 7500
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Not Addressed

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

REVIEWER: Ron M. Snyder

DATE: 8/17/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 88AD-01
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Carbon Steel Valve MOV
 SPEC. NO. SHI-88ADP.O.310512 VENDOR Velan
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL AC5MB-0-25 Reliance Class BH
 VENDOR TEST REPORT NO. 80058 + App B - 600376A
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE - 323-71 TEST METHOD Sequential Testing
 IEEE - 382-72 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ See comments + special conditions
 NUREG 0588 CAT. II EQREF-88V-1
 QUALIFIED LIFE > 40yrs

TEST SEQUENCE (R: pp 3-5 (600376A))

- | | |
|---------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Seismic Qualification</u> | 9. _____ |
| 5. <u>Accident Simulation</u> | 10. _____ |

TEST ENVIRONMENT (R: Franklin Institute Report; FC3441)
pg 3-5

APPLICABLE ENV. ZONES

TIME	0-3hr	3-6hr	6-9hr	9-12hr	12-13hr	13hr-30days	RAD
TEMP. °F	340	<u>cool</u>	340	320	320-252	251	<u>D, G</u>
PRES. PSIG	105	<u>down</u>	105	77	19	15	T/P <u>3, 22</u>
R.H.	<u>100</u>						
OP. TIME DEMO	<u>30 days</u>						ACC/PERF DEMO _____

RADIATION AGING (R: pg 4 (600376A))

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 204×10^6 RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 204×10^6 RADS

THERMAL AGING (R: pg 3, (80058-pg 10, 11))

Only the motor stator aged
 AGED TO SIMULATED LIFE OF 48 YRS.
 BASED ON AMBIENT TEMP OF 158 °F
 AGING TEMP./ DURATION 180°C / 100 HRS

CYCLE AGING (R: pg 3, 4 (600376A))

CYCLES REQUIRED 500
 CYCLES PERFORMED 500
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Not Given
 ACTUATOR
 NOT AGED-JUSTIFIED BY ANALYSIS TO > 40 YRS.
 Equip. age at 158°F is determined by proportioning to thermal life figures given in 80058

REVIEWER: Gene W. Smith

DATE: 11/30/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 88AD-02
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Carbon Steel Valve MOV
 SPEC. NO. SHI-88AD P.O. 310501 VENDOR Anchor Darling
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL MOTOR+ACTUATOR-SMB-0-25
 VENDOR TEST REPORT NO. B0058+AppD-80003 MOTORS (ALONE)-25+40 ft-lb start torq,
Reliance, AC, class B [ALL MOTORS]
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE - 382-1972 TEST METHOD Sequential Testing
 IEEE - 323-1971 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ See comments + special
 NUREG 0588 CAT. II conditions - EQ REF-88V-3
 QUALIFIED LIFE 40 yrs

- TEST SEQUENCE (R: pg 7-10 (80003))
1. Thermal Aging 6. _____
 2. Mechanical Aging 7. _____
 3. Radiation Aging 8. _____
 4. Seismic Aging 9. _____
 5. Environmental Test 10. _____

TEST ENVIRONMENT (R: pg 10 (80003))

TIME	<u>0-.5hr</u>	<u>.5-2hr</u>	<u>2-24hr</u>	<u>24-25hr</u>	<u>25hr-16days</u>	APPLICABLE ENV. ZONES RAD <u>T,G</u> T/P <u>1,2,3,7,10</u> <u>11,12</u>
TEMP. °F	<u>250</u>	<u>250+20</u>	<u>250</u>	<u>250-200</u>	<u>200</u>	
PRES. PSIG	<u>25</u>	<u>-</u>	<u>25</u>	<u>-</u>	<u>10</u>	
R.H. %	<u>100</u>	<u>*</u>	<u>*</u>	<u>*</u>	<u>*</u>	
OP. TIME DEMO	<u>16 days</u>					

RADIATION AGING (R: pg 8 (80003))

DOSE RATE 1×10^6 RAD/HR

DOSE PRIOR TO ENV. TEST 2×10^7 RADS

DOSE DURING ENV. TEST _____ RADS

TOTAL DOSE 2×10^7 RADS

THERMAL AGING (R: pg 7 (80003) (80058-p12))

AGED TO SIMULATED LIFE OF 232 days

BASED ON AMBIENT TEMP OF 104 °F

AGING TEMP./ DURATION 165 °F / 200 [199.8] HRS

REL. HUMIDITY 100 %

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.
[pg 12-15 80058]
Equiv. Age at 104°F obtained by proportioning to thermal life figures

CYCLE AGING (R: pg 7-8 (80003))

CYCLES REQUIRED 500

CYCLES PERFORMED 7993
(Electro-Mechanical Equip. only)

REVIEWER: Gene W. Smith DATE: 12/11/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 88V-01
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Carbon Steel Valve - MOV
 SPEC. NO. SH-88V P.O. 310502 VENDOR Velan
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL AC15MB-0-25 Reliance Class BH
 VENDOR TEST REPORT NO. 80058 + App B - 600376A
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE - 323-71 TEST METHOD Sequential Testing
 IEEE - 382-72 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ See comments + special conditions
 NUREG 0588 CAT. II EQREF-88V-1
 QUALIFIED LIFE > 40 yrs

TEST SEQUENCE (R: pp 3-5 (600376A))

- | | |
|---------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Seismic Qualification</u> | 9. _____ |
| 5. <u>Accident Simulation</u> | 10. _____ |

TEST ENVIRONMENT (R: Franklin Institute Report; FC3441)
pg 3-5

APPLICABLE ENV. ZONES

TIME	0-3hr	3-6hr	6-9hr	9-12hr	12-13hr	13hr-30 days
TEMP. °F	340	<u>Con</u>	340	320	320-252	251
PRES. PSIG	105	<u>Down</u>	105	77	19	15
R.H.	<u>100</u>					
OP. TIME DEMO	<u>30 days</u>					
ACC/PERF DEMO	_____					

RAD B, C, D, G, K, L

T/P 1, 2, 3, 5, 7, 15
22

RADIATION AGING (R: pg 4 (600376A))

THERMAL AGING (R: pg 3, (80058-pg 10, 11))

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 204×10^6 RADS
 DOSE DURING ENV. TEST — RADS
 TOTAL DOSE 204×10^6 RADS

Only the motor/stator aged
 AGED TO SIMULATED LIFE OF 48 YRS.

BASED ON AMBIENT TEMP OF 158 °F

AGING TEMP./ DURATION 180°C / 100 HRS

CYCLE AGING (R: pg 3, 4 (600376A))

REL. HUMIDITY Not Given

CYCLES REQUIRED 500
 CYCLES PERFORMED 500
 (Electro-Mechanical Equip. only)

Actuator
 NOT AGED-JUSTIFIED BY ANALYSIS TO > 40 YRS.

Equip. age at 158°F is determined by proportioning to thermal life figures given in 80058

REVIEWER Jim W. Smith

DATE: 11/30/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 88V-02
SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE CARBON STEEL MOTOR OPERATED VALVES
 SPEC. NO. SH-88V P.O. 310502 VENDOR VELAN
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL SMB-0-25 Reliance, DC, class H
 VENDOR TEST REPORT NO. B0058 + App E - B0009
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE - 382-72 TEST METHOD Sequential Testing
 IEEE - 323-71 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE - See comments and special
conditions EQREF-88V-2
 NUREG 0588 CAT. II QUALIFIED LIFE 240 yrs

TEST SEQUENCE (R: pg. 6-9 (B0009))

- | | |
|------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Seismic Testing</u> | 9. _____ |
| 5. <u>Environmental Test</u> | 10. _____ |

TEST ENVIRONMENT (R: pg. 10 (B0009))

TIME	<u>0-1hr</u>	<u>1-2hr</u>	<u>2-4hr</u>	<u>4-7hr</u>	<u>7-25hrs</u>
TEMP. °F	<u>120-340</u>	<u>340</u>	<u>330</u>	<u>310</u>	<u>212</u>
PRES. PSIG	<u>0-68</u>	<u>68-104</u>	<u>104-86</u>	<u>86-63</u>	<u>0</u>
R.H.	<u>100</u>				
OP. TIME DEMO	<u>25 hrs</u>		ACC/PERF DEMO _____		

APPLICABLE ENV. ZONES
 RAD _____
 T/P _____

RADIATION AGING (R: pg 7 (B0009))

DOSE RATE _____ RAD/HR
 DOSE PRIOR TO ENV. TEST 1x10⁷ RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 1x10⁷ RADS

THERMAL AGING (R: pg. 6 + App III (B0009))

Motor Stator Only
 AGED TO SIMULATED LIFE OF 135 YRS.
 BASED ON AMBIENT TEMP OF 140 (60°C) °F
 AGING TEMP./ DURATION 180°C / 100

CYCLE AGING (R: pg 7 (B0009))

CYCLES REQUIRED 500
 CYCLES PERFORMED 2004
 (Electro-Mechanical Equip. only)

REL. HUMIDITY Not Given
 Actuator
 NOT AGED - JUSTIFIED BY ANALYSIS TO 40 YRS. [B0058 pg 13-15]
 Equiv. Age derived by proportioning to thermal life figures [pg 10-11 B0058]

REVIEWER: Jim W. Smith DATE: 12/1/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 88V-03
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE Carbon Steel Valve - MOV
 SPEC. NO. SHI-88V P.O. 310502 VENDOR Velan
 TEST ITEM DESC. Limitorque MOV
 MAKE Limitorque MODEL MOTOR+ACTUATOR-SMB-0-25
 VENDOR TEST REPORT NO. B0058+AppD-B0003 MOTORS (ALONET- 25+40 ft-lb start torq
 APPLICABLE STANDARDS TEST REPORT NO. Reliance, AC class B [ALL MOTORS]
 IEEE - 382-1972 TEST METHOD Sequential Testing
 IEEE - 323-1971 DOCUMENTATION ACCEPTABILITY Acceptable
 IEEE _____ See comments + special
 NUREG 0586 CAT. II conditions - EQREF-88V-3
 QUALIFIED LIFE 40 yrs

TEST SEQUENCE (R: pg 7-10 (B0003))

- | | |
|------------------------------|-----------|
| 1. <u>Thermal Aging</u> | 6. _____ |
| 2. <u>Mechanical Aging</u> | 7. _____ |
| 3. <u>Radiation Aging</u> | 8. _____ |
| 4. <u>Siismic Aging</u> | 9. _____ |
| 5. <u>Environmental Test</u> | 10. _____ |

TEST ENVIRONMENT (R: pg 10 (B0003))

TIME	<u>0-.5hr</u>	<u>.5-2hr</u>	<u>2-24hr</u>	<u>24-25hr</u>	<u>25hr-16days</u>
TEMP. °F	<u>250</u>	<u>250+120</u>	<u>250</u>	<u>250-200</u>	<u>200</u>
PRES. PSIG	<u>25</u>	<u>-</u>	<u>25</u>	<u>-</u>	<u>10</u>
R.H.	<u>100</u>	<u>*</u>	<u>*</u>	<u>*</u>	<u>*</u>
OP. TIME DEMO	<u>16 days</u>				
ACC/PERF DEMO	_____				

APPLICABLE ENV. ZONES
 RAD G, H, L, N, P
 T/P 1, 2, 3, 7, 9, 10, 12, 14, 18

RADIATION AGING (R: pg 8 (B0003))

DOSE RATE 1 x 10⁶ RAD/HR
 DOSE PRIOR TO ENV. TEST 2 x 10⁷ RADS
 DOSE DURING ENV. TEST _____ RADS
 TOTAL DOSE 2 x 10⁷ RADS

THERMAL AGING (R: pg 7 (B0003) (B0058-p12))

AGED TO SIMULATED LIFE OF 232 days
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION 165° / 200 [199.8] hrs
 REL. HUMIDITY 100 %

CYCLE AGING (R: pg 7-8 (B0003))

CYCLES REQUIRED 500
 CYCLES PERFORMED 1993
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.
[pg 12-15 B0058]
 Equiv. Age at 104°F obtained by proportioning to thermal life figures

REVIEWER: Gene W. Smith

DATE: 12/3/81

SPEC. TITLE _____
 SPEC. NO. SHI-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. PRESSURE SWITCH
 MAKE BARKSDALE MODEL BLT
 VENDOR TEST REPORT NO. BARKSDALE PROCEDURE 9993
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3018-A
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 6 YRS BY ANALYSIS

TEST SEQUENCE (R: BARKSDALE - 9993)

- | | |
|----------------------------|-----------|
| 1. <u>FUNCTIONAL</u> | 6. _____ |
| 2. <u>STEAM/FUNCTIONAL</u> | 7. _____ |
| 3. <u>FUNCTIONAL</u> | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: BARKSDALE-9993)

TIME 6 HRS
 TEMP. °F 212
 PRES. PSIG .25
 R.H. 100%
 OP. TIME DEMO 6 HRS ACC/PERF DEMO 2.3% FSPE

APPLICABLE ENV. ZONES

RAD 6
 T/P 1

RADIATION AGING (R: EDS Calc No 0630-001-013)

DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 3 x 10⁶ BY ANALYSIS RADS

THERMAL AGING (R: EDS Calc No 0630-001-013)

AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION NONE

CYCLE AGING (R: BARKSDALE 9993)

CYCLES REQUIRED UNDETERMINED
 CYCLES PERFORMED 12
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NONE
 NOT AGED-JUSTIFIED BY ANALYSIS TO 6 YRS.

REVIEWER: [Signature]

DATE: 12/31/3

SPEC. TITLE _____
 SPEC. NO. SH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. PRESSURE SWITCH
 MAKE BARKSDALE MODEL D2H
 VENDOR TEST REPORT NO. BARKSDALE PROCEDURE 9993
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3021-A
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 6 YRS BY ANALYSIS

TEST SEQUENCE (R: BARKSDALE 9993)

- | | |
|-----------------------------------|-----------|
| 1. <u>FUNCTIONAL</u> | 6. _____ |
| 2. <u>STEAM / FUNCTIONAL TEST</u> | 7. _____ |
| 3. <u>FUNCTIONAL TEST</u> | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: BARKSDALE 9993)

TIME 6 HRS
 TEMP. °F 212
 PRES. PSIG .25
 R.H. 100%
 OP. TIME DEMO 6 Hrs ACC/PERF DEMO 1.6% PSPS

APPLICABLE ENV. ZONES

RAD G.H
 T/P 1, 10, 12

RADIATION AGING (R: EDS Calc No 0630-001-013)

DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 3 x 10⁶ By Analysis RADS

THERMAL AGING (R: EDS Calc No 0630-001-014)

AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION NONE
 REL. HUMIDITY NONE %

CYCLE AGING (R: BARKSDALE 9993)

CYCLES REQUIRED UNDETERMINED
 CYCLES PERFORMED 12
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 6 YRS.

REVIEWER: [Signature]

DATE: 12/1/81

SPEC. TITLE _____
 SPEC. NO. SH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. PRESSURE SWITCH
 MAKE BARKSDALE MODEL PIH
 VENDOR TEST REPORT NO. BARKSDALE PROCEDURE 9993
 APPLICABLE STANDARDS TEST REPORT NO. 3025-H
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 6 YEARS BY ANALYSIS

TEST SEQUENCE (R: BARKSDALE 9993)

- | | |
|------------------------------------|-----------|
| 1. <u>FUNCTIONAL</u> | 6. _____ |
| 2. <u>STEADY / FUNCTIONAL TEST</u> | 7. _____ |
| 3. <u>FUNCTIONAL</u> | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: BARKSDALE - 9993)

TIME 6 HRS
 TEMP. °F 212°F
 PRES. PSIG .25
 R.H. 100%
 OP. TIME DEMO 6 HRS ACC/PERF DEMO 1.9% FSPE

APPLICABLE ENV. ZONES

RAD 6
 T/P 1

RADIATION AGING (R: EDS CALL NO 0630-001-022)

DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 5 x 10⁶ BY ANALYSIS RADS

THERMAL AGING (R: EDS CALL NO 0630-001-022)

AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF 104°F °F
 AGING TEMP./ DURATION NONE
 REL. HUMIDITY NONE %

CYCLE AGING (R: DELAVAL 9993)

CYCLES REQUIRED UNDETERMINED
 CYCLES PERFORMED 12
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 6 YRS.

REVIEWER: Steve Paul

DATE: 12/31/81

SPEC. TITLE _____
 SPEC. NO. SA-003 P.O. 30010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. DIFFERENTIAL PRESSURE INDICATING SWITCH
 MAKE ITT BARTON MODEL 288A/289A
 VENDOR TEST REPORT NO. ITT BARTON 9999.1217.2 AND R3-288A-1
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3027-A & 3027B
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. I QUALIFIED LIFE 40 YEARS BY ANALYSIS

TEST SEQUENCE (R: SEE BELOW)
ITT BARTON 9999.1217.2 ITT BARTON R3-288A-1
 1. FUNCTIONAL TEST (CALIBRATION) 1 INSPECTION 6 FUNCTIONAL TEST
 2. STEAM TEST 2 FUNCTIONAL TEST
 3. FUNCTIONAL TEST (CALIBRATION) 3 RADIATION
 4. _____ 4 FUNCTIONAL TEST
 5. _____ 5 SEISMIC

TEST ENVIRONMENT (R: ITT BARTON 9999.1217.2)
 TIME 6 HRS RAD G, H
 TEMP. °F 212 °F
 PRES. PSIG 7 IN WC T/P 1, 2, 10, 12
 R.H. 100%
 OP. TIME DEMO 6 HRS ACC/PERF DEMO ± 1%

RADIATION AGING (R: BARTON R3-288A-1)
EDS Calc No 0630-001-010
 DOSE RATE 1x10⁶ RAD/HR
 DOSE PRIOR TO ENV. TEST 3x10⁶ RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 3x10⁶ BY TEST / 1x10⁷ BY ANALYSIS RADS

THERMAL AGING (R: EDS Calc No 0630-001-010)
 AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION NONE
 REL. HUMIDITY NONE

CYCLE AGING (R: BARTON R3-288A-1)
 CYCLES REQUIRED UNDETERMINED
 CYCLES PERFORMED 36
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.

REVIEWER: Steve Paul DATE: 1/11/82

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 3032 Revision 0
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE _____
 SPEC. NO. SH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. PRESSURE SWITCH
 MAKE STATIC-O-RING MODEL 5N(GN) SERIES
 VENDOR TEST REPORT NO. VIKING LABORATORIES TEST LETTER REPORT No 30203-1
 APPLICABLE STANDARDS TEST REPORT NO. 3032-A
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE (LATER)

TEST SEQUENCE (R: VIKING: 30203-1)

- | | |
|---|-----------|
| 1. <u>FUNCTIONAL</u> | 6. _____ |
| 2. <u>PRESSURE/TEMPERATURE/HUMIDITY</u> | 7. _____ |
| 3. <u>INSPECTION</u> | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: VIKING: 30203-1)

	(MIDRANGE)	(HIGH RANGE)	(LOW RANGE)
TIME	<u>6 HRS</u>	<u>6 HRS</u>	<u>6 HRS</u>
TEMP. °F	<u>212°F</u>	<u>212°F</u>	<u>212°F</u>
PRES. PSIG	<u>.25 ± .05 PSIG</u>	<u>.25 ± .05 PSIG</u>	<u>.25 ± .05 PSIG</u>
R.H.	<u>100%</u>		
OP. TIME DEMO	<u>18 HRS</u>	ACC/PERF DEMO <u>NONE REPORTED</u>	

APPLICABLE ENV. ZONES

RAD GL

T/P 1,2

RADIATION AGING (R: _____)

DOSE RATE NONE RAD/HR

DOSE PRIOR TO ENV. TEST NONE RADS

DOSE DURING ENV. TEST NONE RADS

TOTAL DOSE (LATER) RADS

THERMAL AGING (R: _____)

AGED TO SIMULATED LIFE OF NONE YRS.

BASED ON AMBIENT TEMP OF 104 °F

AGING TEMP./DURATION NONE

REL. HUMIDITY NONE

CYCLE AGING (R: VIKING: 3023-1)

CYCLES REQUIRED UNDETERMINED

CYCLES PERFORMED 27
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO (LATER) YRS.

REVIEWER: Wayne P. Swain DATE: 2/21/81

ENVIRONMENTAL QUALIFICATION SUMMARY NO. 3037 Revision 0
 SHOREHAM NUCLEAR POWER STATION-UNIT 1

SPEC. TITLE _____
 SPEC. NO. CH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. REMOTE LEVEL INDICATOR
 MAKE YARWAY MODEL 4418C
 VENDOR TEST REPORT NO. YARWAY TEST REPORT NO. 5628-3509
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3037-A
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____
 NUREG 0588 CAT. II QUALIFIED LIFE 12 YRS BY ANALYSIS
 (SEE BELOW)

TEST SEQUENCE (R: YARWAY: 5628-3509)

1. <u>SEISMIC</u>	6. _____
2. <u>TEMPERATURE - HUMIDITY</u>	7. _____
3. _____	8. _____
4. _____	9. _____
5. _____	10. _____

TEST ENVIRONMENT (R: <u>YARWAY: 5628-3509</u>)								APPLICABLE ENV. ZONES
TIME	30 min	30 min	30 min	30 min	30 min	30 min	30 min	RAD <u>G</u>
TEMP. °F	156	212	235	250	235	212	156	T/P <u>12, 12</u>
PRES. PSIG	—	—	—	—	—	—	—	
R.H.	<u>~ 100</u>							
OP. TIME DEMO	<u>3.5 Hrs</u>			ACC/PERF DEMO	<u>4%</u>			

<p>RADIATION AGING (R: <u>503 GEC No. 060-02-01</u>)</p> <p>DOSE RATE <u>NONE</u> RAD/HR</p> <p>DOSE PRIOR TO ENV. TEST <u>NONE</u> RADS</p> <p>DOSE DURING ENV. TEST <u>NONE</u> RADS</p> <p>TOTAL DOSE <u>1 x 10⁶ By Analysis</u> RADS</p>	<p>THERMAL AGING (R: <u>515 AC 10 600-001-016</u>)</p> <p>AGED TO SIMULATED LIFE OF <u>NONE</u> YRS.</p> <p>BASED ON AMBIENT TEMP OF <u>104</u> °F</p> <p>AGING TEMP./ DURATION <u>NONE</u></p>
---	---

<p>CYCLE AGING (R: <u>YARWAY: 5628-3509</u>)</p> <p>CYCLES REQUIRED <u>UNDETERMINED</u></p> <p>CYCLES PERFORMED <u>100</u> (Electro-Mechanical Equip. only)</p>	<p>REL. HUMIDITY <u>NONE</u></p> <p>NOT AGED-JUSTIFIED BY ANALYSIS TO <u>6</u> YRS.</p>
--	---

REVIEWER: A. J. P. [Signature] DATE: 2/20/84

SPEC. TITLE _____
 SPEC. NO. SH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. TEMPERATURE SWITCH
 MAKE FENVAL MODEL 17002-40
 VENDOR TEST REPORT NO. FENVAL ENG. REPORT No 6350 / VIKING LABORATORY REPORT No 30411
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3040-A, 3040-B
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 40 YEARS BY ANALYSIS

TEST SEQUENCE (R: SEE BELOW)

- FENVAL: 6350
- | | |
|---------------------------------|-------------------------|
| <u>1. INSULATION RESISTANCE</u> | <u>7. RESPONSE TIME</u> |
| <u>2. DIELECTRIC STRENGTH</u> | <u>8. IMMERSION</u> |
| <u>3. CALIBRATION</u> | |
| <u>4. UNDERSHOOT</u> | <u>VIKING: 30411</u> |
| <u>5. OVERTSHOT</u> | <u>1. CYCLING</u> |
| <u>6. CONTACT RATING</u> | <u>2. _____</u> |

TEST ENVIRONMENT (R: <u>FENVAL: 6350</u>) (Pgs 5, 6, 9)				APPLICABLE ENV. ZONES
TIME	<u>30 min</u>	<u>30 min</u>	<u>30 min</u>	RAD <u>ST</u>
TEMP. °F	<u>305°F</u>	<u>305°F</u>	<u>305°F</u>	
PRES. PSIG	<u>10 PSIG</u>	<u>10 PSIG</u>	<u>10 PSIG</u>	T/P <u>ST</u>
R.H.	<u>100%</u>			
OP. TIME DEMO	<u>1.5 Hrs</u>	ACC/PERF DEMO	<u>± 2°F</u>	

RADIATION AGING (R: EDS CAL No 0630-001-024)

DOSE RATE NONE RAD/HR

DOSE PRIOR TO ENV. TEST NONE RADS

DOSE DURING ENV. TEST NONE RADS

TOTAL DOSE 1 x 10³ By Analysis RADS

THERMAL AGING (R: EDS CAL No 0630-001-024)

AGED TO SIMULATED LIFE OF NONE YRS.

BASED ON AMBIENT TEMP OF 104 °F

AGING TEMP./ DURATION NONE

CYCLE AGING (R: VIKING: 30411)

CYCLES REQUIRED NOT DETERMINED

CYCLES PERFORMED 12,202
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NONE

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.

REVIEWER: Walter P. Burman DATE: 12/30/61

SPEC. TITLE _____
 SPEC. NO. SH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. PRESSURE TRANSDUCER
 MAKE ROSEMOUNT MODEL 1151
 VENDOR TEST REPORT NO. ROSEMOUNT REPORT Nos 117415, 127227
 APPLICABLE STANDARDS TEST REPORT NO. 3048-A, 3048-B
 IEEE 322-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. I QUALIFIED LIFE 1.4 YRS

TEST SEQUENCE (R: ROSEMOUNT: 117415, Pg 3)

- | | |
|--------------------------------------|-----------|
| 1. <u>THERMAL AGING</u> | 6. _____ |
| 2. <u>RADIATION EXPOSURE</u> | 7. _____ |
| 3. <u>SEISMIC VIBRATION</u> | 8. _____ |
| 4. <u>STEAM PRESSURE ENVIRONMENT</u> | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: ROSEMOUNT: 117415, Pg 9)

TIME	10 MIN	1 HR	7HR	42 HR
TEMP. °F	350	316	303	230
PRES. PSIG	60	70	55.4	6
R.H.	<u>100%</u>			
OP. TIME DEMO	<u>50 Hrs, 10 MIN ACC/PERF DEMO 0.5% FS</u>			

APPLICABLE ENV. ZONES

RAD H, G
 T/P 1, 5, 10, 12, 16

RADIATION AGING (R: ROSEMOUNT: 127227)

DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^6 RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 2×10^6 RADS

THERMAL AGING (R: W/48: 17464-0902)

AGED TO SIMULATED LIFE OF 1.4 YRS.
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION 350°F/17HR, 316°F/1HR, 303°F/7HR, 230°F/29HR

CYCLE AGING (R: _____)

CYCLES REQUIRED N/A
 CYCLES PERFORMED 1/A
 (Electro-Mechanical Equip. only)

REL. HUMIDITY 100
 NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

REVIEWER: [Signature]

DATE: 12/31/82

SPEC. TITLE _____
 SPEC. NO. SH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. PRESSURE TRANSMITTER
 MAKE BAILEY MODEL K6556
 VENDOR TEST REPORT NO. WYCC/NUTECH: BWR EQUIPMENT QUALIFICATION SUMMARY QSR-094-A-01
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3094-A
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ NOT ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE NONE

TEST SEQUENCE (R: _____)

- | | |
|----------------|-----------|
| 1. <u>NONE</u> | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: WYCC/NUTECH: QSR-094-A-01, Pg 5)

TIME UNKNOWN
 TEMP. °F 180°F
 PRES. PSIG NONE
 R.H. NONE
 CP. TIME DEMO UNKNOWN ACC/PERF DEMO ± 1%

APPLICABLE ENV. ZONES
 RAD G
 T/P 1

RADIATION AGING (R: _____)

DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE NONE RADS

THERMAL AGING (R: _____)

AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF NONE °F
 AGING TEMP./ DURATION NONE
 REL. HUMIDITY? NONE
 NOT AGED-JUSTIFIED BY ANALYSIS TO NONE YRS.

CYCLE AGING (R: _____)

CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

REVIEWER: [Signature]

DATE: 12/29/81

SPEC. TITLE _____
 SPEC. NO. SHI-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. SOLENOID VALVE
 MAKE ASCO MODEL HT-X-8320-A20
 VENDOR TEST REPORT NO. ROCKWELL REPORT No 2792-03-02, Rev 1
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3096-A
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 40 YRS BY ANALYSIS

- TEST SEQUENCE (R: ROCKWELL 2792-03-02)
- | | |
|---------------------------|-----------|
| 1. <u>LEAKAGE TESTING</u> | 6. _____ |
| 2. <u>STEAM</u> | 7. _____ |
| 3. <u>CYCLING</u> | 8. _____ |
| 4. <u>LEAKAGE TEST</u> | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: <u>ROCKWELL 2792-03-02</u>)		APPLICABLE ENV. ZONES
TIME	<u>2 HRS</u>	RAD <u>B, H</u>
TEMP. °F	<u>340</u>	_____
PRES. PSIG	<u>110</u>	T/P <u>B, 22</u>
R.H.	<u>100</u>	_____
OP. TIME DEMO	<u>2 HRS</u>	ACC/PERF DEMO <u>LEAKAGE 20.5 SCFH</u>

RADIATION AGING (R: EDS CALC No 0630-001-025)

DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 6 X 10⁶ BY ANALYSIS RADS

THERMAL AGING (R: EDS CALC No 0630-001-025)

AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF 150 °F
 AGING TEMP./DURATION NONE

CYCLE AGING (R: ROCKWELL : 2792-03-02, P. 4)

CYCLES REQUIRED UNDETERMINED
 CYCLES PERFORMED 20,000
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NONE
 NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.

REVIEWER: Steve Paul DATE: 12/28/81

SPEC. TITLE _____
 SPEC. NO. SHI-003 P.O. 310010 VENDOR. GENERAL ELECTRIC
 TEST ITEM DESC. TEMPERATURE ELEMENT
 MAKE PYCO/CALIFORNIA ALLOY/NEGI MODEL GE PPD 145C322A
 VENDOR TEST REPORT NO. PYCO REPORT No. 122375, REV 0
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3110-A
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 28.8 YRS BY ANALYSIS
 (SEE BELOW)

TEST SEQUENCE (R: PYCO:122375)

- | | |
|-------------------------|-----------|
| 1. <u>THERMAL AGING</u> | 6. _____ |
| 2. <u>INSPECTION</u> | 7. _____ |
| 3. <u>RADIATION</u> | 8. _____ |
| 4. <u>INSPECTION</u> | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: PYCO:122375)

TIME	<u>168 HRS</u>
TEMP. °F	<u>250°F</u>
PRES. PSIG	<u>ATMOSPHERIC (ASSUMED)</u>
R.H.	<u>MOIST</u>
OP. TIME DEMO	<u>168 HRS</u>
ACC/PERF DEMO	<u>NONE REPORTED</u>

APPLICABLE ENV. ZONES

RAD G,H,K,A,ST

T/P 1,5,6,13,14,15,16,18,19,ST

RADIATION AGING (R: PYCO:122375)

DOSE RATE 7.5×10^5 RAD/HR

DOSE PRIOR TO ENV. TEST 2×10^8 RADS

DOSE DURING ENV. TEST NONE RADS

TOTAL DOSE 2×10^8 RADS

THERMAL AGING (R: EOS CALL NO. 0620-001-017)

AGED TO SIMULATED LIFE OF NONE YRS.

BASED ON AMBIENT TEMP OF 104 °F

AGING TEMP./DURATION NONE

REL. HUMIDITY NONE

CYCLE AGING (R: _____)

CYCLES REQUIRED N/A

CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 28.9 YRS.

REVIEWER: Warren P. Durman DATE: 12/21/81

SPEC. TITLE _____
 SPEC. NO. SH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. ECS PUMP MOTOR
 MAKE GENERAL ELECTRIC MODEL 5K6339XC94A
 VENDOR TEST REPORT NO. GE REPORT 1703 NEDM-10672 AND 491HA988
 APPLICABLE STANDARDS TEST REPORT NO. 3111-A, 3111-B
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE 334-1971 DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 40 YRS WITH ANNUAL MAINTENANCE

TEST SEQUENCE (R: GE; NEDM-10672 GE, 491HA988)
 1. PRE-AGED (1) FUNCTIONAL (6) FUNCTIONAL &
 2. STEAM TEST (2) AGRIMA INSPECTION
 3. HI-POT TEST (3) RADIATION
 4. _____ (4) SEISMIC
 5. _____ (5) STEAM

TEST ENVIRONMENT (R: GE; NEDM-10672)

TIME	<u>6 HRS</u>	<u>1 HR</u>	<u>6 HRS</u>	<u>96 HRS</u>	RAD	<u>G</u>
TEMP. °F	<u>212</u>	<u>AMBIENT</u>	<u>212</u>	<u>AMBIENT</u>		
PRES. PSIG	<u>7" H₂O GAGE</u>	<u>AMBIENT</u>	<u>7" H₂O GAGE</u>	<u>AMBIENT</u>	T/P	<u>01</u>
R.H.	<u>100%</u>					
OP. TIME DEMO	<u>99 HRS</u>	ACC/PERF DEMO	<u>N/A</u>			

APPLICABLE ENV. ZONES

RADIATION AGING (R: GE 491HA988)
 DOSE RATE NONE REPORTED RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST 5.5 x 10⁶ RADS
 TOTAL DOSE 5.5 x 10⁶ RADS

THERMAL AGING (R: FDS CAL No 0630-001-012)
 AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF 104°F °F
 AGING TEMP./ DURATION NONE
 REL. HUMIDITY NONE

CYCLE AGING (R: GE NEDM-10672, P2)
 CYCLES REQUIRED 170
 CYCLES PERFORMED 300
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS.
 PROVIDED LUBE OIL AND LEAD WIRE SEALS ARE CHECKED/CHANGED ANNUALLY

REVIEWER: [Signature] DATE: 12/27/81

SPEC. TITLE _____

SPEC. NO. SH-003 P.C. 310010 VENDOR GENERAL ELECTRIC

TEST ITEM DESC. E/P CONVERTER

MAKE FISHER GOVERNOR MODEL 546

VENDOR TEST REPORT NO. NO TEST DATA FOUND

APPLICABLE STANDARDS _____ TEST REPORT NO. _____

IEEE 323-1971 TEST METHOD _____

IEEE _____ DOCUMENTATION ACCEPTABILITY _____

IEEE _____

NUREG 0588 CAT. II QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)

- | | |
|----------------|-----------|
| 1. <u>NONE</u> | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: _____)

APPLICABLE ENV. ZONES

TIME	<u>NONE</u>
TEMP. °F	<u>NONE</u>
PRES. PSIG	<u>NONE</u>
R.H.	<u>NONE</u>
OP. TIME DEMO	<u>NONE</u>
ACC/PERF DEMO	<u>NONE</u>

RAD	<u>6</u>
T/P	<u>1</u>

RADIATION AGING (R: _____)

THERMAL AGING (R: _____)

DOSE RATE NONE RAD/HR
DOSE PRIOR TO ENV. TEST NONE RADS
DOSE DURING ENV. TEST NONE RADS
TOTAL DOSE NONE RADS

AGED TO SIMULATED LIFE OF NONE YRS.
BASED ON AMBIENT TEMP OF NONE °F
AGING TEMP./DURATION NONE

CYCLE AGING (R: _____)

REL. HUMIDITY NONE

CYCLES REQUIRED UNDETERMINED
CYCLES PERFORMED NONE
(Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO NONE YRS.

REVIEWER: [Signature]

DATE: 1/11/82

SPEC. TITLE _____
 SPEC. NO. SHI-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. FLOW TRANSMITTER AND ELEMENT
 MAKE AMETEK MODEL 078-5004
 VENDOR TEST REPORT NO. No TEST DATA FOUND
 APPLICABLE STANDARDS _____ TEST REPORT NO. _____
 IEEE 323-197 TEST METHOD _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____
 NUREG 0588 CAT. II QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)

- | | |
|----------------|-----------|
| 1. <u>NONE</u> | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: _____)

TIME NONE
 TEMP. °F NONE
 PRES. PSIG NONE
 R.H. NONE
 OP. TIME DEMO NONE ACC/PERF DEMO NONE

APPLICABLE ENV. ZONES

RAD 6
 T/P 5,6

RADIATION AGING (R: _____)

DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE NONE RADS

THERMAL AGING (R: _____)

AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF NONE °F
 AGING TEMP./ DURATION NONE
 REL. HUMIDITY NONE

CYCLE AGING (R: _____)

CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO NONE YRS.

REVIEWER: Steve Perry

DATE: 1/11/82

SPEC. TITLE _____
 SPEC. NO. SHI-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. LEVEL TRANSMITTER
 MAKE ITT BARTON MODEL 760
 VENDOR TEST REPORT NO. AETL 5350-2114
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3129-A
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE NONE

TEST SEQUENCE (R: WVH-NUTEL: QSR-129-A-01, Pg 6)

- | | |
|----------------------|------------------------|
| 1. <u>FUNCTIONAL</u> | 6. <u>212°F TEST</u> |
| 2. <u>40°F TEST</u> | 7. <u>FUNCTIONAL</u> |
| 3. <u>FUNCTIONAL</u> | 8. <u>AMBIENT TEST</u> |
| 4. <u>100°F TEST</u> | 9. <u>FUNCTIONAL</u> |
| 5. <u>FUNCTIONAL</u> | 10. _____ |

TEST ENVIRONMENT (R: AETL 5350-2114 pg 2, RL-760-2)

APPLICABLE ENV. ZONES

TIME	1hr	1hr	1hr	1hr
TEMP. °F	40	70	100	212
PRES. PSIG	0-1 1/2	0	0	0 + 7" H ₂ O
R.H.	<u>100 max</u>			
OP. TIME DEMO	<u>4 HRS.</u>	ACC/PERF DEMO	<u>1.7%</u>	

RAD 9
 T/P 9,10,11

RADIATION AGING (R: _____)

THERMAL AGING (R: _____)

DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE NONE RADS

AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF NONE °F
 AGING TEMP./ DURATION NONE

CYCLE AGING (R: _____)

REL. HUMIDITY NONE

CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO NONE YRS.

REVIEWER: Wayne P. Egan

DATE: 12/16/81

SPEC. TITLE _____
 SPEC. NO. SHI-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. LEVEL SWITCH
 MAKE MAGNETROL MODEL 3.5-751-1X-MPG-M14HY
 VENDOR TEST REPORT NO. WYLE LAB, REPORT No 43235-1, REVISION A
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3143-A
 IEEE 323-1974 TEST METHOD SEQUENTIAL
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 40 YRS BY ANALYSIS

TEST SEQUENCE (R: WYLE: 43235-1)

- | | |
|--|--|
| 1. <u>NUCLEAR RAD. DAMAGE THRESHOLD TEST</u> | 6. <u>75 HZ PLANT INDUCED VIBRATION TEST</u> |
| 2. <u>REGRESSION ANALYSES</u> | 7. <u>SEISMIC QUALIFICATION</u> |
| 3. <u>BASELINE FUNCTIONAL * HYDROST. PRESS. TEST</u> | 8. <u>TYPE TEST PLAN</u> |
| 4. <u>NUCLEAR RADIATION AGING</u> | 9. _____ |
| 5. <u>ELEVATED TEMP/HUMIDITY/CYCLE AGING</u> | 10. _____ |

TEST ENVIRONMENT (R: WYLE: 43235-1, Pg 196)

TIME	<u>160 HRS</u>
TEMP. °F	<u>300</u>
PRES. PSIG	<u>None Given - Assume Atmospheric</u>
R.H.	<u>100%</u>
OP. TIME DEMO	<u>160 HRS</u>
ACC/PERF DEMO	<u>Not Given</u>

APPLICABLE ENV. ZONES

RAD	<u>G</u>
T/P	<u>1</u>

RADIATION AGING (R: WYLE: 43235-1, Pg 7 AND TABLE 1)

DOSE RATE 1.2×10^5 To 3.3×10^6 RAD/HR

DOSE PRIOR TO ENV. TEST $> 1 \times 10^6$ RADS

DOSE DURING ENV. TEST None RADS

TOTAL DOSE $> 1 \times 10^6$ RADS

THERMAL AGING (R: WYLE: 43235-1, Pg 196)
EOS CASE No 0630-001-027

AGED TO SIMULATED LIFE OF NOT GIVEN YRS.

BASED ON AMBIENT TEMP OF 104°F °F

AGING TEMP./DURATION 300°F / 160 hrs

CYCLE AGING (R: WYLE 43235-1, Pg 146)

CYCLES REQUIRED UNDETERMINED

CYCLES PERFORMED 10,000
 (Electro-Mechanical Equip. only)

REL. HUMIDITY None

NOT AGED-JUSTIFIED BY ANALYSIS TO 1.7 YRS YRS.

REVIEWER: Warren P. Gurnan DATE: 12/1/81

SPEC. TITLE _____
 SPEC. NO. SH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. LEVEL TRANSMITTER
 MAKE ITT BARTON MODEL 36B
 VENDOR TEST REPORT NO. No ENVIRONMENTAL TEST FOUND
 APPLICABLE STANDARDS TEST REPORT NO. _____
 IEEE 323-1971 TEST METHOD _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____
 NUREG 0588 CAT. II QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)
 1. NONE 6. _____
 2. _____ 7. _____
 3. _____ 8. _____
 4. _____ 9. _____
 5. _____ 10. _____

TEST ENVIRONMENT (R: _____)		APPLICABLE ENV. ZONES
TIME	<u>NONE</u>	RAD <u>6</u>
TEMP. °F	<u>NONE</u>	_____
PRES. PSIG	<u>NONE</u>	T/P <u>1</u>
R.H.	<u>NONE</u>	_____
OP. TIME DEMO	<u>NONE</u>	ACC/PERF DEMO <u>NONE</u>

RADIATION AGING (R: _____)
 DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE NONE RADS

THERMAL AGING (R: _____)
 AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF NONE °F
 AGING TEMP./DURATION NONE

CYCLE AGING (R: _____)
 CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NONE
 NOT AGED-JUSTIFIED BY ANALYSIS TO NONE YRS.

REVIEWER: Walter P. Emmeri DATE: 12/20/81

SPEC. TITLE _____
 SPEC. NO. 21A9370 P.O. 705-693 | VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. Coax explosive Valve.
 MAKE Coax MODEL P/N 1832-159-01
 VENDOR TEST REPORT NO. COIAX REPORT No TR-39
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3146-A
 IEEE 323-1971 TEST METHOD Seperate
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. _____ QUALIFIED LIFE _____

TEST SEQUENCE (R: Coax TR 39, Page 5-7.)

- | | |
|--------------------------------------|-------------------------|
| 1. <u>Bridge wire Resistance</u> | 6. <u>Irradiation</u> |
| 2. <u>Circuit Resistance testing</u> | 7. <u>Seismic Test.</u> |
| 3. <u>Temp./ Humidity</u> | 8. _____ |
| 4. <u>Visual Inspection</u> | 9. _____ |
| 5. <u>Aging (Seismic Aging)</u> | 10. _____ |

TEST ENVIRONMENT (R: Coax TR 39, Pages 5-7)

APPLICABLE ENV. ZONES

TIME 100 days
 TEMP. °F 185 to 190 F
 PRES. PSIG Atm.
 R.H. 100
 OP. TIME DEMO 100 DYS ACC/PERF DEMO N/A

RAD J
 T/P 15

RADIATION AGING (R: Coax TR-39, Pg 6)

DOSE RATE 2.2×10^4 to 2.4×10^4 RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST 2.2×10^4 RADS
 TOTAL DOSE 2.2×10^4 RADS

THERMAL AGING (R: _____)

AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF NONE °F
 AGING TEMP./ DURATION NONE

CYCLE AGING (R: _____)

CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NONE

NOT AGED-JUSTIFIED BY ANALYSIS TO NONE YRS.

REVIEWER: Steve Parry

DATE: 4/1/82

SPEC. TITLE _____
 SPEC. NO. SHI-002 P.O. 30010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. PUMP MOTOR
 MAKE GENERAL ELECTRIC MODEL 5K 32A AK 2034
 VENDOR TEST REPORT NO. No Test Data Found
 APPLICABLE STANDARDS _____ TEST REPORT NO. _____
 IEEE 323-1991 TEST METHOD _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____
 NUREG 0588 CAT. II QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)
 1. NONE 6. _____
 2. _____ 7. _____
 3. _____ 8. _____
 4. _____ 9. _____
 5. _____ 10. _____

TEST ENVIRONMENT (R: _____)	APPLICABLE ENV. ZONES
TIME <u>NONE</u>	RAD <u>J</u>
TEMP. °F <u>NONE</u>	_____
PRES. PSIG <u>NONE</u>	T/P <u>15</u>
R.H. <u>NONE</u>	_____
OP. TIME DEMO <u>NONE</u> ACC/PERF DEMO <u>NONE</u>	_____

RADIATION AGING (R: _____)
 DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE NONE RADS

THERMAL AGING (R: _____)
 AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF NONE °F
 AGING TEMP./ DURATION NONE

CYCLE AGING (R: _____)
 CYCLES REQUIRED UNDETERMINED
 CYCLES PERFORMED NONE
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NONE
 NOT AGED-JUSTIFIED BY ANALYSIS TO NONE YRS.

REVIEWER: John P. [Signature] DATE: 11/82

SPEC. TITLE _____
 SPEC. NO. SH-203 P.O. 31090 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. ELECTRIC HEATER
 MAKE GENERAL ELECTRIC MODEL 47D518673
 VENDOR TEST REPORT NO. GE REPORT 9232-SA2-4, REV A
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3902-4
 IEEE 323-1971 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 40 YRS BY ANALYSIS

TEST SEQUENCE (R: GE: 9232-SA2-4)
 1. ENERGIZE HEATER (2 Hours) 6. _____
 2. DEENERGIZE HEATER 7. _____
 3. ENERGIZE HEATER (100 DYS) 8. _____
 4. _____ 9. _____
 5. _____ 10. _____

TEST ENVIRONMENT (R: <u>GE: 9232-SA2-4</u>)		APPLICABLE ENV. ZONES
TIME	<u>1000 DYS</u>	RAD <u>6</u>
TEMP. °F	<u>NORMAL AMBIENT</u>	
PRES. PSIG	<u>NORMAL AMBIENT</u>	T/P <u>7</u>
R.H.	<u>NORMAL AMBIENT</u>	
OP. TIME DEMO	<u>100 DYS</u>	
ACC/PERF DEMO	<u>N/A</u>	

RADIATION AGING (R: EDS CAL 0630-001-028)
 DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 1x10¹² BY ANALYSIS RADS

THERMAL AGING (R: EDS CAL 0630-001-028)
 AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./DURATION NONE

CYCLE AGING (R: _____)
 CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NONE
 NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS YRS.

REVIEWER: [Signature] DATE: 12/31/91

SPEC. TITLE _____
 SPEC. NO. 541-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. BLOWER
 MAKE GENERAL ELECTRIC MODEL 2CH6-041-1U
 VENDOR TEST REPORT NO. GE REPORT No 8272-NL9-4 R-1A
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3903-A
 IEEE 323-71 TEST METHOD SEPARATE
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 6 YRS BY ANALYSIS

TEST SEQUENCE (R: GE: 8272-NL9-4)

- | | |
|--------------------------------------|-----------|
| 1. <u>CONTINUOUS FUNCTIONAL</u> | 6. _____ |
| 2. <u>TEST IN STRESS ENVIRONMENT</u> | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: <u>GE: 8272-NL9-4</u>)		APPLICABLE ENV. ZONES
TIME	<u>100 DYS</u>	RAD <u>6</u>
TEMP. °F	<u>150</u>	
PRES. PSIG	<u>ATMOSPHERIC</u>	T/P <u>4,6</u>
R.H.	<u>97</u>	
OP. TIME DEMO <u>100 DYS</u>	ACC/PERF DEMO <u>N/A</u>	

RADIATION AGING (R: <u>EDS Calc 0630-001-026</u>)	THERMAL AGING (R: <u>EDS Calc 0630-001-026</u>)
DOSE RATE <u>NONE</u> RAD/HR	AGED TO SIMULATED LIFE OF <u>NONE</u> YRS.
DOSE PRIOR TO ENV. TEST <u>NONE</u> RADS	BASED ON AMBIENT TEMP OF <u>104</u> °F
DOSE DURING ENV. TEST <u>NONE</u> RADS	AGING TEMP./ DURATION <u>NONE</u>
TOTAL DOSE <u>1x10⁷ BY ANALYSIS</u> RADS	

CYCLE AGING (R: <u>GE 8272-NL9-4</u>)	REL. HUMIDITY <u>NONE</u>
CYCLES REQUIRED <u>UNDETERMINED</u>	NOT AGED-JUSTIFIED BY ANALYSIS TO <u>6</u> YRS.
CYCLES PERFORMED <u>7</u> (Electro-Mechanical Equip. only)	

REVIEWER: [Signature] DATE: 12/31/31

SPEC. TITLE _____
 SPEC. NO. SH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. SOLENOID VALVE
 MAKE TARGET ROCK MODEL Y2 SMS-A-01
 VENDOR TEST REPORT NO. TARGET ROCK REPORT NO. 2199A
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3904-A
 IEEE 323-1974 TEST METHOD SEQUENTIAL
 IEEE 382-1972 DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 40 YRS BY ANALYSIS

- TEST SEQUENCE (R: TARGET ROCK REPORT No 2199A)
- | | |
|--|--------------------------------|
| 1. <u>FUNCTIONAL</u> | 6. <u>PRESSURE/TEMPERATURE</u> |
| 2. <u>IRADIATION</u> | 7. <u>CYCLING/LEAKAGE</u> |
| 3. <u>FUNCTIONAL</u> | 8. <u>FUNCTIONAL</u> |
| 4. <u>TEMPERATURE/HUMIDITY & CYCLING</u> | 9. <u>IRADIATION</u> |
| 5. <u>FUNCTIONAL</u> | 10. <u>FUNCTIONAL</u> |
| | 11. <u>INSPECTION</u> |

TEST ENVIRONMENT (R: <u>TARGET ROCK REPORT No 2199A</u>)									APPLICABLE ENV. ZONES
TIME (min.)	0-T	2-20	20-181	181-299	300-301	301-480	482-650	650-5501	RAD <u>B</u>
TEMP. °F	337	334-346	342	94-85	343	344-347	322	301-290	
PRES. PSIG	65	50-48	48	0	65	51-46	46	25-26	T/P <u>22</u>
R.H.	<u>100</u>								
OP. TIME DEMO	<u>92 Hrs</u>			ACC/PERF DEMO	<u>N/A</u>				

RADIATION AGING (R: TARGET ROCK 2199A)
 (PRIOR TO ENV. TEST)
 DOSE RATE 1×10^6 RAD/HR
 DOSE PRIOR TO ENV. TEST 1.9×10^7 RADS
 DOSE DURING ENV. TEST 1.3×10^7 RADS
 TOTAL DOSE 3.2×10^7 RADS

THERMAL AGING (R: EOS C.16 No 0630-02V-020)
 AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF 150 °F
 AGING TEMP./DURATION NONE
 REL. HUMIDITY NONE

CYCLE AGING (R: TARGET ROCK 2199A)
 CYCLES REQUIRED NOT DETERMINED
 CYCLES PERFORMED 8000
 (Electro-Mechanical Equip only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 40 YRS YRS.

REVIEWER: William P. Giovanni DATE: 12/21/81

SPEC. TITLE _____
 SPEC. NO. EH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. TEMPERATURE ELEMENT
 MAKE PYCO MODEL 102-3171
 VENDOR TEST REPORT NO. PYCO QUALIFICATION TEST REPORT DOCUMENT No. 770831
 APPLICABLE STANDARDS TEST REPORT NO. 310-A
 IEEE 323-1974 TEST METHOD SEQUENTIAL
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY _____
 IEEE 382-1972 / 383-1974 ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 28.9 Yrs BY ANALYSIS

- TEST SEQUENCE (R: PYCO DOCUMENT No. 770831)
- | | |
|---|-----------|
| 1. <u>THERMAL & RADIATION AGING</u> | 6. _____ |
| 2. <u>DEVELOPMENTAL</u> | 7. _____ |
| 3. <u>SEISMIC / VIBRATION</u> | 8. _____ |
| 4. <u>LOCA SIMULATION</u> | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: PYCO DOCUMENT No. 770831)

TIME	3 Hrs	2 Hrs	3 Hrs	3 Hrs	4 Hrs	8 Hrs	500
TEMP. °F	346	140	346	335	315	265	215
PRES. PSIG	113	—	113	95	69	28	—
R.H.	<u>100%</u>						
OP. TIME DEMO	<u>720 Hrs</u>			ACC/PERF DEMO	<u>NONE REPORTED</u>		

APPLICABLE ENV. ZONES
 RAD G, H, K, P, ST
 T/P 01, 05, 13, 14, 15, 16, 18, 19, ST

RADIATION AGING (R: PYCO # 770831)

DOSE RATE 5×10^5 RAD/HR
 DOSE PRIOR TO ENV. TEST 2×10^8 RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE 2×10^8 RADS

THERMAL AGING (R: PYCO # 770831)
 EDS CMC. No 0630-001-017

AGED TO SIMULATED LIFE OF NOT GIVEN YRS.
 BASED ON AMBIENT TEMP OF 104 °F
 AGING TEMP./ DURATION 121°C / 7 DAYS
 REL. HUMIDITY 85-95

CYCLE AGING (R: _____)

CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO 28.9 YRS.

REVIEWER: Walter P. [Signature] DATE: 12/21/21

SPEC. TITLE _____
 SPEC. NO. SHI-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. SOLENOID VALVE
 MAKE ASCO MODEL NP8316C37
 VENDOR TEST REPORT NO. Automatic Switch Co. TEST REPORT NO. AQS21678/TR REV. A
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3909-A
 IEEE 323-1974 / 382/ANSI N274.2.1 TEST METHOD SEQUENTIAL TESTS
 IEEE 382-1972 DOCUMENTATION ACCEPTABILITY _____
 IEEE 344-1975 ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 22.93 Yrs BY ANALYSIS

TEST SEQUENCE (R: ASCO Report No. AQS21678/TR)

- | | |
|-------------------------|----------------------------------|
| 1. <u>THERMAL AGING</u> | 6. <u>ACCIDENT RADIATION</u> |
| 2. <u>RADIATION</u> | 7. <u>30-DAY LOCA SIMULATION</u> |
| 3. <u>WEAR ALLOW</u> | 8. _____ |
| 4. <u>SEISMIC</u> | 9. _____ |
| 5. <u>VIBRATION</u> | 10. _____ |

TEST ENVIRONMENT (R: ASCO Report No. AQS21678/TR)
 FIGURE 2

TIME	<u>4 Hrs</u>	<u>1 Hr</u>	<u>3 Hr</u>	<u>3 Hr</u>	<u>85 Hr</u>	<u>26 DYS</u>
TEMP. °F	<u>346</u>	<u>140</u>	<u>346</u>	<u>320</u>	<u>250</u>	<u>200</u>
PRES. PSIG	<u>110</u>	<u>Ambient</u>	<u>110</u>	<u>75</u>	<u>15</u>	<u>10</u>
R.H.	<u>100 %</u>					
OP. TIME DEMO	<u>30 DAYS</u>		ACC/PERF DEMO	<u>N/A</u>		

APPLICABLE ENV. ZONES

RAD G
 T/F 25

RADIATION AGING (R: ASCO AQS21678/TR)

DOSE RATE $< 1 \times 10^6$ RAD/HR
 DOSE PRIOR TO ENV. TEST 5×10^7 RADS
 DOSE DURING ENV. TEST 1.5×10^8 RADS
 TOTAL DOSE 2×10^8 RADS

CYCLE AGING (R: AQS21678/TR)

CYCLES REQUIRED UNDETERMINED
 CYCLES PERFORMED 40,000
 (Electro-Mechanical Equip. only)

THERMAL AGING (R: ASCO AQS21678/TR)
 EDSCALC No 0630-001-021

AGED TO SIMULATED LIFE OF 4 YRS.
 BASED ON AMBIENT TEMP OF 150 °F
 AGING TEMP./ DURATION 268°F / 12 DYS

REL. HUMIDITY NOT GIVEN

NOT AGED-JUSTIFIED BY ANALYSIS TO 22.93 YRS.

REVIEWER: Walter P. Furman DATE: 12/29/81

SPEC. TITLE _____
SPEC. NO. SH-003 P.O. 310010 VENDOR GENERAL ELECTRIC
TEST ITEM DESC. POSITION SWITCH
MAKE NAMCO MODEL EAT40-8000-1 (PRE-1978)
VENDOR TEST REPORT NO. NO TESTING HAS BEEN PERFORMED ON THIS DEVICE
APPLICABLE STANDARDS _____ TEST REPORT NO. _____
IEEE 323-1971 TEST METHOD _____
IEEE _____ DOCUMENTATION ACCEPTABILITY _____
IEEE _____
NUREG 0588 CAT. II QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)

- | | |
|----------------|-----------|
| 1. <u>NONE</u> | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: _____)

TIME NONE
TEMP. °F NONE
PRES. PSIG NONE
R.H. NONE
OP. TIME DEMO NONE ACC/PERF DEMO NONE

APPLICABLE ENV. ZONES

RAD D,T
T/P 2,22

RADIATION AGING (R: _____)

DOSE RATE NONE RAD/HR
DOSE PRIOR TO ENV. TEST NONE RADS
DOSE DURING ENV. TEST NONE RADS
TOTAL DOSE NONE RADS

THERMAL AGING (R: _____)

AGED TO SIMULATED LIFE OF NONE YRS.
BASED ON AMBIENT TEMP OF NONE °F
AGING TEMP./ DURATION NONE

CYCLE AGING (R: _____)

CYCLES REQUIRED UNDETERMINED
CYCLES PERFORMED NONE
(Electro-Mechanical Equip. only)

REL. HUMIDITY NONE

NOT AGED-JUSTIFIED BY ANALYSIS TO NONE YRS.

REVIEWER: St. Barry

DATE: 1/12/82

SPEC. TITLE _____
 SPEC. NO. SH1003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. INSTRUMENT PANELS
 MAKE GENERAL ELECTRIC MODEL INSTRUMENT PANELS
 VENDOR TEST REPORT NO. CONTENTS OF PANEL HAVE NOT AS YET BEEN IDENTIFIED
 APPLICABLE STANDARDS _____ TEST REPORT NO. _____
 IEEE 323-1977 TEST METHOD _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____
 NUREG 0588 CAT. II QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)

- | | |
|-------------------|-----------|
| 1. <u>(LATER)</u> | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: _____)

APPLICABLE ENV. ZONES

TIME (LATER)
 TEMP. °F (LATER)
 PRES. PSIG (LATER)
 R.H. (LATER)
 OP. TIME DEMO (LATER) ACC/PERF DEMO (LATER)

RAD G, H, L
 T/P 1, 2, 5, 10, 11, 12, 16

RADIATION AGING (R: _____)

THERMAL AGING (R: _____)

DOSE RATE (LATER) RAD/HR
 DOSE PRIOR TO ENV. TEST (LATER) RADS
 DOSE DURING ENV. TEST (LATER) RADS
 TOTAL DOSE (LATER) RADS

AGED TO SIMULATED LIFE OF (LATER) YRS.
 BASED ON AMBIENT TEMP OF (LATER) °F
 AGING TEMP./ DURATION (LATER)

CYCLE AGING (R: _____)

REL. HUMIDITY (LATER)

CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

NOT AGED-JUSTIFIED BY ANALYSIS TO (LATER) YRS.

REVIEWER: [Signature]

DATE: 1/12/92

SPEC. TITLE _____
 SPEC. NO. SHI-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. TURBINE
 MAKE TERRY MODEL GS-1
 VENDOR TEST REPORT NO. NO TESTING HAS BEEN PERFORMED ON THIS DEVICE
 APPLICABLE STANDARDS _____ TEST REPORT NO. _____
 IEEE 323-1971 TEST METHOD _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____
 NUREG 0588 CAT. II QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)

- | | |
|----------------|-----------|
| 1. <u>NONE</u> | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: _____)

APPLICABLE ENV. ZONES

TIME	<u>NONE</u>
TEMP. °F	<u>NONE</u>
PRES. PSIG	<u>NONE</u>
R.H.	<u>NONE</u>
OP. TIME DEMO	<u>NONE</u>
ACC/PERF DEMO	<u>NONE</u>

RAD	<u>G</u>
T/P	<u>1</u>

RADIATION AGING (R: _____)

THERMAL AGING (R: _____)

DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE NONE RADS

AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF NONE °F
 AGING TEMP./DURATION NONE
 REL. HUMIDITY NONE

CYCLE AGING (R: _____)

NOT AGED-JUSTIFIED BY ANALYSIS TO NONE YRS.

CYCLES REQUIRED UNDETERMINED
 CYCLES PERFORMED NONE
 (Electro-Mechanical Equip. only)

REVIEWER: Wm. P. Furman

DATE: 2/2/81

SPEC. TITLE _____
 SPEC. NO. SHI-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. RADIATION MONITOR
 MAKE GENERAL ELECTRIC MODEL 237X731G001
 VENDOR TEST REPORT NO. NO TEST DATA HAS BEEN FOUND
 APPLICABLE STANDARDS _____ TEST REPORT NO. _____
 IEEE 323-1971 TEST METHOD _____
 IEEE _____ DOCUMENTATION ACCEPTABILITY _____
 IEEE _____
 NUREG 0588 CAT. II QUALIFIED LIFE _____

TEST SEQUENCE (R: _____)

- | | |
|----------------|-----------|
| 1. <u>NONE</u> | 6. _____ |
| 2. _____ | 7. _____ |
| 3. _____ | 8. _____ |
| 4. _____ | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: _____)

APPLICABLE ENV. ZONES

TIME NONE
 TEMP. °F NONE
 PRES. PSIG NONE
 R.H. NONE
 OP. TIME DEMO NONE ACC/PERF DEMO NONE

RAD ST
 T/P ST

RADIATION AGING (R: _____)

DOSE RATE NONE RAD/HR
 DOSE PRIOR TO ENV. TEST NONE RADS
 DOSE DURING ENV. TEST NONE RADS
 TOTAL DOSE NONE RADS

THERMAL AGING (R: _____)

AGED TO SIMULATED LIFE OF NONE YRS.
 BASED ON AMBIENT TEMP OF NONE °F
 AGING TEMP./ DURATION NONE

CYCLE AGING (R: _____)

CYCLES REQUIRED N/A
 CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

REL. HUMIDITY NONE

NOT AGED-JUSTIFIED BY ANALYSIS TO NONE YRS.

REVIEWER: St. Pavy

DATE: 1/2/32

SPEC. TITLE _____
 SPEC. NO. SHI-003 P.O. 310010 VENDOR GENERAL ELECTRIC
 TEST ITEM DESC. PRESSURE TRANSMITTER
 MAKE ROSEMOUNT MODEL 1152
 VENDOR TEST REPORT NO. ROSEMOUNT REPORT NO. 117415, REL B
 APPLICABLE STANDARDS _____ TEST REPORT NO. 3915-A
 IEEE 323-1971 TEST METHOD SEQUENTIAL
 IEEE 344-1975 DOCUMENTATION ACCEPTABILITY _____
 IEEE _____ ACCEPTABLE
 NUREG 0588 CAT. II QUALIFIED LIFE 1.4 YRS

TEST SEQUENCE (R: ROSEMOUNT 117415, Pgs)

- | | |
|------------------------------|-----------|
| 1. <u>THERMAL AGING</u> | 6. _____ |
| 2. <u>RADIATION EXPOSURE</u> | 7. _____ |
| 3. <u>SEISMIC</u> | 8. _____ |
| 4. <u>STEAM-PRESSURE</u> | 9. _____ |
| 5. _____ | 10. _____ |

TEST ENVIRONMENT (R: ROSEMOUNT 117415, Pgs)

TIME	<u>10 MIN</u>	<u>1 HR</u>	<u>7 HRS</u>	<u>42 HRS</u>
TEMP. °F	<u>350</u>	<u>316</u>	<u>303</u>	<u>230</u>
PRES. PSIG	<u>60</u>	<u>70</u>	<u>55.4</u>	<u>6</u>
R.H.	<u>100%</u>			
OP. TIME DEMO	<u>50 HRS</u>	ACC/PERF DEMO	<u>2.0% FS</u>	

APPLICABLE ENV. ZONES

RAD G, H

T/P 12, 13

RADIATION AGING (R: ROSEMOUNT 117415, Pgs)

DOSE RATE 1×10^6 RAD/HR

DOSE PRIOR TO ENV. TEST NONE RADS

DOSE DURING ENV. TEST 5×10^6 RADS

TOTAL DOSE 5×10^6 RADS

THERMAL AGING (R: WYLE: 1746A-7002)

AGED TO SIMULATED LIFE OF 1.4 YRS.

BASED ON AMBIENT TEMP OF 104 °F

AGING TEMP./DURATION 350°/17HR; 316°/1HR; 303°/1HR; 230°/39HR

CYCLE AGING (R: _____)

CYCLES REQUIRED N/A

CYCLES PERFORMED N/A
 (Electro-Mechanical Equip. only)

REL. HUMIDITY 100

NOT AGED-JUSTIFIED BY ANALYSIS TO N/A YRS.

REVIEWER: [Signature] DATE: 1/6/82

APPENDIX C
ENVIRONMENTAL ZONE MAPS

APPENDIX C

ENVIRONMENTAL ZONE MAPS


The drawings which follow define the areas of the plant determined to be in a potentially harsh environment. The drawings divide the plant into spatial zones. Radiation zones are identified with letters while pressure/temperature zones are identified with numbers. The radiation zones shown on Figures C-1 through C-15 are the same as Figures II.B.2-1 through 15 in the NUREG-0737 NRC submittal, and are included herein for convenience. Temperature and pressure zones are shown on Figures C-16 through C-22.

INDEX OF ZONE MAPS

<u>Title</u>	<u>Figure No.</u>	<u>Zone No.'s</u>
Radiation Zones, Section View, Reactor Containment	C-1	A,B,C,D,E, F,H
Radiation Zones, Plan El 8° to 20° North, Reactor Containment	C-2	G
Radiation Zones, Plan El 8° to 20° South, Reactor Containment	C-3	G
Radiation Zones, Plan El 20° to 40° North, Reactor Containment	C-4	G
Radiation Zones, Plan El 20° to 40° South, Reactor Containment	C-5	G
Radiation Zones, Plan El 40° to 63° North, Reactor Containment	C-6	G,L
Radiation Zones, Plan El 40° to 63° South, Reactor Containment	C-7	G,L
Radiation Zones, Plan El 63° to 78° North, Reactor Containment	C-8	G
Radiation Zones, Plan El 63° to 78° South, Reactor Containment	C-9	G,L
Radiation Zones, Plan El 78° to 112° North, Reactor Containment	C-10	G,H,M
Radiation Zones, Plan 78° to 112° South, Reactor Containment	C-11	G,H
Radiation Zones, Plan El 76° to 96°, Reactor Containment	C-12	T
Radiation Zones, Plan El 112° to 150° North, Reactor Containment	C-13	H,J,K,N,P
Radiation Zones, Plan El 112° to 150° South, Reactor Containment	C-14	H,J,N,P
Radiation Zones, 150° and Partial Plans, Reactor Containment	C-15	H,N,P,Q,R,S
Temperature and Pressure Zones, Plan El 8° to 40°, Reactor Containment	C-16	1

<u>Title</u>	<u>Figure No.</u>	<u>Zone No.'s</u>
Temperature and Pressure Zones, Plan El 40' to 63', Reactor Containment	C-17	2,21
Temperature and Pressure Zones, Plan El 63' to 78', Reactor Containment	C-18	2,3,4,5, 6,7
Temperature and Pressure Zones, Plan El 78' to 112', Reactor Containment	C-19	8,9,10, 11,12
Temperature and Pressure Zones, Plan El 112' to 150', Reactor Containment	C-20	13,14,15, 16,17,21
Temperature and Pressure Zones, Plan El 150' to 175', Reactor Containment	C-21	18,19,21
Temperature and Pressure Zones, Section View, Reactor Containment	C-22	20,22,23

SECONDARY ZONE H



SECONDARY ZONE H

ZONE B

ZONE A

ZONE B

PLATFORM (TYP)





FIG. C-1
 RADIATION ZONES A, B, C, D, E, F, H
 REACTOR CONTAINMENT
 SECTION VIEW
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT

PRIMARY CONTAINMENT ZONES -A,B,C,D,E,F
 SECONDARY CONTAINMENT EL 175'-9" ZONE-H



CORE SPRAY
 HPE1 LEAK DET B RACK 1/2\"/>

HPE1 CONDENSATE PUMP
 IE4-P-075
 HPE1 GLD SL CONDENS
 IE4-W-036
 HPE1 VAL PUMP
 IE4-P-074
 HPE1 DS A RACK
 IE2HNL-034

DRYWELL EQUIPMENT
 DRAIN TANK PUMPS
 IE1NP-028
 IE1NP-03A

ZONE G

X60N
 C68N
 C60B
 L60B
 X67R
 X60R
 C67A
 C60R
 L60N
 LATER
 C60N
 LATER
 L60R

SUMP AND PUMP TO DRAIN
 ACROSS CONCRETE (H-1-P-224A)
 1/2\"/>

CORE SPRAY RACK A
 IE1HNL-01

CORE SPRAY LOOP
 A LEVEL PUMP
 IE21-P-049(A)

RHR TUBE
 WITHDRAWAL
 SEACE

FLOOR DRAIN
 SUMP K01-TX-056A

RADI-STE EGPT DRAINS
 FLOOR DRAIN SUMP
 PUMP (H-1-P-074) 1/2\"/>

DRYWELL EGPT
 DRAIN PUMPS
 IE1NP-028

CORE SPRAY
 PUMP
 IE21-P-049(A)

FOR DETAILS OF VENTS,
 DRAINS & SEAL WATER SEE
 P1031, P1032, P1038

FOR DETAILS OF VENTS,
 DRAINS & SEAL
 WATER (P-080, P-080C)
 TEST




FIG. C-2
 RADIATION ZONE G
 REACTOR CONTAINMENT
 PLAN EL.8'-0" TO 20'-0" NORTH
 SHOREHAM NUCLEAR POWER STATION UNIT-1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT





FIG. C-3
RADIATION ZONE G
REACTOR CONTAINMENT
PLAN EL. 8'0" TO 20'0" SOUTH
SHOREHAM NUCLEAR POWER STATION-UNIT I
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS IE ELECTRICAL EQUIPMENT






FIG. C-4
 RADIATION ZONE G
 REACTOR CONTAINMENT
 PLAN EL. 20'0" TO 40'0" NORTH
 SHOREHAM NUCLEAR POWER STATION UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS IE ELECTRICAL EQUIPMENT



ZONE G





FIG. C-5
 RADIATION ZONE G
 REACTOR CONTAINMENT
 PLAN EL. 20'0" TO 40'0" SOUTH
 SHOREHAM NUCLEAR POWER STATION UNIT I
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS IE ELECTRICAL EQUIPMENT

0' S A W
 180' G E






FIG. C-6
 RADIATION ZONE G,L
 REACTOR CONTAINMENT
 PLAN EL. 40'0" TO 63'0" NORTH
 SHOREHAM NUCLEAR POWER STATION UNIT I
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS IE ELECTRICAL EQUIPMENT





FIG C-7
 RADIATION ZONES G,L
 REACTOR CONTAINMENT
 PLAN EL. 40' 0" TO 63' 0" SOUTH
 SHOREHAM NUCLEAR POWER STATION-UNIT I
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS I/E ELECTRICAL EQUIPMENT







FIG. C-8
 RADIATION ZONE G
 REACTOR CONTAINMENT
 PLAN EL 63'-0" TO 78'-7" NORTH
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT







FIG. C-9
 RADIATION ZONES
 REACTOR CONTAINMENT
 PLAN EL. 63' 0" TO 78' 7" SOUTH
 SHOREHAM NUCLEAR POWER STATION UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS IE ELECTRICAL EQUIPMENT




- IM41-6-HW-52-151 P-2
- IM41-5-HW-17-151 P-1
- IM50-6-CW-126-151 P-8
- IM50-6-CW-116-151 P-7
- P-27
- IM50-10-CW-24-151-3 P-5
- IM50-4-CW-24-151 P-3
- IM50-4-CW-25-151 P-4
- IM50-10-CW-7-151-3 P-6

ZONE G


ZONE M

- CRD HYDR CONT UNITS
- IC18-CRD-52-901A-2
- L66R, K67R, C67R, C66N
- X67R, X67N, C66N
- K66R, K66N, C66R, C67N, X66R, X66N



X77B
X77N
X76B
X76B
X76B
X77N

FIG. C-10
RADIATION ZONES G, H, M
REACTOR CONTAINMENT
PLAN EL. 78'7" TO 112'9" NORTH
SHOREHAM NUCLEAR POWER STATION UNIT I
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS IE ELECTRICAL EQUIPMENT








FIG. C-II
 RADIATION ZONES G, H
 REACTOR CONTAINMENT
 PLAN EL. 78' 7" TO 112' 9" SOUTH
 SHOREHAM NUCLEAR POWER STATION UNIT I
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS IE ELECTRICAL EQUIPMENT

BUNDLE
 -301-3
 -205-301-3
 -202-301-3




IR21-10⁵ SLP-208-301-3
 IR21-10⁵ SLP-209-301-3
 IR10⁵ SLP-205-301-3

P-206-301-3

PLAN

FIG. C-12
 RADIATION ZONE T
 REACTOR CONTAINMENT
 PLAN EL. 76'-4 1/2" TO 96'-11 1/2"
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS IE ELECTRICAL EQUIPMENT







FIG. C-13
 RADIATION ZONES H,J,K,N,P
 REACTOR CONTAINMENT
 PLAN EL. 112'-9" TO 150'-9" NORTH
 SHOREHAM NUCLEAR POWER STATION-UNIT I
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS I/E ELECTRICAL EQUIPMENT










FIG. C-14
 RADIATION ZONES H, J, N, P
 REACTOR CONTAINMENT
 PLAN EL. 112'9" TO 150'9" SOUTH
 SHOREHAM NUCLEAR POWER STATION UNIT I
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS IE ELECTRICAL EQUIPMENT



PART PLAN EL 159'-9"








NOTE 1 - SEE FIGURE C-22 FOR PRIMARY CONTAINMENT TEMPERATURE AND PRESSURE ZONES.


FIG. C-16
 TEMPERATURE AND PRESSURE ZONE 1
 PLAN EL. 8'-0" TO 40'-0"
 REACTOR CONTAINMENT
 SHOREHAM NUCLEAR POWER STATION - UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT



NOTES:

- 1 ENTIRE SECONDARY CONTAINMENT AIR SPACE IS ZONE 2 EXCEPT AS NOTED FOR ZONE 21 ON THIS ELEVATION
2. SEE FIGURE C-22 FOR PRIMARY CONTAINMENT TEMPERATURE AND PRESSURE ZONES


FIG. C-17
 TEMPERATURE AND PRESSURE ZONES
 2, 21
 PLAN EL. 40'-0" TO 63'-0"
 REACTOR CONTAINMENT
 SHOREHAM NUCLEAR POWER STATION - UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT



PLAN EL 63'-0"

NOTE 1 - SEE FIGURE C-22 FOR PRIMARY CONTAINMENT TEMPERATURE AND PRESSURE ZONES.


FIG. C-18
 TEMPERATURE AND PRESSURE ZONES
 2, 3, 4, 5, 6, 7
 PLAN EL. 63'-0" TO 78'-7"
 REACTOR CONTAINMENT
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT




PLAN EL 78'-7"

NOTE 1- SEE FIGURE C-22 FOR PRIMARY CONTAINMENT TEMPERATURE AND PRESSURE ZONES.

FIG. C-19
 TEMPERATURE AND PRESSURE ZONES
 8, 9, 10, 11, 12
 PLAN EL. 78'-7" TO 112'-9"
 REACTOR CONTAINMENT
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT






PLAN EL 150'-9"

NOTE 1 - SEE FIGURE C-22 FOR PRIMARY CONTAINMENT TEMPERATURE AND PRESSURE ZONES

FIG. C-21
 TEMPERATURE AND PRESSURE ZONES
 18, 19, 21
 PLAN EL. 150'-9" TO 175'-9"
 REACTOR CONTAINMENT
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT



STEAM TO HPCI TURBINE

FIG. C-22
 TEMPERATURE AND PRESSURE ZONES
 SECTION VIEW
 REACTOR CONTAINMENT
 SHOREHAM NUCLEAR POWER STATION-UNIT I
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT

APPENDIX D
RADIATION, TEMPERATURE, AND
PRESSURE DATA

APPENDIX D

RADIATION, TEMPERATURE, AND PRESSURE DATA

The normal and accident service conditions are tabulated and graphed with respect to time as shown on the following sheets. The normal service conditions for primary and secondary containment temperatures, pressures, and levels of humidity are listed in Table D-1 as taken from FSAR Table 3.11.2-1. The reactor building primary containment environmental service conditions and the secondary containment radiation conditions are tabulated on Figures D-1 and D-2, respectively, which are taken from Figure, II.B.2-16 and -17 in the NUREG-0737 submittal to the NRC and are included herein for convenience. Radiation curves are shown on Figures D-3 through D-20. Temperature curves are shown on Figures D-21 through D-40. Pressure curves are shown on Figures D-41 and D-42. Curve D-43 indicates the pressure transient in the secondary containment due to a LOCA and is reproduced from an FSAK figure.

INDEX OF ENVIRONMENTAL
TABLES AND FIGURES

<u>Title</u>	<u>Table No.</u>
Normal Pressure, Temperature and Humidity Conditions	D-1
<u>Title</u>	<u>Figure No.</u>
Reactor Building, Primary Containment Environmental Zones	D-1
Reactor Building, Secondary Containment Normal and Accident Radiation Zones	D-2
Reactor Building, Primary Containment Radiation Level for Zone A	D-3
Reactor Building, Primary Containment Radiation Level for Zone B	D-4
Reactor Building, Primary Containment Radiation Level for Zone C	D-5
Reactor Building, Primary Containment Radiation Level for Zone D	D-6
Reactor Building, Primary Containment Radiation Levels for Zones E and F	D-7
Reactor Building, Secondary Containment Radiation Level for Zone G	D-8
Reactor Building, Secondary Containment Radiation Level for Zone H	D-9
Reactor Building, Secondary Containment Radiation Level for Zone J	D-10
Reactor Building, Secondary Containment Radiation Level for Zone K	D-11
Reactor Building, Secondary Containment Radiation Level for Zone L	D-12
Reactor Building, Secondary Containment Radiation Level for Zone M	D-13
Reactor Building, Secondary Containment Radiation Level for Zone N	D-14

<u>Title</u>	<u>Figure No.</u>
Reactor Building, Secondary Containment Radiation Level for Zone P	D-15
Reactor Building, Secondary Containment Radiation Level for Zone Q	D-16
Reactor Building, Secondary Containment Radiation Level for Zone R	D-17
Reactor Building, Secondary Containment Radiation Level for Zone S	D-18
Reactor Building, Secondary Containment Radiation Level for Zone T	D-19
Reactor Building, Secondary Containment Radiation Level	D-20
Reactor Building, Secondary Containment Temperature Levels for Zone 1	D-21
Reactor Building, Secondary Containment Temperature Levels for Zone 2	D-22
Reactor Building, Secondary Containment Temperature Levels for Zone 3	D-23
Reactor Building, Secondary Containment Temperature Levels for Zone 4	D-24
Reactor Building, Secondary Containment Temperature Levels for Zone 5	D-25
Reactor Building, Secondary Containment Temperature Levels for Zone 6	D-26
Reactor Building, Secondary Containment Temperature Levels for Zone 7	D-27
Reactor Building, Secondary Containment Temperature Levels for Zone 8	D-28
Reactor Building, Secondary Containment Temperature Levels for Zone 9	D-29
Reactor Building, Secondary Containment Temperature Levels for Zone 10	D-30
Reactor Building, Secondary Containment Temperature Levels for Zone 11	D-31

<u>Title</u>	<u>Figure No.</u>
Reactor Building, Secondary Containment Temperature Levels for Zone 12	D-32
Reactor Building, Secondary Containment Temperature Levels for Zone 13	D-33
Reactor Building, Secondary Containment Temperature Levels for Zone 14	D-34
Reactor Building, Secondary Containment Temperature Levels for Zone 15	D-35
Reactor Building, Secondary Containment Temperature Levels for Zone 16	D-36
Reactor Building, Secondary Containment Temperature Levels for Zone 17	D-37
Reactor Building, Secondary Containment Temperature Levels for Zone 18	D-38
Reactor Building, Secondary Containment Temperature Levels for Zone 19	D-39
Reactor Building, Secondary Containment Temperature Levels for Zone 20	D-40
Reactor Building, Secondary Containment Pressure Levels for Zones 1-12 and 15-20	D-41
Reactor Building, Secondary Containment Pressure Levels for Zones 13 and 14	D-42
Simulated Pressure Transient in Secondary Containment	D-43

TABLE D-1

NORMAL PRESSURE, TEMPERATURE,
AND HUMIDITY CONDITIONS
SHOREHAM NUCLEAR POWER STATION - UNIT 1

	<u>Area</u>	<u>Pressure</u>	<u>Temperature</u> <u>°F</u>	<u>Relative</u> <u>Humidity</u> <u>%</u>
I.	<u>Primary Containment</u>			
1.	Area above shield wall to top of drywell (Zone A-22)	-3 to 2 psig	150 max 127 avg	40-55
2.	Region adjacent to core (Zone B-22)	-3 to 2 psig	150 max	40-55
3.	Under reactor pressure vessel, inside of shield wall (Zone C-22)	-3 to 2 psig	150 max	40-55
4.	Vicinity recirculation pump motors (Zone D-22)	-3 to 2 psig	150 max	40-55
5.	Suppression chamber air space (Zone E-23)	-3 to 2 psig	150 max	40-55
6.	Suppression pool (Zone F-23)	-3 to 2 psig	150 max	40-55
II.	<u>Secondary Containment</u>			
1.	All areas except steam tunnel and MCC cubicles	-0.5 to 0 inches water gage, static pressure	60 to 104	50
2.	Main steam tunnel (Zone ST)	Same as above	120 to 135	50
3.	MCC rooms El. 112' (Zone N-21)	Atmospheric	80 to 104	90

ZONE	PRIMARY	NORMAL			
		RADIATION	TEMPERATURE	HUMIDITY	PRESSURE
A-22	AREA ABOVE SHIELD WALL TO TOP OF DRYWELL	8.8 X 10 ⁶ RAD γ 6.3 X 10 ¹³ NEUT/CM ²	150°F MAX 127°F AVG.	40-55% 100% FOR EXTENDED PERIODS	-3 TO 2 PS
B-22	REGION ADJACENT TO CORE OUTSIDE OF SHIELD WALL	7.0 X 10 ⁷ RAD γ 8.3 X 10 ¹⁴ NEUT/CM ²	150°F MAX		
C-22	UNDER RPV INSIDE OF SHIELD WALL AND REACTOR PEDESTAL	2.5 X 10 ⁶ RAD γ 1.3 X 10 ⁹ NEUT/CM ²			
D-22	VICINITY OF RECIRC. PUMP MOTORS	1.8 X 10 ⁷ RAD γ 2.5 X 10 ¹² NEUT/CM ²			
E-23	SUPPRESSION CHAMBER AIR SPACE	3.5 X 10 ⁴ RAD γ 2.5 X 10 ¹¹ NEUT/CM ²			
F-23	SUPPRESSION POOL	3.5 X 10 ⁴ RAD γ 2.5 X 10 ¹¹ NEUT/CM ²			

ZONE	NEUTRON FLUENCE	EQUIVALENT RADS γ	NEW TOTAL RADS γ
A	6.3 X 10 ¹³ NEUT/CM ²	4.0 X 10 ⁵ RADS γ	1.1 X 10 ⁸ RAD γ
B	8.3 X 10 ¹⁴ NEUT/CM ²	5.5 X 10 ⁶ RADS γ	1.76 X 10 ⁸ RAD γ
C	1.3 X 10 ⁹ NEUT/CM ²	8.68 X 10 ⁰ RADS γ	1.0 X 10 ⁸ RAD γ
D	2.5 X 10 ¹² NEUT/CM ²	1.67 X 10 ⁴ RAD γ	1.2 X 10 ⁸ RAD γ
E	2.5 X 10 ¹¹ NEUT/CM ²	1.67 X 10 ³ RAD γ	1.0 X 10 ⁸ RAD γ
F	2.5 X 10 ¹¹ NEUT/CM ²	1.67 X 10 ³ RAD γ	1.0 X 10 ⁸ RAD γ

NOTES:

1. "NORMAL RADIATION" IS CUMULATIVE 40-YR
2. "ACCIDENT RADIATION" IS CUMULATIVE 6-
3. CONSIDER "NEW TOTAL RAD" COLUMN FOR γ
4. THE EFFECTS OF THE NEUTRON FLUENCE IS

ACCIDENT (LOCA)					TOTAL
E	RADIATION	TEMPERATURE	HUMIDITY	PRESSURE	RADIATION
IG	1×10^8 RAD γ 1×10^9 RAD β	340°F - 0-3 HRS 320°F - 3-6 HRS 250°F - 6 HRS-1 DAY 200°F - 1-4 DAYS 150°F - 5-180 DAYS	100% (SUPERHEATED) (STEAM FOR FIRST DAY)	0 to 48 PSIG - 0 to 6 HRS 48 to 15 PSIG - 6 HRS to 4 DAYS 15 to 10 PSIG - 4 DAYS to 180 DAYS	1.1×10^8 RAD γ 1×10^9 RAD β 6.3×10^{13} NEUT/CM ²
	1×10^8 RAD γ 1×10^9 RAD β				1.7×10^8 RAD γ 1×10^9 RAD β 8.3×10^{14} NEUT/CM ²
					1×10^8 RAD γ 1×10^9 RAD β 1.3×10^9 NEUT/CM ²
					1.2×10^8 RAD γ 1×10^9 RAD β 2.5×10^{12} NEUT/CM ²
		225°F - 0-12 HRS 212°F - 12 HRS-1 DAY 150°F - 1-7 DAYS 90°F - 8-180 DAYS			1×10^8 RAD γ 1×10^9 RAD β 2.5×10^{11} NEUT/CM ²
					1×10^8 RAD γ 1×10^9 RAD β 2.5×10^{11} NEUT/CM ²

TOTAL
 MONTH TOTAL
 RADIATION
 NEGLIGIBLE

FIG. D-1
 REACTOR BUILDING PRIMARY
 CONTAINMENT ENVIRONMENTAL ZONES
 SHOREHAM NUCLEAR POWER STATION-UNIT I
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS IE ELECTRICAL EQUIPMENT

ZONES	G		H		J		K		L		M
NORMAL RADIATION (RADS%) (40YR)	1.8×10^3		1.8×10^3		1.8×10^3		1.8×10^3		1.8×10^3		1.8×10^3
ACCIDENT RADIATION (6 MO)	SUPPRESSION POOL WATER		REACTOR BLDG (AIRBORNE)		HYDROGEN RECOMBINER		RBSVS FILTER		24 INCH RHR PIPE		8 FT 4 PC PI
			LOCA PBOC								
TIME (HR)	RAD/HR	RAD	RAD/HR	RAD	RAD/HR	RAD	RAD/HR	RAD	RAD/HR	RAD	RAD/HR
0.0	1.96+5	0.00	0.00	0.00	1.40+4	0.00	0.00	0.00	1.43+5	0.00	1.87+4
0.1	1.60+5	1.77+4	2.32+1	1.24+0	1.05+4	1.22+3	3.14+1	1.24+0	1.18+5	1.30+4	1.33+4
			7.40+3	8.21+2							
0.5	1.42+5	7.81+4	8.80+1	2.41+1	8.04+3	4.90+3	2.60+2	5.19+1	1.05+5	5.76+4	9.54+3
			5.63+3	3.35+3							
1.0	1.16+5	1.42+5	1.45+2	8.32+1	6.52+3	8.53+3	7.23+2	2.78+2	8.65+4	1.05+5	7.61+3
			4.57+3	5.88+3							
5.0	4.51+4	4.20+5	2.89+2	1.05+3	2.74+3	2.76+4	6.14+3	1.34+4	3.34+4	3.11+5	2.46+3
			1.78+3	1.70+4							
8.0	3.27+4	5.36+5	3.01+2	1.94+3	2.06+3	3.47+4	1.08+4	3.86+4	2.40+4	3.97+5	2.20+3
			1.14+3	2.13+4							
24.0	1.36+4	8.74+5	2.76+2	6.55+3	1.06+3	5.81+4	3.36+4	3.90+5	9.60+3	6.41+5	1.07+3
			2.65+2	3.03+4							
720.0	1.00+3	2.82+6	8.42+0	4.87+4	4.36+1	2.10+5	9.52+4	9.48+7	6.95+2	1.96+6	2.77+1
			9.48-4	3.45+4							
2160.0	3.34+2	3.62+6	4.48-2	5.08+4	7.14+0	2.34+5	1.40+3	1.27+8	2.43+2	2.52+6	1.30-1
			5.42-6	3.45+4							
4380.0	1.60+2	4.14+6	9.19-3	5.08+4	3.37+0	2.45+5	7.91-1	1.27+8	1.17+2	2.91+6	9.24-2
			1.89-9	3.45+4							
8760.0 (1 YEAR)	5.97+1	6.20+6	2.25-3	5.08+4	1.58+0	2.45+5	2.25-3	1.27+8	4.35+1	3.38+6	7.25-2
			≈ 0	3.45+4							

BETA DOSE RATE AND INTEGRATED DOSE-ALL SECONDARY

TIME (HRS)	0.0	0.1	0.5	1.0	4.0	8.0	24.0	72.0	2160
DOSE RATE (RADS/HR)	0.0	1.01+2	3.18+02	5.31+2	1.22+3	1.68+3	2.26+3	8.10+1	1.07+1
INTEGREGATED DOSE (RADS)	0.0	5.79+0	9.14+1	3.06+2	3.09+3	8.46+3	4.18+4	4.81+5	5.13+5

NOTE

FOR PBOC CASE, USE ZONE H VALUES FOR ENTIRE REACTOR SECONDARY CONTAINMENT


	N		P		Q		R		S		T		
10^3	1.8×10^3		1.1×10^5		1.3×10^8		2.1×10^5		1.8×10^6		4.9×10^5		
INCH AC PE	MCC CUBICLE		RWCU PUMP ROOM		RWCU FILTERS & TANKS		RWCU HEAT EXCHANGERS		FPC & CU ROOM		STEAM TUNNEL		
RAD	RAD/HR	RAD	RAD/HR	RAD	RAD/HR	RAD	RAD/HR	RAD	RAD/HR	RAD	RAD/HR	RAD	
0.00	0.00	0.00	SAME AS ZONE H									SAME AS ZONE L	
5.58+3	2.32+1	1.24+0											
5.11+3	8.84+1	2.41+1											
1.04+4	1.46+2	8.36+1											
1.85+4	3.02+2	1.10+3											
1.55+4	3.24+2	2.02+3											
1.96+4	3.46+2	7.37+3											
1.99+5	2.00+2	2.39+5											
2.05+5	2.85+0	3.05+5											
1.06+5	1.08-2	3.06+5											
1.06+5	2.25-3	3.06+5											

CONTAINMENT ZONES

4380	6570	8760	10950	13140	15330	17520
1.78+0	3.20+0	1.77+0	9.78-1	5.42-1	3.00-1	1.60-1
1.31+5	5.41+5	5.46+5	5.49+5	5.50+5	5.51+5	5.52+5

FIG. D-2
REACTOR BUILDING SECONDARY
CONTAINMENT NORMAL AND ACCIDENT
RADIATION ZONES

SHOREHAM NUCLEAR POWER STATION-UNIT 1
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES:

THE PROFILE FOR THE INTEGRATED TOTAL RADIATION SHOWS THE 2 YEAR LOCA PROFILE BEGINNING AFTER THE 40 YEAR TOTAL (LINE a-b)

IT IS ASSUMED HERE THAT THE LOCA OCCURS AFTER 40 YEARS AT NORMAL OPERATION AND THE DOSE IS CUMULATIVE

FIG. D-3
 REACTOR BUILDING, PRIMARY CONTAINMENT RADIATION LEVEL FOR ZONE A
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT



NOTES:


THE PROFILE FOR THE INTEGRATED TOTAL RADIATION SHOWS THE 2 YEAR LOCA PROFILE BEGINNING AFTER THE 40 YEAR TOTAL (LINE a-b)

IT IS ASSUMED HERE THAT THE LOCA OCCURS AFTER 40 YEARS AT NORMAL OPERATION AND THE DOSE IS CUMULATIVE

FIG. D-4

REACTOR BUILDING, PRIMARY CONTAINMENT RADIATION LEVEL FOR ZONE B

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS I/E ELECTRICAL EQUIPMENT



NOTES:


THE PROFILE FOR THE INTEGRATED TOTAL RADIATION SHOWS THE 2 YEAR LOCA PROFILE BEGINNING AFTER THE 40 YEAR TOTAL (LINE a-b)

IT IS ASSUMED HERE THAT THE LOCA OCCURS AFTER 40 YEARS AT NORMAL OPERATION AND THE DOSE IS CUMULATIVE

FIG. D-5

REACTOR BUILDING, PRIMARY CONTAINMENT RADIATION LEVEL FOR ZONE C

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES:

THE PROFILE FOR THE INTEGRATED TOTAL RADIATION SHOWS THE 2 YEAR LOCA PROFILE BEGINNING AFTER THE 40 YEAR TOTAL (LINE a-b)

IT IS ASSUMED HERE THAT THE LOCA OCCURS AFTER 40 YEARS AT NORMAL OPERATION AND THE DOSE IS CUMULATIVE

FIG. D-6
 REACTOR BUILDING, PRIMARY CONTAINMENT RADIATION LEVEL FOR ZONE D
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS 1E ELECTRICAL EQUIPMENT



NOTES:


THE PROFILE FOR THE INTEGRATED TOTAL RADIATION SHOWS THE 2 YEAR LOCA PROFILE BEGINNING AFTER THE 40 YEAR TOTAL (LINE a-b)

IT IS ASSUMED HERE THAT THE LOCA OCCURS AFTER 40 YEARS AT NORMAL OPERATION AND THE DOSE IS CUMULATIVE

FIG. D-7

REACTOR BUILDING, PRIMARY CONTAINMENT RADIATION LEVELS FOR ZONES E & F

SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS I/E ELECTRICAL EQUIPMENT




NOTES

1. ACCIDENT DOSE FROM LOCA ONLY
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE = ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b).

FIG D-8

REACTOR BUILDING, SECONDARY
CONTAINMENT RADIATION LEVEL
FOR ZONE G

SHOREHAM NUCLEAR POWER STATION-UNIT 1
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES

1. ACCIDENT DOSE FROM LOCA ONLY
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE=ACCIDENT DOSE+ 40 YEAR NORMAL DOSE (LINE a-b).

FIG. D-9

REACTOR BUILDING, SECONDARY CONTAINMENT RADIATION LEVEL FOR ZONE H


SHOREHAM NUCLEAR POWER STATION-UNIT I ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS I/E ELECTRICAL EQUIPMENT



NOTES

1. ACCIDENT DOSE FROM LOCA ONLY.
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE = ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b).

FIG. D-10
 REACTOR BUILDING, SECONDARY
 CONTAINMENT RADIATION LEVEL
 FOR ZONE J
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS I/E ELECTRICAL EQUIPMENT




NOTES

1. ACCIDENT DOSE FROM LOCA ONLY.
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE = ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b).

FIG. D-II

REACTOR BUILDING, SECONDARY CONTAINMENT RADIATION LEVEL FOR ZONE K

SHOREHAM NUCLEAR POWER STATION-UNIT I ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS I E ELECTRICAL EQUIPMENT




NOTES

1. ACCIDENT DOSE FROM LOCA ONLY.
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE = ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b).

FIG. D-12

REACTOR BUILDING, SECONDARY
CONTAINMENT RADIATION LEVEL
FOR ZONE L

SHOREHAM NUCLEAR POWER STATION-UNIT I
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS I/E ELECTRICAL EQUIPMENT




NOTES

1. ACCIDENT DOSE FROM LOCA ONLY.
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE = ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b)

FIG. D-13

REACTOR BUILDING, SECONDARY
CONTAINMENT RADIATION LEVEL
FOR ZONE M


SHOREHAM NUCLEAR POWER STATION - UNIT 1
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS I/E ELECTRICAL EQUIPMENT



NOTES

1. ACCIDENT DOSE FROM LOCA ONLY.
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE = ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b).


FIG. D-14
 REACTOR BUILDING, SECONDARY
 CONTAINMENT RADIATION LEVEL
 FOR ZONE N
 SHOREHAM NUCLEAR POWER STATION-UNIT I
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS I/E ELECTRICAL EQUIPMENT



NOTES

1. ACCIDENT DOSE FROM LOCA ONLY.
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE = ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b).

FIG. D-15
 REACTOR BUILDING, SECONDARY
 CONTAINMENT RADIATION LEVEL
 FOR ZONE P
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS IE ELECTRICAL EQUIPMENT




NOTES

1. ACCIDENT DOSE FROM LOCA ONLY.
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE = ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b).

FIG. D-16

REACTOR BUILDING, SECONDARY
CONTAINMENT RADIATION LEVEL
FOR ZONE Q

SHOREHAM NUCLEAR POWER STATION-UNIT I
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS I E ELECTRICAL EQUIPMENT




NOTES

1. ACCIDENT DOSE FROM LOCA ONLY.
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE=ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b).

FIG. D-17

REACTOR BUILDING, SECONDARY CONTAINMENT RADIATION LEVEL FOR ZONE R

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS I/E ELECTRICAL EQUIPMENT




NOTES

1. ACCIDENT DOSE FROM LOCA ONLY.
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE = ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b).

FIG. D-18

REACTOR BUILDING, SECONDARY
CONTAINMENT RADIATION LEVEL
FOR ZONE S

SHOREHAM NUCLEAR POWER STATION-UNIT I
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS I E ELECTRICAL EQUIPMENT




NOTES

1. ACCIDENT DOSE FROM LOCA ONLY.
2. SEE FIGURE D-20 FOR PBOC RAD.
3. INTEGRATED DOSE = ACCIDENT DOSE + 40 YEAR NORMAL DOSE (LINE a-b)

FIG. D-19


REACTOR BUILDING, SECONDARY
CONTAINMENT RADIATION LEVEL
FOR ZONE T

SHOREHAM NUCLEAR POWER STATION-UNIT I
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS I/E ELECTRICAL EQUIPMENT



NOTE
'PBOC RAD' APPLIES TO ALL
SECONDARY CONTAINMENT (RBS) ZONES

FIG. D-20
REACTOR BUILDING, SECONDARY
CONTAINMENT PBOC RADIATION LEVEL
SHOREHAM NUCLEAR POWER STATION-UNIT I
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS I/E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 700 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-21

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 1

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS I/E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 700 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-22

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 2

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS I/E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 700 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-23

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 3

SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS I/E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 70 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPS HELB.

FIG. D-24

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 4

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS I/E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 47 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-25

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 5

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 32 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-26

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 6

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 66 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-27

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 7
 SHOREHAM NUCLEAR POWER STATION-UNIT 4
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 26 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. 3" MSD RETURNS TO 104°F AT 2.8 HRS.
4. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB

FIG. D-28

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 8


SHOREHAM NUCLEAR POWER STATION-UNIT 1
ENVIRONMENTAL QUALIFICATION REPORT
FOR CLASS 1E ELECTRICAL EQUIPMENT



NOTES

1. PEAK TEMPERATURE RISE WITHIN 25 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.


FIG. D-29
REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 9
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT



NOTES

1. PEAK TEMPERATURE RISE WITHIN 33 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-30
 REACTOR BUILDING, SECONDARY
 CONTAINMENT TEMPERATURE
 LEVELS FOR ZONE 10
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 29 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-31

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 11


SHOREHAM NUCLEAR POWER STATION - UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS I/E ELECTRICAL EQUIPMENT



NOTES

1. PEAK TEMPERATURE RISE WITHIN 15 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-32
 REACTOR BUILDING, SECONDARY
 CONTAINMENT TEMPERATURE
 LEVELS FOR ZONE 12
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 9 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-33

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 13

SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 9 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-34


REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 14

SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS I/E ELECTRICAL EQUIPMENT



- NOTES
1. PEAK TEMPERATURE RISE WITHIN 36 SECONDS FROM TIME ZERO.
 2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
 3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-35
 REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 15
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 36 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-36

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 16

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 35 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-37

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 17


SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS 1E ELECTRICAL EQUIPMENT



NOTES

1. PEAK TEMPERATURE RISE WITHIN 103 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-38
 REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 18
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT




NOTES

1. PEAK TEMPERATURE RISE WITHIN 54 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-39

REACTOR BUILDING, SECONDARY CONTAINMENT TEMPERATURE LEVELS FOR ZONE 19


SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS 1E ELECTRICAL EQUIPMENT



NOTES

1. PEAK TEMPERATURE RISE WITHIN 517 SECONDS FROM TIME ZERO.
2. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
3. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-40
 REACTOR BUILDING, SECONDARY
 CONTAINMENT TEMPERATURE
 LEVELS FOR ZONE 20
 SHOREHAM NUCLEAR POWER STATION-UNIT 1
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS I/E ELECTRICAL EQUIPMENT




NOTE

1. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
2. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB

FIG. D-41

REACTOR BUILDING, SECONDARY CONTAINMENT PRESSURE LEVELS FOR ZONES 1-12 & 15-20

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS 1E ELECTRICAL EQUIPMENT



NOTE

1. LIMITING PROFILE FOR HELB, ALSO ENVELOPES MELB.
2. LIMITING PROFILE FOR MELB, ALSO ENVELOPES HELB.

FIG. D-42

REACTOR BUILDING, SECONDARY CONTAINMENT PRESSURE LEVELS FOR ZONES 13 & 14

SHOREHAM NUCLEAR POWER STATION-UNIT 1 ENVIRONMENTAL QUALIFICATION REPORT FOR CLASS I/E ELECTRICAL EQUIPMENT




FIG. D-43
 PRESSURE IN SECONDARY CONTAINMENT
 FOLLOWING A LOCA
 SHOREHAM NUCLEAR POWER STATION - UNIT I
 ENVIRONMENTAL QUALIFICATION REPORT
 FOR CLASS I E ELECTRICAL EQUIPMENT

APPENDIX E
ENVIRONMENTAL PROFILE CALCULATIONS

APPENDIX E

ENVIRONMENTAL PROFILE CALCULATIONS

E.1 INTRODUCTION

This appendix describes the environmental profile calculations methodology, as indicated in Section 3 of the text.

E.2 SHORT TERM RESPONSE TO HIGH ENERGY LINE BREAKS (HELB)

In the HELB analysis, the following specific breaks are considered:

1. Six inch RWCU break in RWCU pump room, "B" pump, elevation 112 ft.
2. Four inch RWCU break in RWCU heat exchanger room, elevation 126 ft.
3. Ten inch HPCI steam line break, elevation 8 ft.
4. Three inch RCIC steam line and three inch Main Steam Drain (MSD) breaks in steam tunnel, elevation 76 ft.

Blowdown due to breaks is calculated by using the Moody critical flow model, from "Maximum Flow Rate of a Single Component, Two-Phase Mixture," by F.J. Moody, Transactions of the ASME, February 1965. This model states that the mass release rate is equal to the mass flux times the cross-sectional area of the break.

$$\dot{m} = GA_1, \text{ (eq-1)}$$

where \dot{m} = mass release rate,

G = mass flux based on a pressure of 1055 psia, and

A_1 = cross-sectional area of the pipe.

A_1 is the area of the smallest restriction in the pipe upstream of the break. To include the volume of pipe between the smallest restriction and the break with the volume of piping downstream from the break in the blowdown determination requires the following equations (from GE Mark III Pressure Suppression Containment System Analytical Model, June 1974, Appendix B):

for liquid breaks:

$$\dot{m} = 0.5 GA_2 \text{ (eq-2A)}$$

for steam breaks:

$$\dot{m} = 0.75 GA_2 \text{ (eq-2B)}$$

where A_2 = cross sectional area of the
break pipe

These volumes are assumed to blowdown in this manner at a constant pressure until the mass initially contained in the pipe is depleted. The blowdown continues in accordance with eq-1 until blowdown isolation occurs.

The following assumptions are made concerning blowdown duration:

1. For the 6 inch RWCU, 4 inch RWCU, 10 inch HPCI, and 3 inch MSD breaks, the blowdown is isolated automatically on area high temperature.
2. For the 10 inch HPCI and 3 inch MSD breaks, the blowdown is assumed to end abruptly upon isolation valve closure due to the relatively small size of the isolation valves.
3. For the 6 inch RWCU and 4 inch RWCU breaks, the isolation valve is a large gate valve which causes the blowdown rate to ramp down as the valve closes.
4. Blowdown duration is determined as follows:
 - a. The pipe break node reaches setpoint temperature of the automatic closure system followed by a 10 second "soak" time for the detector to respond, followed by the isolation valve closure time.
 - b. Simultaneously with the pipe break, a loss of offsite power is assumed which requires an additional 10 second delay until power is restored via the diesel generator.
 - c. For some breaks the area high temperature setpoint is achieved almost instantaneously. In these cases, the time to reach the setpoint temperature and the detector "soak" time are assumed to occur during the 10 second duration of power loss. Therefore, isolation valve closure starts 10 seconds after the break occurs.

- d. The 3 inch RCIC break does not have automatic isolation. Thus, blowdown duration includes all other time delays in addition to a ten minute operator response time to manually initiate blowdown isolation due to area high temperature alarm.

For pipe breaks which cause a plant trip and an assumed loss of power or for cases where normal ventilation is unavailable, the reactor building RBSVS would be initiated automatically and operate throughout the duration of the analysis. However, credit is taken for only one train of RBSVS (the other train is assumed to be a single failure).

Heat sinks are modeled in the short-term analyses but only concrete heat sinks were considered and no energy transfer out of the secondary containment is assumed through the heat sinks. Metal heat sinks are neglected for conservatism.

A 20 zone model of the Reactor Building secondary containment is used (see environmental zone maps in Appendix D).

This 20 zone model with blowdown data, ventilation data, and heat sink data are input into a computer code (called THREED) which calculates peak temperatures and pressures. This computer code was developed by S&W and used in previous Section 6.2 FSAR analyses.

E.3 SHORT TERM RESPONSE TO MODERATE ENERGY LINE CRACKS (MELB)

The blowdown rate is based on Bernoulli's theorem. The crack postulated consists of a sub-cooled liquid and is modeled as an orifice with an area of:

$$A = D/2 \times th/2$$

where A = area of crack,

D = Diameter of cracked pipe, and
th = wall thickness of the cracked pipe.

The blowdown is assumed to be frictionless and an orifice discharge coefficient of 1.0 is used. The following equation represents the mass blowdown rate in lbm/sec:

$$\dot{m} = 0.525d^2 C \sqrt{\Delta P \rho} \quad (\text{eq-3})$$

where m = mass release rate,

d = effective diameter of the crack,

C = orifice discharge coefficient,

ΔP = difference in pressure between
RHR system pressure and atmospheric
pressure, and

δ = density of the system water.

d is determined from the following:

$$d = 2 \sqrt{A/\pi}$$

The energy release rate \dot{Q} is determined by multiplying the mass release rate \dot{m} by the enthalpy h of the fluid.

$$\dot{Q} = \dot{m} h$$

The RHR crack is assumed to be isolated in 11 minutes after the crack occurs. The 11 minutes includes time for water to accumulate at the 8 ft elevation for a high water alarm followed by the time required for an operator to initiate isolation and time for the isolation valves to close.

The model of the Reactor Building secondary containment used for an RHR crack is a 24 zone model, similar to the 20 zone model mentioned earlier except that El. 8 it is subdivided into two zones and El. 40 ft is subdivided into four zones.

Heat sinks are modeled in 20 of the 24 zones. Heat sinks for the smallest zones are neglected.

No part of the ventilation system is considered in the RHR crack short-term analysis.

The 24 zone model data, blowdown data, and heat sink data are input into a computer code (called THREED VER 12 LEV 01) which calculates peak temperatures and pressures.

E.4 RADIATION CALCULATIONS

A. Source Term

Radioactive Source Release and Distribution assumptions are as follows:

1. Radioactive Source Release

The percents of core inventory radioactive fission products assumed to be released from the fuel rods for LOCA events are:

noble gases (Kr, Xe)	100%
iodine	50%
others	1%

This entire release is assumed to occur instantaneously at the start of the accident.

2. Radioactive Source Distribution

In order to envelope the full spectrum of break sizes and depressurization rates, two bounding events and source distributions are considered.

The first event considered is a LOCA (both pressurized and depressurized events).

In this event, the following fission products are considered to be uniformly mixed in the following volumes:

a. Suppression Pool

noble gases	0%
iodine	50%
others	1%

b. Combined Drywell/Wetwell Air Space

noble gases	100%
iodine	25%
others	0%

c. Reactor Coolant System Steam Space

The following distribution is used for determining reactor building pipe shine doses due to HPCI, RCIC and MSIV-LCS operation

noble gases	100%
iodine	25%
others	0%

Using the above distribution, time history radiation zones are established within the primary containment and within the secondary containment as follows:

1. Primary Containment - Previously described accident radiation levels (FSAR Table 3.11.2-1) adequately bound all LOCA

events for equipment within the primary containment and no new analyses are required.

2. Secondary Containment - Time history radiation zones are established for the secondary containment using the above sources distributed in the steam and liquid piping in the following fluid systems which are conservatively assumed to operate concurrently:

- a. High Pressure Coolant Injection (HPCI)
- b. Reactor Core Isolation Cooling (RCIC)
- c. Residual Heat Removal (RHR - all essential modes)
- d. Core Spray
- e. Reactor Building Standby Ventilation System (RBSVS)
- f. Main Steam Isolation Valve - Leakage Control (MSIV-LCS)
- g. Primary Containment Atmospheric Control (PCAC)

In addition to the radiation shine from the above system piping and components, the primary containment is assumed to leak at technical specification limits resulting in an airborne source term which is included in the radiation zoning. As provided by NUREG 0737, no additional leakage is assumed.

3. Excluded Systems

- a. All piping which could potentially carry undiluted reactor coolant into the secondary containment is isolated and is nonessential (e.g., RWCU, shutdown cooling mode of RHR). Accordingly, the undiluted reactor coolant liquid source discussed above is excluded. Adequate means are provided (Post Accident Sampling System) to insure safe radiation levels exist prior to use of any of these nonessential systems.
- b. The post accident sampling lines are excluded from specific evaluation due to

their size (typically 3/8 in. tubing) and because they are flushed after each use. Sufficient conservatism in integrated dose calculations exists to bound any effects of these small sources.

- c. The gaseous radwaste system lines are also excluded because they do not act as sources for any safety-related equipment. They are also located outside the reactor building and are isolated.
4. Outside Reactor Building - the calculated dose rates and integrated dose values for components located in buildings other than the Reactor Building are derived from the following sources:
- a. Direct shine from radioactivity within the Reactor Building which is both airborne and contained in specific components.
 - b. Airborne activity in the respective building due to ventilation intake.
 - c. Semi-infinite radioactive cloud which surrounds the respective building.
 - d. Skyshine from radiation originating in the Reactor Building and air-scattered to a receptor.

The pipe break inside primary containment and nonpipe break events are bounded by the LOCA event above.

The other event considered is a pipe break in secondary containment. This event provides the bounding values in some zones within the secondary containment in the short term (i.e., less than 30 days). However, the LOCA doses provide the boundary values for doses for times longer than 30 days.

APPENDIX F
ENVIRONMENTAL QUALIFICATION
STATUS REPORT

APPENDIX F

ENVIRONMENTAL QUALIFICATION STATUS REPORT

The following is a sample of an entry into the Environmental Qualification Status Report (EQSR):

REPORT NO. PES-000	STONE AND WEBSTER ENGINEERING LOCATION	PROJECT DATE	01/11/00	PAGE	28
JOB NUMBER 1160007	PROJECT EQUIPMENT SYSTEM - LIS-1293	RESET NO.	803		
JOB NAME SHOREHAM - UNIT 1	ENVIRONMENTAL QUALIFICATION STATUS REPORT	RESET DATE	07/01/01		
JOB CLIENT LILCO	SORTED BY - IMA / IHD / SPEC				

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PC NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUPP	OP TIME	ACC / PERT	TR-CAT ENG CHG OP CD
1E21-PT010*	REACTOR PRESSURE	1E	G-10		BARTON	3129	180 DYS	7.5 IN.	*RG
BCL-HR550	GENERAL ELEC 110010	003	RES	00978	740	*FR MST			ALL A

Definitions of the entry headings are given below. An alphabetized list of equipment type abbreviations is provided in Appendix H.

Data definitions for entry headings are as follows:

EQUIPMENT ID
VENDOR ID

The first line identifies the Stone & Webster unique identification or mark number for each equipment. The first four characters represent the system number followed by an asterisk, "*", to indicate the equipment is safety-related or a dash "-", to indicate the equipment was not originally safety-related but is now identified by NRC Regulatory Guide 1.97 or other requirements. The key to the system code is described in Section 2.

The succeeding characters indicate the equipment type using the equipment identification symbol as documented in the Shoreham Project Procedures. The key to the equipment type symbol is provided in Appendix H. Additional characters provide a unique alpha-numeric identification for identical or redundant equipment. The second line indicates the General Electric identification code (the Master Parts List number) if the item is in the NSSS design.

EQUIPMENT DESCRIPTION
VENDOR NAME
PO NUMBER

The top line provides an abbreviated functional or application description of the equipment identified. IT DOES NOT GENERALLY INDICATE THE EQUIPMENT TYPE. The middle line is the equipment supplier. The lower line is the purchase order number for the equipment.

QAC
SPEC

The upper line is the Quality Assurance Category of the equipment, which is Class "1E" or "2E". The second line is the specification number under which the equipment is procured; the specifications are identified by the specification numbers listed in Section 2.

ZONE
BLDG ELEV

The first line provides an alpha-numeric code for the environmental zone in which the equipment is located in a format of "letter - two digit number." The radiation zone is designated by the first (letter) character. The two digits after "-" designate the temperature/pressure zone. Radiation zones and temperature/pressure zones do not necessarily coincide. The second line provides building and elevation (feet above sea level) to describe equipment location. The key to the building abbreviations is as follows:

<u>Building Code</u>	<u>Building Name</u>
RBD	Reactor Building Drywell
RBS	Reactor Building Secondary
RBP	Reactor Building Primary
YD	Yard
ST	Steam Tunnel

MAKE/MANUFACTURER
MODEL/CATALOG NO.

The first line identifies the equipment manufacturer. The second line provides the manufacturer's model or catalog number, or any other identifying number for the equipment.

EQ SHEET
QUAL STAT
SUBMG

The first line identifies the Environmental Qualification Summary Sheet (EQSS). Each EQSS for BOP equipment is identified by the specification number, summary sheet number, and revision level if

not the original issue. For NSSS equipment, each EQSS is identified with a four digit number. The first digit is "3" representing Specification SH1-003 with the equipment group designated by the succeeding digits. The second line lists the qualification status of equipment in an abbreviated form as follows:

EQ - Equipment is qualified

QG - Equipment is qualified except for aging

FT - Documentation has been reviewed, further test/analysis recommended

MR - Modification of equipment is recommended for qualification

RR - Replacement is recommended, test report for qualified replacement will be evaluated

DR - Documentation is in review

TA - Testing/analysis program has been initiated

IJ - Qualification documentation not expected to be completed prior to fuel load, refer to Appendix G of this report for status

The third line indicates whether the equipment is exposed to containment spray or mist conditions. The following abbreviations are used:

SPR - Containment spray
MST - Mist conditions

OP TIME

This field describes the time required, including the margins applied, for the equipment to operate during and subsequent to a design basis event. The first portion of the field is a number followed by one of the following abbreviations to record the units of time:

CON - Continuous
YRS - Years
MON - Months
DYS - Days
HRS - Hours

MIN - Minutes

ACC/PERF

This field indicates the accuracy specification of instruments for trip functions and post-accident monitoring. Where not applicable to the specific equipment, "N/A" is entered.

NU CAT
EMG CND
OP CD

The first line will indicate "RG" if the equipment must be qualified to the requirement of Nuclear Regulatory Guide 1.97.

The second line indicates for which design basis event(s) the equipment must be qualified, with abbreviations as follows:

- L - Loss of Coolant Accident (LOCA)
- H - High Energy Line Break (HELB)
- M - Moderate Energy Line Crack (MELB)
- ALL - LOCA, HELB, MELB

The third line indicates operability code with letters A or B referring to the equipment categories defined in NUREG-0588, Appendix E. Equipment designated as operability code A with operability time less than 180 days revert to operability code B for the remainder of the 180 days unless otherwise noted.

1T46*FT004A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 2

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = AIR MONITOR CORP.

.1T46*FT004A	RBSVS EXH AIR FLOH POWERS REGUL 310738	1E 319	H-18 RBS	00150	*AIR MONITOR CORP. *VELTRON 800	*319-01 *IJ	180 DYS	*RG ALL A
.1T46*FT004B	RBSVS EXH AIR FLOH POWERS REGUL 310738	1E 319	H-18 RBS	00150	*AIR MONITOR CORP. *VELTRON 800	*319-01 *IJ	180 DYS	*RG ALL A

1E32*FT037A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MCD / SPEC

REPORT DATE 01/18/82 PAGE 3

RESET NO. 003

RESET DATE 07/01/01

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = AMETEK

.1E32*FT037A E32-N053B	MSIV A LEAK TO LPH GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	AMETEK 078-5004	*3128 *DR	100 DYS	*L A
.1E32*FT037B E32-N053F	MSIV B LEAK TO LPH GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	AMETEK 078-5004	*3128 *DR	100 DYS	*L A
.1E32*FT037C E32-N053K	MSIV C LEAK TO LPH GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	AMETEK 078-5004	*3128 *DR	100 DYS	*L A
.1E32*FT037D E32-N053P	MSIV D LEAK TO LPH GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	AMETEK 078-5004	*3128 *DR	100 DYS	*L A

REPORT NO. PES-800 STONE AND WEBSTER ENGINEERING CORPORATION
 JOB NUMBER 1160002 PROJECT EQUIPMENT SYSTEM - (IS-129) REPORT DATE 01/18/82 PAGE 4
 JOB NAME SHOREHAM - UNIT 1 ENVIRONMENTAL QUALIFICATION STATUS REPORT RESET NO. 003
 JOB CLIENT LILCO SORTED BY - MAK / MOD / SPEC RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBHG			OP CD

REPORT GROUP MAK = ASCO

.1B21*SOV81AX *B21-F022A	1B21*AOV081A CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A
.1B21*SOV81AY *B21-F022A	1B21*AOV081A CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A
.1B21*SOV81AZ *B21-F022A	1B21*AOV081A CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A
.1B21*SOV81BX *B21-F022B	1B21*AOV081B CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A
.1B21*SOV81BY *B21-F022B	1B21*AOV081B CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A
.1B21*SOV81BZ *B21-F022B	1B21*AOV081B CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A
.1B21*SOV81CX *B21-F022C	1B21*AOV081C CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A
.1B21*SOV81CY *B21-F022C	1B21*AOV081C CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A
.1B21*SOV81CZ *B21-F022C	1B21*AOV081C CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A
.1B21*SOV81DX *B21-F022D	1B21*AOV081D CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A
.1B21*SOV81DY *B21-F022D	1B21*AOV081D CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *MST	070 MIN	N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 5
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	RU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1B21*SOV61DZ *B21-F022D	1B21*AOV081D CONTROL GENERAL ELECT 310010	1E 003	*D-22 *RBP	00082	ASCO HT-X-8320A20	3096 *IJ *HST	070 MIN	N/A	ALL A
.1B21*SOV82AX *B21-F028A	1B21*AOV082A CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1B21*SOV62AY *B21-F028A	1B21*AOV082A CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1B21*SOV82AZ *B21-F028A	1B21*AOV082A CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1B21*SOV82BX *B21-F028B	1B21*AOV082B CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1B21*SOV82BY *B21-F028B	1B21*AOV082B CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1B21*SOV82BZ *B21-F028B	1B21*AOV082B CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1B21*SOV82CX *B21-F028C	1B21*AOV082C CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1B21*SOV82CY *B21-F028C	1B21*AOV082C CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1B21*SOV82CZ *B21-F028C	1B21*AOV082C CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1B21*SOV82DX *B21-F028D	1B21*AOV082D CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1B21*SOV82DY *B21-F028D	1B21*AOV082D CONTROL GENERAL ELECT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 6
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EHG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1B21*SOV82DZ *B21-F028D	1B21*AOV082D CONTROL GENERAL ELCT 310010	1E 003	*T-08 *ST	00082	ASCO HT-X-8320A20	3096 *IJ	070 MIN	N/A	ALL A
.1T46*SOV035A	OPERATES 1T46*AOV035A FISHER CONT. 310655	1E 111	G-01 RBS	00112	ASCO HV200-926-1F-EP	*RR	070 MIN	N/A	ALL A
.1T46*SOV035B	OPERATES 1T46*AOV035B FISHER CONT. 310655	1E 111	G-01 RBS	00112	ASCO HV200-926-1F-EP	*RR	070 MIN	N/A	ALL A
.1T46*SOV037A	OPERATES 1T46*AOV037A FISHER CONT. 310655	1E 111	G-01 RBS	00095	ASCO HV200-926-1F-EP	*RR	070 MIN	N/A	ALL A
.1T46*SOV037B	OPERATES 1T46*AOV037B FISHER CONT. 310655	1E 111	G-01 RBS	00095	ASCO HV200-926-1F-EP	*RR	070 MIN	N/A	ALL A
.1T46*SOV038A	PR1 CONTAINMENT PURGE VALVE FISHER CONT. *373023	1E *172	D-22 RBP	00078	ASCO HV200-926-1F-EP	*RR *MST	070 MIN	N/A	ALL A
.1T46*SOV038B	PR1 CONTAINMENT PURGE VALVE FISHER CONT. *373023	1E *172	H-10 RBS	00078	ASCO HV200-926-1F-EP	*RR	070 MIN	N/A	ALL A
.1T46*SOV038C	PR1 CONTAINMENT PURGE VALVE FISHER CONT. 310574	1E 172	L-02 RBS	00040	ASCO HV200-926-1F-EP	*RR	070 MIN	N/A	ALL A
.1T46*SOV038D	PR1 CONTAINMENT PURGE VALVE FISHER CONT. 310574	1E 172	L-02 RBS	00040	ASCO HV200-926-1F-EP	*RR	070 MIN	N/A	ALL A
.1T46*SOV039A	PR1 CONTAINMENT PURGE VALVE FISHER CONT. 310574	1E *172	B-22 RBP	00112	ASCO HV200-926-1F-EP	*RR *SPR	070 MIN	N/A	ALL A
.1T46*SOV039B	PR1 CONTAINMENT PURGE VALVE FISHER CONT. 310574	1E 172	K-15 RBS	00112	ASCO HV200-926-1F-EP	*RR	070 MIN	N/A	ALL A
.1T46*SOV039C	PR1 CONTAINMENT PURGE VALVE FISHER CONT. *373023	1E *172	G-02 RBS	00040	ASCO HV200-926-1F-EP	*RR	070 MIN	N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 7
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENH CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
.1T46*SOV039D	PR1 CONTAINMENT PURGE VALVE FISHER CONT. *373823	1E *172	G-02 RBS	00040	ASCO HV200-926-1F-EP	*RR	070 MIN	N/A	ALL A
.1C11*SOV042A	BACK UP SCRAM SYSTEM 310010	1E 003	G-05 RBS	00063	*ASCO *NP8316C37	*3909 *QG	070 MIN	*N/A	*RG ALL A
.1C11*SOV042B	BACK UP SCRAM SYSTEM 310010	1E 003	G-05 RBS	00063	*ASCO *NP8316C37	*3909 *QG	070 MIN	*N/A	*RG ALL A
.1P42*PS021A	PUMP 1P42*P005A DISCH AUTO SWITCH 10072	1E 348	H-18 RBS	150	ASCO SB11AKR/TF10A32B	TA	070 MIN	1% SP	ALL A
.1P42*PS021B	PUMP 1P42*P005B DISCH AUTO SWITCH 10072	1E 348	H-18 RBS	150	ASCO SB11AKR/TF10A32B	TA	070 MIN	1% SP	ALL A
.1P42*PS021C	PUMP 1P42*P005C DISCH AUTO SWITCH 10072	1E 348	H-18 RBS	150	ASCO SB11AKR/TF10A32B	TA	070 MIN	1% SP	ALL A
.1P42*PS022A	PUMP 1P42*P005A DISCH AUTO SWITCH 10072	1E 348	H-18 RBS	150	ASCO SB11AKR/TF10A32B	TA	070 MIN	1% SP	ALL A
.1P42*PS022B	PUMP 1P42*P005B DISCH AUTO SWITCH 10072	1E 348	H-18 RBS	150	ASCO SB11AKR/TF10A32B	TA	070 MIN	1% SP	ALL A
.1P42*PS022C	PUMP 1P42*P005C DISCH AUTO SWITCH 10072	1E 348	H-18 RBS	150	ASCO SB11AKR/TF10A32B	TA	070 MIN	1% SP	ALL A
.1P42*PS046A	PUMP 1P42*P005A DISCH AUTO SWITCH 10072	1E 348	H-18 RBS	150	ASCO SB11AKR/TF10A32B	TA	180 DYS	1% SP	ALL A
.1P42*PS046B	PUMP 1P42*P005B DISCH AUTO SWITCH 10072	1E 348	H-18 RBS	150	ASCO SB11AKR/TF10A32B	TA	180 DYS	1% SP	ALL A
.1P42*PS046C	PUMP 1P42*P005C DISCH AUTO SWITCH 10072	1E 348	H-18 RBS	150	ASCO SB11AKR/TF10A32B	TA	180 DYS	1% SP	ALL A

1P50*PS105A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 8

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD

.1P50*PS105A 04450008	SERV AIR HDR A PRESS AUTO SWITCH 10072 OP CODE B FOR LOCA	1E 348	H-18 RBS	151	ASCO SB11AKR/TG10A32B	TA	070 MIN	1% SP	H,H A
.1P50*PS105B 04470008	SERV AIR HDR B PRESS AUTO SWITCH 10072 OP CODE B FOR LOCA	1E 348	H-18 RBS	151	ASCO SB11AKR/TG10A32B	TA	070 MIN	1% SP	H,H A
.1P50*PS113A 04490008	SERV AIR HDR A NORM SUP AUTO SWITCH 10072 OP CODE B FOR LOCA	1E 348	H-18 RBS	151	ASCO SB11AKR/TG10A32B	TA	070 MIN	1% SP	H,H A
.1P50*PS113B 04510008	SERV AIR HDR B NORM SUP AUTO SWITCH 10072 OP CODE B FOR LOCA	1E 348	H-18 RBS	151	ASCO SB11AKR/TG10A32B	TA	070 MIN	1% SP	H,H A
.1B21*SOV036A	OPERATES 1B21*AOV036A VELAN 310595 OP CODE B FOR HELB & MELB	1E 232	H-18 RBS	00087	ASCO *HJHKX-8320-A89E	*232-01 *EQ	070 MIN		L A
.1B21*SOV036B	REACTOR FN INLET AOV036A VELAN 310595 OP CODE B FOR HELB & MELB	1E 232	H-18 RBS	00087	ASCO *HJHKX-8320-A89E	*232-01 *EQ	070 MIN		L A
*1E11*SOV081A ADDED	*ON 1E11*AOV081A *310595	*1E *232	*D-22 *RBP	*00079	*ASCO *HJHKX-8320-A89E	*232-01 *EQ *HST	*180 *DYS		*ALL *B
.1E11*SOV081B	*FOR 1E11*AOV081B VELAN *310595	*1E *232	*D-22 *RBP	*00079	*ASCO *HJHKX-8320-A89E	*232-01 *EQ *HST	*180 *DYS		ALL *B
.1E21*SOV081A	*FOR 1E21*AOV081A VELAN *310595	*1E *232	*B-22 *RBP	*00126	*ASCO *HJHKX-8320-A89E	*232-01 *EQ *HST	*180 *DYS		L *B
.1E21*SOV081B	*FOR 1E21*AOV081B VELAN *310595	*1E *232	*B-22 *RBP	*00126	*ASCO *HJHKX-8320-A89E	*232-01 *EQ *HST	*180 *DYS		L *B
.1P42*SOV282	RBCLCH RETURN CHECK VLV				ASCO	*232-01	070 MIN		

REPORT NO. PES-800 STONE AND WEBSTER ENGINEERING CORPORATION
 JOB NUMBER 1160002 PROJECT EQUIPMENT SYSTEM - (IS-129) REPORT DATE 01/18/82 PAGE 9
 JOB NAME SHOREHAM - UNIT 1 ENVIRONMENTAL QUALIFICATION STATUS REPORT RESET NO. 003
 JOB CLIENT LILCO SORTED BY - MAK / MOD / SPEC RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL. STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
	VELAN 310595	1E 232	G-01 RBS 00016	WJHKX-8320-A89E	*EQ			ALL A
.1P42*SOV293	RBCLON RETURN CHECK VLV VELAN 310595	1E 232	G-01 RBS 00039	ASCO WJHKX-8320-A89E	*232-01 *EQ	070 MIN		ALL A
.1P42*SOV294	RBCLON RETURN CHECK VLV VELAN 310595	1E 232	G-01 RBS 00039	ASCO WJHKX-8320-A89E	*232-01 *EQ	070 MIN		ALL A
.1B31*SOV081	OPERATES 1B31*AOV081 COPEX VULCAN 310735	1E 318	H-15 RBS 00133	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1B31*SOV082	OPERATES 1B31*AOV092 COPEX VULCAN 310735	1E 318	H-18 RBS 00155	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E11*SOV003A	STM TO RHR HX SHELL COPEX VULCAN 310735	1E 318	G-03 RBS 65	ASCO WJHKX-8320-A89E	*318-01 *EQ	180 DYS	NA	ALL B
.1E11*SOV003B	STM TO RHR HX SHELL COPEX VULCAN 310735	1E 318	G-07 RBS 65	ASCO WJHKX-8320-A89E	*318-01 *EQ	180 DYS	NA	ALL B
.1E11*SOV007A	STM TO RHR HX SHELL COPEX VULCAN 310735	1E 318	G-01 RBS 12	ASCO WJHKX-8320-A89E	*318-01 *EQ	180 DYS	NA	ALL B
.1E11*SOV007B	STM TO RHR HX SHELL COPEX VULCAN 310735	1E 318	G-01 RBS 10	ASCO WJHKX-8320-A89E	*318-01 *EQ	180 DYS	NA	ALL B
.1E11*SOV061A	RHR SAMPLE LINE VALVE COPEX VULCAN 310735	1E 318	G-01 RBS 8	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E11*SOV061B	RHR SAMPLE LINE VALVE COPEX VULCAN 310735	1E 318	G-01 RBS 8	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E11*SOV062A	RHR SAMPLE LINE VALVE COPEX VULCAN 310735	1E 318	G-01 RBS 8	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 10

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****
.1E11*SOV062B	RHR SAMPLE LINE VALVE COPEX VULCAN 310735	1E 318	G-01 RBS 8	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E41*SOV081	OPERATES 1E41*AOV081 COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS 00008	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E41*SOV082	OPERATES 1E41*AOV082 COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS 00008	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E41*SOV083	OPERATES 1E41*AOV083 COPEX VULCAN 310735	1E 318	G-01 RBS 00008	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E41*SOV091	OPERATES 1E41*LCV091 *COPEX VULCAN 310735	*1E *318	*G-01 *RBS *00008	*ASCO *WJHKX-8320-A89E	*318-01 *EQ	*180 *DYS	*N/A	*ALL *B
.1E41*SOV095	OPERATES 1E41*LCV095 COPEX VULCAN 310735	1E 318	G-01 RBS 00008	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E51*SOV081	OPERATES 1E51*AOV081 COPEX VULCAN 310735	1E 318	G-01 RBS 00008	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E51*SOV082	OPERATES 1E51*AOV082 COPEX VULCAN 310735	1E 318	G-01 RBS 00008	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E51*SOV083	OPERATES 1E51*AOV083 COPEX VULCAN 310735	1E 318	G-01 RBS 00008	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1E51*SOV091	OPERATES 1E51*LCV091 COPEX VULCAN 310735	1E 318	G-01 RBS 00008	ASCO WJHKX-8320-A89E	*318-01 *EQ	180 DYS	NA	ALL B
.1E51*SOV095	OPERATES 1E51*LCV095 COPEX VULCAN 310735	1E 318	G-01 RBS 00008	ASCO WJHKX-8320-A89E	*318-01 *EQ	070 MIN	NA	ALL A
.1T46*SOV040A	*OPERATES A00040A			*ASCO	*319-03	*070 *MIN	*	

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 11

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT E' CND Ov' CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
	POWERS REGUL 310738	*1E *319	*H-18 *RBS	*00150	*WJHKX-8320-A89E	*EQ			*ALL *A
.1T46*SOV040B	*OPERATES A00040B POWERS REGUL 310738	*1E *319	*H-18 *RBS	*00150	*ASCO *WJHKX-8320-A89E	*319-03 *EQ	*070 *MIN *		*ALL *A
.1T46*SOV041A	*OPERATES A00041A POWERS REGUL 310738	*1E *319	*K-15 *RBS	*00112	*ASCO *WJHKX-8320-A89E	*319-03 *EQ	*070 *MIN *		*ALL *A
.1T46*SOV041B	*OPERATES A00041B POWERS REGUL 310738	*1E *319	*K-15 *RBS	*00112	*ASCO *WJHKX-8320-A89E	*319-03 *EQ	*070 *MIN *		*ALL *A
.1P42*SOV001H	RBCLCH HX E-11A BYPASS FISHER CONTRO 310772 LOCA IS OP CODE B AFTER 70 MIN	1E 423	G-01 RBS	00008	ASCO WJHKX-8320-A89E	*423-01 *EQ	180 DYS	NA	ALL A
.1P42*SOV001X	RBCLCH HX E-11A BYPASS FISHER CONTRO 310772 LOCA IS OP CODE B AFTER 70 MIN	1E 423	G-01 RBS	00008	ASCO WJHKX-8320-A89E	*423-01 *EQ	180 DYS	NA	ALL A
.1P42*SOV001Y	RBCLCH HX E-11B BYPASS FISHER CONTRO 310772 LOCA IS OP CODE B AFTER 70 MIN	1E 423	G-01 RBS	00008	ASCO WJHKX-8320-A89E	*423-01 *EQ	180 DYS	NA	ALL A
.1P42*SOV001Z	RBCLCH HX E-11B BYPASS FISHER CONTRO 310772 LOCA IS OP CODE B AFTER 70 MIN	1E 423	G-01 RBS	00008	ASCO WJHKX-8320-A89E	*423-01 *EQ	180 DYS	NA	ALL A
.1T24*SOV001A	DRYHELL ISOL VLV 1T24*AV0001A COPEX VULCAN 310735	1E 318	G-02 RBS	00040	ASCO WJK206-380-6F	*318-02 *EQ	180 DYS	NA	L A
.1T24*SOV001B	DRYHELL ISOL VLV 1T24*AV0001B COPEX VULCAN 310735	1E 318	G-02 RBS	00040	ASCO WJK206-380-6F	*318-02 *EQ	180 DYS	NA	L A
.1T46*SOV078A	NR MOV 078A COPEX VULCAN 310735	1E 318	G-12 RBS	00090	ASCO WJK206-380-6F	*318-02 *EQ	070 MIN	NA	ALL A

1T46*SOV078B

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 12
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMS CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****
.1T46*SOV078B	DRYWELL VENT TO PRIM CNT COPEL VULCAN 310735	1E 316	G-12 RBS 00090	ASCO WJK206-380-6F	*318-02 *EQ	070 MIN	NA	AL A
.1T46*SOV079A	OPERATES 1T46*ADV079A COPEL VULCAN 310735	1E 318	G-06 RBS 00063	ASCO WJK206-380-6F	*318-02 *EQ	070 MIN	NA	ALL A
.1T46*SOV079B	OPERATES 1T46*ADV079B COPEL VULCAN 310735	1E 318	G-06 RBS 00063	ASCO WJK206-380-6F	*318-02 *EQ	070 MIN	NA	ALL A
1R24*TRS111X	480V AUTO TRANSFER SWITCH ASCO 310922	1E 438	N-21 RBS 112	ASCO 307A66C	TA	180 DYS		ALL A
1R24*TRS112Y	480V AUTO TRANSFER SWITCH ASCO	1E 438	N-21 RBS 112	ASCO 307A66C	TA	180 DYS		ALL A

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 13

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EHG CND
	PO NUMBER		ELEV		SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = ATOMICS INT

.1T48*PNL48A	*HYD RECOM PWR PNL A ATOMICS INT 310624	1E 289	J-16 RBS	00112	*ATOMICS INT *N/A	* *TA	180 DYS	NA	L A
.1T48*PNL48B	HYD RECOM PWR PNL B ATOMICS INT 310624	1E 289	J-16 RBS	00112	*ATOMICS INT *N/A	* *TA	180 DYS	NA	L A
.1T48*RC002A	HYDROGEN RECOMB ATOMICS INT 310624	1E 289	J-15 RBS	00112	ATOMICS INT N/A	* *TA	180 DYS		L A
.1T48*RC002B	HYDROGEN RECOMB ATOMICS INT 310624	1E 289	J-15 RBS	00112	ATOMICS INT N/A	* *TA	180 DYS		L A

1E11*PT003A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 14
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = BAILEY

.1E11*PT003A E11-N026A	STM TO RHR HX SHELL GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BAILEY KG55610DAAA1WEM	3094 *RR	180 DYS 2%	ALL B
.1E11*PT003B E11-N026B	STM TO RHR HX SHELL GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BAILEY KG55610DAAA1WEM	3094 *RR	180 DYS 2%	ALL B
.1E11*PT005 E11-N028	RHR HX SHELL TO RCIC GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BAILEY KG556110CAAA1WEL	3094 *RR	180 DYS *2%	ALL B
.1E21*PT001A E21-N001A	CORE SPRAY PUMP DISCH GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BAILEY KG556110DAAA1WEM	3094 *RR	180 DYS *	L B
.1E21*PT001B E21-N001B	CORE SPRAY PUMP DISCH GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BAILEY KG556110DAAA1WEM	3094 *RR	180 DYS *	L B
.1C61*PT006 C61-N006	NUCLEAR PRESSURE GENERAL ELEC 310010	1E 003	G-09 RBS	00078	*BAILEY *55610EAAA1WEN	*3904 *RR	180 DYS	ALL B
.1E51*PT001 E51-N005	RCIC PUMP SUCTION GENERAL ELEC 310010	1E 003	G-01 RBS	00008	*BAILEY *556110EAAA1WEN	*3904 *RR	180 DYS *1%	ALL B
.1E51*PT002 E51-N004	RCIC PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS	00008	*BAILEY *556110EAAA1WEN	*3904 *RR	180 DYS *1%	ALL B
.1E51*PT004 E51-N007	RCIC STM TO TURBINE GENERAL ELEC 310010	1E 003	G-01 RBS	00008	*BAILEY *556110EAAA1WEN	*3904 *RR	180 DYS *1%	ALL B
.1E51*PT005 E51-N008	TURBINE DISCHARGE GENERAL ELEC 310010	*1E 003	G-01 RBS	00008	*BAILEY *556110EAAA1WEN	*3904 *RR	180 DYS *1%	ALL B

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 15
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			ENG CND
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = BARKSDALE

.1B21*PS022A B21-N020A	MAIN STEAM LINE ISO GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-10 RBS	*BARKSDALE *BIT-M12SS	*3018 *IJ	070 MIN	*1.5%	L A
.1B21*PS022B B21-N020B	MAIN STEAM LINE ISO GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-10 RBS	*BARKSDALE *BIT-M12SS	*3018 *IJ	070 MIN	*1.5%	L A
.1B21*PS022C B21-N020C	MAIN STEAM LINE ISO GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-12 RBS	*BARKSDALE *BIT-M12SS	*3018 *IJ	070 MIN	*1.5%	L A
.1B21*PS022D B21-N020D	MAIN STEAM LINE ISO GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-12 RBS	*BARKSDALE *BIT-M12SS	*3018 *IJ	070 MIN	*1.5%	L A
.1E41*PS002 E41-N027	HPCI PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS	*BARKSDALE *BIT-M12SS	3018 *IJ	001 DYS		ALL A
.1E51*PS002 E51-N020	RCIC PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS	BARKSDALE BIT-M12SS	3018 *IJ	001 DYS	*2.6%	ALL A
.1E11*PS134A E11-N016A	RHR PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS	BARKSDALE BIT-M12SS	3018 *IJ	1 DYS	*.8%	*ALL A
.1E11*PS134B E11-N016B	RHR PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS	BARKSDALE BIT-M12SS	3018 *IJ	1 DYS	*.8%	*ALL A
.1E11*PS134C E11-N016C	RHR PUMP DISCHARGE GENERAL ELEC 348838	1E 003	G-01 RBS	BARKSDALE BIT-M12SS	3018 *IJ	1 DYS	*.8%	*ALL A
.1E11*PS134D E11-N016D	RHR PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS	BARKSDALE BIT-M12SS	3018 *IJ	1 DYS	*.8%	*ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 16
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1E11*PS135A E11-N020A	RHR PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS	8	BARKSDALE B1T-M12SS	3018 *IJ	1 DYS	*.8%	*ALL A
.1E11*PS135B E11-N020B	RHR PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS	8	BARKSDALE B1T-M12SS	3018 *IJ	1 DYS	*.8%	*ALL A
.1E11*PS135C E11-N020C	RHR PUMP DISCHARGE GENERAL ELEC 348838	1E 003	G-01 RBS	8	BARKSDALE B1T-M12SS	3018 *IJ	1 DYS	*.8%	*ALL A
.1E11*PS135D E11-N020D	RHR PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS	8	BARKSDALE B1T-M12SS	3018 *IJ	1 DYS	*.8%	*ALL A
.1E41*PS025A E41-N012A	DRAIN POT VENT G.E. 310010	1E 003	G-01 RDS	00008	BARKSDALE D2H-M150SS	3021 *IJ	001 DYS		ALL A
.1E41*PS025B E41-N012B	DRAIN POT VENT G.E. 310010	1E 003	G-01 RBS	00008	BARKSDALE D2H-M150SS	3021 *IJ	001 DYS		ALL A
.1E41*PS025C E41-N012C	DRAIN POT VENT G.E. 310010	1E 003	G-01 RBS	00008	BARKSDALE D2H-M150SS	3021 *IJ	001 DYS		ALL A
.1E41*PS025D E41-N012D	DRAIN POT VENT G.E. 310010	1E 003	G-01 RBS	00008	BARKSDALE D2H-M150SS	3021 *IJ	001 DYS		ALL A
.1E41*PS026A E41-N017A	HIGH EXHAUST LINE PRESS G.E. 310010	1E 003	G-01 RBS	00008	BARKSDALE D2H-M150SS	3021 *IJ	001 DYS	*10%	ALL A
.1E41*PS026B E41-N017B	HIGH EXHAUST LINE PRESS G.E. 310010	1E 003	G-01 RBS	00008	BARKSDALE D2H-M150SS	3021 *IJ	001 DYS	*10%	ALL A
.1E11*PS138A E11-N010A	PRIMARY CONTAINMENT HP GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-10 RBS	00008	BARKSDALE D2H-M18SS	3021 *IJ	070 MIN	*.1 PSIG	L A
.1E11*PS138B E11-N010B	PRIMARY CONTAINMENT HP GENERAL ELEC	1E	H-12		BARKSDALE D2H-M18SS	3021 *IJ	070 MIN	*.1 PSIG	L

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 17

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
	310010 OP CODE B FOR HELB & MELB	003	RBS 00078					A
.1E11*PS138C E11-N010C	PRIMARY CONTAINMENT HP GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-10 RBS 00078	BARKSDALE D2H-M185S	3021 *IJ	070 MIN	*.1 PSIG	L A
.1E11*PS138D E11-N010D	PRIMARY CONTAINMENT HP GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	H-12 RBS 00078	BARKSDALE D2H-M185S	3021 *IJ	070 MIN	*.1 PSIG	L A
.1E51*PS025A E51-N012A	DRAIN POT VENT GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARKSDALE D2H-M805S	3021 *IJ	001 DYS	*2.7%	ALL A
.1E51*PS025B E51-N012B	DRAIN POT VENT GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARKSDALE D2H-M805S	3021 *IJ	001 DYS	*2.7%	ALL A
.1E51*PS025C E51-N012C	DRAIN POT VENT GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARKSDALE D2H-M805S	3021 *IJ	001 DYS	*2.7%	ALL A
.1E51*PS025D E51-N012D	DRAIN POT VENT GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARKSDALE D2H-M805S	3021 *IJ	001 DYS	*2.7%	ALL A
.1E51*PS026A E51-N009A	HIGH EXHAUST LINE PRESS GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARKSDALE D2H-M805S	3021 *IJ	001 DYS	*2.5%	ALL A
.1E51*PS026B E51-N009B	HIGH EXHAUST LINE PRESS GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARKSDALE D2H-M805S	3021 *IJ	001 DYS	*2.5%	ALL A
.1E21*PS012A E21-N008A	CORE SPRAY PUMP DISCH GENERAL ELEC 310010	1E 003	G-01 RBS 8	BARKSDALE P1H-M345S	3025 *IJ	007 DYS	*1.5%	L A
.1E21*PS012B E21-N008B	CORE SPRAY PUMP DISCH GENERAL ELEC 310010	1E 003	G-01 RBS 8	BARKSDALE P1H-M345S	3025 *IJ	007 DYS	*1.5%	L A
.1E21*PS013A E21-N009A	CORE SPRAY PUMP DISCH GENERAL ELEC	1E	G-01	BARKSDALE P1H-M345S	3025 *IJ	007 DYS	*1.5%	L

1E21*PS013A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 18
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			ENG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
	310010	003	RBS 8					A
1E21*PS013B	CORE SPRAY PUMP DISCH	1E	G-01	BARKSDALE	3025	007 DYS	*1.5%	L
E21-N009B	GENERAL ELEC	003	RBS 8	PIH-H3455	*IJ			A

1B21*PDS02.1

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 19
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
REPORT GROUP MAK = BARTON								
.1B21*PDS02A1 B21-N006A	MAIN STM LINE A FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02A2 B21-N006B	MAIN STM LINE A FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02A3 B21-N006C	MAIN STM LINE A FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02A4 B21-N006D	MAIN STM LINE A FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02B1 B21-N007A	MAIN STM LINE B FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02B2 B21-N007B	MAIN STM LINE B FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02B3 B21-N007C	MAIN STM LINE B FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02B4 B21-N007D	MAIN STM LINE B FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02C1 B21-N008A	MAIN STM LINE C FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02C2 B21-N008B	MAIN STM LINE C FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02C3 B21-N008C	MAIN STM LINE C FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 20

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1B21*PDS02C4 B21-N008D	MAIN STM LINE C FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS	00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02D1 B21-N009A	MAIN STM LINE D FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS	00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02D2 B21-N009B	MAIN STM LINE D FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS	00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02D3 B21-N009C	MAIN STM LINE D FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS	00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1B21*PDS02D4 B21-N009D	MAIN STM LINE D FLOW DET GENERAL ELEC 310010	1E 003	G-02 RBS	00040	BARTON 288A	3027 *IJ	001 DYS	*2%	H A
.1E71*PS00A E71-N004	PRIMARY CONTAINMENT HP GENERAL ELEC 310010	1E 003	G-10 RBS	00078	BARTON 288A	3027 *IJ	180 DYS	*1% PSIG	ALL B
.1E21*PDS033A E21-N005A	CORE SPRAY PUMP DISCH GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BARTON 288A	3027 *IJ	180 DYS	*	L A
.1E21*PDS033B E21-N005B	CORE SPRAY PUMP DISCH GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BARTON 288A	3027 *IJ	180 DYS	*	L A
.1E41*PDS022A E41-N004	HPCI AUTO ISOLATION GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BARTON 288A	3027 *IJ	001 DYS	*.8%	ALL A
.1E41*PDS022B E41-N005	HPCI AUTO ISOLATION GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BARTON 288A	3027 *IJ	001 DYS	*.8%	ALL A
.1E41*PS023A E41-N001A	HPCI AUTO ISOLATION GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BARTON 288A	3027 *IJ	001 DYS	*.5%	ALL A
.1E41*PS023B E41-N001B	HPCI AUTO ISOLATION GENERAL ELEC 310010	1E 003	G-01 RBS	00008	BARTON 288A	3027 *IJ	001 DYS	*.5%	ALL A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 21

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
.1E41*PS023C E41-N001C	HPCI AUTO ISOLATION GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARTON 288A	3027 *IJ	001 DYS	*.5%	ALL A
.1E41*PS023D E41-N001D	HPCI AUTO ISOLATION GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARTON 288A	3027 *IJ	001 DYS	*.5%	ALL A
.1E51*FS003 E51-N002	RCIC PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARTON 288A	3027 *IJ	001 DYS	*5%A	ALL A
.1E51*PDS022A E51-N017	RCIC AUTO ISOLATION GENERAL ELEC 310010	1E 003	L-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	ALL A
.1E51*PDS022B E51-N018	RCIC AUTO ISOLATION GENERAL ELEC 310010	1E 003	L-02 RBS 00040	BARTON 288A	3027 *IJ	001 DYS	*2%	ALL A
.1E11*PDS001A E11-N021A	VALVE INTERLOCK GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARTON 289A	*3027 *IJ	180 DYS	1.5%	ALL A
.1E11*PDS001B E11-N021B	VALVE INTERLOCK GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARTON 289A	*3027 *IJ	180 DYS	1.5%	ALL A
.1E21*FIS002A E21-N006A	CORE SPRAY PUMP DISCH GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARTON 289A	*3027 *IJ	180 DYS	*	L A
.1E21*FIS002B E21-N006B	CORE SPRAY PUMP DISCH GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARTON 289A	*3027 *IJ	180 DYS	*	L A
.1E41*FS003 E41-N006	HPCI PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS 00008	BARTON 289A	*3027 *IJ	001 DYS		ALL A
.1E11*LT002A E11-N008A	RHR HX SHELL GENERAL ELEC 310010	1E 003	G-01 RBS 8	BARTON 368	*3144 *RR	180 DYS	*.5% SPAN	ALL B
.1E11*LT002B E11-N008B	RHR HX SHELL GENERAL ELEC 310010	1E 003	G-01 RBS 8	BARTON 368	*3144 *RR	180 DYS	*.5% SPAN	ALL B

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UN
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 22
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT ENH CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1B21*LIT007A B21-N037A	FUEL ZONE GENERAL ELEC 310010	1E 003	G-09 RBS	00078	BARTON 760	3129 *RR	180 DYS *		*RG ALL A
.1B21*LIT007B B21-N037B	FUEL ZONE GENERAL ELEC 310010	1E 003	G-11 RBS	00078	BARTON 760	3129 *RR	180 DYS *		*RG ALL A
.1B21*PT004A B21-N055A	REACTOR PRESSURE GENERAL ELEC 310010	1E 003	G-10 RBS	00078	BARTON 760	3129 *RR	180 DYS *		*RG ALL A
.1B21*PT004B B21-N055B	REACTOR PRESSURE GENERAL ELEC 310010	1E 003	G-10 RBS	00078	BARTON 760	3129 *RR	180 DYS *		*RG ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 23
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EHG CND OP CD
** (*****	*****	*****	*****	*****	*****	*****	*****	*****	****
REPORT GROUP MAK = BECK									
.1E41*PCV142 E41-F035	TO LUBE OIL COOLER FISHER CONTRL 310736	1E 310	G-01 RBS	16	BECK 14-101-023645(ES)	*310-01 *IJ	001 DYS	N/A	ALL A
.1E51*PCV142 E51-F015	TO LUBE OIL COOLER FISHER CONTRL 310736	1E 310	G-01 RBS	00008	BECK 14-101-023645(ES)	*310-01 *IJ	001 DYS	N/A	ALL A
.1T46*TCV022A	RB STANDBY VENT UC 2A FISHER CONTRL 310736	1E 310	G-01 RBS	00008	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV022B	RB STANDBY VENT UC 2B FISHER CONTRL 310736	1E 310	G-01 RBS	00040	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV023A	RB STANDBY VENT UC 3A FISHER CONTRL 310736	1E 310	G-01 RBS	00008	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV023B	RB STANDBY VENT UC 3B FISHER CONTRL 310736	1E 310	G-02 RBS	00040	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV024A	RB STANDBY VENT UC-4A FISHER CONTRL 310736	1E 310	H-20 RBS	175	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV024B	RB STANDBY VENT UC-4B FISHER CONTRL 310736	1E 310	H-20 RBS	175	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV025A	RB STANDBY VENT UC-5A FISHER CONTRL 310736	1E 310	H-20 RBS	175	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV025B	RB STANDBY VENT UC-5B FISHER CONTRL 310736	1E 310	H-20 RBS	175	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV026A	RB STANDBY VENT UC-6A FISHER CONTRL 310736	1E 310	K-15 RBS	00112	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 24
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
.1T46*TCV026B	RB STANDBY VENT UC-6B FISHER CONTRL 310736	1E 310	K-15 RBS 00112	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV028A	MCC RM UNIT COOLER FISHER CONTRL 310736	1E 310	N-16 RBS 00112	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV028B	MCC RM UNIT COOLER FISHER CONTRL 310736	1E 310	K-15 RBS 00112	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV059A	UC-21A UNIT CLEAR FISHER CONTRL 310736	1E 310	H-19 RBS 00150	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV059B	UC-21B UNIT CLEAR FISHER CONT. 310736	1E 310	H-19 RBS 00150	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV060A	UC-22A UNIT CLEAR FISHER CONT. 310736	1E 310	H-19 RBS 00150	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A
.1T46*TCV060B	UC-22B UNIT CLEAR FISHER CONT. 310736	1E 310	H-19 RBS 00150	BECK 14-101-023645(ES)	*310-01 *IJ	180 DYS	N/A	ALL A

1R32*NFP-63

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 25

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = BRAND REX

1R32*NFP-63

*INST CABLE

BRAND REX

*455-01

180 DYS N/A

BRAND REX

1E ALL

LOW CAP INST CABLE

EQ

ALL

310965

455 RB

*SPR

A

REPRESENTS ALL CABLE PURCHASED UNDER SH1-455

1G33*TE071A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 26
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = CALIF. ALLOY

.1G33*TE071A G33-N016A	RX WTR CLN UP AMB GENERAL ELEC 310010	1E 003	P-14 RBS	112	CALIF. ALLOY 145C3224P2	3110 *IJ	*001 *DYS	*ANSI C96.1	*H A
.1G33*TE071B G33-N016B	RX WTR CLN UP AMB GENERAL ELEC 310010	1E 003	P-13 RBS	112	CALIF. ALLOY 145C3224P2	3110 *IJ	*001 *DYS	*ANSI C96.1	*H A
.1G33*TE071C G33-N016C	RX WTR CLN UP AMB GENERAL ELEC 310010	1E 003	K-15 RBS	140	CALIF. ALLOY 145C3224P2	3110 *IJ	070 MIN	*ANSI C96.1	H,H A
.1G33*TE071D G33-N016D	RX WTR CLN UP AMB GENERAL ELEC 310010	1E 003	H-16 RBS	140	CALIF. ALLOY 145C3224P2	3110 *IJ	070 MIN	*ANSI C96.1	H,H A
.1G33*TE071E G33-N016E	RX WTR CLN UP AMB GENERAL ELEC 310010	1E 003	H-18 RBS	173	CALIF. ALLOY 145C3224P2	3110 *IJ	070 MIN	*ANSI C96.1	H,H A
.1G33*TE071F G33-N016F	RX WTR CLN UP AMB GENERAL ELEC 310010	1E 003	H-19 RBS	173	CALIF. ALLOY 145C3224P2	3110 *IJ	070 MIN	*ANSI C96.1	H,H A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 27

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	HAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = CALIFORNIA ALLOY

.1B21*TE43AX B21-N016A	MAIN STM TUNNEL INLET GENERAL ELEC 310010 OP CODE C FOR REMAINDER OF HELB	1E 003	ST ST		*CALIFORNIA ALLOY *145C3224P001	*3110 *DR	*70	*HIN	*ANSI C96.1	H A
.1B21*TE43BX B21-N016B	MAIN STM TUNNEL INLET GENERAL ELEC 310010 OP CODE C FOR REMAINDER OF HELB	1E 003	ST ST	00078	*CALIFORNIA ALLOY *145C3224P001	*3110 *DR	*70	*MIN	*ANSI C96.1	H A
.1B21*TE43CX B21-N016C	MAIN STM TUNNEL INLET GENERAL ELEC 310010 OP CODE C FOR REMAINDER OF HELB	1E 003	ST ST	00078	*CALIFORNIA ALLOY *145C3224P001	*3110 *DR	*70	*MIN	*ANSI C96.1	H A
.1B21*TE43DX B21-N016D	MAIN STM TUNNEL INLET GENERAL ELEC 310010 OP CODE C FOR REMAINDER OF HELB	1E 003	ST ST	00078	*CALIFORNIA ALLOY *145C3224P001	*3110 *DR	*70	*MIN	*ANSI C96.1	H A

1T46*ADD040A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 28
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = CENTERLINE

.1T46*ADD040A	RB REFUEL LEVEL EXHAUST			CENTERLINE	*319-01	070 MIN		ALL
	POWERS REGUL	1E	H-18	32046-6	*EQ			A
	310738	319	RBS	00150				
.1T46*ADD040B	RB REFUEL LEVEL EXHAUST			CENTERLINE	*319-01	070 MIN		ALL
	POWERS REGUL	1E	H-18	32046-6	*EQ			A
	310738	319	RBS	00150				

REPORT NO. PES-800 STONE AND WEBSTER ENGINEERING CORPORATION
 JOB NUMBER 1160002 PROJECT EQUIPMENT SYSTEM - (IS-129)
 JOB NAME SHOREHAM - UNIT 1 ENVIRONMENTAL QUALIFICATION STATUS REPORT REPORT DATE 01/18/82 PAGE 29
 JOB CLIENT LILCO SORTED BY - MAK / MOD / SPEC RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = COMSIP INC

.1T48*H2Z115A AE/1	DRYWELL HYDROGEN ANALYZER DELPHI INDUST 310737	1E 344	J-15 RBS	00112	COMSIP INC B	*344-01 *EQ	180 DYS *2%FS	L A
.1T48*H2Z115B AE/1	DRYWELL HYDROGEN ANALYZER DELPHI INDUST 310737	1E 344	J-16 RBS	00112	COMSIP INC B	*344-01 *EQ	180 DYS *2%FS	L A
.1T48*H2Z116A AE/1	SUPP CHBR/RECOM DISCH ANALYZER DELPHI INDUST 310737	1E 344	J-15 RBS	00112	COMSIP INC B	*344-01 *EQ	180 DYS *2%FS	L A
.1T48*H2Z116B AE	SUPP CHBR/RECOM DISCH ANALYZER DELPHI INDUST 310737	1E 344	J-16 RBS	00112	COMSIP INC B	*344-01 *EQ	180 DYS *2%FS	L A
.1T48*O2Z123A	PRIMARY CONT OXYGEN DELPHI INDUST. 310737	1E 344	J-15 RBS	00112	COMSIP INC J	*344-01 *EQ	180 DYS *2%FS	L A
.1T48*O2Z123B	PRIMARY CONT OXYGEN DELPHI INDUST. 310737	1E 344	J-15 RBS	00112	COMSIP INC J	*344-01 *EQ	180 DYS *2%FS	L A
.1T48*PNL68A	GAS ANALYZER DRYWELL DELPHI INDUST. 310737	1E 344	J-15 RBS	112	*COMSIP INC K-IV	*344-01 *EQ	180 DYS N/A	*RG L A
SAMPLE PUMP BEARINGS REQUIRE REPLACEMENT.SAMPLE PUMP IS BEING RETESTED.ALL OTHER COMPONENTS ARE EQ.								
.1T48*PNL68B	GAS ANALYZER DRYWELL DELPHI INDUST. 310737	1E 344	J-16 RBS	112	*COMSIP INC K-IV	*344-01 *EQ	180 DYS N/A	*RG L A
SAMPLE PUMP BEARINGS REQUIRE REPLACEMENT.SAMPLE PUMP IS BEING RETESTED.ALL OTHER COMPONENTS ARE EQ.								
.1T48*PNL69A	GAS ANALYZER SUPPR CHAMBER DELPHI INDUST. 310737	1E 344	J-15 RBS	112	*COMSIP INC K-IV	*344-01 *EQ	180 DYS N/A	*RG L A
SAMPLE PUMP BEARINGS REQUIRE REPLACEMENT.SAMPLE PUMP IS BEING RETESTED.ALL OTHER COMPONENTS ARE EQ.								
.1T48*PNL69B	GAS ANALYZER SUPPR CHAMBER DELPHI INDUST. 310737	1E 344	J-16 RBS	112	*COMSIP INC K-IV	*344-01 *EQ	180 DYS N/A	*RG L A
SAMPLE PUMP BEARINGS REQUIRE REPLACEMENT.SAMPLE PUMP IS BEING RETESTED.ALL OTHER COMPONENTS ARE EQ.								

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 30
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = CONAX

.1T23*Z-EB1	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 456	D-22 RBP	00078	CONAX LOW VOLT POWER CONT	*456-02 *EQ *MST	180 DYS N/A	*1 L A
	GENERAL ELECTRIC HEADER PLATES WITH CONAX MODULES							
.1T23-Z-HC1	REACTOR CONT ELEC PENET *CONAX 310967	1E 456	D-22 RBP	00078	CONAX LOW VOLT POWER CONT	*456-01 *EQ *MST	180 DYS N/A	*1 L A
.1T23*Z-HB3	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 456	D-22 RBP	00078	CONAX LOW VOLT POWER CONT.	*456-02 *EQ *MST	180 DYS N/A	*1 L A
	GENERAL ELECTRIC HEADER PLATES WITH CONAX MODULES							
.1C41*EV010A C41-F004A	EXPLOSIVE VALVE GENERAL ELEC 344953	1E 003	J-15 RBS	00120	CONAX 1832-159-01	3146 FT	180 DYS N/A	ALL *B
.1C41*EV010B C41-F004B	EXPLOSIVE VALVE GENERAL ELEC 344953	1E 003	J-15 RBS	00120	CONAX 1832-159-01	3146 FT	180 DYS N/A	ALL *B

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 31
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = DWYER

.1T46*PDS045A	FN-3B DIFF PRESSURE POWERS REGUL 310738	1E 319	K-15 RBS	DWYER 1627	*319-01 *IJ	180 DYS		ALL A
.1T46*PDS045B	FN-3A DIFF PRESSURE POWERS REGUL 310738	1E 319	K-15 RBS	DWYER 1627	*319-01 *IJ	180 DYS		ALL A
.1T46*PDS045C	FN-3A DIFF PRESSURE POWERS REGUL 310738	1E 319	K-15 RBS	DWYER 1627	*319-01 *IJ	180 DYS		ALL A
.1T46*PDS046A	FN-3C DIFF PRESSURE POWERS REGUL 310738	1E 319	K-15 RBS	DWYER 1627	*319-01 *IJ	180 DYS		ALL A
.1T46*PDS046B	FN-3C DIFF PRESSURE POWERS REGUL 310738	1E 319	K-15 RBS	DWYER 1627	*319-01 *IJ	180 DYS		ALL A
.1T46*PDS046C	FN-3B DIFF PRESSURE POWERS REGUL 310738	1E 319	K-15 RBS	DWYER 1627	*319-01 *IJ	180 DYS		ALL A

1T46*FLT01A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 32
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	ELEV	MODEL / CATALOG NO	QUAL STAT		EHG CND
	PO NUMBER					SUBMG		OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = FARR

.1T46*FLT01A	FILTER TRAIN REHEAT COIL	RBSVS		FARR		180 DYS		ALL
	FARR CO	1E	K-15	N-240	*IJ			A
	310599	105	RBS	112				
.1T46*FLT01B	FILTER TRAIN REHEAT COIL	RBSVS		FARR		180 DYS		ALL
	FARR CO	1E	K-15	N-240	*IJ			A
	310599	105	RBS	112				

REPORT NO. PES-800 STONE AND WEBSTER ENGINEERING CORPORATION
 JOB NUMBER 1160002 PROJECT EQUIPMENT SYSTEM - (IS-129)
 JOB NAME SHOREHAM - UNIT 1 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 JOB CLIENT LILCO REPORT DATE 01/18/82 PAGE 33
 RESET NO. 003
 RESET DATE 07/01/81
 SORTED BY - MAK / MOD / SPEC

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = FENHAL

.1B21*TE43AY B21-N010A	MAIN STM TUNNEL OUTLET GENERAL ELEC 310010 OP CODE C FOR REMAINDER OF HELB	1E 003	ST ST	*FENHAL *145C3004P002	*3110 *DR	*70	*MIN	*.6%	H A
.1B21*TE43BY B21-N010B	MAIN STM TUNNEL OUTLET GENERAL ELEC 310010 OP CODE C FOR REMAINDER OF HELB	1E 003	ST ST	*FENHAL *145C3004P002	*3110 *DR	*70	*MIN	*.6%	H A
.1B21*TE43CY B21-N010C	MAIN STM TUNNEL OUTLET GENERAL ELEC 310010 OP CODE C FOR REMAINDER OF HELB	1E 003	ST ST	*FENHAL *145C3004P002	*3110 *DR	*70	*MIN	*.6%	H A
.1B21*TE43DY B21-N010D	MAIN STM TUNNEL OUTLET GENERAL ELEC 310010 OP CODE C FOR REMAINDER OF HELB	1E 003	ST ST	*FENHAL *145C3004P002	*3110 *DR	*70	*MIN	*.6%	H A

1E11*E/P007A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 34
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = FISHER GOVERNOR

.1E11*E/P007A E11-K001A	STM TO RHR HX SHELL GENERAL ELEC 310010	1E 003	G-01 RBS	*FISHER GOVERNOR *546	*3122 *DR	180 DYS	*2%	ALL B
.1E11*E/P007B E11-K001B	RHR HX SHELL TO RCIC GENERAL ELEC 310010	1E 003	G-01 RBS	*FISHER GOVERNOR *546	*3122 *DR	180 DYS	*2%	ALL B

1G11*LE642C

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 35
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PG NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = GEMS

.1G11*LE642C	*REACT BLDG FLOOR DRN SUMP 056C			GEMS		180 DYS	2%	
	DELEVAL	1E	G-01	XM-54854	*IJ			*L
	10091	473	RBS	00008				A
	OP CODE B FOR HELB & HELB							
.1G11*LE645A	REACT BLD FLOOD LEVEL			GEMS		180 DYS	2%	*RG
	DELEVAL	1E	G-01	XM-54854	*IJ			ALL
	10091	473	RBS	00008				A
.1G11*LE645B	REACT BLD FLOOD LEVEL			GEMS		180 DYS	2%	*RG
	DELEVAL	1E	G-01	XM-54854	*IJ			ALL
	10091	473	RBS	00008				A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 36
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
REPORT GROUP MAK = GENERAL ELECTRIC									
.1H21*PNL02 *H21-P002	RVCU SYSTEM INST RACK 310010	1E 003	H-16 RBS	112	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A
.1H21*PNL04 *H21-P004	RX VES L&P RACK A 310010	1E 003	G-10 RBS	70	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A
.1H21*PNL05 *H21-P005	RX VES L&D RACK B 310010	1E 003	G-12 RBS	78	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A
.1H21*PNL06 *H21-P006	RECIRC PUMP A RACK 310010	1E 003	G-02 RBS	40	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A
.1H21*PNL09 *H21-P009	JET PUMP INST RACK A 310010	1E 003	G-09 RBS	79	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A
.1H21*PNL10 *H21-P010	JET PUMP INST RACK B 310010	1E 003	G-11 RBS	79	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A
.1H21*PNL14 *H21-P014	HPCI INST RACK 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A
.1H21*PNL15 *H21-P015	MAIN STEAM FLOW RACK A 310010	1E 003	G-01 RBS	40	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A
.1H21*PNL16 *H21-P016	CS/HPCI LEAK DET I RK 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A
.1H21*PNL17 *H21-P017	RCIC INST RACK 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A
.1H21*PNL18 *H21-P018	RHR INST RK CH A 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC *DR	*3912	180 DYS	*N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPFC

REPORT DATE 01/18/82 PAGE 37
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE ELDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
.1H21*PNL19 *H21-P019	CORE SPRAY RK CH B 310010	1E 003	G-01 RBS 8	*GENERAL ELECTRIC	*3912 *DR	180 DYS	*N/A	ALL A
.1H21*PNL21 *H21-P021	RHR INST RK CH B 310010	1E 003	G-01 RBS 8	*GENERAL ELECTRIC	*3912 *DR	180 DYS	*N/A	ALL A
.1H21*PNL22 *H21-P022	RECIRC PUMP B RACK 310010	1E 003	L-02 RBS 40	*GENERAL ELECTRIC	*3912 *DR	180 DYS	*N/A	ALL A
.1H21*PNL25 *H21-P025	MAIN STEAM FLOW RK B 310010	1E 003	G-02 RBS 40	*GENERAL ELECTRIC	*3912 *DR	180 DYS	*N/A	ALL A
.1H21*PNL26 *H21-P026	RV LEVEL & PRESS INST 310010	1E 003	H-12 RBS 78	*GENERAL ELECTRIC	*3912 *DR	180 DYS	*N/A	ALL A
.1H21*PNL35 *H21-P035	CS/RCIC LEAK DET RK B 310010	1E 003	L-02 RBS 40	*GENERAL ELECTRIC	*3912 *DR	180 DYS	*N/A	ALL A
.1H21*PNL36 *H21-P036	HPCI LEAK DET RK B 310010	1E 003	G-01 RBS 8	*GENERAL ELECTRIC	*3912 *DR	180 DYS	*N/A	ALL A
.1H21*PNL37 *H21-P037	RCIC LEAK DET RK A 310010	1E 003	G-01 RBS 8	*GENERAL ELECTRIC	*3912 *DR	180 DYS	*N/A	ALL A
.1H21*PNL38 *H21-P038	RCIC LEAK DET RK B 310010	1E 003	L-02 RBS 40	*GENERAL ELECTRIC	*3912 *DR	180 DYS	*N/A	ALL A
.1H21*PNL41 *H21-P041	MAIN STM FLOW SYS C 310010	1E 003	G-02 RBS 40	*GENERAL ELECTRIC	*3912 *DR	180 DYS	*N/A	ALL A
.1E41*P127 *E-036	HPCI TURB HYD & BER OIL AUX PP GE-TERRY TURB 310010	1E 003	G-01 RBS 8	*GENERAL ELECTRIC *CD 259A7	* *TA	001 DYS	*N/A	ALL A
.1R42*MCC0A1	125VDC MOTOR CONT CENTER GEN ELEC 310562	1E 168	*L-02 RBS 40	GENERAL ELECTRIC DC MTR CONT CENTER	*IJ	180 DYS		*L A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 38

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

H,M-OP CODE B 1 DAY, C REM. (MCC REV.)

.1R42*HCC0A2	125VDC MOTOR CONT CENTER GEN ELEC 310562	1E 168	N-21 RBS	112	GENERAL ELECTRIC DC HTR CONT CENTER	*IJ	180 DYS	ALL A
.1R42*HCC0B1	125VDC MOTOR CONT CENTER GEN ELEC 310562	1E 168	*N-21 RBS	40	GENERAL ELECTRIC DC HTR CONT CENTER	*IJ	180 DYS	ALL A
.1R42*HCC0B2	125VDC MOTOR CONT CENTER GEN ELEC 310562	1E 168	N-21 RBS	112	GENERAL ELECTRIC DC HTR CONT CENTER	*IJ	180 DYS	ALL A
.1H21*PNL01 *H21-P001	CORE SPRAY RACK CH 4 GENERAL ELEC 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC M26	*3912 *DR	180 DYS *N/A	ALL A
.1H21*PNL73 *H21-P073	MSIV LEAKAGE INST RACK GENERAL ELEC	1E 003	G-05 RBS	63	*GENERAL ELECTRIC M26	*3912 *DR	180 DYS *N/A	ALL A
.1H21*PNL74 *H21-P074	MSIV LEAKAGE INST RACK GENERAL ELEC 310010	1E 003	G-05 RBS	63	*GENERAL ELECTRIC M26	*3912 *DR	180 DYS *N/A	ALL A
.1B31*BKR01A	REAC RECIRC PP TRIP BKR (RED) GENERAL ELEC 310057	1E 039	L-02 RBS	00040	*GENERAL ELECTRIC M26	*DR	180 DYS	*L *B
	H,M OP CODE B 1 DAY, C REM							
.1B31*BKR01B	REAC RECIRC PP TRIP BKR (RED) GENERAL ELEC 310057	1E 039	L-02 RBS	00040	*GENERAL ELECTRIC M26	*DR	180 DYS	*L *B
	H,M OP CODE B 1 DAY, C REM							
.1B31*BKR02A	REAC RECIRC PP TRIP BKR (BLUE) GENERAL ELEC 310057	1E 039	L-02 RBS	00040	*GENERAL ELECTRIC M26	*DR	180 DYS	*L *B
	H,M OP CODE B 1 DAY, C REM							
.1B31*BKR02B	REAC RECIRC PP TRIP BKR (BLUE) GENERAL ELEC 310057	1E 039	L-02 RBS	00040	*GENERAL ELECTRIC M26	*DR	180 DYS	*L *B
	H,M OP CODE B 1 DAY, C REM							
.1T23-Z-EA2	REACTOR CONT ELEC PENET				GENERAL ELECTRIC	*134-02	180 DYS	N/A

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 39

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
	GEN ELEC CO 310578	1E 134	D-22 RBP	00078	SERIES 100 MED VOLT	*IJ *MST			L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23-Z-HA2	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 100 MED VOLT	*134-02 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23-Z-HA3	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 100 MED VOLT	*134-02 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23-Z-EA3	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 200 LOW VOLT	*134-01 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23-Z-EB3	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 200 LOW VOLT	*134-01 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23-Z-EB5	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 200 LOW VOLT	*134-01 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23-Z-EB6	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 200 LOW VOLT	*134-01 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23-Z-EC5	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 200 LOW VOLT	*134-01 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23-Z-EC6	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 200 LOW VOLT	*134-01 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23-Z-WB1	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 200 LOW VOLT	*134-01 *IJ *MST	180 DYS	N/A	L A

1T23-Z-WB1

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 40
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	MODEL / CATALOG NO	QUAL STAT			ENG CND
	QAC ZONE		SUBMG			OP CD
	PO NUMBER SPEC BLDG ELEV					
*****	*****	*****	*****	*****	*****	****

REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F

.1T23-Z-WB2	REACTOR CONT ELEC PENET	GENERAL ELECTRIC	*134-01	180 DYS	N/A	
	GEN ELEC CO	SERIES 200 LOW VOLT	*IJ			L
	310578	1E D-22 RBP 00078	*HST			A

REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F

.1T23-Z-WB5	REACTOR CONT ELEC PENET	GENERAL ELECTRIC	*134-01	180 DYS	N/A	
	GEN ELEC CO	SERIES 200 LOW VOLT	*IJ			L
	310578	1E D-22 RBP 00078	*HST			A

REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F

.1T23-Z-WB6	REACTOR CONT ELEC PENET	GENERAL ELECTRIC	*134-01	180 DYS	N/A	
	GEN ELEC CO	SERIES 200 LOW VOLT	*IJ			L
	310578	1E D-22 RBP 00078	*HST			A

REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F

.1T23-Z-WC5	REACTOR CONT ELEC PENET	GENERAL ELECTRIC	*134-01	180 DYS	N/A	
	GEN ELEC CO	SERIES 200 LOW VOLT	*IJ			L
	310578	1E D-22 RBP 00078	*HST			A

REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F

.1T23-Z-WC6	REACTOR CONT ELEC PENET	GENERAL ELECTRIC	*134-01	180 DYS	N/A	
	GEN ELEC CO	SERIES 200 LOW VOLT	*IJ			L
	310578	1E D-22 RBP 00078	*HST			A

REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F

.1T23*Z-EA1	REACTOR CONT ELEC PENET	GENERAL ELECTRIC	*134-01	180 DYS	N/A	
	GEN ELEC CO	SERIES 200, LOW VOLT	*IJ			L
	310578	1E D-22 RBP 00078	*HST			A

REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F

.1T23*Z-EB2	REACTOR CONT ELEC PENET	GENERAL ELECTRIC	*134-01	180 DYS	N/A	
	GEN ELEC CO	SERIES 200, LOW VOLT	*IJ			L
	310578	1E D-22 RBP 00078	*HST			A

REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F

.1T23*Z-ED5	REACTOR CONT ELEC PENET	GENERAL ELECTRIC	*134-01	180 DYS	N/A	
	GEN ELEC CO	SERIES 200, LOW VOLT	*IJ			L
	310578	1E D-22 RBP 00078	*HST			A

REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F

.1T23*Z-ED6	REACTOR CONT ELEC PENET	GENERAL ELECTRIC	*134-01	180 DYS	N/A	
	GEN ELEC CO	SERIES 200, LOW VOLT	*IJ			L
	310578	1E D-22 RBP 00078	*HST			A

REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 41
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1T23*Z-WB4	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 200, LOW VOLT	*134-01 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23*Z-WD1	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 200, LOW VOLT	*134-01 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1T23*Z-WD2	REACTOR CONT ELEC PENET GEN ELEC CO 310578	1E 134	D-22 RBP	00078	GENERAL ELECTRIC SERIES 200, LOW VOLT	*134-01 *IJ *MST	180 DYS	N/A	L A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1E41*P074 *E-036	HPCI VACUUM PUMP NEAR COL C-9 GE-TERRY TURB 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC 1.5HP,1750RPM,120VDC	* *TA	001 DYS	*N/A	ALL A
.1E32*BLO013	OUTBD MSIV BLOWER GE 310010	1E 003	G-06 RBS	76	*GENERAL ELECTRIC 2CH6 041-1U	*3903 *IJ	100 DYS	*N/A	L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1E32*BLO014A	OUTBD MSIV BLOWER GENERAL ELEC 310010	1E 003	G-04 RBS	00063	*GENERAL ELECTRIC 2CH6 041-1U	*3903 *IJ	100 DYS	*N/A	L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1E32*BLO014B	OUTBD MSIV BLOWER GENERAL ELEC 310010	1E 003	G-04 RBS	00063	*GENERAL ELECTRIC 2CH6 041-1U	*3903 *IJ	100 DYS	*N/A	L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1T23*Z-WC4	REACTOR CONT ELEC PENET *GEN. ELECT. CO. 310578	*1E *134	*D-22 *RBP	*00078	*GENERAL ELECTRIC *200 SERIES LOW VOLT	*134-01 *IJ *MST	*180 DYS	*N/A	L *A
	REQUIRED RADIATION DOSE REDUCED TO 1.0E8 BY CALCULATION SNPS-1-UR-22-F								
.1D11*RE011A D11-N006A	RADIATION MONITORING DETECTOR GENERAL ELEC 310010	1E 003	ST ST	63	*GENERAL ELECTRIC *237X731G001	*3914 *DR	070 MIN		L A
.1D11*RE011B D11-N006B	RADIATION MONITORING DETECTOR GENERAL ELEC 310010	1E 003	ST ST	63	*GENERAL ELECTRIC *237X731G001	*3914 *DR	070 MIN		L A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 42
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EHG STAT OP CD

.1D11*RE011C D11-N006C	RADIATION MONITORING DETECTOR GENERAL ELEC 310010	1E 003	ST ST	63	*GENERAL ELECTRIC *237X731G001	*3914 *DR	070 MIN		L A
.1D11*RE011D D11-N006D	RADIATION MONITORING DETECTOR GENERAL ELEC 310010	1E 003	ST ST	63	*GENERAL ELECTRIC *237X731G001	*3914 *DR	070 MIN		L A
*1P41*HSS102A ADDED	*SAMPLE TO RAD MONITOR *POWERS REGUL *310736	*1E *319	*G-01 *RBS	*00008	*GENERAL ELECTRIC *2940US203E	*IJ	*180 *DYS		*ALL *B
*1P41*HSS102B ADDED	*SAMPLE TO RAD MONITOR *POWERS REGUL	*1E *319	*G-01 *RBS	*00008	*GENERAL ELECTRIC *2940US203E	*IJ	*180 *DYS		*ALL *B
.1E51*P076	RCIRC CONDENSER VAC PP GE-TERRY TURB 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC 3HP,1900RPM,120VDC	*****	001 DYS	*N/A	ALL A
.1E51*P077	RCIC COND PHP GE-TERRY TURB 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC 3HP,1900RPM,120VDC	*****	001 DYS	*N/A	ALL A
.1E41*P075 *E-036	HPCI COND PP NEAR COLUMN GE-TERRY TURB 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC 3HP,3500RPM,120VDC	*TA	001 DYS	*N/A	ALL A
.1E32*HC053A *B-001B	LCS INBOARD HEATER GE 310010	1E 003	G-07 RBS	00063	*GENERAL ELECTRIC 47D518673	*3902 *IJ	100 DYS	*N/A	*L A
L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (HCC REV.)									
.1E32*HC053B *B-001P	LCS INBOARD HEATER GE 310010	1E 003	G-07 RBS	00063	*GENERAL ELECTRIC 47D518673	*3902 *IJ	100 DYS	*N/A	*L A
OP CODE B FOR HELB & MELB									
.1E32*HC053C *B-001K	LCS INBOARD HEATER GE 310010	1E 003	G-07 RBS	00063	*GENERAL ELECTRIC 47D518673	*3902 *IJ	100 DYS	*N/A	*L A
OP CODE B FOR HELB & MELB									
.1E32*HC053D	LCS INBOARD HEATER GE 310010	1E 003	G-07 RBS	00063	*GENERAL ELECTRIC 47D518673	*3902 *IJ	100 DYS	*N/A	*L A
L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (HCC REV.)									

1C41*P024A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 43
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EHG CND OP CD
*A*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1C41*P024A	STANDBY LIQ CONTROL PP GE-UNION PUMP 310010	1E 003	J-15 RBS	112	*GENERAL ELECTRIC 5K324AK2084	*3900 *FT	180 DYS	N/A	ALL *B
.1C41*P024B	STANDBY LIQ CONTROL PP GE-UNION PUMP 310010	1E 003	J-15 RBS	112	*GENERAL ELECTRIC 5K324AK2084	*3900 *FT	180 DYS	N/A	ALL *B
.1E11*P014A	RHR PUMP NEAR COLUMN C-11 GE-BYRON JACKSON 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC 5K6339XC91A	3111 *EQ	180 DYS	N/A	ALL A
.1E11*P014B	RHR PUMP NEAR COLUMN GE-BYRON JACKSON 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC 5K6339XC91A	3111 *EQ	180 DYS	N/A	ALL A
.1E11*P014C	RHR PUMP NEAR COLUMN C-11 GE-BYRON JACKSON 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC 5K6339XC91A	3111 *EQ	180 DYS	N/A	ALL A
.1E11*P014D	RHR PUMP NEAR COLUMN C-5 GE-BYRON JACKSON 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC 5K6339XC91A	3111 *EQ	180 DYS	N/A	ALL A
.1E21*P013A	CORE SPRAY PP NEAR COLUMN C-11 GE-BYRON JACK 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC 5K6339XC94A	3111 *EQ	180 DYS	*N/A	L A
.1E21*P013B	CORE SPRAY PP NEAR COLUMN C-5 GE-BYRON JACK 310010	1E 003	G-01 RBS	8	*GENERAL ELECTRIC 5K6339XC94A	3111 *EQ	180 DYS	*N/A	L A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 44
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT ENH CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = GOULD

1R24*PNL111	M-G SET CONTROL CABINET 111 LOUIS ALLIS 310950	1E 439	N-21 RBS	00150	*GOULD *5600 SERIES	*439-02 *FT	180 DYS	N/A	ALL A
1R24*PNL112	M-G SET CONTROL CABINET 112 LOUIS ALLIS 310950	1E 439	N-21 RBS	00150	*GOULD *5600 SERIES	*439-02 *FT	180 DYS	N/A	ALL A
1R24*PNL113A	M-G SET CONTROL CABINET 113A LOUIS ALLIS 310950	1E 439	N-21 RBS	00150	*GOULD *5600 SERIES	*439-02 *FT	180 DYS	N/A	ALL A
1R24*PNL113B	M-G SET CONTROL CABINET 113B LOUIS ALLIS 310950	1E 439	N-21 RBS	00150	*GOULD *5600 SERIES	*439-02 *FT	180 DYS	N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 45
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = ITT

.1T46#M00034A	RBSVS FILTER TRAIN DISCH			ITT	*319-02	180	DrS	
	POWERS REGUL	1E	H-20	NH91	*IJ			ALL
	310738	319	RBS	182				A
.1T46#M00034B	RBSVS FILTER TRAIN DISCH			ITT	*319-02	180	DYS	
	POWERS REGUL	1E	H-20	NH91	*IJ			ALL
	310738	319	RBS	182				A

REPORT NO. PES-800 STONE AND WEBSTER ENGINEERING CORPORATION REPORT DATE 01/18/82 PAGE 46
 JOB NUMBER 1160002 PROJECT EQUIPMENT SYSTEM - (IS-129) RESET NO. 003
 JOB NAME SHOREHAM - UNIT 1 ENVIRONMENTAL QUALIFICATION STATUS REPORT RESET DATE 07/01/81
 JOB CLIENT LILCO SORTED BY - MAK / MOD / SPEC

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	HAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			ENG CND
	PO NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = KAHEN

*1D21*RE085A	*CONTAIN. HIGH RANGE RAD.DET.	*1E	*D-22	*KAHEN	*TA	*180 *DYS		*ALL
ADDED	*310985	*475	*RBD		*MST			*A
*1D21*RE085B	*CONTAIN. HIGH RANGE RAD.DET.	*1E	*D-22	*KAHEN	*TA	*180 *DYS		*ALL
ADDED	*310985	*475	*RBD		*MST			*A
*1D21-PNL085A	*CONTAIN.HIGH RANGE AREA MON.	*2E	*H-09	*KAHEN	*TA	*180 *DYS		*ALL
ADDED	*310985	*475	*RBS *00078					*A
*1D21-PNL085B	*CONTAIN.HIGH RANGE AREA MON.	*2E	*H-09	*KAHEN	*TA	*180 *DYS		*ALL
ADDED	*310985	*475	*RBS *00078					*A

1R31*NFN03

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 47

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = KERITE CO

.1R31*NFN03

*PWR CABLES

KERITE CO

310561

REPRESENTS ALL CABLE PURCHASED UNDER SH1-127

1E ALL

127 RB

KERITE CO

5 KV POWER CABLE

*127-01

*EQ

*SPR

180 DYS NA

ALL

A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 48
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLNG ELEV	MODEL / CATALOG NO	QUAL STAT			ENG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = LIMITORQUE

.1P41*MOV129B	DRYWELL BSTR HX DISCH VV CONTROMATICS 310744	1E *281	G-01 RBS	00008	LIMITORQUE HIBC-SMB-000-02	*197-01 *EQ	070 MIN	N/A	ALL A
.1P41*MOV042A 03160004	EMER SW TO FUEL POOL HENRY PRATT 310546	1E 197	G-01 RBS	31	LIMITORQUE H0BC-SMB-00-02	*197-01 *EQ	180 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1P41*MOV042B 03180004	EMER SW TO FUEL POOL HENRY PRATT 310546	1E 197	G-01 RBS	31	LIMITORQUE H0BC-SMB-00-02	*197-01 *EQ	180 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1P41*MOV034A E11-F002A	RHR HX E-34A DISCH HENRY PRATT 310546	1E 197	G-01 RBS	32	LIMITORQUE H2BC-SMB-00-05	*197-01 *EQ	180 DYS	N/A	ALL A
.1P41*MOV034B E11-F002B	RHR HX E-34B DISCH HENRY PRATT 310546	1E 197	G-01 RBS	27	LIMITORQUE H2BC-SMB-00-05	*197-01 *EQ	180 DYS	N/A	ALL A
.1P41*MOV037A	RBCLCH HX DISCH HENRY PRATT 310546	1E 197	G-01 RBS	23	LIMITORQUE H2BC-SMB-00-05	*197-01 *EQ	180 DYS	N/A	ALL A
.1P41*MOV037B	RBCLCW HX DISCH HENRY PRATT 310546	1E 197	G-01 RBS	23	LIMITORQUE H2BC-SMB-00-05	*197-01 *EQ	180 DYS	N/A	ALL A
.1P41*MOV033A 02940003	TO RHR SYSTEM HENRY PRATT 310546	1E 197	G-01 RBS	28	LIMITORQUE H2BC-SMB-000-02	*197-01 *EQ	180 DYS	N/A	*L A
.1P41*MOV033B 02960003	TO RHR SYSTEM HENRY PRATT 310546	1E 197	G-01 RBS	28	LIMITORQUE H2BC-SMB-000-02	*197-01 *EQ	180 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1P41*MOV033C 02980004	TO RHR SYSTEM HENRY PRATT 310546	1E 197	G-01 RBS	32	LIMITORQUE H2BC-SMB-000-05	*197-01 *EQ	180 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 49
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD

.1P41*MOV033D 03000004	TO RHR SYSTEM HENRY PRATT 310546 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 197	G-01 RBS	32	LIMITORQUE H2BC-SMB-000-05 (HCC REV.)	*197-01 *EQ	180 DYS	N/A	*L A
.1E11*MOV037A E11-F015A	*RHR OUTBOARD VV NR COLUMN C-5 ANCHOR DARLIN 310501	1E 86AD	G-03 RBS	72	LIMITORQUE SB-4-200	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*MOV037B E11-F015B	*RHR OUTBOARD VV NR COLUMN C-5 ANCHOR DARLIN 310501	1E 88AD	G-07 RBS	72	LIMITORQUE SB-4-200	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E51*MOV044	TURBINE STOP VALVE GENERAL ELEC 310010	1E 003	G-01 RBS	12	LIMITORQUE SMB-0	DR	001 DYS	N/A	ALL A
.1E41*MOV043 E41-F001	HPCI STM TO TURB NEAR COL C-8 VELAN 310502 OP CODE B FOR HELB & HELB	1E 88V	G-01 RBP	00019	LIMITORQUE SMB-0-15	*88V-02 *EQ	*001 *DYS		*L A
.1E41*MOV044 E41-F021	TURB EXH TO SUPP POOL C-8 VELAN 310502	1E 88V	G-02 RBS	33	LIMITORQUE SMB-0-15	*DR	*001 *DYS	N/A	ALL B
.1E11*MOV039A E11-F021A	RHR CONT SPRAY HDR NR COL C-11 VELAN 310502	1E 86V	G-10 RBS	103	LIMITORQUE SMB-0-25	*88V-03 *EQ	001 DYS	NA	ALL A
.1E11*MOV039B E11-F021B	RHR CONT SPRAY VV NR COL C-5 VELAN 310502	1E 88V	G-10 RBS	103	LIMITORQUE SMB-0-25	*88V-03 *EQ	001 DYS	NA	ALL A
.1E41*MOV031 E41-F004	HPCI PP SUCT COND STG NR C-6 VELAN 310502	1E 88V	G-01 RBS	20	LIMITORQUE SMB-0-25	*DR	001 DYS	N/A	ALL A
.1E41*MOV032 E41-F042	HPCI PP SUCT SUPP POOL NR C-7 VELAN 310502	1E 88V	G-01 RBS	24	LIMITORQUE SMB-0-25	*DR	001 DYS	N/A	ALL A
.1P42*MOV041A	RBCLCH HX CROSSOVER INLET VV VELAN *310512	1E *88V	G-01 RBS	28	LIMITORQUE SMB-0-25	*88V-03 *EQ	070 MIN	N/A	*L A
.1P42*MOV041B	RBCLCH HX CROSSOVER INLET VV				LIMITORQUE	*88V-03	070 MIN	N/A	

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 50
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	MU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
	VELAN 310502 L-OP CODE B REH: H,H-OP CODE B 1 DAY, C REH.	1E 88V	G-01 RBS	28	SMB-0-25 (HCC REV.)	*EQ			*L A
.1P42*HOV042A	RBCLCH HT EXC INLET VV VELAN 310502	1E 88V	G-01 RBS	30	LIMITORQUE SMB-0-25	*88V-03 *EQ	070 MIN	N/A	ALL A
.1P42*HOV042B	RBCLCH HT EXCH INLET VV VELAN 310502	1E 88V	G-01 RBS	30	LIMITORQUE SMB-0-25	*88V-03 *EQ	070 MIN	N/A	ALL A
.1E11*HOV031A E11-F004A	RHR PP SUCTION NR COLUMN C-11 ANCHOR DARLIN 310501	1E 88AD	G-01 RBS	24	LIMITORQUE SMB-0-40	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*HOV031B E11-F004B	RHR PP SUCTION NR COLUMN C-5 ANCHOR DARLIN 310501	1E 88AD	G-01 RBS	24	LIMITORQUE SMB-0-40	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*HOV031C E11-F004C	RHR PP SUCTION NR COLUMN C-12 ANCHOR DARLIN 310501	1E 88AD	G-01 RBS	24	LIMITORQUE SMB-0-40	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*HOV031D E11-F004D	RHR PP SUCTION NR COLUMN C-4 ANCHOR DARLIN 310501	1E 88AD	G-01 RBS	24	LIMITORQUE SMB-0-40	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*HOV032A E11-F006A	RHR PUMP SUCTION C-11 ANCHOR DARLIN 310501 OP CODE A FOR LOCA FOR 70 MINS	1E 88AD	G-01 RBS	15	LIMITORQUE SMB-0-40	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*HOV032B E11-F006B	RHR PUMP SUCTION C-5 ANCHOR DARLIN 310501 OP CODE A FOR LOCA FOR 70 MINS	1E 88AD	G-01 RBS	10	LIMITORQUE SMB-0-40	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*HOV032C E11-F006C	RHR PUMP SUCTION C-12 ANCHOR DARLIN 310501 OP CODE A FOR LOCA FOR 70 MINS	1E 88AD	G-01 RBS	20	LIMITORQUE SMB-0-40	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*HOV032D E11-F006D	RHR PUMP SUCTION C-4 ANCHOR DARLIN 310501 OP CODE A FOR LOCA FOR 70 MINS	1E 88AD	G-01 RBS	19	LIMITORQUE SMB-0-40	*88AD-02 *EQ	180 DYS	NA	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 51
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1G33*HOV031 G33-F102	REAC RECIRC SUCT EAST DRYWELL VELAN 310502	1E 253	B-22 RBD	99	LIMITORQUE SMB-0-40	*88V-04 *EQ *SPR	180 DYS	N/A	ALL B
.1G41*HOV034A	P-211 SUCTION VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-01 RBS	30	LIMITORQUE SMB-0-7.5 (MCC REV.)	*88V-01 *EQ	070 MIN	N/A	*L A
.1G41*HOV034B	P-211 SUCTION VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-01 RBS	30	LIMITORQUE SMB-0-7.5 (MCC REV.)	* *DR	070 MIN	N/A	*L A
.1E11*HOV081A E11-F122A	1E11*AOV081A BYPASS SW DRYWELL VELAN 310512	1E 253	D-22 RBD	81	LIMITORQUE SMB-00-05	* *DR *HST	070 MIN	N/A	ALL A
.1E11*HOV081B E11-F122B	1E11*AOV081B BYPASS NE DRYWELL VELAN 310512	1E 253	D-22 RBD	81	LIMITORQUE SMB-00-05	* *DR *HST	070 MIN	N/A	ALL A
.1E21*HOV081A	1E21*AOV081A BYPASS WEST RB VELAN 310512	1E 253	B-22 RBD	128	LIMITORQUE SMB-00-05	* *DR *HST	070 MIN	N/A	L A
.1E21*HOV081B	1E21*AOV081B BYPASS EAST RB VELAN 310512	1E 253	B-22 RBD	128	LIMITORQUE SMB-00-05	* *DR *HST	070 MIN	N/A	L A
.1E41*HOV039 E41-F059	TO LUBE OIL COOLER C-8 VELAN 310512	1E 253	G-01 RBS	16	LIMITORQUE SMB-00-05	*253-01 *EQ	001 DYS	N/A	ALL A
.1G41*HOV032A	SERVICE WATER INLET VALVE ITT GRINNELL 310539 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 203	S-18 RBS	00162	LIMITORQUE SMB-00-10 (MCC REV.)	*197-01 *EQ	180 DYS	NA	*L A
.1G41*HOV032B	SERVICE WATER INLET VALVE ITT GRINNELL 310539 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 203	S-18 RBS	00162	LIMITORQUE SMB-00-10 (MCC REV.)	*197-01 *EQ	180 DYS	NA	*L A
.1B21*HOV062 B21-F067B	MAIN STM LINE DRAIN VALVE VELAN 310512	1E 253	*T-08 RBS	00078	LIMITORQUE SMB-00-10	*253-03 *EQ *HST	070 MIN	N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 52
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLOG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
.1B21*MOV031 B21-F016	DRAIN TO CONDNSR NORTH DRYWELL VELAN 310502	1E 88V	D-22 RBD 79	LIMITORQUE SMB-00-10	*88V-01 *EQ *MST	070 MIN	NA	ALL A
.1E11*MOV052 E11-F040	TO RADWASTE SURGE TK NEAR C-4 VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-07 RBS 73	LIMITORQUE SMB-00-10 (MCC REV.)	*88V-03 *EQ	070 MIN	N/A	*L A
.1E11*MOV053 E11-F023	RHR HEAD SPRAY NR COLUMN C-5 VELAN 310502	1E 88V	G-07 RBS 103	LIMITORQUE SMB-00-10	*DR	070 MIN	N/A	ALL A
.1E41*MOV036 E41-F012	HPCI P MIN FLOW BYPASS NR C-7 VELAN 310502	1E 88V	G-01 RBS 20	LIMITORQUE SMB-00-10	*DR	001 DYS	N/A	ALL A
.1E51*MOV034 E51-F012	RCIC PUMP DISCH VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-01 RBS 19	LIMITORQUE SMB-00-10 (MCC REV.)	*DR	001 DYS	N/A	*L A
.1E51*MOV035 E51-F013	RCIC PUMP DISCH VELAN 310502	1E 88V	T-12 RBS 80	LIMITORQUE SMB-00-10	*DR	001 DYS	N/A	ALL A
.1E51*MOV037 E51-F022	RCIC DISCH TO COND STG VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-01 RBS 20	LIMITORQUE SMB-00-10 (MCC REV.)	*DR	070 MIN	N/A	*L A
.1E51*MOV041 E51-F007	RCIC STEAM TO TURB NRT DRYWELL VELAN 310502	1E 88V	D-22 RBD 88	LIMITORQUE SMB-00-10	*88V-01 *EQ *MST	001 DYS	N/A	ALL A
.1G33*MOV032 G33-F101	REAC VESSEL DRAIN EAST DRYWELL VELAN 310502	1E 88V	D-22 RBD 99	LIMITORQUE SMB-00-10	*88V-01 *EQ *MST	180 DYS	N/A	ALL B
.1E11*MOV041A E11-F027A	RHR SUPP POOL SPRAY HD NR C-10 VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-02 RBS 51	LIMITORQUE SMB-00-15 (MCC REV.)	*88V-03 *EQ	*001 *DYS	NA	*L A
.1E11*MOV041B E11-F027B	RHR SUPP POOL SPRAY HD NR C-6 VELAN *399772	1E *88V	L-02 RES 40	LIMITORQUE SMB-00-15	*88V-03 *EQ	*001 *DYS	NA	*L A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOPEHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 53

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL SHEET SUBHG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD

	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.				(MCC REV.)				
.1E11*MOV043A E11-F026A	RHR HX TO RCIC P SUCT NR C-11 VELAN 310502	1E 88V	G-01 RBS	17	LIMITORQUE SHB-00-15	*88V-03 *EQ	070 MIN	NA	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.				(MCC REV.)				
.1E11*MOV043B E11-F026B	RHR HX TO RCIC P SUCT NR C-5 VELAN 310502	1E 88V	G-01 RBS	17	LIMITORQUE SHB-00-15	*88V-03 *EQ	070 MIN	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.				(MCC REV.)				
.1E11*MOV044A E11-F011A	RHR HX DR TO SUPP POOL C-11 VELAN 310502	1E 88V	G-01 RBS	17	LIMITORQUE SHB-00-15	*88V-03 *EQ	070 MIN	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.				(MCC REV.)				
.1E11*MOV044B E11-F011B	RHR HX DR TO SUPP POOL C-5 VELAN 310502	1E 88V	G-01 RBS	17	LIMITORQUE SHB-00-15	*88V-03 *EQ	070 MIN	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.				(MCC REV.)				
.1E11*MOV054 E11-F022	RHR HEAD SPRAY NR COLUMN C-5 VELAN 310502	1E 88V	B-22 RBD	104	LIMITORQUE SHB-00-15	*DR *SPR	070 MIN	N/A	ALL A
.1G33*MOV030A G33-F106	REAC RECIRC SUCT EAST DRYWELL VELAN 310502	1E 88V	B-22 RBD	98	LIMITORQUE SHB-00-15	*88V-04 *EQ *SPR	180 DYS	N/A	ALL B
.1G33*MOV030B G33-F100	REAC RECIRC SUCT EAST DRYWELL VELAN 310502	1E 88V	B-22 RBD	99	LIMITORQUE SHB-00-15	*88V-04 *EQ *SPR	180 DYS	N/A	ALL B
.1G33*MOV034 G33-F004	REACTOR VESSEL DISCH VELAN 310502	1E 88V	P-13 RBS	121	LIMITORQUE SHB-00-15	*DR	070 MIN	N/A	ALL A
.1N11*MOV036	MISC STM FROM DHR ISOL VELAN 310502	1E 88V	ST ST	53	LIMITORQUE SHB-00-15	*88V-03 *EQ	070 MIN	N/A	L A
.1N11*MOV041	AUX STEAM SUPPLY VELAN 310502	1E 88V	ST ST	50	LIMITORQUE SHB-00-15	*88V-03 *EQ	070 MIN	N/A	L A
.1G33*MOV033	REAC VESSEL DISCH EAST DRYWELL				LIMITORQUE	*88V-01	070 MIN	N/A	

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/16/82 PAGE 54
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	GAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
G33-F001	VELAN 310502	1E 88V	B-22 RBD	121	SMB-00-25	*EQ *MST			ALL A
.1E51*HOV031 E51-F010	RCIC PUMP SUCT COND STG VELAN 310502	1E 88V	G-01 RBS	24	LIMITORQUE SMB-00-5	*DR	001 DYS	N/A	ALL A
.1E51*HOV032 E51-F031	RCIC PUMP SUCT SUPP POOL VELAN 310502	1E 88V	G-01 RBS	24	LIMITORQUE SMB-00-5	*DR	001 DYS	N/A	ALL A
.1T48*HOV031A	ATHOS INBD CONT ISO NW DRYWELL VELAN 310502	1E 88V	D-22 RBD	67	LIMITORQUE SMB-00-5	*88V-01 *EQ *MST	180 DYS	N/A	ALL A
.1T48*HOV031B	ATHOS INBD CONT ISO SE DRYWELL VELAN 310502	1E 88V	D-22 RBD	73	LIMITORQUE SMB-00-5	*88V-01 *EQ *MST	180 DYS	N/A	ALL A
.1T48*HOV033A	ATHOS INBD CONT ISO N SUP CHM VELAN 310502	1E 88V	L-02 RBS	51	LIMITORQUE SMB-00-5	*88V-01 *EQ	180 DYS	N/A	ALL A
.1T48*HOV033B	ATHOS INBD CONT ISO NE SUP CHM VELAN 310502	1E 88V	L-02 RBS	51	LIMITORQUE SMB-00-5	*88V-01 *EQ	180 DYS	N/A	ALL A
.1B21*HOV034 B21-F020	DRAIN TO CONDENSER VELAN 310502	1E 88V	H-08 RBS	78	LIMITORQUE SMB-00-7.5	* *DR	180 DYS	NA	ALL B
.1E51*HOV042 E51-F008	RCIC STEAM TO TURBINE VELAN 310502	1E 88V	T-12 RBS	88	LIMITORQUE SMB-00-7.5	*88V-02 *EQ	001 DYS	N/A	ALL A
.1E51*HOV043 E51-F045	RCIC STM TO TURBINE VELAN 310502	1E 88V	G-01 RBS	12	LIMITORQUE SMB-00-7.5	*88V-02 *EQ	001 DYS	N/A	ALL A
.1T48*HOV032A	ATHOS INBD CONT ISO SW DRYWELL VELAN 310502	1E 88V	D-22 RBD	71	LIMITORQUE SMB-00-7.5	*88V-01 *EQ *MST	180 DYS	N/A	ALL A
.1T48*HOV032B	ATHOS INBD CONT ISO NE DRYWELL VELAN 310502	1E 88V	D-22 RBD	71	LIMITORQUE SMB-00-7.5	*88V-01 *EQ *MST	180 DYS	N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 55
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	GAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
.1T48*MOV034A	ATHOS INBD CONT ISO SW SUP CHM VELAN 310502	1E 88V	L-02 RBS	51	LIMITORQUE SMB-00-7.5	*88V-01 *EQ	180 DYS	N/A	ALL A
.1T48*MOV034B	ATHOS INBD CONT ISO S SUP CHM VELAN 310502	1E 88V	L-02 RBS	51	LIMITORQUE SMB-00-7.5	*88V-01 *EQ	180 DYS	N/A	ALL A
.1T48*MOV037A	ATHOS OTBD CONT ISO VELAN 310502	1E 88V	G-03 RBS	73	LIMITORQUE SMB-00-7.5	*88V-01 *EQ	180 DYS	N/A	ALL A
.1T48*MOV037B	ATHOS OTBD CONT ISO VELAN 310502	1E 88V	G-03 RBS	72	LIMITORQUE SMB-00-7.5	*88V-01 *EQ	180 DYS	N/A	ALL A
.1T48*MOV040A	ATHOS OTBD CONT ISO VELAN 310502 OP CODE B FOR HELB & MELB	1E 88V	L-02 RBS	51	LIMITORQUE SMB-00-7.5	* *DR	180 DYS	N/A	*L A
.1T48*MOV040B	ATHOS OTBD CONT ISO VELAN 310502 L-OP CODE B REM: H,H-OP CODE B 1 DAY, C REM. (MCC REV.)	1E 88V	L-02 RBS	51	LIMITORQUE SMB-00-7.5	* *DR	180 DYS	N/A	*L A
.1T48*FCV06A FV-1	GAS INLET VALVE ATOMICS INT 310624	*1E 289	*J-15 RBS	00112	*LIMITORQUE *SMB-000	* *DR	*180 *DYS	*N/A	*L *A
.1T48*FCV06B FV-1	GAS INLET VALVE ATOMICS INT 310624	*1E 289	*J-15 RBS	00112	*LIMITORQUE *SMB-000	* *DR	*180 *DYS	*N/A	*L *A
.1T48*FCV07A FV-2	RECIRC GAS VALVE ATOMICS INT 310624	*1E 289	*J-15 RBS	00112	*LIMITORQUE *SMB-000	* *DR	*180 *DYS	*N/A	*L *A
.1T48*FCV07B FV-2	RECIRC GAS ATOMICS INT 310624	*1E 289	*J-15 RBS	00112	*LIMITORQUE *SMB-000	* *DR	*180 *DYS	*N/A	*L *A
*1T48*MOV016A *MV-10 - ADDED	*WATER VALVE *ATOMICS INST *310624	*1E *289	*J-15 *RBS	*00112	*LIMITORQUE *SMB-000	*289-02 *EQ	*180 *DYS	*N/A	*L *A
*1T48*MOV016B	*WATER VALVE				*LIMITORQUE	*289-02	*180 *DYS	*N/A	

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 56
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EHG CND OP CD
*MV-10 ADDED	*ATOMICS INST *310624	*1E *289	*J-15 *RBS *00112	*SMB-000	*EQ			*L *A
.1P41*MOV039A 03120004	DRAW TO RHP SYSTEM ITT GRINNELL 310539	1E 203	G-01 RBS 28	LIMITORQUE SMB-000-02	*197-01 *EQ	180 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1P41*MOV039B 03140004	DRAIN TO RHR SYSTEM ITT GRINNELL 310539	1E 203	G-01 RBS 28	LIMITORQUE SMB-000-02	*197-01 *EQ	180 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1P41*MOV043 03200004	SPENT FUEL POOL LINE DRAIN VV ITT GRINNELL 310539	1E 203	G-01 RBS 18	LIMITORQUE SMB-000-02	*197-01 *EQ	180 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1P41*MOV102A	SAMPLE TO RAD MONITOR ITT GRINNELL 310539	*1E 203	G-01 RBS 8	LIMITORQUE SMB-000-02	*197-01 *EQ	180 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1P41*MOV102B	SAMPLE TO RAD MONITOR ITT GRINNELL 310539	*1E 203	G-01 RBS 8	LIMITORQUE SMB-000-02	*197-01 *EQ	180 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1P50*MOV104	*INST AIR TO SUPP CHAMBER VV VELAN 310512	*1E *214	G-01 RBS 00020	LIMITORQUE SMB-000-02	*214-02 *EQ	070 MIN	NA	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1P50*MOV106	INSTR AIR TO SUPP CHAMBER BB VELAN 310512	1E 214	G-01 RBS 00020	LIMITORQUE SMB-000-02	*214-02 *EQ	070 MIN	NA	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1T23*MOV031A	INLET PRESS TO ACC-A VELAN 310512	1E 214	L-02 RBS 40	LIMITORQUE SMB-000-02	*214-02 *EQ	001 DYS	NA	L A
.1T23*MOV031B	INLET PRESS TO ACC-B VELAN 310512	1E 214	L-02 RBS 40	LIMITORQUE SMB-000-02	*214-02 *EQ	001 DYS	NA	L A
.1D11*MOV032A	RADIATION MONITORING XS-12			LIMITORQUE	*253-01	070 MIN	N/A	

REPORT NO. PES-800 STONE AND WEBSTER ENGINEERING CORPORATION
 JOB NUMBER 1160002 PROJECT EQUIPMENT SYSTEM - (IS-129)
 JOB NAME SHOREHAM - UNIT 1 ENVIRONMENTAL QUALIFICATION STATUS REPORT REPORT DATE 01/18/82 PAGE 57
 JOB CLIENT LILCO SORTED BY - MAK / MOD / SPEC RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EHG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
	VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 253	D-22 RBD	75	SMB-000-02 (HCC REV.)	*EQ *MST			*L A
.1D11*MOV032B	RADIATION MONITORING XS-12 VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 253	G-06 RBS	00063	LIMITORQUE SMB-000-02 (HCC REV.)	*253-03 *EQ	070 MIN	N/A	*L A
.1D11*MOV033A	RADIATION MONITORING XS-13 VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 253	D-22 RBD	75	LIMITORQUE SMB-000-02 (HCC REV.)	*253-01 *EQ *MST	070 MIN	N/A	*L A
.1D11*MOV033B	RADIATION MONITORING XS-13 VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 253	G-06 RBS	00063	LIMITORQUE SMB-000-02 (HCC REV.)	*253-03 *EQ	070 MIN	N/A	*L A
.1E11*MOV055A E11-F104A	RHR HX SHELL VENT NR C-11 VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 253	G-02 RBS	45	LIMITORQUE SMB-000-02 (HCC REV.)	*253-03 *EQ	070 MIN	N/A	*L A
.1E11*MOV055B E11-F104B	RHR HX SHELL VENT NR C-5 VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 253	G-02 RBS	45	LIMITORQUE SMB-000-02 (HCC REV.)	*253-03 *EQ	070 MIN	N/A	*L A
.1E11*MOV056A E11-F103A	RHR HX SHELL VENT NR C-11 VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 253	G-02 RBS	45	LIMITORQUE SMB-000-02 (HCC REV.)	*253-03 *EQ	070 MIN	N/A	*L A
.1E11*MOV056B E11-F103B	RHR HX SHELL VENT NR C-5 VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 253	G-02 RBS	45	LIMITORQUE SMB-000-02 (HCC REV.)	*253-03 *EQ	070 MIN	N/A	*L A
.1E11*MOV057A	TO HYDROGEN RECOMBINER WEST VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 253	G-01 RBS	8	LIMITORQUE SMB-000-02 (HCC REV.)	*253-03 *EQ	180 DYS	N/A	*L A
.1E11*MOV057B	TO HYDROGEN RECOMBINER EAST VELAN 310512	1E 253	G-01 RBS	8	LIMITORQUE SMB-000-02	*253-03 *EQ	180 DYS	N/A	*L A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 58
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD

L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)									
.1E41*HOV047 E41-F097	HOV041 BYPASS NRTH DRYWELL VELAN 310512	1E 253	Q-22 RBD	66	LIMITORQUE SMB-000-02	*253-01 *EQ *MST	001 DYS	N/A	ALL A
.1E41*HOV048 E41-F080	HOV042 BYPASS NR C-7 VELAN 310512	1E 253	*L-05 RBS	64	LIMITORQUE SMB-000-02	*253-02 *EQ *MST	001 DYS	N/A	ALL A
.1E41*HOV049 E41-F079	HPCI TURB EXH VAC BKR C-8 VELAN 310512	1E 253	G-01 RBS	34	LIMITORQUE SMB-000-02	*DR	001 DYS	N/A	ALL A
.1E51*HOV047 E51-F085	1E51*HOV041 BYPASS NRT DRYWELL VELAN 310512	1E 253	D-22 RBD	88	LIMITORQUE SMB-000-02	*253-01 *EQ *MST	001 DYS	N/A	ALL A
.1E51*HOV048 E51-F075	1E51*HOV042 BYPASS VELAN 310512	1E 253	T-08 RBS	88	LIMITORQUE SMB-000-02	*253-02 *EQ	001 DYS	N/A	ALL A
.1E51*HOV049 E51-F084	RCIC TURB EXH VAC BKR VELAN 310512	1E 253	G-01 RBS	34	LIMITORQUE SMB-000-02	*DR	*001 *DYS	N/A	*L *A
L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)									
.1T48*HOV004	SUPPRESSION POOL INLET VELAN 310512	1E 253	L-02 RBS	40	LIMITORQUE SMB-000-02	*253-03 *EQ	180 DYS	N/A	L A
.1P50*HOV103A 04330008	*COMPA SVCE OUTBD ISOLV VELAN 310512	*1E 214	*D-22 RBS	00078	LIMITORQUE SMB-000-05	*214-02 *EQ	180 DYS	NA	ALL A
.1P50*HOV103B 04350008	COMPA SVCE OUTBD ISOL VV VELAN 310512	*1E 214	*D-22 RBS	00078	LIMITORQUE SMB-000-05	*214-02 *EQ	180 DYS	NA	ALL A
.1P50*HOV105A	COMPA SVCE INBOARD ISOL VV VELAN 310512	*1E 214	*D-22 *RBD	00078	LIMITORQUE SMB-000-05	*214-01 *EQ	070 MIN	NA	ALL A
.1P50*HOV105B	*SERVICE AIR HDR A PRESS VELAN 310512	*1E *214	*D-22 *RBD	00078	LIMITORQUE SMB-000-05	*214-01 *EQ	070 MIN	NA	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 59
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
.1P50*HOV113A 04370008	*COMPA SVCE NORM SUPPLY VV VELAN 310512	*1E 214	*D-22 RBS 00078	LIMITORQUE SHB-000-05	*214-02 *EQ	070 MIN	NA	ALL A
.1P50*HOV113B 04390008	COMPA SVCE NORM. SPLY VV VELAN 310512	1E 214	G-12 RBS 00078	LIMITORQUE SHB-000-05	*214-02 *EQ	070 MIN	NA	ALL A
.1P50*HOV114A 04410008	*COMPA SVCE EMERG SPLY VV VELAN 310512	*1E *214	*D-22 RBS 00078	LIMITORQUE SHB-000-05	*214-02 *EQ	070 MIN	NA	ALL A
.1P50*HOV114B 04430008	*COMPA SVCE EMER SPLY VV VELAN 310512	*1E *214	*D-22 RBS 00078	LIMITORQUE SHB-000-05	*214-02 *EQ	070 MIN	NA	ALL A
.1B21*HOV068A	*HN 5TH LINE OUTBD DRN VVS VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	*1E *253	T-08 RBS 00078	LIMITORQUE SHB-000-05	* *DR	070 MIN	N/A	*L A
.1B21*HOV068B	*HN 5TH LINE OUTBD DRN VVS VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	*1E *253	T-08 RBS 00078	LIMITORQUE SHB-000-05	* *DR	070 MIN	N/A	*L A
.1B21*HOV068C	*HN 5TH LINE OUTBD DRN VVS VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	*1E *253	T-08 RBS 00078	LIMITORQUE SHB-000-05	* *DR	070 MIN	N/A	*L A
.1B21*HOV068D	*HN 5TH LINE OUTBD DRN VVS VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	*1E *253	T-08 RBS 00078	LIMITORQUE SHB-000-05	* *DR	070 MIN	N/A	*L A
.1B21*HOV083 B21-F001	REAC VESSEL HEAD VENT VELAN 310512 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 253	*A-22 RBP 00141	LIMITORQUE SHB-000-05	*253-01 *EQ *HST	180 DYS	N/A	ALL A
.1B21*HOV084 B21-F002	REAC VESSEL HEAD VENT VELAN 310512	1E 253	*A-22 RBP 00141	LIMITORQUE SHB-000-05	*253-01 *EQ *HST	180 DYS	N/A	ALL A
.1B21*HOV085 B21-F005	REAC VESSEL HEAD VENT VELAN	1E	*A-22	LIMITORQUE SHB-000-05	*253-01 *EQ	180 DYS	N/A	ALL

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SH. REHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 60

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
	310512	253	RBP	00141		*HST			B
.1E32*HOV024 E32-F006	LCS OUTBOARD PROCESS VLV VELAN 310512	1E 253	T-08 R35	00078	LIMITORQUE SMB-000-05	*253-03 *EQ	100 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1E32*HOV025 E32-F007	LCS OUTBOARD PROCESS VLV VELAN 310512	1E 253	T-08 R35	00078	LIMITORQUE SMB-000-05	*253-03 *EQ	100 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1E32*HOV026 E32-F008	LCS OUTBOARD BYPASS VLV VELAN 310512	1E 253	T-08 R35	00078	LIMITORQUE SMB-000-05	*253-03 *EQ	100 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1E32*HOV027 E32-F009	LCS OUTBOARD BYPASS VLV VELAN 310512	1E 253	T-08 R35	00078	LIMITORQUE SMB-000-05	*253-03 *EQ	100 DYS	N/A	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1E51*HOV036 E51-F019	RCIC PUMP MIN FLOW BYPASS VELAN 310512	1E 253	G-01 R35	18	LIMITORQUE SMB-000-05	*DR	001 DYS	N/A	ALL A
.1E51*HOV038 E51-F046	TO LUBE OIL COOLER VELAN 310512	1E 253	G-01 R35	15	LIMITORQUE SMB-000-05	*DR	001 DYS	N/A	ALL A
.1G11*HOV639A	*CHANGED TO 1Z91*HOV001 VELAN 310502	1E 88V	G-01 R35	00020	LIMITORQUE SMB-000-05	*88V-03 *EQ	070 MIN	N/A	L A
	OP CODE B FOR HELB & HELB								
.1G11*HOV639B	*CHANGED TO 1Z91*HOV002 VELAN 310502	1E 88V	G-01 R35	00020	LIMITORQUE SMB-000-05	*88V-03 *EQ	070 MIN	N/A	L A
	OP CODE B FOR HELB & HELB								
.1G11*HOV639C	SUPP POOL PMP BACK ISOL VV VELAN *310502	1E *88V	G-01 R35	00020	LIMITORQUE SMB-000-05	*88V-03 *EQ	180 DYS	N/A	L A
	OP CODE B FOR HELB & HELB								
.1P42*HOV233	*IN.VV TO DRYHELL COOLER VELAN	17A 1E	G-07		LIMITORQUE SMB-000-05	*88V-03 *EQ	070 MIN	N/A	*L

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 61
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EHG CHD OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****
	310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	88V RBS	68	(HCC REV.)				A
.1P42*MOV234	*IN.VV TO DRYWELL COOLER 17A VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V RBS	G-07 69	LIMITORQUE SMB-000-05 (HCC REV.)	*88V-03 *EQ	070 MIN	N/A	*L A
.1P42*MOV235	*IN.VV TO DRYWELL COOLER 17A VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V RBS	G-07 70	LIMITORQUE SMB-000-05 (HCC REV.)	*88V-03 *EQ	070 MIN	N/A	*L A
.1P42*MOV236	*OUT.VV TO DRYWELL COOLER 17B VELAN 310502	1E 88V RBS	G-03 66	LIMITORQUE SMB-000-05	*88V-03 *EQ	070 MIN	N/A	ALL A
.1P42*MOV237	*IN.VV TO DRYWELL COOLER 17B VELAN 310502	1E 88V RBS	G-03 67	LIMITORQUE SMB-000-05	*88V-03 *EQ	070 MIN	N/A	ALL A
.1P42*MOV238	*IN.VV TO DRYWELL COOLER 17B VELAN 310502	1E 88V RBS	G-03 68	LIMITORQUE SMB-000-05	*88V-03 *EQ	070 MIN	N/A	ALL A
.1P42*MOV239	*IN.VV TO DRYWELL COOLER 17B VELAN 310502	1E 88V RBS	G-03 69	LIMITORQUE SMB-000-05	*88V-03 *EQ	070 MIN	N/A	ALL A
.1P42*MOV240	*IN.VV TO DRYWELL COOLER 17B VELAN 310502	1E 88V RBS	G-03 70	LIMITORQUE SMB-000-05	*88V-03 *EQ	070 MIN	N/A	ALL A
.1T48*MOV035A	ATHOS OTBD CONT ISO VELAN 310502	1E 88V RBS	G-03 68	LIMITORQUE SMB-000-05	*88V-01 *EQ	180 DYS	N/A	ALL A
.1T48*MOV035B	ATHOS OTBD CONT ISO VELAN 310502	1E 88V RBS	G-07 73	LIMITORQUE SMB-000-05	*88V-01 *EQ	180 DYS	N/A	ALL A
.1E21*MOV031A E21-F001A	CORE SPRAY PP SUCT NR COL C-10 ANCHOR DARLIN 310501	1E 88AD RBS	G-01 14	LIMITORQUE SMB-000-5	*88AD-02 *EQ	180 DYS	NA	L A
.1E21*MOV031B E21-F001B	CORE SPRAY PP SUCT NR COL C-6 ANCHOR DARLIN	1E RBS	G-01	LIMITORQUE SMB-000-5	*88AD-02 *EQ	180 DYS	NA	L

REPORT NO. PES-800

JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCOSTONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPECREPORT DATE 01/18/82 PAGE 62
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
	310501	88AD	RBS	24					A
.1E21*MOV032 B21-F019	DRAIN TO CONDENSER VELAN 310502	1E 88V	H-08 RBS		LIMITORQUE SMB-000-5	*88V-02 *EQ	070 MIN	NA	ALL A
.1E11*MOV045A E11-F007A	RHR PP MIN FLOW BYPASS NR C-11 VELAN 310502	1E 88V	G-01 RBS	17	LIMITORQUE SMB-000-5	*88V-03 *EQ	180 DYS	N/A	ALL A
.1E11*MOV045B E11-F007B	RHR PP MIN FLOW BYPASS NR C-5 VELAN *371843	1E *88V	G-01 RBS	17	LIMITORQUE SMB-000-5	*88V-03 *EQ	180 DYS	N/A	ALL A
.1E21*MOV034A E21-F031A	CORE SPRAY P MI FL NR COL C-11 VELAN 310502	1E 88V	G-01 RBS	15	LIMITORQUE SMB-000-5	*88V-03 *EQ	180 DYS	N/A	L A
.1E21*MOV034B E21-F031B	CORE SPRAY P MI FL NR COL C-5 VELAN 310502	1E 88V	G-01 RBS	15	LIMITORQUE SMB-000-5	*88V-03 *EQ	180 DYS	N/A	L A
.1E51*MOV045 E51-F001	TURB EXH TO SUPP POOL VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-01 RBS	31	LIMITORQUE SMB-000-5 (MCC REV.)	*DR	*001 *DYS	N/A	*L *A
.1G11*MOV246	DRYWELL EQUIP DR VV VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-02 RBS	40	LIMITORQUE SMB-000-5 (MCC REV.)	*88V-01 *EQ	070 MIN	N/A	*L A
.1G11*MOV247	DRYWELL EQUIP DR VV VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-02 RBS	40	LIMITORQUE SMB-000-5 (MCC REV.)	*88V-03 *EQ	070 MIN	N/A	*L A
.1G11*MOV248	DRYWELL FLOOR DRAINS VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-02 RBS	40	LIMITORQUE SMB-000-5 (MCC REV.)	*88V-01 *EQ	070 MIN	N/A	*L A
.1G11*MOV249	DRYWELL FLOOR DRAINS VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	G-02 RBS	40	LIMITORQUE SMB-000-5 (MCC REV.)	*88V-03 *EQ	070 MIN	N/A	*L A

REPORT NO. PES-800
 JOB NUME 1160002
 JOB NAME 40REHAM - UNIT 1
 JOB CLIEH LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 63
 RESET NO. 003
 RESET DAT 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBMG			OP CD

.1G41*HOV033A	SUPPRESSION POOL INLET			LIMITORQUE	*88V-03	070 MIN	N/A	
	VELAN	1E	G-02	SMB-000-5	*EQ			*L
	310502	88V	RBS 46					A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.			(MCC REV.)				
.1G41*HOV033B	SUPPRESSION POOL INLET			LIMITORQUE	*88V-03	070 MIN	N/A	
	VELAN	1E	G-02	SMB-000-5	*EQ			*L
	310502	88V	RBS 44					A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.			(MCC REV.)				
.1P42*HOV031A	RBCLCH HX DISCH XOVER			LIMITORQUE	*88V-03	070 MIN	N/A	
	VELAN	1E	G-01	SMB-000-5	*EQ			*L
	310502	88V	RBS 56					A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.			(MCC REV.)				
.1P42*HOV031B	RBCLCH HX DISCH XOVER			LIMITORQUE	*88V-03	070 MIN	N/A	
	VELAN	1E	G-01	SMB-000-5	*EQ			*L
	310502	88V	RBS 59					A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.			(MCC REV.)				
.1P42*HOV032A	RBCLCH PP DISCH XOVER VV			LIMITORQUE	*88V-03	070 MIN	N/A	
	VELAN	1E	H-18	SMB-000-5	*EQ			*L
	310502	88V	RBS 150					A
.1P42*HOV032B	RBCLCH PP DISCH XOVER VV			LIMITORQUE	*88V-03	070 MIN	N/A	
	VELAN	1E	H-18	SMB-000-5	*EQ			*L
	310502	88V	RBS 150					A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.			(MCC REV.)				
.1P42*HOV033A	RBCLCH ISOL VALVE			LIMITORQUE	*88V-03	070 MIN	N/A	
	VELAN	1E	H-18	SMB-000-5	*EQ			*L
	310502	88V	RBS 150					A
.1P42*HOV033B	RBCLCH ISOL VALVE			LIMITORQUE	*88V-03	070 MIN	N/A	
	VELAN	1E	H-18	SMB-000-5	*EQ			*L
	310502	88V	RBS 150					A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.			(MCC REV.)				
.1P42*HOV034A	RBCLCH ISOL VALVE			LIMITORQUE	*88V-03	070 MIN	N/A	
	VELAN	1E	P-14	SMB-000-5	*EQ			ALL
	310502	88V	RBS 126					A
.1P42*HOV034B	RBCLCH ISOL VALVE			LIMITORQUE	*88V-03	070 MIN	N/A	
	VELAN	1E	P-14	SMB-000-5	*EQ			ALL
	310502	88V	RBS 126					A
.1P42*HOV035	RBCLCH INLET TO P-1A COOLERS			LIMITORQUE	*88V-03	070 MIN	N/A	

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 64
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUEHG	OP TIME	ACC / PERF	NU-CAT ENG CHD OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****
	VELAN 310502	1E 88V	G-03 RBS 67	SMB-000-5	*EQ			ALL A
.1P42*MOV036	RBCLCH OUTLET FROM P-1A VELAN 310502	1E 88V	G-03 RBS 67	LIMITORQUE SMB-000-5	*88V-03 *EQ	070 MIN	N/A	ALL A
.1P42*MOV043A	HG SET FL CPLG INLET VV VELAN 310502	1E 88V	L-02 RBS 56	LIMITORQUE SMB-000-5	*88V-03 *EQ	070 MIN	N/A	*L A
.1P42*MOV043B	HG SET FL CPLG INLET VV VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	L-02 RBS 54	LIMITORQUE SMB-000-5 (MCC REV.)	*88V-03 *EQ	070 MIN	N/A	*L A
.1P42*MOV044A	HG SET FL CPLG INLET VV VELAN 310502	1E 88V	L-02 RBS 56	LIMITORQUE SMB-000-5	*88V-03 *EQ	070 MIN	N/A	*L A
.1P42*MOV044B	HG SET FL CPLG INLET VV VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	L-02 RBS 54	LIMITORQUE SMB-000-5 (MCC REV.)	*88V-03 *EQ	070 MIN	N/A	*L A
.1P42*MOV047	RBCLCH INLET TO P-1B COOLERS VELAN 310502	1E 88V	N-07 RBS 68	LIMITORQUE SMB-000-5	*88V-03 *EQ	070 MIN	N/A	ALL A
.1P42*MOV048	RBCLCH OUTLET FROM P-1B VELAN 310502	1E 88V	N-07 RBS 68	LIMITORQUE SMB-000-5	*88V-03 *EQ	070 MIN	N/A	ALL A
.1P42*MOV147	DRYHELL COOLER OUTLET VV VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	D-22 RBD 00074	LIMITORQUE SMB-000-5 (MCC REV.)	*88V-01 *EQ *MST	070 MIN	N/A	*L A
.1P42*MOV148	DRYHELL COOLER OUTLET VV VELAN 310502 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88V	D-22 RBD 00074	LIMITORQUE SMB-000-5 (MCC REV.)	*88V-01 *EQ *MST	070 MIN	N/A	*L A
.1P42*MOV231	*OUT.VV TO DRYHELL COOLER VELAN 310502	1E 88V	G-07 RBS 66	LIMITORQUE SMB-000-5	*88V-03 *EQ	070 MIN	N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 65
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QCC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CMD OP CD

.1P42*MOV232	*IN.VV TO DRYWELL COOLER VELAN 310502	17A 1E 88V	G-07 RBS 67	LIMITORQUE SMB-000-5	*88V-03 *EQ	070 MIN	N/A	*L A
	L-OP CODE B REM: H,H-OP CODE B 1 DAY, C REM.			(MCC REV.)				
.1T48*MOV038A	ATHOS DTBD CONT ISO VELAN 310502	1E 88V	L-02 RBS 51	LIMITORQUE SMB-000-5	* *RR	180 DYS	N/A	ALL A
.1T48*MOV038B	ATHOS DTBD CONT ISO VELAN 310502	1E 88V	L-02 RBS 51	LIMITORQUE SMB-000-5	* *RR	180 DYS	N/A	ALL A
.1T48*MOV041	RELEASE TO ATHOS VELAN 310502	1E 88V	J-15 RBS 112	LIMITORQUE SMB-000-5	* *RR	180 DYS	N/A	L A
.1T48*MOV042	RELEASE TO ATHOS VELAN 310502	1E 88V	J-15 RBS 112	LIMITORQUE SMB-000-5	* *DR	180 DYS	N/A	L A
.1T48*MOV043A	ATHOS DTBD CONT ISC VELAN 310502	1E 88V	G-03 RBS 68	LIMITORQUE SMB-000-5	* *DR	180 DYS	N/A	L A
.1T48*MOV043B	ATHOS DTBD CONT ISO VELAN 310502	1E 88V	G-07 RBS 73	LIMITORQUE SMB-000-5	* *DR	180 DYS	N/A	L A
.1T48*MOV044A	ATHOS DTBD CONT ISO VELAN 310502	1E 88V	L-02 RBS 51	LIMITORQUE SMB-000-5	*88V-03 *EQ	180 DYS	N/A	L A
.1T48*MOV044B	ATHOS DTBD CONT ISO VELAN 310502	1E 88V	L-02 RBS 51	LIMITORQUE SMB-000-5	*88V-03 *EQ	180 DYS	N/A	L A
.1E51*MOV046 E51-F002	VAC PUMP DISCH TO POOL VELAN 310512	1E 253	G-01 RBS 29	LIMITORQUE SMB-002-02	*DR	*001 *DYS	N/A	*L *A
	L-OP CODE B REM: H,H-OP CODE B 1 DAY, C REM.			(MCC REV.)				
.1E41*MOV037 E41-F008	HPCI P DIS TO COND STOR C-7 VELAN 310502	1E 88V	G-01 RBS 18	LIMITORQUE SMB-1-25	*DR	070 MIN	N/A	ALL A
	BECOMES OP CODE C AFTER 1 DAY							

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 66

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
.1B21*MOV035A B21-F032A	REAC FEEDWTR INLET PIPE TUNNEL ANCHOR DARLIN 310501	1E 88AD	T-12 RBS 78	LIMITORQUE SMB-1-40	*88AD-02 *EQ	070 MIN	NA	L A
	OP CODE B FOR HELB & MELB							
.1B21*MOV035B B21-F032B	REAC FEEDWTR INLET PIPE TUNNEL ANCHOR DARLIN 310501	1E 88AD	T-12 RBS 78	LIMITORQUE SMB-1-40	*88AD-02 *EQ	070 MIN	NA	L A
	OP CODE B FOR HELB & MELB							
.1E21*MOV035A E21-F015A	CORE SPRAY P RECIRC NEAR ANCHOR DARLIN 310501	1E 88AD	G-01 RBS 53	LIMITORQUE SMB-1-40	*88AD-02 *EQ	070 MIN	NA	L A
.1E21*MOV035B E21-F015B	CORE SPRAY P RECIRC NEAR ANCHOR DARLIN 310501	1E 88AD	G-02 RBS 53	LIMITORQUE SMB-1-40	*88AD-02 *EQ	070 MIN	NA	L A
.1E41*MOV038 E41-F011	HPCI P DIS TO COND STOR VELAN 310502	1E 88V	G-01 RBS 18	LIMITORQUE SMB-1-40	*DR	070 MIN	N/A	ALL A
	BECOMES OP CODE C AFTER 1 DAY							
.1E11*MOV033A E11-F047A	RHR HX SHELL INLET NR COL VELAN 310502	1E 88V	G-01 RBS 22	LIMITORQUE SME-1-60	*88V-03 *EQ	180 DYS	NA	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1E11*MOV033B E11-F047B	RHR HX SHELL INLET NR COL VELAN 310502	1E 88V	G-01 RBS 22	LIMITORQUE SMB-1-60	*88V-03 *EQ	180 DYS	NA	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1E11*MOV035A E11-F003A	RHR HX SHELL OUTLET NEAR VELAN 310502	1E 88V	G-01 RBS 30	LIMITORQUE SMB-1-60	*88V-03 *EQ	180 DYS	NA	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1E11*MOV035B E11-F003B	RHR HX SHELL OUTLET NEAR VELAN 310502	1E 88V	G-01 RBS 30	LIMITORQUE SMB-1-60	*88V-03 *EQ	180 DYS	NA	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1E11*MOV040A E11-F028A	RHR FLOW TO SUPP POOL NR VELAN 310502	1E 88V	G-03 RBS 72	LIMITORQUE SMB-1-60	*88V-03 *EQ	180 DYS	NA	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 67
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBNG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
.1E11*MOV040B E11-F028B	RHR FLOW TO SUPP POOL NR C-5 VELAN 310502	1E 88V	G-07 RBS 72	LIMITORQUE SMB-1-60	*88V-03 *EQ	180 DYS	NA	ALL A
.1E41*MOV042 E41-F003	HPCI STH TO TURB NEAR COL C-8 VELAN 310502	1E 88V	L-05 RBS 63	LIMITORQUE SMB-1-60	*88V-02 *EQ	001 DYS	N/A	ALL A
.1N11*MOV031A MOV-RSSV-1	2ND STAGE REHEAT STH VELAN 310502	1E 88V	ST ST 50	LIMITORQUE SMB-1-60	*88V-03 *EQ	070 MIN	N/A	L A
.1N11*MOV031B MOV-RSSV-2	2ND STAGE REHEAT STH VELAN 310502	1E 88V	ST ST 50	LIMITORQUE SMB-1-60	*88V-03 *EQ	070 MIN	N/A	L A
.1B31*MOV031A B31-F023A	RECIRC PUMP SUCTION NW DRYWELL GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	D-22 RBD 66	*LIMITORQUE *SMB-2	*003-01 *IJ *MST	070 MIN		*L A
.1B31*MOV031B B31-F023B	RECIRC PUMP SUCTION SE DRYWELL GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	D-22 RBD 66	*LIMITORQUE *SMB-2	*003-01 *IJ *MST	070 MIN		*L A
.1E11*MOV038A E11-F016A	RHR CONT SPRAY HDR NR COL C-11 ANCHOR DARLIN 310501	1E 88AD	G-10 RBS 103	LIMITORQUE SMB-2-60	*88AD-02 *EQ	001 DYS	NA	ALL A
.1E11*MOV038B E11-F016B	RHP CONT SPRAY HDR NR COL C-5 ANCHOR DARLIN 310501	1E 88AD	G-11 RBS 103	LIMITORQUE SMB-2-60	*88AD-02 *EQ	001 DYS	NA	ALL A
.1E11*MOV047 E11-F009	RHR SUCT FH RECIRC SE DRYWELL ANCHOR DARLIN 310501 OP CODE A FOR LOCA FOR 70 MINS	1E 88AD	D-22 RBD 84	LIMITORQUE SMB-2-60	*88AD-01 *EQ *MST	180 DYS	NA	ALL A
.1E11*MOV048 E11-F008	RHR SUCT FROM RECIRC PIPE C-11 ANCHOR DARLIN 310501 OP CODE A FOR LOCA FOR 70 MINS	1E 88AD	G-03 RBS 63	LIMITORQUE SMB-2-60	*DR	180 DYS	NA	ALL A
.1E11*MOV050 E11-F010	RHR MAIN FLOW CROSSOVER C-5 VELAN 310502	1E 88V	G-07 RBS 72	LIMITORQUE SMB-2-60	*88V-03 *EQ	180 DYS	N/A	ALL B

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 68
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT ENG CHD OP CD

.1E41*MOV034 E41-F007	HPCI PP DISCH NR C-9 VELAN 310502	1E 88V	G-02 RBS 63	LIMITORQUE SMB-2-60	*DR	001 DYS	N/A	ALL A
.1E11*MOV049 E11-F052	FM HPCI TURB INLET LINE C-8 VELAN 310502 OP CODE B FOR HELB & MELB	1E 88V	G-05 RBS 66	LIMITORQUE SMB-2-60	*88V-01 *EQ	070 MIN	N/A	*L A
.1E21*MOV033A E21-F005A	CORE SPRAY P DISCH NR COL C-10 VELAN 310502	1E 88V	G-09 RBS 104	LIMITORQUE SMB-2-60	*88V-03 *EQ	180 DYS	N/A	L A
.1E21*MOV033B E21-F005B	CORE SPRAY P DISCH NR COL C-6 VELAN 310502	1E 88V	G-12 RBS 104	LIMITORQUE SMB-2-60	*88V-03 *EQ	180 DYS	N/A	L A
.1B31*MOV032A B31-F031A	RECIRC PUMP DISCHRG NW DRYWELL GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	D-22 RBD 70	*LIMITORQUE *SMB-3	*003-01 *IJ *MST	070 MIN		*L A
.1B31*MOV032B B31-F031B	RECIRC PUMP DISCHRG SE DRYWELL GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	D-22 RBD 70	*LIMITORQUE *SMB-3	*003-01 *IJ *MST	070 MIN		*L A
.1E41*MOV035 E41-F006	HPCI PP DISCH NR C-9 ANCHOR DARLIN 310501	1E 88AD	G-02 RBS 63	LIMITORQUE SMB-3-100	*DR	001 DYS	NA	ALL A
.1E11*MOV034A E11-F048A	RHR HX SHELL BYPASS NEAR C-12 ANCHOR DARLIN 310501	1E 88AD	G-01 RBS 27	LIMITORQUE SMB-3-150	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*MOV034B E11-F048B	RHR HX SHELL BYPASS NEAR C-4 ANCHOR DARLIN 310501	1E 88AD	G-01 RBS 22	LIMITORQUE SMB-3-150	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*MOV042A E11-F024A	RHR FL TO SUP POLL NR COL C-11 ANCHOR DARLIN 310501 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 88AD	G-01 RBS 29	LIMITORQUE SMB-3-80 (MCC REV.)	*88AD-02 *EQ	*070 *MIN	NA	*L A
.1E11*MOV042B E11-F024B	RHR FL TO SUP POOL NR COL C-5 ANCHOR DARLIN 310501	1E 88AD	G-01 RBS 29	LIMITORQUE SMB-3-80	*88AD-02 *EQ	*070 *MIN	NA	*L A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 69
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLOG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD

L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)									
.1E41*MOV041 E41-F002	HPCI STM TO TURB NRTH DRYWELL VELAN 310502	1E 88V	C-22 RBD	66	LIMITORQUE SMB-3-80	*88V-01 *EQ *MST	001 DYS	N/A	ALL A
.1E11*MOV036A E11-F017A	RHR OUTBOARD VV NR COLUMN C-11 ANCHOR DARLIN 310501	1E 88AD	G-03 RBS	72	LIMITORQUE SMB-4-200	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E11*MOV036B E11-F017B	RHR OUTBOARD VV NR COLUMN C-5 ANCHOR DARLIN 310501	1E 88AD	G-07 RBS	72	LIMITORQUE SMB-4-200	*88AD-02 *EQ	180 DYS	NA	ALL A
.1E32*MOV022A E32-F002B	LCS INBOARD PROCESS VLV VELAN 310512	1E 253	T-08 RBS	00078	LIMITORQUE SHC-04-3	*253-03 *EQ	100 DYS	N/A	*L A
L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)									
.1E32*MOV022B E32-F002F	LCS INBOARD PROCESS VLV VELAN 310512	1E 253	T-08 RBS	00078	LIMITORQUE SHC-04-3	*253-03 *EQ	100 DYS	N/A	*L A
L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)									
.1E32*MOV022C E32-F002K	LCS INBOARD PROCESS VLV VELAN 310512	1E 253	T-08 RBS	00078	LIMITORQUE SHC-04-3	*253-03 *EQ	100 DYS	N/A	*L A
L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)									
.1E32*MOV022D E32-F002P	LCS INBOARD PROCESS VLV VELAN 310512	1E 253	T-08 RBS	00078	LIMITORQUE SHC-04-3	*253-03 *EQ	100 DYS	N/A	*L A
OP CODE B FOR HELB & MELB									
.1E32*MOV023A E32-F003B	LCS INBOARD BYPASS VLV VELAN 310512	1E 253	G-06 RBS	00064	LIMITORQUE SHC-04-3	*253-03 *EQ	100 DYS	N/A	*L A
L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)									
.1E32*MOV023B E32-F003F	LCS INBOARD BYPASS VLV VELAN 310512	1E 253	G-06 RBS	00064	LIMITORQUE SHC-04-3	*253-03 *EQ	100 DYS	N/A	*L A
L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)									
.1E32*MOV023C E32-F003K	LCS INBOARD BYPASS VLV VELAN 310512	1E 253	G-06 RBS	00064	LIMITORQUE SHC-04-3	*253-03 *EQ	100 DYS	N/A	*L A

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 70

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****

L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)

.1E32*MOV0230 E32-F003P	LCS INBOARD BYPASS VLV VELAN 310512	1E 253	G-06 RBS	00064	LIMITORQUE SMC-04-3	*253-03 *EQ	100 DYS	N/A	*L A
----------------------------	---	-----------	-------------	-------	------------------------	----------------	---------	-----	---------

OP CODE B FOR HELB & HELB

.1E32*MOV021A E32-F001B	LCS INBOARD PROCESS VLV VELAN 310512	1E 253	T-08 RBS	00078	LIMITORQUE SMC-04-5	*253-03 *EQ	100 DYS	N/A	*L A
----------------------------	--	-----------	-------------	-------	------------------------	----------------	---------	-----	---------

L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)

.1E32*MOV021B E32-F001F	LCS INBOARD PROCESS VLV VELAN 310512	1E 253	T-08 RBS	00078	LIMITORQUE SMC-04-5	*253-03 *EQ	100 DYS	N/A	*L A
----------------------------	--	-----------	-------------	-------	------------------------	----------------	---------	-----	---------

L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)

.1E32*MOV021C E32-F001K	LCS INBOARD PROCESS VLV VELAN 310512	1E 253	T-08 RBS	00078	LIMITORQUE SMC-04-5	*253-03 *EQ	100 DYS	N/A	*L A
----------------------------	--	-----------	-------------	-------	------------------------	----------------	---------	-----	---------

L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)

.1E32*MOV021D E32-F001P	LCS INBOARD PROCESS VLV VELAN 310512	1E 253	T-08 RBS	00078	LIMITORQUE SMC-04-5	*253-03 *EQ	100 DYS	N/A	*L A
----------------------------	--	-----------	-------------	-------	------------------------	----------------	---------	-----	---------

OP CODE B FOR HELB & HELB

1R24*HG111

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 71
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = LOUIS ALLIS

.1R24*HG111	480V MOTOR GENERATOR (RED) LOUIS ALLIS 310950	1E 439	N-21 RBS	150	LOUIS ALLIS COGSF	*439-01 *EQ	180 DYS	NA	ALL A
.1R24*HG112	480V MOTOR GENERATOR (BLUE) LOUIS ALLIS 310950	1E 439	N-21 RBS	150	LOUIS ALLIS COGSF	*439-01 *EQ	180 DYS	NA	ALL A
.1R24*HG113A	480V MOTOR GENERATOR (ORANGE) LOUIS ALLIS 310950	1E 439	N-21 RBS	150	LOUIS ALLIS COGSF	*439-01 *EQ	180 DYS	NA	ALL A
.1R24*HG113B	480V MOTOR GENERATOR (ORANGE) LOUIS ALLIS 310950	1E 439	N-21 RBS	150	LOUIS ALLIS COGSF	*439-01 *EQ	180 DYS	NA	ALL A

1R35*T-B2

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 22

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-C&Y
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EHG CND
	PO NUMBER				SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = MAG. ETICS

.1R35*T-B2	480-120/240V TRANS MAGNETICS 310739	1E 248	N-21 RBS	112	MAGNETICS L-12514	*248-01 *EQ	180 DYS	ALL A
.1R35*T-R2	480-120/240V TRANS MAGNETICS 310739	1E 248	N-21 RBS	112	MAGNETICS L-12514	*248-01 *EQ	180 DYS	ALL A

1P42*LS012A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 73
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	VENDOR ID	EQUIPMENT DESCRIPTION	VENDOR NAME	PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = MAGNETROL

.1P42*LS012A		LS ON TK 026A MAGNETROL 10042			1E 407	H-18 RBS	00160	MAGNETROL 291-MPG-X-M14DC	*407-01 *IJ	180 DYS		*ALL A
.1P42*LS012B		RBCLCH TK-026B MAGNETROL 10042			1E 407	H-18 RBS	00160	MAGNETROL 291-MPG-X-M14DC	*407-01 *IJ	180 DYS		*ALL A
.1P42*LS013A		1P42-TK-026A HEAD TK LEVEL MAGNETROL 10042			1E 407	H-18 RBS	00160	MAGNETROL 291-MPG-X-M14DC	*407-01 *IJ	180 DYS		*ALL A
.1P42*LS013B		TK-026A HEAD TK LVL MAGNETROL 10042			1E 407	H-18 RBS	00160	MAGNETROL 291-MPG-X-M14DC	*407-01 *IJ	180 DYS		*ALL A
.1T48*LS061A		COND LEVEL MAGNETROL 10042			1E 407	G-03 RBS	63	MAGNETROL 291-MPG-X-M14DC	*407-01 *IJ	180 DYS		ALL B
.1T48*LS061B		COND LEVEL MAGNETROL 10042			1E 407	G-10 RBS	78	MAGNETROL 291-MPG-X-M14DC	*407-01 *IJ	180 DYS		ALL B
.1E41*LS092A E41-N015A		SUPPRESSION POOL G.E. 310010			1E 003	G-01 RBS	00008	MAGNETROL *3.5-751-1X-MPG-M14HY	*3143 *IJ	001 DYS *		ALL A
.1E41*LS092B E41-N015B		SUPPRESSION POOL G.E. 310010			1E 003	G-01 RBS	00008	MAGNETROL *3.5-751-1X-MPG-M14HY	*3143 *IJ	001 DYS *		ALL A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 74

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EHG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = NAMCO

.1E41*PNS840 LS-1,2	1E41*HOV-052 POSITION GENERAL ELEC 310010	*1E 003	*G-01 *RBS	*00008	*NAMCO *D1200	* *TA	*180 *DYS	*N/A	*ALL *A
.1E41*PNS841 LS 3,4	1E41*HOV-051 POSITION GENERAL ELEC 310010	*1E 003	*G-01 *RBS	*00008	*NAMCO *D1200	* *TA	*180 *DYS	*N/A	*ALL *A
.1E21*PNS071A	1E21*HCV071A POSITION SW *NAMCO *347565 MARK NO. REPRESENTS 2 SWITCHES	*1E *FIELD	J-16 RBS	00131	NAMCO *EA180-11302	*DR	180 DYS	N/A	L B
.1E21*PNS071B	1E21*HCV071B POSITION SW *NAMCO *347565 MARK NO. REPRESENTS 2 SWITCHES	*1E *FIELD	P-16 RBS	00131	NAMCO *EA180-11302	*DR	180 DYS	N/A	L B
.1E11*PNS031C	POS SW ON 1E11*HOV031C NAMCO CONTROLS 347565	*1E 088	*G-01 RBS	24	*NAMCO *EA180-11302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS032B	POS SW ON 1E11*HOV032B NAMCO CONTROLS 347565	*1E 088	*G-01 RBS	10	*NAMCO *EA180-11302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS032C	POS SW ON 1E11*HOV032C NAMCO CONTROLS 347565	*1E 088	*G-01 RBS	20	*NAMCO *EA180-11302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS071A	1E11-HV071A POSITION *NAMCO *347565 MARK NO. REPRESENTS 2 SWITCHES	*1E *FIELD	D-22 RBP		NAMCO *EA180-31302	*DR *HST	180 DYS		ALL B
.1E11*PNS071B	1E11-HV071B POSITION *NAMCO *347565 MARK NO. REPRESENTS 2 SWITCHES	*1E *FIELD	D-22 RBP		NAMCO *EA180-31302	*DR *HST	180 DYS		ALL B
.1E11*PNS031A	POS SW ON 1E11*HOV031A NAMCO CONTROLS 347565	*1E 088	*G-01 RBS	24	*NAMCO *EA180-31302	*DR	*180 *DYS	*N/A	*ALL *A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 75

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EMG CMD OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
.1E11*PNS031B	POS SW ON 1E11*MOV031B NAMCO CONTROLS 347565	*1E 088	*G-01 RBS 24	*NAMCO *EA180-31302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS031D	POS SW ON 1E11*MOV031D NAMCO CONTROLS 347565	*1E 088	*G-01 RBS 24	*NAMCO *EA180-31302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS032A	POS SW ON 1E11*MOV032A 347565	*1E 088	*G-01 RBS 15	*NAMCO *EA180-31302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS032D	POS SW ON 1E11*MOV032D 347565	*1E 088	*G-01 RBS 19	*NAMCO *EA180-31302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS050	POS SW ON 1E11*MOV050 NAMCO CONTROLS 347565	*1E 088	*G-07 RBS 72	*NAMCO *EA180-31302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS037A	POS SW ON 1E11*MOV037A NAMCO CONTROLS 347565	*1E 088	*G-03 RBS 72	*NAMCO *EA180-32302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS037B	POS SW ON 1E11*MOV037B NAMCO CONTROLS 347565	*1E 088	*G-03 RBS 72	*NAMCO *EA180-32302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS040A	POS SW ON 1E11*MOV040A VELAN 347565	*1E 088	*G-03 RBS 72	*NAMCO *EA180-32302	*DR	*180 *DYS	*N/A	*ALL *A
.1E11*PNS040B	POS SW ON 1E11*MOV040B VELAN 347565	*1E 088	*G-07 RBS 72	*NAMCO *EA180-32302	*DR	*180 *DYS	*N/A	*ALL *A
.1T46*PNS035A	RBSVS INITIATION SIGNAL FISHER CONTROLS 310655 MARK NO. REPRESENTS 6 SWITCHES	1E 111	G-01 RBS 00112	NAMCO *EA740-20001	*RR	070 MIN	N/A	ALL A
.1T46*PNS035B	RBSVS INITIATION SIGNAL FISHER CONTROLS 310655 MARK NO. REPRESENTS 6 SWITCHES	1E 111	G-01 RBS 00112	NAMCO *EA740-20001	*RR	070 MIN	N/A	ALL A
.1T46*PNS037A	RBSVS INITIATION SIGNAL			NAMCO		070 MIN	N/A	

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 76

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
	FISHER CONTROLS 310655	1E 111	H-12 RBS	00095	*EA740-20001	*RR			ALL A
	MARK NO. REPRESENTS 6 SWITCHES								
.1T46*PNS037B	RBSVS INITIATION SIGNAL FISHER CONTROLS 310655	1E 111	H-12 RBS	00095	NAHCO *EA740-20001	*RR	070 MIN	N/A	ALL A
	MARK NO. REPRESENTS 6 SWITCHES								
.1T46*PNS038A	PRI CONT PURGE VA 1T46*AOV038A FISHER CONTROLS 310574	1E 172	D-22 RBP	00078	NAHCO EA740-20001	*RR *MST	070 MIN	N/A	ALL A
	MARK NO. REPRESENTS 4 SWITCHES								
.1T46*PNS038B	PRI CONT PURGE VA 1T46*AOV038B FISHER CONTROLS 310574	1E 172	H-10 RBS	00078	NAHCO EA740-20001	*RR	070 MIN	N/A	ALL A
	MARK NO. REPRESENTS 4 SWITCHES								
.1T46*PNS038C	PRI CONT PURGE VA 1T46*AOV038C FISHER CONTROLS 310574	1E 172	L-02 RBS	00040	NAHCO EA740-20001	*RR	070 MIN	N/A	ALL A
	MARK NO. REPRESENTS 4 SWITCHES								
.1T46*PNS038D	PRI CONT PURGE VA 1T46*AOV038D FISHER CONTROLS 310574	1E 172	L-02 RBS	00040	NAHCO EA740-20001	*RR	070 MIN	N/A	ALL A
	MARK NO. REPRESENTS 4 SWITCHES								
.1T46*PNS039A	PRI CONTAINMENT PURGE VALVE FISHER CONTROLS 310574	1E 172	B-22 RBP	00112	NAHCO EA740-20001	*RR *SPR	070 MIN	N/A	ALL A
	MARK NO. REPRESENTS 6 SWITCHES								
.1T46*PNS039B	PRI CONTAINMENT PURGE VALVE FISHER CONTROLS 310574	1E 172	K-15 RBS	00112	NAHCO EA740-20001	*RR	070 MIN	N/A	ALL A
	MARK NO. REPRESENTS 6 SWITCHES								
.1T46*PNS039C	PRI CONTAINMENT PURGE VALVE FISHER CONTROLS 310574	1E 172	G-02 RBS	00040	NAHCO EA740-20001	*RR	070 MIN	N/A	ALL A
	MARK NO. REPRESENTS 6 SWITCHES								
.1T46*PNS039D	PRI CONTAINMENT PURGE VALVE FISHER CONTROLS 310574	1E 172	G-02 RBS	00040	NAHCO EA740-20001	*RR	070 MIN	N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 77
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG END
	PO NUMBER				SUBMG			OP CD

MARK NO. REPRESENTS 6 SWITCHES

.1B21*PNS036A	REACTOR FW INLET AOV036A			NAMCO		070 MIN		
	VELAN	1E	H-18	*EA740-20100	*RR			L
	310595	232	RBS	00087				A

MARK NO. REPRESENTS 2 SWITCHES CODE B FOR HELB & MELB

.1B21*PNS036B	1B21*AOV036A POSITION			NAMCO		070 MIN		
	VELAN	1E	H-18	*EA740-20100	*RR			L
	310595	232	RBS	00087				A

MARK NO. REPRESENTS 2 SWITCHES CODE B FOR HELB & MELB

.1E11*PNS081A	RHR CHECK VALVE 1E11*AOV081A			*NAMCO		*180 *DYS		
	VELAN	*1E	*D-22	*EA740-20100	*RR			*ALL
	310595	*232	*RBP	*00079	*HST			*B

MARK NO. REPRESENTS 2 SWITCHES

.1E11*PNS081B	RHR CHECK VALVE 1E11*AOV081B			*NAMCO		*180 *DYS		
	VELAN	*1E	*D-22	*EA740-20100	*RR			*ALL
	310595	*232	*RBP	*00079	*HST			*B

MARK NO. REPRESENTS 2 SWITCHES

.1E21*PNS081A	CORE SPRAY HDR VA 1E21*AOV081A			NAMCO		180 DYS NA		
	VELAN	1E	B-22	*EA740-20100	*RR			L
	310512	*232	RBP	00126	*HST			B

MARK NO. REPRESENTS 2 SWITCHES

.1E21*PNS081B	CORE SPRAY HDR VA 1E21*AOV081B			NAMCO		180 DYS NA		
	VELAN	1E	B-22	*EA740-20100	*RR			L
	310512	*232	RBP	00126	*HST			B

MARK NO. REPRESENTS 2 SWITCHES

.1P42*PNS282	RBCLCH RETURN CHECK VLV			NAMCO		070 MIN		
	VELAN	1E	G-01	*EA740-20100	*RR			ALL
	310595	232	RBS	00016				A

MARK NO. REPRESENTS 2 SWITCHES

.1P42*PNS293	RBCLCH RETURN CHECK VLV			NAMCO		070 MIN		
	VELAN	1E	G-01	*EA740-20100	*RR			ALL
	310595	232	RBS	00039				A

MARK NO. REPRESENTS 2 SWITCHES

.1P42*PNS294	RBCLCH RETURN CHECK VLV			NAMCO		070 MIN		
	VELAN	1E	G-01	*EA740-20100	*RR			ALL
	310595	232	RBS	00039				A

MARK NO. REPRESENTS 2 SWITCHES

1B31*PNS081

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 78
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1B31*PNS081	1B31*AOV081 POS SH COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	K-15 RBS	00155	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1B31*PNS082	1B31*AOV082 POS SH NAMCO 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	H-18 RBS	00155	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E11*PNS061A	ON 1E11*AOV061A COPEX VULCAN *370964 MARK NO. REPRESENTS 4 SWITCHES	1E *318	G-01 RBS	00008	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E11*PNS061B	ON 1E11*AOV061B COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	00008	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E11*PNS062A	ON 1E11*AOV062A COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	00008	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E11*PNS062B	ON 1E11*AOV062B COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	00008	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E41*PNS081	ON 1E41*AOV081 COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	00009	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E41*PNS082	ON 1E41*AOV082 COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	00008	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E41*PNS083	ON 1E41*AOV083 COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	00008	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
*1E41*PNS091	*ON 1E41*LCV091 *COPEX VULCAN	*1E	*G-01		*NAMCO *EA740-20100	* *RR	*180 *DYS	*N/A	*ALL

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 79
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			ENG CND
*****	*****	*****	*****	*****	*****	*****	*****	****
ADDED	*310735 MARK NO. REPRESENTS 2 SWITCHES	*318	*RBS	*70008				*B
.1E41*PNS095	ON 1E41*LCV095 COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E51*PNS081	ON 1E51*AOV081 COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E51*PNS082	ON 1E51*AOV082 COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E51*PNS083	ON 1E51*AOV083 COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1E51*PNS091	*ON 1E41*LCV091 *COPEX VULCAN 310735 MARK NO REPRESENTS 2 SWITCHES	*1E *318	*G-01 *RBS	*NAMCO *EA740-20100	*RR	*070 *MIN	*N/A	*ALL *A
.1E51*PNS095	ON 1E51*LCV095 COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-01 RBS	NAMCO EA740-20100	*RR	070 MIN	NA	ALL A
.1T24*PNS001A	ON 1T24*AOV001A COPEX VULCAN 310735 MARK NO. REPRESENTS 2 SWITCHES	1E 318	G-02 RBS	NAMCO EA740-20100	*RR	180 DYS	NA	L A
.1T24*PNS001B	ON 1T24*AOV001B COPEX VULCAN 310735 MARK NO. REPRESENTS 2 SWITCHES	1E 318	G-02 RBS	NAMCO EA740-20100	*RR	180 DYS	NA	L A
.1T46*PNS076A	DRYHL VENT 1T46L*AOV076 POS SW COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-06 RBS	NAMCO EA740-20100	* *RR	070 MIN	NA	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 80
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1T46*PNS078B	ON 1T46*AOV078B COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-12 RBS	00096	NAHCO EA740-20100	*RR	070 MIN	NA	ALL A
.1T46*PNS079A	ON 1T46*AOV079A COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-06 RBS	00063	NAHCO EA740-20100	*RR	070 MIN	NA	ALL A
.1T46*PNS079B	ON 1T46*AOV079B COPEX VULCAN 310735 MARK NO. REPRESENTS 4 SWITCHES	1E 318	G-06 RBS	00063	NAHCO EA740-20100	*RR	070 MIN	NA	ALL A
.1B21*PNS081A	POSITION SHS ON AOV081A GE-NED 310010	1E 003	*D-22 *RBP	00082	*NAHCO *EA740-8000	*3911 *RR *MST	070 MIN	*1%	ALL A
.1B21*PNS081B	POSITION SHS ON AOV081B GE-NED 310010	1E 003	*D-22 *RBP	00082	*NAHCO *EA740-8000	*3911 *RR *MST	070 MIN	*1%	ALL A
.1B21*PNS081C	POSITION SHS ON AOV081C GENERAL ELEC 310010	1E 003	*D-22 *RBP	00082	*NAHCO *EA740-8000	*3911 *RR *MST	070 MIN	*1%	ALL A
.1B21*PNS081D	POSITION SHS ON AOV081D GENERAL ELEC 310010	1E 003	*D-22 *RBP	00082	*NAHCO *EA740-8000	*3911 *RR *MST	070 MIN	*1%	ALL A
.1B21*PNS082A	POSITION SHS ON AOV082A GENERAL ELEC 310010	1E 003	*T-08 *ST	00082	*NAHCO *EA740-8000	*3911 *RR	070 MIN	*1%	ALL A
.1B21*PNS082B	POSITION SHS ON AOV082B GENERAL ELEC 310010	1E 003	*T-08 *ST	00082	*NAHCO *EA740-8000	*3911 *RR	070 MIN	*1%	ALL A
.1B21*PNS082C	POSITION SHS ON AOV082C GENERAL ELEC 310010	1E 003	*T-08 *ST	00082	*NAHCO *EA740-8000	*3911 *RR	070 MIN	*1%	ALL A
.1B21*PNS082D	POSITION SHS ON AOV082D GENERAL ELEC 310010	1E 003	*T-08 *ST	00082	*NAHCO *EA740-8000	*3911 *RR	070 MIN	*1%	ALL A

REPORT NO. PES-600
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 81
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	GAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBING	OP TIME	ACC / PERF	NU-CAT EHG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1B21*PNS093A	ON 1B21*RV093A	*1E *175	*E-23 *RBP	*00050	*NAHCO *EA740-80001	*RR *SPR	*180 *DYS		*ALL *B
	MARK NO. REPRESENTS 2 SWITCHES								
.1B21*PNS093B	ON 1B21*RV093B	*1E *175	*E-23 *RBP	*00050	*NAHCO *EA740-80001	*RR *SPR	*180 *DYS		*ALL *B
	MARK NO. REPRESENTS 2 SWITCHES								
.1B21*PNS093C	ON 1B21*RV093C *ANDERSN GRNHD *310649	*1E *175	*E-23 *RBP	*00050	*NAHCO *EA740-80001	*RR *SPR	*180 *DYS	*N/A	*ALL *B
	MARK NO. REPRESENTS 2 SWITCHES								
.1B21*PNS093D	ON 1B21*RV093D *ANDERSN GRNHD *310649	*1E *175	*E-23 *RBP	*00050	*NAHCO *EA740-80001	*RR *SPR	*180 *DYS	*N/A	*ALL *B
	MARK NO. REPRESENTS 2 SWITCHES								
.1B21*PNS093E	ON 1B21*RV093E *ANDERSN GRNHD *310649	*1E *175	*E-23 *RBP	*00050	*NAHCO *EA740-80001	*RR *SPR	*180 *DYS	*N/A	*ALL *B
	MARK NO. REPRESENTS 2 SWITCHES								
.1B21*PNS093F	ON 1B21*RV093F *ANDERSN GRNHD *310649	*1E *175	*E-23 *RBP	*00050	*NAHCO *EA740-80001	*RR *SPR	*180 *DYS	*N/A	*ALL *B
	MARK NO. REPRESENTS 2 SWITCHES								
.1B21*PNS093G	ON 1B21*RV093G *ANDERSN GRNHD *310649	*1E *175	*E-23 *RBP	*00050	*NAHCO *EA740-80001	*RR *SPR	*180 *DYS	*N/A	*ALL *B
	MARK NO. REPRESENTS 2 SWITCHES								
.1B21*PNS093H	ON 1B21*RV093H *ANDERSN GRNHD *310649	*1E *175	*E-23 *RBP	*00050	*NAHCO *EA740-80001	*RR *SPR	*180 *DYS	*N/A	*ALL *B
	MARK NO. REPRESENTS 2 SWITCHES								
.1B21*PNS093J	ON 1B21*RV093J *ANDERSN GRNHD *310649	*1E *175	*E-23 *RBP	*00050	*NAHCO *EA740-80001	*RR *SPR	*180 *DYS	*N/A	*ALL *B
	MARK NO. REPRESENTS 2 SWITCHES								
.1B21*PNS093K	ON 1B21*RV093K *ANDERSN GRNHD	*1E	*E-23		*NAHCO *EA740-80001	*RR	*180 *DYS	*N/A	*ALL

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 82

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****
	*310649 MARK NO. REPRESENTS 2 SWITCHES	*175	*RBP *00050		*SPR			*E
.1B21*PNS093L	ON 1B21*RV093L *ANDERSN GRNHD *310649 MARK NO. REPRESENTS 2 SWITCHES	*1E *175	*E-23 *RBP *00050	*NAMCO *EA740-80001	*RR *SPR	*180 *DYS	*N/A	*ALL *B
.1B21*PNS093M	ON 1B21*RV093M *ANDERSN GRNHD *310649 MARK NO. REPRESENTS 2 SWITCHES	*1E *175	*E-23 *RBP *00050	*NAMCO *EA740-80001	*RR *SPR	*180 *DYS	*N/A	*ALL *B
.1T46*PNS031A	*POSITION ON MOD031A *POWERS REGUL 310738	*1E *319	*K-15 *RBS *00135	*NAMCO *EA750-50100	*RR	*180 *DYS	*N/A	*ALL *A
.1T46*PNS031B	*POSITION ON MOD031B *POWERS REGUL 310738	*1E *319	*K-15 *RBS *00135	*NAMCO *EA750-50100	*RR	*180 *DYS	*N/A	*ALL *A
.1T46*PNS034A	*POSITION ON MOD034A *POWERS REGUL 310738	*1E *319	*H-20 *RBS *00182	*NAMCO *EA750-50100	*RR	*180 *DYS	*N/A	*ALL *A
.1T46*PNS034B	*POSITION ON MOD034B *POWERS REGUL 310738	*1E *319	*H-20 *RBS *00182	*NAMCO *EA750-50100	*RR	*180 *DYS	*N/A	*ALL *A
.1T46*PNS040A	*POSITION ON A00040A *POWERS REGUL 310738	*1E *319	*H-18 *RBS *00150	*NAMCO *EA750-50100	*RR	*070 *MIN	*NA	*ALL *A
.1T46*PNS040B	*POSITION ON A00040B *POWERS REGUL 310738	*1E *319	*H-18 *RBS *00150	*NAMCO *EA750-50100	*RR	*070 *MIN	*NA	*ALL *A
.1T46*PNS041A	*POSITION ON A00041A *POWERS REGUL 310738	*1E *319	*K-15 *RBS *00112	*NAMCO *EA750-50100	*RR	*070 *MIN	*NA	*ALL *A
.1T46*PNS041B	*POSITION ON A00041B *POWERS REGUL 310738	*1E *319	*K-15 *RBS *00112	*NAMCO *EA750-50100	*RR	*070 *MIN	*NA	*ALL *A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 83

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBNG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = NECI

.1B21*TE059A	MAIN STH TUNNEL AMB			*NECI	*3110	*70	*MIN	*ANSI C96.1	
B21-N014A	GENERAL ELEC	1E	ST	*145C3224P001	*DR				H
	310010	003	ST	00078					A
	OP CODE C FOR REMAINDER OF HELB								
.1B21*TE059B	MAIN STH TUNNEL AMB			*NECI	*3110	*70	*MIN	*ANSI C96.1	
B21-N014B	GENERAL ELEC	1E	ST	*145C3224P001	*DR				H
	310010	003	ST	00078					A
	OP CODE C FOR REMAINDER OF HELB								
.1B21*TE059C	MAIN STH TUNNEL AMB			*NECI	*3110	*70	*MIN	*ANSI C96.1	
B21-N014C	GENERAL ELEC	1E	ST	*145C3224P001	*DR				H
	310010	003	ST	00078					A
	OP CODE C FOR REMAINDER OF HELB								
.1B21*TE059D	MAIN STH TUNNEL AMB			*NECI	*3110	*70	*MIN	*ANSI C96.1	
B21-N014D	GENERAL ELEC	1E	ST	*145C3224P001	*DR				H
	310010	003	ST	00078					A
	OP CODE C FOR REMAINDER OF HELB								

1D11-PMR 041

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 84

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = NMC

.1D11-PNL041

SHOREHAM STATION VENT MON

*NHC

*180 *DYS

*RG

*N.M.C.

*2E

*H-20

*N/A

*L

*310782

*332

*RBS

*00175

*A

1E41*LS091

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 85
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = NOT DETERMINED

.1E41*LS091 E41-N014	HPCI STM DRN POT G.E. 310010	1E 003	G-01 RBS	00016	*NOT DETERMINED	*DR	180 DYS	ALL B
.1E51*PNS823 LS-3,4	1E51*HOV-044 POSITION GENERAL ELEC 310010	*1E 003	*G-01 *RBS	*00008	*NOT DETERMINED	*DR	*180 *DYS *	*ALL *B
.1E51*PNS825 LS-1,2	1E51*HOV-051 POSITION GENERAL ELEC 310010	*1E 003	*G-01 *RBS	*00008	*NOT DETERMINED	*DR	*180 *DYS *	*ALL *B
.1E51*PNS828	1E51*TU-005 MECH TRIP GENERAL ELEC 310010	*1E 003	*G-01 *RBS	*00008	*NOT DETERMINED	*DR	*180 *DYS *	*ALL *A

1R31*NFH02

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

REPORT DATE 01/18/82 PAGE 86

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

RESET NO. 003

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET DATE 07/01/81

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = OKONITE

.1R31*NFH02

POWER CABLE

OKONITE

*128-01

180 DYS NA

OKONITE

1E ALL

600 V POWER CABLEST

*EQ

ALL

310557

128 RB

*SPR

A

REPRESENTS ALL CABLE PURCHASED UNDER SH1-128

REPORT NO. PES-800	STONE AND WEBSTER ENGINEERING CORPORATION	REPORT DATE 01/18/82	PAGE 87
JOB NUMBER 1160002	PROJECT EQUIPMENT SYSTEM - (IS-129)	RESET NO. 003	
JOB NAME SHOREHAM - UNIT 1	ENVIRONMENTAL QUALIFICATION STATUS REPORT	RESET DATE 07/01/81	
JOB CLIENT LILCO	SORTED BY - MAK / MOD / SPEC		

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			ENG CND
	PO NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = POWERS

.1T46*A0D041A	RB POT CONTAM AREA EXH			POWERS	*319-01	070 MIN		
	POWERS REGUL	1E	K-15	331-2792	*EQ			ALL
	310738	319	RBS	00112				A
.1T46*A0D041B	RB POT CONTAM AREA EXH			POWERS	*319-01	070 MIN		
	POWERS REGUL	1E	K-15	331-2792	*EQ			ALL
	310738	319	RBS	00112				A

1E11-TE012A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 88
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			ENG CND
	PO NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = PYCO

*1E11-TE012A	RHR MAIN FLOW			PYCO	*3906	180 DYS	*USASC96.1	*RG
E11-N027A	GENERAL ELEC	1E	G-02	102-3171	*EQ			ALL
ADDED	310010	003	RBS	00040				A
.1E11-TE012B	RHR MAIN FLOW			*PYCO	*3906	*180 *DYS	*USASC96.1	*RG
E11-N027B	*GENERAL ELEC	*1E	*G-02	*102-3171	*EQ			ALL
	310010	*003	*RBS	*00040				*A

REPORT NO. PES-800	STONE AND WEBSTER ENGINEERING CORPORATION	REPORT DATE 01/18/82	PAGE 89
JOB NUMBER 1160002	PROJECT EQUIPMENT SYSTEM - (IS-129)	RESET NO. 003	
JOB NAME SHOREHAM - UNIT 1	ENVIRONMENTAL QUALIFICATION STATUS REPORT	RESET DATE 07/01/81	
JOB CLIENT LILCO	SORTED BY - MAK / MOD / SPEC		

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBNG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = RAYCHEM

.1R32*NFP 044	*INST CABLE			RAYCHEM	*130-01	180 DYS	N/A	
	RAYCHEM	1E	ALL	INSTRUMENT CABLE	EQ			ALL
	310567	130	RB		*SPR			A
	REPRESENTS ALL CABLE PURCHASED UNDER SH1-130							

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 90
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = RAYMOND

.1T46*MOD031A	*RBSVS INLE TO MIXED PLEN *POWERS REGUL 310738	*1E *319	*K-15 *RBS	*00135	RAYMOND MASR-49	*319-01 *IJ	*180 *DYS *		ALL *A
.1T46*MOD031B	*RBSVS INLE TO MIXED PLEN *POWERS REGUL 310738	*1E *319	*K-15 *RBS	*00135	RAYMOND MASR-49	*319-01 *IJ	*180 *DYS **N/A		ALL *A
.1T46*MOD036A	MOT DAMPER FOR FN 1T46*FN-003A POWERS REGUL 310738	1E 319	K-15 RBS	00112	RAYMOND MASR-49	*319-01 *IJ	180 DYS		ALL A
.1T46*MOD036B	MOT DAMPER FOR FN 1T46*FN-003B POWERS REGUL 310738	1E 319	K-15 RBS	00112	RAYMOND MASR-49	*319-01 *IJ	180 DYS		ALL A
.1T46*MOD036C	MOT DAMPER FOR FN 1T46*FN-003C POWERS REGUL 310738	1E 319	K-15 RBS	126	RAYMOND MASR-49	*319-01 *IJ	180 DYS		ALL A
.1T46*MOD047A	FN-79A DISCHARGE AIR POWERS REGUL 310738	1E 319	K-15 RBS	00112	RAYMOND MASR-9	*319-01 *IJ	180 DYS		ALL A
.1T46*MOD047B	FN-79B DISCHARGE AIR POWERS REGUL 310738	1E 319	K-15 RBS	00112	RAYMOND MASR-9	*319-01 *IJ	180 DYS		ALL A
.1T46*MOD048A	FLT 1A POWERS REGUL 310738	1E 319	K-15 RBS	00112	RAYMOND MASR-9	*319-01 *IJ	180 DYS		ALL A
.1T46*MOD048B	FLT 1B POWERS REGUL 310738	1E 319	K-15 RBS	00112	RAYMOND MASR-9	*319-01 *IJ	180 DYS		ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 91
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			ENG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = RELIANCE

.1P42*P005A	RBCLCH CIRC PP GOULD PUMP 310582	1E 62G	H-18 RBS	150	RELIANCE 100-HP-405TS	*DR	180 DYS	ALL A
.1P42*P005B	RBCLCH CIRC PP GOULD PUMP 310582	1E 62G	H-18 RBS	150	RELIANCE 100-HP-405TS	*DR	180 DYS	ALL A
.1P42*P005C	RBCLCH CIRC PP GOULD PUMP 310582	1E 62G	H-18 RBS	150	RELIANCE 100-HP-405TS	*DR	180 DYS	ALL A
.1G41*P023A	SPENT FUEL POOL COOLING PP GOULD PUMP 310582 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 62G	S-18 RBS	150	RELIANCE 20-HP-286T (MCC REV.)	*DR	180 DYS	*L A
.1G41*P023B	SPENT FUEL POOL COOLING PP GOULD PUMP 310582 L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM.	1E 62G	S-18 RBS	150	RELIANCE 20-HP-286T (MCC REV.)	*DR	180 DYS	*L A
.1T48*BLO01A	HYD RECOMBINER BLOWER 1A ATOMICS INT 3100624	1E 289	J-15 RBS	112	RELIANCE 324T	*289-03 *EQ	180 DYS NA	L A
.1T48*BLO01B	HYD RECOMBINER BLOWER 1B *ATOMICS INT 3100624	1E 289	J-15 RBS	112	RELIANCE 324T	*289-03 *EQ	180 DYS NA	L A

1R32*NFP097

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 92
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = ROCKBESTOS

.1R32*NFP097	*INST CABLE ROCKBESTOS 310553	1E 129	ALL RB	ROCKBESTOS *COAXIAL & TRIAXIAL	*129-02 *EQ *SPR	180 DYS	NA	ALL A
	REPRESENTS ALL COAXIAL & TRIAXIAL CABLE PURCHASED UNDER SH1-129							
.1R32*NFP010	*INST CABLE ROCKBESTOS 310664	1E 131	ALL RB	ROCKBESTOS THERMOCOUPLE WIRE	*129-01 *EQ *SPR	180 DYS	NA	ALL A
	REPRESENTS ALL CABLE PURCHASED UNDER SH1-131							
*1R32*NFP020	*INST CABLE *ROCKBESTOS *310553	*1E *129	*ALL *RB	*ROCKBESTOS *300/600 CONT & INST	*129-01 *EQ *SPR	*180 *DYS	*N/A	*ALL *A
ADDED	REPRESENTS ALL 300/600 CONT & INST CABLE PURCHASED UNDER SH1-129							

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 93
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			ENG CND
	PO NUMBER				SUBNG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = ROSEMOUNT

*1B21*LT154A	*REACTOR LEVEL TRIPS			*ROSEMOUNT	*3048	*001 *DYS	*3 IN.	
*B21-N080A	*GENERAL ELEC	*1E	*G-10	*1151	*EQ			*ALL
ADDED	*310010	*003	*RBS	*00078				*A
*1B21*LT154B	*REACTOR LEVEL TRIPS			*ROSEMOUNT	*3048	*001 *DYS	*3 IN.	
*B21-N080B	*GENERAL ELEC	*1E	*G-10	*1151	*EQ			*ALL
ADDED	*310010	*003	*RBS	*00078				*A
*1B21*LT154C	*REACTOR LEVEL TRIPS			*ROSEMOUNT	*3048	*001 *DYS	*3 IN.	
*B21-N080C	*GENERAL ELEC	*1E	*G-12	*1151	*EQ			*ALL
ADDED	*310010	*003	*RBS	*00078				*A
*1B21*LT154D	*REACTOR LEVEL TRIPS			*ROSEMOUNT	*3048	*001 *DYS	*3 IN.	
*B21-N080D	*GENERAL ELEC	*1E	*G-12	*1151	*EQ			*ALL
ADDED	*310010	*003	*RBS	*00078				*A
*1B21*LT155A	*WIDE RANGE			*ROSEMOUNT	*3048	*180 *DYS	*7.5 IN.	
*B21-N081A	*GENERAL ELEC	*1E	*G-10	*1151	*FT			*ALL
ADDED	*310010	*003	*RBS	*00078				*A
*1B21*LT155B	*WIDE RANGE			*ROSEMOUNT	*3048	*070 *MIN	*7.5 IN.	
*B21-N081B	*GENERAL ELEC	*1E	*G-10	*1151	*EQ			*L
ADDED	*310010	*003	*RBS	*00078				*A
*1B21*LT155C	*WIDE RANGE			*ROSEMOUNT	*3048	*180 *DYS	*7.5 IN.	
*B21-N081C	*GENERAL ELEC	*1E	*G-12	*1151	*FT			*ALL
ADDED	*310010	*003	*RBS	*00078				*A
*1B21*LT155D	*WIDE RANGE			*ROSEMOUNT	*3048	*070 *MIN	*7.5 IN.	
*B21-N081D	*GENERAL ELEC	*1E	*G-10	*1151	*EQ			*L
ADDED	*310010	*003	*RBS	*00078				*A
*1B21*LT157A	*REACTOR LEVEL TRIPS			*ROSEMOUNT	*3048	*180 *DYS	*2.5% FSDP	
*B21-N091A	*GENERAL ELEC	*1E	*G-10	*1151	*FT			*ALL
ADDED	*310010	*003	*RBS	*00078				*A
*1B21*LT157B	*REACTOR LEVEL TRIPS			*ROSEMOUNT	*3048	*180 *DYS	*2.5% FSDP	
*B21-N091B	*GENERAL ELEC	*1E	*G-12	*1151	*FT			*ALL
ADDED	*310010	*003	*RBS	*00078				*A
*1B21*LT157C	REACTOR LEVEL TRIPS			*ROSEMOUNT	*3048	*180 *DYS	*2.5% FSDP	
B21-N091C	*GENERAL ELEC	*1E	*G-10	*1151	*FT			*ALL
	310010	*003	*RBS	*00078				*A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 94
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
*1B21*LT157D *B21-N091D ADDED	*REACTOR LEVEL TRIPS *GENERAL ELEC *310010	*1E *003	*G-12 *RBS	*00078	*ROSEMOUNT *1151	*3048 *FT	*180 *DYS	*2.5% FSDP	*ALL *A
*1B21*PT156A *B21-N078A ADDED	*REACTOR HI PRESS SCRAM *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*10 PSIG	*L *A
*1B21*PT156B *B21-N078B ADDED	*REACTOR HI PRESS SCRAM *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*10 PSIG	*L *A
*1B21*PT156C *B21-N078C ADDED	*REACTOR HI PRESS SCRAM *GENERAL ELEC *310010	*1E *003	*G-12 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*10 PSIG	*L *A
*1B21*PT156D *B21-N078D ADDED	*REACTOR HI PRESS SCRAM *GENERAL ELEC *310010	*1E *003	*G-12 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*10 PSIG	*L *A
*1B21*PT158A *B21-N097A ADDED	*CS 7 RHR VALVE OPENING *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*1% FS	*L *A
*1B21*PT158B *B21-N097B ADDED	*CS & RHR VALVE OPENING *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*1% FS	*L *A
*1B21*PT158C *B21-N097C ADDED	*CS & RHR VALVE OPENING *GENERAL ELEC *310010	*1E *003	*G-12 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*1% FS	*L *A
*1B21*PT158D *B21-N097D ADDED	*CS & RHR VALVE OPENING *GENERAL ELEC *310010	*1E *003	*G-12 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*1% FS	*L *A
*1C71*PT007A *C71-N050A ADDED	*PRIMARY CONTAINMENT HP *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*1% FS	*L *A
*1C71*PT007B *C71-N050B ADDED	*PRIMARY CONTAINMENT HP *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*1% FS	*L *A
*1C71*PT007C *C71-N050C ADDED	*PRIMARY CONTAINMENT HP *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*1% FS	*L *A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 95
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
*1C71*PT007D *C71-N0500 ADDED	*PRIMARY CONTAINMENT HP *GENERAL ELEC *310010	*1E *003	*G-12 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*1% FS	*L *A
*1E11*PT165A ADDED	*PRIMARY CONT HP *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*.1 PSIG	*L *A
*1E11*PT165B ADDED	*PRIMARY CONT HP *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*.1 PSIG	*L *A
*1E11*PT165C ADDED	*PRIMARY CONT HP *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*.1 PSIG	*L *A
*1E11*PT165D ADDED	*PRIMARY CONT HP *GENERAL ELEC *310010	*1E *003	*G-12 *RBS	*00078	*ROSEMOUNT *1151	*3048 *EQ	*070 *MIN	*.1 PSIG	*L *A
.1E32*PT031A E32-N051B	MSIV A LEAKAGE LINE GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	ROSEMOUNT 1151AP	3048 FT	100 DYS		*RG *L A
.1E32*PT031B E32-N051F	MSIV B LEAKAGE LINE GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	ROSEMOUNT 1151AP	3048 FT	100 DYS		*RG *L A
.1E32*PT031C E32-N051K	MSIV C LEAKAGE LINE GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	ROSEMOUNT 1151AP	3048 FT	100 DYS		*RG *L A
.1E32*PT031D E32-N051P	MSIV D LEAKAGE LINE GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	ROSEMOUNT 1151AP	3048 FT	100 DYS		*RG *L A
.1E32*PT034 E32-N056	MN STM LINE LEAKAGE GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	ROSEMOUNT 1151AP	3048 FT	100 DYS		*RG *L A
.1C61*FT001 C61-N001	RHR MAIN FLOW GENERAL ELEC	1E	G-01		*ROSEMOUNT *1151DP	*FT	180 DYS		ALL

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 96

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENH CMD OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
	310010	003	RBS	00008					B
.1E11*FT001A E11-N015A	RHR MAIN FLOW GENERAL ELEC 310010	1E 003	G-01 RBS	00008	ROSEMOUNT 1151DP	3048 FT	180 DYS	*2.25%	*RG ALL A
.1E11*FT001B E11-N015B	RHR MAIN FLOW GENERAL ELEC 310010	1E 003	G-01 RBS	00008	ROSEMOUNT 1151DP	3048 FT	180 DYS	*2.25%	*RG ALL A
.1E11*FT006A E11-N007A	*CHANGED TO 1Z91*FT020 GENERAL ELEC 310010	1E 003	G-01 RBS	00008	ROSEMOUNT 1151DP	3048 FT	180 DYS	*2%	*RG ALL *B
.1E11*FT006B E11-N007B	RHR EX SERV WATER INLET GENERAL ELEC 310010	1E 003	G-01 RBS	00008	ROSEMOUNT 1151DP	3048 FT	180 DYS	*2%	*RG ALL *B
.1E21*FT002A E21-N003A	CORE SPRAY PUMP DISCH GENERAL ELEC 310010	1E 003	G-01 RBS	00008	ROSEMOUNT 1151DP	3048 FT	180 DYS	*	*RG L A
.1E21*FT002B E21-N003B	CORE SPRAY PUMP DISCH GENERAL ELEC 310010	1E 003	G-01 RBS	00008	ROSEMOUNT 1151DP	3048 FT	180 DYS	*	*RG L A
.1E32*PDT035 E32-N059	DILUTION AIRFLOW,OB GENERAL ELEC 310010	1E 003	G-05 RBS	00063	ROSEMOUNT 1151DP	3048 FT	180 DYS		*RG *L A
.1E32*PDT038 E32-N054	DILUTION AIRFLOW IB GENERAL ELEC 310010	1E 003	G-05 RBS	00063	ROSEMOUNT 1151DP	3048 FT	100 DYS		*RG *L A
	OP CODE B FOR HELB & HELB								
.1E41*FT003 E41-N008	*CHANGED TO 1Z91*FT002 GENERAL ELEC 310010	1E 003	G-01 RBS	00008	ROSEMOUNT 1151DP	3048 *EQ	001 DYS		*RG ALL A
.1E51*FT003 E51-N003	RCIC PUMP DISCHARGE GENERAL ELEC 310010	1E 003	G-01 RBS	00008	ROSEMOUNT 1151DP	3048 *EQ	001 DYS	*.67%	*RG ALL A
.1G33*FT011 G33-N036	RWCU SYSTEM INLET GENERAL ELEC 310010	1E 003	H-16 RBS	00112	ROSEMOUNT 1151DP	3048 *EQ	070 MIN	*2% SPAN	H,H A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 97
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	OAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
.1G33*FT012 G33-N041	RWCU SYS REACTOR RETURN GENERAL ELEC 310010	1E 003	H-16 RBS	63	ROSEMOUNT 1151DP	3048 *EQ	070 MIN	*2% SPAN	H,M A
.1G33*FT013 G33-N012	RWCU SYS BLOWDOWN GENERAL ELEC 310010	1E 003	H-16 RBS	00112	ROSEMOUNT 1151DP	3048 *EQ	070 MIN	*2% SPAN	H,M A
.1E32*PT032A E32-N061B	MSIV A LEAKAGE LINE GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	ROSEMOUNT 1151GP	3048 FT	100 DYS		*RG *L A
.1E32*PT032B E32-N061F	MSIV B LEAKAGE LINE GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	ROSEMOUNT 1151GP	3048 FT	100 DYS		*RG *L A
.1E32*PT032C E32-N061K	MSIV C LEAKAGE LINE GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	ROSEMOUNT 1151GP	3048 FT	100 DYS		*RG *L A
.1E32*PT032D E32-N061P	MSIV D LEAKAGE LINE GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	ROSEMOUNT 1151GP	3048 FT	100 DYS		*RG *L A
.1E32*PT033 E32-N055	MN STM LINE LEAKAGE GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-05 RBS	00063	ROSEMOUNT 1151GP	3048 FT	100 DYS		*RG *L A
.1E32*PT041 E32-N058	OUTBD MSIV LEAKAGE CONT GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-10 RBS	00078	ROSEMOUNT 1151GP	3048 *FT	180 DYS		L A
.1E32*PT042 E32-N060	INBD MSIV LEAKAGE CONT GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-12 RBS	00078	ROSEMOUNT 1151GP	3048 *FT	180 DYS		L A
.1E32*PT043 E32-N050	INBD MSIV LEAKAGE CONT GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-12 RBS	00078	ROSEMOUNT 1151GP	3048 *FT	180 DYS		L A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 98

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EHG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
*1B21*LT159A *B21-N095A ADDED	*AUTO DEPRESSURIZATION *GENERAL ELEC *310010	*1E *003	*G-10 *RBS	*00078	*ROSEMOUNT *1152	*3915 *EQ	*001 *DYS	*2.5% FSDP	*ALL *A
.1B21*LT159B B21-N095B	AUTO DEPRESSURIZATION *GENERAL ELEC 310010	*1E *003	*H-12 *RBS	*00078	*ROSEMOUNT *1152	*3915 *EQ	*001 *DYS	*2.5% FSDP	*ALL *A
.1C61*PT012	PRESS TRANS DRYWELL PRESS ROSEMOUNT 310773	1E 406	G-10 RBS	00098	*ROSEMOUNT 1152AP5E22T0280PB	*406-02 *EQ	180 DYS		ALL B
.1T46*PDT003A	FLT-1A DIFF PRESSURE ROSEMOUNT 310773 RELOCATION BY FIELD REQUIRED	1E 406	K-15 RBS	00112	*ROSEMOUNT 1152DP3A22PB	*HR	180 DYS		ALL A
.1T46*PDT003B	FLT-1B DIFF PRESSURE ROSEMOUNT 310773 RELOCATION BY FIELD REQUIRED	1E 406	K-15 RBS	00112	*ROSEMOUNT 1152DP3A22PB	*HR	180 DYS		ALL A
.1T46*PDT043A	REACTOR BLDG DIFF ROSEMOUNT 310773	1E 406	H-20 RBS	00220	*ROSEMOUNT 1152DP3A22PB	*HR	180 DYS		ALL A
.1T46*PDT043B	REACTOR BLDG DIFF ROSEMOUNT 310773	1E 406	H-20 RBS	00220	*ROSEMOUNT 1152DP3A22PB	*HR	180 DYS		ALL A
.1C61*LT026	SUPP POOL ROSEMOUNT 310773	1E 406	G-01 RBS	00008	*ROSEMOUNT 1152DP4A22PB	*HR	180 DYS		ALL B
.1G11*FT647A	*CHANGED TO 1Z91*FT003A ROSEMOUNT 310773	1E 406	G-01 RBS	00008	*ROSEMOUNT 1152DP4A22PB	*HR	180 DYS		ALL B
.1G11*FT647B	*CHANGED TO 1Z91*FT003B ROSEMOUNT 310773	1E 406	G-01 RBS	00008	*ROSEMOUNT 1152DP4A22PB	*HR	180 DYS		ALL B
.1G11*FT647C	LEAKAGE RETURN PP P-270C DISCH ROSEMOUNT 310773	1E 406	G-01 RBS	00008	*ROSEMOUNT 1152DP4A22PB	*HR	180 DYS		ALL B
.1Z93*LT001A	SUPPRESSION POOL LEV XMTR				*ROSEMOUNT	*	180 DYS		*RG

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 99
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
	ROSEMOUNT 310773	1E 406	G-01 RBS	00008	1152DP4A22PB	*MR			ALL A
.1Z93*LT001B	SUPPRESSION POOL LEV XMTR ROSEMOUNT 310773	1E 406	G-01 RBS	00008	ROSEMOUNT 1152DP4A22PB	* *MR	180 DYS		*RG ALL A
.1C61*PT106	SRV AIR HEADER PRESS 310773	1E 406	G-10 RBS	00101	*ROSEMOUNT 1152GP7A22PB	*MR	180 DYS		ALL B
.1P50*PT116A 04530008	SERVICE AIR HEADER A ROSEMOUNT 310773	1E 406	H-18 RBS	151	*ROSEMOUNT 1152GP7A22PB	*MR	180 DYS		*RG ALL A
.1P50*PT116B 04560008	SERVICE AIR HEADER B ROSEMOUNT 310773	1E 406	H-18 RBS	151	*ROSEMOUNT 1152GP7A22PB	*MR	180 DYS		*RG ALL A
.1B21*PT153A	RV092A MONITOR ROSEMOUNT 310773	1E 406	G-01 RBS	00008	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A
.1B21*PT153B	RV092B MONITOR ROSEMOUNT 310773	1E 406	G-01 RBS	00008	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A
.1B21*PT153C	RV092C MONITOR ROSEMOUNT 310773	1E 406	G-01 RBS	00008	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A
.1B21*PT153D	RV092D MONITOR ROSEMOUNT 310773	1E 406	G-01 RBS	00008	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A
.1B21*PT153E	SRV MONITOR E ROSEMOUNT 310773	1E 406	G-01 RBS	40	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A
.1B21*PT153F	RV092F MONITOR ROSEMOUNT 310773	1E 406	L-02 RBS	00040	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A
.1B21*PT153G	RV092G MONITOR ROSEMOUNT 310773	1E 406	L-02 RBS	00040	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A

1B21*PT153H

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 100

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBING	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****
.1B21*PT153H	RV092H MONITOR ROSEMOUNT 310773	1E 406	L-02 RBS 00040	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A
.1B21*PT153J	RV092J MONITOR ROSEMOUNT 310773	1E 406	L-02 RBS 00040	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A
.1B21*PT153K	RV092K MONITOR ROSEMOUNT 310773	1E 406	L-02 RBS 00040	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A
.1B21*PT153L	SRV MONITOR L ROSEMOUNT 310773	1E 406	L-02 RBS 00040	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		*RG ALL A
.1E41*PT142	TO LUBE OIL COOLER ROSEMOUNT 310773	1E 406	G-01 RBS 00008	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		ALL A
.1E51*PT142	LUBE OIL COOLER CONT VALVE ROSEMOUNT 310773	1E 406	G-01 RBS 00008	*ROSEMOUNT 1152GP7E22PB	*406-02 *EQ	001 DYS		ALL A
.1T48*FT005	HEPA FILTER INLET ROSEMOUNT 310773	1E 406	J-15 RBS 00113	*ROSEMOUNT 1153DB3A22PB	*406-01 EQ	180 DYS		L A
*1P41*FT146A 1P41-FT146A EQUIP ID CHGD	1P42*E011A OUTLET FLOW ROSEMOUNT 310773	*2E 406	G-01 RB 00008	*ROSEMOUNT *1153DB4A22PB	*406-02 EQ	180 DYS		ALL B
*1P41*FT146B 1P41-FT146B EQUIP ID CHGD	1P42*E011B OUTLET FLOW ROSEMOUNT 310773	*2E 406	G-01 RB 00008	*ROSEMOUNT *1153DB4A22PB	*406-02 EQ	180 DYS		ALL B
.1P41*FT151A	RHR SERV WTR RAD MON SAMPLE ROSEMOUNT 310773	1E 406	G-01 RBS 00008	*ROSEMOUNT 1153DB4A22PB	*406-02 EQ	180 DYS		ALL A
.1P41*FT151B	RHR SERV WTR RAD MON SAMPLE ROSEMOUNT 310773	1E 406	G-01 RBS 00008	*ROSEMOUNT 1153DB4A22PB	*406-02 EQ	180 DYS		ALL A
.1Z93*PT003A	DRYWELL PRESSURE ROSEMOUNT 310773	1E 406	G-10 RBS 00078	*ROSEMOUNT 1153GB7A22PB	*406-01 EQ	180 DYS		*RG *L A

1Z93*PT003A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 101
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLOG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EMG CMD OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
	OP CODE B FOR HELB & HELB								
.1Z93*PT003B	DRYWELL & SUPPRESSION POOL PRE ROSEMOUNT 310773	1E 406	G-10 RBS	00078	*ROSEMOUNT 1153GB7A22PB	*406-01 EQ	180 DYS		*RG *L A
	OP CODE B FOR HELB & HELB								
.1Z93*PT004A	SUPPRESSION POOL ACCESS HATCH ROSEMOUNT 310773	1E 406	G-02 RBS	00040	ROSEMOUNT 1153GB7A22PB	*406-01 EQ	180 DYS		*RG ALL A
.1Z93*PT004B	SUPPRESSION POOL ACCESS HATCH ROSEMOUNT 310773	1E 406	G-07 RBS	00063	ROSEMOUNT 1153GB7A22PB	*406-01 EQ	180 DYS		*RG ALL A
.1Z93*TE110W	RV092ACL DISCHARGE 1FT ROSEMOUNT 310773	1E 406	F-23 RBD	00028	*ROSEMOUNT 88-149-1	*406-03 *EQ *MST	180 DYS		ALL A
.1Z93*TE110X	RV092ACL DISCHARGE 1FT ROSEMOUNT 310773	1E 406	F-23 RBD	00028	*ROSEMOUNT 88-149-1	*406-03 *EQ *MST	180 DYS		ALL A
.1Z93*TE110Y	RV092ACL DISCHARGE 1FT ROSEMOUNT 310773	1E 406	F-23 RBD	00025	*ROSEMOUNT 88-149-1	*406-03 *EQ *MST	180 DYS		ALL A
.1Z93*TE110Z	RV092ACL DISCHARGE 1FT ROSEMOUNT 310773	1E 406	F-23 RBD	00025	*ROSEMOUNT 88-149-1	*406-03 *EQ *MST	180 DYS		ALL A
.1Z93*TE132A	RV092ACL DISCHARGE 2FT ROSEMOUNT 310773	1E 406	E-23 RBD	25	*ROSEMOUNT 88-149-2	*406-03 *EQ *MST	180 DYS		*RG ALL A
.1Z93*TE132B	RV092ACL DISCHARGE 2FT ROSEMOUNT 310773	1E 406	E-23 RBD	25	*ROSEMOUNT 88-149-2	*406-03 *EQ *MST	180 DYS		*RG ALL A
.1Z93*TE133A	RV092BDE DISCHARGE 2FT ROSEMOUNT 310773	1E 406	E-23 RBD	25	*ROSEMOUNT 88-149-2	*406-03 *EQ *MST	180 DYS		*RG ALL A
.1Z93*TE133B	RV092BDE DISCHARGE 2FT ROSEMOUNT 310773	1E 406	E-23 RBD	25	*ROSEMOUNT 88-149-2	*406-03 *EQ *MST	180 DYS		*RG ALL A

1Z93*TE134A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 102
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
.1Z93*TE134A	RV092HG DISCHARGE 2FT ROSEMOUNT 310773	1E 406	E-23 RBD	25	*ROSEMOUNT 88-149-2	*406-03 *EQ *MST	180 DYS		*RG ALL A
.1Z93*TE134B	RV092HG DISCHARGE 2FT ROSEMOUNT 310773	1E 406	E-23 RBD	25	*ROSEMOUNT 88-149-2	*406-03 *EQ *MST	180 DYS		*RG ALL A
.1Z93*TE135A	RV092FHJ DISCHARGE 2FT ROSEMOUNT 310773	1E 406	E-23 RBD	25	*ROSEMOUNT 88-149-2	*406-03 *EQ *MST	180 DYS		*RG ALL A
.1Z93*TE135B	RV092FHJ DISCHARGE 2FT ROSEMOUNT 310773	1E 406	E-23 RBD	25	*ROSEMOUNT 88-149-2	*406-03 *EQ *MST	180 DYS		*RG ALL A
.1T46*TE001B	RBSVS RECIRC AIR TEMP ROSEMOUNT 310773	1E 406	K-15 RBS	112	*ROSEMOUNT 89-138-2/88-14-3	*406-03 *EQ	180 DYS		ALL A
.1T46*TE001A	RBSVS RECIRC AIR TEMP ROSEMOUNT 310773	1E 406	K-15 RBS	112	*ROSEMOUNT 89-86-4/88-14-1	*406-03 *EQ	180 DYS		ALL A
.1T46*TE022A	AIR RETURN TO UC-2A ROSEMOUNT 310773	1E 406	G-01 RBS	00010	*ROSEMOUNT 89-86-4/88-14-1	*406-03 *EQ	180 DYS		ALL A
.1T46*TE022B	AIR RETURN TO UC-2B ROSEMOUNT 310773	1E 406	G-01 RBS	00042	*ROSEMOUNT 89-86-4/88-14-1	*406-03 *EQ	180 DYS		ALL A
.1T46*TE023A	AIR RETURN TO UC-3A ROSEMOUNT 310773	1E 406	G-01 RBS	00012	*ROSEMOUNT 89-86-4/88-14-1	*406-03 *EQ	180 DYS		ALL A
.1T46*TE023B	AIR RETURN TO UC-3B ROSEMOUNT 310773	1E 406	G-02 RBS	00042	*ROSEMOUNT 89-86-4/88-14-1	*406-03 *EQ	180 DYS		ALL A
.1T46*TE024A	AIR RETURN TO UC-4A ROSEMOUNT 310773	1E 406	H-20 RBS	00220	*ROSEMOUNT 89-86-4/88-14-1	*406-03 *EQ	180 DYS		ALL A
.1T46*TE024B	AIR RETURN TO UC-4B ROSEMOUNT 310773	1E 406	H-20 RBS	00220	*ROSEMOUNT 89-86-4/88-14-1	*406-03 *EQ	180 DYS		ALL A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 103

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
.1T46*TE025A	AIR RETURN TO UC-5A ROSEMOUNT 310773	1E 406	H-20 RBS	00220	*ROSEMOUNT 89-86-4/88-14-1	*406-03 *EQ	180 DYS		ALL A
.1T46*TE025B	AIR RETURN TO UC-5B ROSEMOUNT 310773	1E 406	H-20 RDS	00220	*ROSEMOUNT 89-86-4/88-14-1	*406-03 *EQ	180 DYS		ALL A
.1T46*TE028A	MCC RH UNIT COOLER ROSEMOUNT 310773	1E 406	H-16 RBS	00116	*ROSEMOUNT 89-86-4/88-14-3	*406-03 *EQ	180 DYS		ALL A
.1T46*TE028B	MCC RH UNIT COOLER ROSEMOUNT 310773	1E 406	J-15 RBS	00116	*ROSEMOUNT 89-86-4/88-14-3	*406-03 *EQ	180 DYS		ALL A
.1T46*TE059A	UC-21A UNIT CLEAR ROSEMOUNT 310773	1E 406	H-19 RBS	00155	*ROSEMOUNT 89-86-4/88-14-3	*406-03 *EQ	180 DYS		ALL A
.1T46*TE059B	UC-21B UNIT CLEAR ROSEMOUNT 310773	1E 406	H-19 RBS	00155	*ROSEMOUNT 89-86-4/88-14-3	*406-03 *EQ	180 DYS		ALL A
.1T46*TE060A	UC-22A UNIT CLEAR ROSEMOUNT 310773	1E 406	H-19 RBS	00160	*ROSEMOUNT 89-86-4/88-14-3	*406-03 *EQ	180 DYS		ALL A
.1T46*TE060B	UC-22B UNIT CLEAR ROSEMOUNT 310773	1E 406	H-19 RBS	00160	*ROSEMOUNT 89-86-4/88-14-3	*406-03 *EQ	180 DYS		ALL A

1E32*FE037A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 104
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = SCHUTTE & KOERTING

.1E32*FE037A E32-N006B	MSIV A LEAK TO LPM GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-06 RBS	00065	SCHUTTE & KOERTING *3128 *DR	100 DYS		*L A
.1E32*FE037B E32-N006F	MSIV B LEAK TO LPM GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-06 RBS	00065	SCHUTTE & KOERTING *3128 *DR	100 DYS		*L A
.1E32*FE037C E32-N006K	MSIV C LEAK TO LPM GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-06 RBS	00065	SCHUTTE & KOERTING *3128 *DR	100 DYS		*L A
.1E32*FE037D E32-N006P	MSIV D LEAK TO LPM GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-06 RBS	00065	SCHUTTE & KOERTING *3128 *DR	100 DYS		*L A

1E41*PS016

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 105

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = SQUARE D

1E41*PS016

AUX OIL PMP TURB CONT OIL PRES

*SQUARE D

*

001 DYS *2 PSIG

PSI

GENERAL ELEC

1E

G-01

*CLASS 9012, ACH-22

*TA

ALL

310010

003

RBS

00008

A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 106

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBNG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = SQUARE D CO.

.1R24*PNL-R1	BREAKER DIST PNL (RED) SQUARE D 310535	1E 115	N-21 RBS	112	SQUARE D CO. *BREAKER DIST PNL	*IJ	180 DYS	ALL A
.1R24*PNL-R2	BREAKER DIST PNL (RED) SQUARE D 310535	1E 115	N-21 RBS	112	SQUARE D CO. *BREAKER DIST PNL	*IJ	180 DYS	ALL A
.1R24*PNL01	BREAKER DIST PNL (BLACK) SQUARE D 310535 H,M-OP CODE B 1 DAY, C REM. (MCC REV.)	1E 115	G-10 RBS	00078	*SQUARE D CO. BREAKER DIST PNL	*IJ	180 DYS	*L B
.1R24*PNL02	BREAKER DIST PNL (BLACK) SQUARE D 310535 H,M-OP CODE B 1 DAY, C REM. (MCC REV.)	1E 115	G-10 RBS	00078	*SQUARE D CO. BREAKER DIST PNL	*IJ	180 DYS	*L B
.1R24*PNL03	BREAKER DIST PNL (BLACK) SQUARE D 310535 H,M-OP CODE B 1 DAY, C REM. (MCC REV.)	1E 115	H-11 RBS	00078	*SQUARE D CO. BREAKER DIST PNL	*IJ	180 DYS	*L B
.1R24*PNL04	120VAC POWER PNL TO RSP SQUARE D 310535	1E 115	N-21 RBS	00112	*SQUARE D CO. BREAKER DIST PNL	*IJ	180 DYS	ALL A
.1R24*HCC111W	MOTOR CONTROL CENTER SQUARE D CO. 310535	1E 115	N-21 RBS	150	SQUARE D CO. MODEL 4	*IJ	180 DYS	ALL A
.1R24*HCC111X	MOTOR CONTROL CENTER-LCP1 SQUARE D CO 310535	1E 115	N-21 RBS	112	SQUARE D CO. MODEL 4	*IJ	180 DYS	ALL A
.1R24*HCC111Y	MOTOR CONTROL CENTER-EMER SQUARE D CO. 310535 H,M-OP CODE B 1 DAY, C REM. (MCC REV.)	1E 115	H-09 RBS	78	SQUARE D CO. MODEL 4	*IJ	180 DYS	*L A
.1R24*HCC111Z	MOTOR CONTROL CENTER-EMER SQUARE D CO. 310535	1E 115	H-09 RBS	78	SQUARE D CO. MODEL 4	*IJ	180 DYS	*L A

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 107

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

H,M-CP CODE B 1 DAY, C REM. (MCC REV.)

.1R24*MCC1111	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	G-02 RBS	40	SQUARE D CO. MODEL 4		*IJ	180 DYS	*L A
	H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1R24*MCC1112	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	N-21 RBS	112	SQUARE D CO. MODEL 4		*IJ	180 DYS	ALL A
.1R24*MCC1113	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	N-21 RBS	112	SQUARE D CO. MODEL 4		*IJ	180 DYS	ALL A
.1R24*MCC1114	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	H-18 RBS	150	SQUARE D CO. MODEL 4		*IJ	180 DYS	*L A
	H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1R24*MCC1117	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	G-02 RBS	40	SQUARE D CO. MODEL 4		*IJ	180 DYS	*L A
	H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1R24*MCC1118	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	N-21 RBS	112	SQUARE D CO. MODEL 4		*IJ	180 DYS	ALL A
.1R24*MCC1119	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	L-02 RBS	40	SQUARE D CO. MODEL 4		*IJ	180 DYS	*L A
	H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1R24*MCC112H	MOTOR CONTROL CENTER SQUARE D CO. 310535	1E 115	N-21 RBS	150	SQUARE D CO. MODEL 4		*IJ	180 DYS	ALL A
.1R24*MCC112X	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	H-12 RBS	78	SQUARE D CO. MODEL 4		*IJ	180 DYS	*L A
	H,M-OP CODE B 1 DAY, C REM. (MCC REV.)								
.1R24*MCC112Y	MOTOR CONTROL CENTER-LCPI SQUARE D CO. 310535	1E 115	N-21 RBS	112	SQUARE D CO. MODEL 4		*IJ	180 DYS	ALL A

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 108

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1R24*MCC1121	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535 H,M-OP CODE B 1 DAY, C REM. (MCC REV.)	1E 115	G-02 RBS	40	SQUARE D CO. MODEL 4	*IJ	180 DYS		*L A
.1R24*MCC1122	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	N-21 RBS	112	SQUARE D CO. MODEL 4	*IJ	180 DYS		ALL A
.1R24*MCC1123	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	N-21 RBS	112	SQUARE D CO. MODEL 4	*IJ	180 DYS		ALL A
.1R24*MCC1124	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535 H,M-OP CODE B 1 DAY, C REM. (MCC REV.)	1E 115	H-18 RBS	150	SQUARE D CO. MODEL 4	*IJ	180 DYS		*L A
.1R24*MCC1127	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535 H,M-OP CODE B 1 DAY, C REM. (MCC REV.)	1E 115	G-02 RBS	40	SQUARE D CO. MODEL 4	*IJ	180 DYS		*L A
.1R24*MCC1128	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	N-21 RBS	112	SQUARE D CO. MODEL 4	*IJ	180 DYS		ALL A
.1R24*MCC1129	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535 H,M-OP CODE B 1 DAY, C REM. (MCC REV.)	1E 115	L-02 RBS	40	SQUARE D CO. MODEL 4	*IJ	180 DYS		*L A
.1R24*MCC1131	MOTOR CONTROL CENTER-EMER SQUARE D CO 310535	1E 115	N-21 RBS	150	SQUARE D CO. MODEL 4	*IJ	180 DYS		ALL A
.1R24*PNL-B1	BREAKER DIST PNL (BLUE) SQUARE D 310535	1E 115	N-21 RBS	00112	*SQUARE D CO. *480V PNL	*IJ	180 DYS		ALL A
.1R24*PNL-G1	BREAKER DIST PNL (GREEN) SQUARE D 310535	1E 115	N-21 RBS	00112	*SQUARE D CO. *480V PNL	*IJ	180 DYS		ALL A
.1R24*PNL-Y1	BREAKER DIST PNL (YELLOW) SQUARE D 310535	1E 115	N-21 RBS	112	SQUARE D CO. *480V PNL	*IJ	180 DYS		ALL A

1E41*LS095

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 109
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EHG CND
	PO NUMBER		ELEV		SUBHG			OP CD

.1E41*LS095	COND&VAC TR F-36 GENERAL ELEC 310010	1E 003	G-01 RBS	*SQUARE D CO. 9038-AG154	*TA	001 DYS	*3 IN.	ALL A
.1E51*LS095H	COND & VAC TR E-38 GENERAL ELEC 310010	1E 003	G-01 RBS	*SQUARE D CO. 9038-AG154	*DR	001 DYS		ALL A
.1E51*LS091 E51-N010	RCIC STM DRN POT GENERAL ELEC 310010	1E 003	G-01 RBS	*SQUARE D CO. 9038-A6154	*3916 *DR	180 DYS	*.5 IN	ALL B

REPORT NO. PES-800	STONE AND WEBSTER ENGINEERING CORPORATION	REPORT DATE 01/18/82	PAGE 110
JOB NUMBER 1160002	PROJECT EQUIPMENT SYSTEM - (IS-129)	RESET NO. 003	
JOB NAME SHOREHAM - UNIT 1	ENVIRONMENTAL QUALIFICATION STATUS REPORT	RESET DATE 07/01/81	
JOB CLIENT LILCO	SORTED BY - MAK / MOD / SPEC		

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	CP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = STATIC-O-RING

.1B31*PS023A B31-N018A	*RECIRC SUC FR RHR VLV INTLK GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	1E 003	G-02 RBS	00040	STATIC-O-RING 5N-AA3-X10STT	3032 *DR	007 DYS .5%	*L *A
.1B31*PS023B B31-N018B	*RECIRC SUC PR RHR VLV INTLK GENERAL ELEC 310010 OP CODE B FOR HELB & MELB	*1E *003	*G-02 *RBS	*00040	*STATIC-O-RING *5N-AA3-X10STT	*3032 *DR	*007 *DYS *13%	*L *A
.1E51*PS023A E51-N019A	RCIC AUTO ISOLATION GENERAL ELEC 310010	1E 003	L-02 RBS	00040	STATIC-O-RING 5N-AA3-X10STT	3032 *DR	001 DYS *13%	ALL A
.1E51*PS023B E51-N019B	RCIC AUTO ISOLATION GENERAL ELEC 310010	1E 003	L-02 RBS	00040	STATIC-O-RING 5N-AA3-X10STT	3032 *DR	001 DYS *13%	ALL A
.1E51*PS023C E51-N019C	RCIC AUTO ISOLATION GENERAL ELEC 310010	1E 003	L-02 RBS	00040	STATIC-O-RING 5N-AA3-X10STT	3032 *DR	001 DYS *13%	ALL A
.1E51*PS023D E51-N019D	RCIC AUTO ISOLATION GENERAL ELEC 310010	1E 003	L-02 RBS	00040	STATIC-O-RING 5N-AA3-X10STT	3032 *DR	001 DYS *13%	ALL A
.1E51*PS021L E51-N006	RCIC PUMP SUCTION GENERAL ELEC 310010	1E 003	G-01 RBS	00008	STATIC-O-RING 6N-AA21-X10VSTT	3032 *DR	001 DYS *2 PSIG	ALL A
.1E41*PS021L E41-N010	HPCI PUMP SUCT GENERAL ELEC 310010	1E 003	G-01 RBS	00008	STATIC-O-RING 6N-AA21-X10V557	3032 *DR	001 DYS	ALL A

1R35*PNL-B2

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800

STONE AND WEBSTER ENGINEERING CORPORATION

JOB NUMBER 1160002

PROJECT EQUIPMENT SYSTEM - (IS-129)

REPORT DATE 01/18/82 PAGE 111

JOB NAME SHOREHAM - UNIT 1

ENVIRONMENTAL QUALIFICATION STATUS REPORT

RESET NO. 003

JOB CLIENT LILCO

SORTED BY - MAK / MOD / SPEC

RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			ENG CND
	PO NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = SYSTEMS CONTROL

.1R35*PNL-B2

120VAC DIST PNL REAC BLDG

SYSTEMS CONTROL

*124-01

180 DYS N/A

SYSTEM CONT

1E N-21

120-VAC-DIST-PNL

*EQ

ALL

310713

124 RBS 112

A

REQUIRED 6 MONTH ACCIDENT DOSE REDUCED TO 1.0E5 PER CALCULATION SNPS-1-UR-21-N

.1R35*PNL-R2

120VAC DIST PNL REAC BLDG

SYSTEMS CONTROL

*124-01

180 DYS N A

SYSTEM CONT

1E N-21

120-VAC-DIST-PNL

*EQ

ALL

310713

124 RBS 112

A

REQUIRED 6 MONTH ACCIDENT DOSE REDUCED TO 1.0E5 PER CALCULATION SNPS-1-UR-21-N

REPORT NO. PES-800 STONE AND WEBSTER ENGINEERING CORPORATION
 JOB NUMBER 1160002 PROJECT EQUIPMENT SYSTEM - (IS-129) REPORT DATE 01/18/82 PAGE 112
 JOB NAME SHOREHAM - UNIT 1 ENVIRONMENTAL QUALIFICATION STATUS REPORT RESET NO. 003
 JOB CLIENT LILCO SORTED BY - MAK / MOD / SPEC RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBMG			OP CD

REPORT GROUP MAK = TARGET

.1B21*SOV92AX *B21-F013A	ADS VLV 1B21*RV-92A SOV A GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92AY *B21-F013A	ADS VLV 1B21*RV-92A SOV B GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92BX *B21-F013B	ADS VLV 1B21*RV-92B SOV A GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	*180 *DYS	*N/A	ALL A
.1B21*SOV92BY *B21-F013B	ADS VLV 1B21*RV-92B SOV B GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92CX *B21-F013C	ADS VLV 1B21*RV-92C SOV A GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92CY *B21-F013C	ADS VLV 1B21*RV-92C SOV B GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92DX *B21-F013D	ADS VLV 1B21*RV-92D SOV A GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92DY *B21-F013D	ADS VLV 1B21*RV-92D SOV B GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92EX *B21-F013E	ADS VLV 1B21*RV-92E SOV A GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92EY *B21-F013E	ADS VLV 1B21*RV-92E SOV B GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92FX *B21-F013F	ADS VLV 1B21*RV-92F SOV A GENERAL ELECT 310010	1E 003	B-22 RBD	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A

REPORT NO. PES-800

JOB NUMBER 1160002

JOB NAME SHOREHAM - UNIT 1

JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION

PROJECT EQUIPMENT SYSTEM - (IS-129)

ENVIRONMENTAL QUALIFICATION STATUS REPORT

SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 113

RESET NO. 003

RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
.1B21*SOV92FY *B21-F013F	ADS VLV 1B21*RV-92F SOV B GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92GX *B21-F013G	ADS VLV 1B21*RV-92G SOV A GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92GY *B21-F013G	ADS VLV 1B21*RV-92G SOV B GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92HX *B21-F013H	ADS VLV 1B21*RV-92H SOV A GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92HY *B21-F013H	ADS VLV 1B21*RV-92H SOV B GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92JX *B21-F013J	ADS VLV 1B21*RV-92J SOV A GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92JY *B21-F013J	ADS VLV 1B21*RV-92J SOV B GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92KX *B21-F013K	ADS VLV 1B21*RV-92K SOV A GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92KY *B21-F013K	ADS VLV 1B21*RV-92K SOV B GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92LX *B21-F013L	ADS VLV 1B21*RV-92L SOV A GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A
.1B21*SOV92LY *B21-F013L	ADS VLV 1B21*RV-92L SOV B GENERAL ELECT 310010	1E 003	B-22 RBD 00102	TARGET 1/2 SMS-A-01	3904 *RR *SPR	180 DYS	*N/A	ALL A

1E41*TU002 REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 114
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			ENG CND
	PO NUMBER		ELEV		SUBHG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = TERRY

.1E41*TU002	HPCI TURBINE			*TERRY	*3913	*012	*HRS	*N/A	
	*GE-TERRY TURB	*1E	*G-01	*GS-1	*TA				*ALL
	310010	003	RBS	8					*A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 115
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EHG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = VALCOR

.1T48*SOV131	ATMOSPHERE SAMPLE VALCOR 310979-1	1E 15.54	G-02 RBS	00063	VALCOR *V526-5295-59	*15.54-01 *EQ	180 DYS	N/A	ALL A
.1T48*SOV126B	ATMOSPHERE SAMPLE VALCOR 310979-1	1E 15.54	G-02 RBS	00063	VALCOR *V526-5295-61	*15.54-01 *EQ	180 DYS	N/A	ALL A
.1T48*SOV127B	ATMOSPHERE SAMPLE VALCOR 310979	1E 15.54	G-02 RBS	00040	VALCOR V526-5295-61	*15.54-01 *EQ	180 DYS	NA	ALL A
.1T48*SOV128B	ATMOSPHERE SAMPLE VALCOR 310979-1	1E 15.54	G-10 RBS	00078	VALCOR *V526-5295-61	*15.54-01 *EQ	180 DYS	N/A	ALL A
.1T48*SOV129B	ATMOSPHERE SAMPLE VALCOR 310979	1E 15.54	G-02 RBS	00040	VALCOR V526-5295-61	*15.54-01 *EQ	180 DYS	NA	ALL A
.1T48*SOV126A	ATMOSPHERE SAMPLE VALCOR 310979	1E 15.54	G-02 RBS	00063	VALCOR *V526-5295-62	*15.54-01 *EQ	180 DYS	N/A	ALL A
.1T48*SOV127A	ATMOSPHERE SAMPLE VALCOR 310979	1E 15.54	G-02 RBS	00040	VALCOR V526-5295-62	*15.54-01 *EQ	180 DYS	NA	ALL A
.1T48*SOV128A	ATMOSPHERE SAMPLE VALCOR 310979-1	1E 15.54	G-10 RBS	00078	VALCOR *V526-5295-62	*15.54-01 *EQ	180 DYS	N/A	ALL A
.1T48*SOV129A	ATMOSPHERE SAMPLE VALCOR 310979	1E 15.54	G-02 RBS	00040	VALCOR *V526-5295-62	*15.54-01 *EQ	180 DYS	NA	ALL A
.1B21*SOV313A	SAMPLE PP SUPPRESS POOL RETURN VALCOR 310979	1E 15.54	G-09 RBS	00078	VALCOR *V526-5683-26	*15.54-01 *EQ	180 DYS	NA	ALL A
.1B21*SOV314A	SAMPLE PP SUPPRESS POOL RETURN VALCOR 310979	1E 15.54	G-12 RBS	00078	VALCOR *V526-5683-26	*15.54-01 *EQ	180 DYS	NA	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOO / SPEC

REPORT DATE 01/18/82 PAGE 116
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT EMG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
.1E11*SOV166A	LQD SAMPLE RHR VALCOR 310979	1E 15.54	G-01 RBS	00008	VALCOR *V526-5683-27	*15.54-01 *EQ	180 DYS	N/A	ALL A
.1E11*SOV167A	LQD SAMPLE RHR VALCOR 310979	1E 15.54	G-02 RBS	00040	VALCOR *V526-5683-27	*15.54-01 *EQ	180 DYS	N/A	ALL A
.1B21*SOV313B	SAMPLE PP SUPPRESS POOL RETURN VALCOR 310979	1E 15.54	G-09 RBS	00076	VALCOR *V526-5683-28	*15.54-01 *EQ	180 DYS	NA	ALL A
.1B21*SOV314B	SAMPLE PP SUPPRESS POOL RETURN VALCOR 310979	1E 15.54	G-12 RBS	00078	VALCOR *V526-5683-28	*15.54-01 *EQ	180 DYS	NA	ALL A
.1E11*SOV168	SAMPLE PP SUPPRESS POOL RETURN VALCOR 310979	1E 15.54	G-01 RBS	00008	VALCOR *V526-5683-29	*15.54-01 *EQ	180 DYS	N/A	ALL A
.1E11*SOV169	SAMPLE PP SUPPRESS POOL RETURN VALCOR 310979	1E 15.54	G-01 RBS	00008	VALCOR V526-5683-29	*15.54-01 *EQ	180 DYS	N/A	ALL A
.1E11*SOV166B	LQD SAMPLE RHR VALCOR 310979	1E 15.54	G-02 RBS	00040	VALCOR *V526-5683-30	*15.54-01 *EQ	180 DYS	N/A	ALL A
.1E11*SOV167B	LQD SAMPLE RHR VALCOR 310979	1E 15.54	G-02 RBS	00040	VALCOR *V526-5683-30	*15.54-01 *EQ	180 DYS	N/A	ALL A

1T46*FN837A

REPORT NO. PES-800 JOB 1140002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
 JOB NUMBER 1140002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 117
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	QAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG ELEV	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER				SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

REPORT GROUP MAK = WESTINGHOUSE

.1T46*FN837A	1T46*UC-020A FAN BUFFALO FORGE 310556	1E 276	J-16 RBS	00112	WESTINGHOUSE 143T	*DR	180 DYS *N/A	ALL A
.1T46*FN837B	1T46*UC-020B FAN BUFFALO FORGE 310556	1E 276	K-15 RBS	00112	WESTINGHOUSE 143T	*DR	180 DYS *N/A	ALL A
	REQUIRED PAD LEVEL REDUCED TO 6.0E07, PER CALCS SNPS-1-UR-17-B REV 2, AND SNPS-1-UR-18-A REV 1.							
.1T46*FN023	1T46*UC-023 FAN BUFFALO FORGE 310556	1E 276	L-02 RBS	00040	WESTINGHOUSE 143TCZ	*276-01 *EQ	180 DYS *N/A	*L A
.1E21*P049A	CORE SPRAY LEV PP C-10 GOULD PUMP 310545	1E 235	G-01 RBS	8	WESTINGHOUSE 213T	*DR	180 DYS	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1E21*P049B	CORE SPRAY LEV PP-C-6 GOULD PUMP 310545	1E 235	G-01 RBS	8	WESTINGHOUSE 213T	*DR	180 DYS	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1E41*P050	HPCI LOOP LVL PUMP GOULD PUMP 310545	1E 235	G-01 RBS	00008	WESTINGHOUSE 213T	*DR	001 DYS	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1E51*P051	RCIC LOOP LEVEL PUMP GOULD PUMP 310545	1E 235	G-01 RBS	8	WESTINGHOUSE 213T	*DR *	001 DYS	*L A
	L-OP CODE B REM: H,M-OP CODE B 1 DAY, C REM. (MCC REV.)							
.1T46*FN838A	1T46*UC-021A FAN BUFFALO FORGE 310556	1E 276	H-19 RBS	00150	WESTINGHOUSE 213T	*DR	180 DYS	ALL A
.1T46*FN838B	1T46*UC-021B FAN BUFFALO FORGE 310556	1E 276	H-19 RBS	00150	WESTINGHOUSE 213T	*DR	180 DYS	ALL A
.1T46*FN839A	1T46*UC-022A FAN BUFFALO FORGE	1E	H-19		WESTINGHOUSE 213T	*DR	180 DYS	ALL

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 118
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG ELEV	MAKE / MANUFACTURE'R MODEL / CATALOG N°	EQ SHEET QUAL STAT SUBMG	OP TIME	ACC / PERF	NU-CAT ENH CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****
	310556	276	RBS 00161					A
.1T46*FN839B	1T46*UC-022B FAN BUFFALO FORGE 310556	1E 276	H-19 RBS 00161	WESTINGHOUSE 213T	*DR	180 DYS		ALL A
.1611*P270C	*SUPP PL PP BK LEAKAGE RET POOL BUFFALO FORGE CO. 348187 OP CODE B FOR HELB & HELB	1E 457	G-01 RBS 00008	WESTINGHOUSE 286T 25HP	*DR	180 DYS		L A
.1T46*FN835A	1T46*UC-004A FAN BUFFALO FORGE 310556	1E 276	H-20 RBS 00219	WESTINGHOUSE 326T	*DR	180 DYS	*N/A	ALL A
.1T46*FN835B	1T46*UC-004B FAN BUFFALO FORGE 310556	1E 276	H-20 RBS 00219	WESTINGHOUSE 326T	*DR	180 DYS	*N/A	ALL A
.1T46*FN836A	1T46*UC-005A FAN BUFFALO FORGE 310556	1E 276	H-20 RBS 00219	WESTINGHOUSE 326T	*DR	180 DYS	*N/A	ALL A
.1T46*FN836B	1T46*UC-005B FAN BUFFALO FORGE 310556	1E 276	H-20 RBS 00219	WESTINGHOUSE 326T	*DR	180 DYS	*N/A	ALL A
.1T46*FN833A	1T46*UC-002A FAN BUFFALO FORGE 310556	1E 276	G-01 RBS 00008	WESTINGHOUSE 364T	*DR	180 DYS	*N/A	ALL A
.1T46*FN833B	1T46*UC-002B FAN BUFFALO FORGE 310556	1E 276	G-01 RBS 00008	WESTINGHOUSE 364T	*DR	180 DYS	*N/A	ALL A
.1T46*FN834A	1T46*UC-003A FAN BUFFALO FORGE 310556	1E 276	G-01 RBS 00008	WESTINGHOUSE 364T	*DR	180 DYS	*N/A	ALL A
.1T46*FN834B	1T46*UC-003B FAN BUFFALO FORGE 310556	1E 276	G-01 RBS 00008	WESTINGHOUSE 364T	*DR	180 DYS	*N/A	ALL A
.1T46*FN003B	RBSVS EXH FAN BUFFALO FORGE 310550	1E 270	K-15 RBS 112	WESTINGHOUSE 405TCZ	*DR	180 DYS	*N/A	ALL A

REPORT NO. PES-800
 JOB NUMBER 1160002
 JOB NAME SHOREHAM - UNIT 1
 JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
 PROJECT EQUIPMENT SYSTEM - (IS-129)
 ENVIRONMENTAL QUALIFICATION STATUS REPORT
 SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 119
 RESET NO. 003
 RESET DATE 07/01/81

EQUIPMENT ID VENDOR ID	EQUIPMENT DESCRIPTION VENDOR NAME PO NUMBER	QAC SPEC	ZONE BLDG	ELEV	MAKE / MANUFACTURER MODEL / CATALOG NO	EQ SHEET QUAL STAT SUBHG	OP TIME	ACC / PERF	NU-CAT ENG CND OP CD
*****	*****	*****	*****	*****	*****	*****	*****	*****	****
.1T46*FN003C	RBSVS EXH FAN BUFFALO FORGE 310550	1E 270	K-15 RBS	112	WESTINGHOUSE 405TCZ	*DR	180 DYS	*N/A	ALL A
.1T46*FN003A	RBSVS EXH FAN BUFFALO FORGE 310550	1E 270	K-15 RBS	112	WESTINGHOUSE 405TOZ	*DR	180 DYS	*N/A	ALL A
.1T46*FN079A	*RB EXHAUST BOOSTER FAN BUFFALO FORGE 310516	*1E 102	K-15 RBS	112	WESTINGHOUSE 7.5 HP 245T	*DR	180 DYS		ALL A
.1T46*FN079B	*RB EXHAUST BOOSTER FAN BUFFALO FORGE 310516	*1E 102	K-15 RBS	112	WESTINGHOUSE 7.5 HP 245T	*DR	180 DYS		ALL A

REPORT NO. PES-800 JOB 1160002 01/18/82

ENVIRONMENTAL QUALIFICATION STATUS REPORT

REPORT NO. PES-800
JOB NUMBER 1160002
JOB NAME SHOREHAM - UNIT 1
JOB CLIENT LILCO

STONE AND WEBSTER ENGINEERING CORPORATION
PROJECT EQUIPMENT SYSTEM - (IS-129)
ENVIRONMENTAL QUALIFICATION STATUS REPORT
SORTED BY - MAK / MOD / SPEC

REPORT DATE 01/18/82 PAGE 120
RESET NO. 003
RESET DATE 07/01/81

EQUIPMENT ID	EQUIPMENT DESCRIPTION	GAC	ZONE	MAKE / MANUFACTURER	EQ SHEET	OP TIME	ACC / PERF	NU-CAT
VENDOR ID	VENDOR NAME	SPEC	BLDG	MODEL / CATALOG NO	QUAL STAT			EMG CND
	PO NUMBER		ELEV		SUBMG			OP CD
*****	*****	*****	*****	*****	*****	*****	*****	****

***** TOTAL EQUIPMENT ON THIS REPORT - 958

MISCELLANEOUS COMPONENTS AND ACCESSORIES
ENVIRONMENTAL QUALIFICATION STATUS REPORT

<u>Equipment ID</u> <u>Vendor ID</u>	<u>Equipment Description</u> <u>Vendor Name</u> <u>PO Number</u>	<u>QAC</u> <u>Spec</u>	<u>Zone</u> <u>Bldg Elev</u>	<u>Make/Manufacturer</u> <u>Model/Catalog No.</u>	<u>Eq Sheet</u> <u>Qual Stat</u>	<u>Op Time</u>	<u>Acc/Peri</u>	<u>EMG Cnd</u> <u>Op CD</u>
Report Group Spec = 159								
NA	Switchboard Wire Various Various	1E 159	All RBP	GE SI57279	QS-159-03 EQ	180 Days	N/A	All B
NA	Switchboard Wire Various Various	1E 159	All RBP	Rockbestos A830__6	QS-159-04 EQ	180 Days	N/A	All B
NA	Tape Various Various	1E 159	All RBS	Kerite S-5MT-NUC	DR	180 Days	N/A	All B
NA	Tape Various Various	1E 159	All RBP	Okonite T35,T95	QS-159-01 IJ	180 Days	N/A	All B
NA	Insulating Material Various Various	1E 159	All RBP	Raychem WCSP-N	QS-159-05 EQ	180 Days	N/A	All B
NA	Lugs & Splices Various Various	1E 159	All RBP	Amp 52900-53900	QS-159-02 EQ, IJ	180 Days	N/A	All B
NA	Flex Conduit Electro-Flex Various	1E 159	All RBS	Electro-Flex CEA Sealtite	IJ	180 Days	N/A	All B
NA	Terminal Blocks Various Various	1E 159	All RBS	GE EB25A04W,-12W	IJ	180 Days	N/A	All B
NA	Terminal Blocks Various Various	1E 159	All RBS	GE EBI	IJ	180 Days	N/A	All B
NA	Terminal Blocks Various Various	1E 159	All RBS	GE CR151A8,-B2,-B4	IJ	180 Days	N/A	All B

<u>Equipment ID</u> <u>Vendor ID</u>	<u>Equipment Description</u> <u>Vendor Name</u> <u>PC Number</u>	<u>QAC</u> <u>Spec</u>	<u>Zone</u> <u>Bldg Elev</u>	<u>Make/Manufacturer</u> <u>Model/Catalog No.</u>	<u>Eq Sheet</u> <u>Qual Stat</u>	<u>Op Time</u>	<u>Acc/Peri</u>	<u>EMG Cnd</u> <u>Op CD</u>
Report Group Spec = 159								
NA	Chico Compounds Various Various	1E 159	All RBS	Crouse-Hinds Chico (X), (A) Compounds	IJ	180 Days	N/A	All B
NA	Selector Switch Various Various	1E 159	All RBS	GE CR2940	IJ	180 Days	N/A	All B
NA	Conduit Coupling Service-Air Various	1E 159	All RBP	Service-Air, Amer. Boa SS Fittings	DR	180 Days	N/A	All B

APPENDIX G

EQUIPMENT WITH INCOMPLETE QUALIFICATION DOCUMENTATION

APPENDIX G

EQUIPMENT WITH INCOMPLETE QUALIFICATION DOCUMENTATION

This Appendix contains summary sheets for equipment exhibiting incomplete qualification documentation at the date of this submittal. These sheets are arranged in alphabetical order by equipment manufacturer, equipment model number, and specification number as shown on the index.

Each summary sheet includes a description of the qualification documentation, the resolution program, and the justification for interim operation. Alternatives provided include the following:

Resolution Program Alternatives

1. Continue current evaluation
 - a. Work with the vendor
 - b. Request further analysis and/or data search from engineering laboratories or consultants
2. Test specimens representative of existing (installed) equipment
 - a. Join other utility programs
 - b. Investigate purchase of identical equipment and test
 - c. Dismount samples or test spares
3. Provide protection or modify environment
 - a. Refine service conditions and/or relax operational requirements
 - b. Provide shielding
 - c. Provide shielding and HVAC
 - d. Relocate
4. Replace installed equipment or components with equipment having known qualification documentation

INDEX

EQUIPMENT WITH INCOMPLETE DOCUMENTATION
 PRIOR TO FUEL LOAD
PROJECTION AS OF JANUARY 15, 1982

<u>Manufacturer</u>	<u>Model</u>	<u>Vendor and Spec.</u>	<u>EQSS No.</u>
Air Monitor	Veltron 800, Flow Transmitter	Powers Regul. (SH1-319)	319-01
AMP	52978 through 52980 splices	N/A (SH1-159)	159-02
Automatic Switch ASCO	HTX-8320A20	GE-NED (SH1-003)	3096
Barksdale	B1T D2H P1H	GE-NED (SH1-003)	3018 3021 3025
Beck	14-101-023645 operator	Fisher Control (SH1-310)	_____
Crouse-Hinds	Chico Compounds	N/A (SH1-159)	_____
Dwyer	1627 PDS	Powers Regul. (SH1-319)	319-01
Electro-Flex	Cea Sealtite	N/A (SH1-159)	_____
Farr	N-240 Charcoal filter train	Farr (SH1-105)	_____
Fenwal	17002-40	GE-NED (SH1-003)	_____
Gems	XM-54854 Level Element	Delaval (SH1-473)	_____
General Electric	2CH6-041-1U 47D5 18673	GE (SH1-003)	3903 3902
General Electric	DC MCC's 7700 Line	GE (SH1-168)	_____
General Electric	Series 100 Penetrations	GE (SH1-134)	134-02
General Electric	Series 200 Penetrations	GE (SH1-134)	174-01

<u>Manufacturer</u>	<u>Model</u>	<u>Vendor and Spec.</u>	<u>EQSS No.</u>
General Electric	CR2940 series Switches	N/A (SH1-159)	_____
General Electric	EB25, EB1, CR151 terminal blocks	N/A (SH1-159)	_____
ITT Barton	288A/289A	GE-NED (SH1-003)	3027
ITT General Controls	NH-91 MOD	Powers Regul. (SH1-319)	319-01
Limitorque	SMB-2 SMB-3	GE-NED (SH1-003)	_____
Magnetrol	291-MPG-X-M14DC Level Switch	Magnetrol (SH1-407)	407-01
Magnetrol	3.5-751X MPG-MI4HY	GE-NED (SH1-003)	3143
Okonite	T35, T95 Tape	N/A (SH1-159)	159-01
Pyco/ California	145C3224	GE-NED (SH1-003)	3110
Raychem	WCSF-N	Raychem (SH1-159)	159-05
Raymond	MASR-49 MOD MASR-9 MOD	Powers Regul. (SH1-319)	319-01
Rosemount	1151 Transmitter	GE-NED (SH1-003)	3048
Square D	Model 4MCC Breaker Panel	Square D (SH1-115)	_____
Static-O-Ring	5N, 6N Series	GE-NED (SH1-003)	3032
Terry Turbine	CCS	GE-NED (SH1-003)	3050
Yarway	4418C	GE-NED (SH1-003)	3037

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: FLOW TRANSMITTER

MANUFACTURER/MODEL: Air Monitor/Veltron 800

EQUIPMENT SPECIFICATION(S): SH1-319

EQSS REFERENCE(S): 319-01

QUALIFICATION SUMMARY:

The flow transmitter was environmentally tested and functioned properly during and after the thermal, cycle, radiation, and seismic tests. However, during the final simulated LOCA test, the flow transmitter output was constant (20 MA dc) when power was applied and pressure differential varied. When the device was removed from the test chamber, three wires connecting the circuit board to the differential pressure sensor were missing insulation at one point and their remaining insulation was brittle. The device was repaired but not functionally retested.

RESOLUTION PROGRAM:

1. Replace wires on the two flow transmitters (1T46*FT004A&B). They are located in the secondary containment. Manufacturer is currently being requested to either provide qualified replacement wire or required characteristics of the wire for procurement and replacement.
2. Retest flow transmitter for applicable service conditions. Vendor has provided a proposal for retesting of this device. Completion of qualification testing is expected by September 1982, or soon thereafter.

JUSTIFICATION FOR INTERIM OPERATION:

1. The device was previously tested to an environment more severe than is required for qualification: (required service condition: 5.1×10^4 rads gamma, 136°F max. temperature; previous test: 1×10^7 rads gamma, 200°F max. temperature) although temperature durations were not in accordance with Shoreham requirements.
2. The only failure noted during the test was in the wire insulation. Retesting the device to less severe conditions with the wire replaced (with a qualified type) is being undertaken with a high confidence level.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: CONDUCTOR SEALED SPLICES
MANUFACTURER/MODEL: AMP/52978 through 52980
EQUIPMENT SPECIFICATION(S): SH1-159
EQSS REFERENCE(S): 159-02

QUALIFICATION SUMMARY:

1. The AMP conductor sealed splices are not known to have been environmentally tested. However, the insulating materials on the sealed splices (polyvinylidene fluoride) are the same as those used on the AMP terminals which have been tested to primary containment type service conditions.
2. The manufacturer is currently testing these splices, and a test report is expected to be available in mid-March 1982.

RESOLUTION PROGRAM:

The conductor sealed splices are expected to be qualification tested in the Shoreham miscellaneous component test program, to be completed by September 1982 or soon thereafter, if the new test being performed by the manufacturer is found to be deficient.

JUSTIFICATION FOR INTERIM OPERATION:

The insulating materials used in the AMP terminal EQ test have been exposed to a LOCA profile which envelops all Shoreham secondary containment postulated design basis accident conditions. The primary containment postulated service conditions are very close to the AMP terminal LOCA test and provide evidence that the insulating materials used in the sealed splices will not fail during a postulated accident.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Solenoid Valve
Manufacturer/Model: ASCO/HTX-8320A20
Equipment Specification: SH1-003
EQSS References: 3096

1. DESCRIPTION

The devices under evaluation are ASCO solenoid valves, Model HT-X-8320-A20.

2. CONCLUSION

These solenoid valves have been qualified by test for the postulated accident temperature, pressure and humidity conditions only. Therefore, they do not fully meet the requirements of NUREG-0588, Category II. However, use of this equipment for interim operation can be justified.

3. LIMITATIONS

1. Materials analysis (EDS Calculation No. 0630-001-025, Rev. 0) indicates that this device has a qualified life of 40 years.
2. The inboard MSIV solenoid valves should be replaced within 2 years of plant startup in order that they will not surpass their radiation tolerance (see Section 4.4 below). This data will be input into the plant preventive maintenance program to ensure timely replacement.

4. JUSTIFICATION FOR INTERIM OPERATION

1. These solenoid valves are required to function to operate the MSIV's. The MSIV's complete their safety function within a very short period of time subsequent to accident initiation (FSAR 5.5.5.3). In this short time, these solenoid valves will not be exposed to the full accident environment, and therefore, are not required to survive such.
2. Failure of this equipment will not prevent it from performing its safety function. These valves are normally energized (FSAR Figure 7.3.1-15) in order to maintain the MSIV's in an open position. On receipt of an accident signal, the MSIV's are closed by deenergizing their associated solenoid valves. According to Westinghouse Report No. NS-CE-755, which is a failure mode and effects study on solenoid valves designed to operate in the above manner, there is no failure which could prevent these valves from performing their required safety function.

3. The outboard MSIV solenoid valves are required to withstand an accident radiation dose of 1×10^5 rads. Materials analysis (EDS Calculation No. 0630-001-025, Rev. 0) indicates that the limiting material contained in this device is a polyamide, with a radiation tolerance of 6×10^6 rads. Therefore, these solenoid valves are expected to perform their safety function as required.
4. The inboard MSIV solenoid valves are required to withstand a 40 year plus accident integration radiation dose of 2.8×10^7 rads. This accident dose is based on a required operating time plus margin of 70 minutes. Because the MSIV's complete their safety function in a very short period of time, reduction of this operating time requirement to 30 minutes will not adversely affect plant safety. The 2 year normal radiation plus 30 minute accident integrated radiation dose is 5.4×10^6 rads. Materials analysis (EDS Calculation No. 0630-001-025, Rev. 0) indicates that the limiting material contained in this device is a polyamide, with a radiation tolerance of 6×10^6 rads. Therefore, these devices are expected to perform their safety function as required.
5. This device is contained within a NEMA 4, 7 and 9 watertight and explosion proof enclosure (ASCO Drawing No. HV-166-592, Rev. 0) and, therefore, will not be affected by containment spray.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Pressure Switch
Manufacturer/Model: Barksdale/BLT
Equipment Specification: SH1-003
EQSS References: 3013

1. DESCRIPTION

The devices under evaluation are Barksdale BLT-M12SS Pressure Switches. Barksdale catalogs indicate that the basic model number is BLT, with any additional suffixes denoting features such as switch rating which do not affect environmental qualification considerations.

2. CONCLUSION

These devices have been qualified by test for the postulated accident temperature and humidity conditions only. Therefore, they do not fully meet the requirements of NUREG-0588, Category II. However, use of this equipment for interim operation can be justified.

3. LIMITATIONS

Materials analysis (EDS Calculation No. 0630-001-013, Rev. 0) indicates that the limiting part in this device, with respect to thermal aging, is the neoprene face gasket with a qualified life of 6 years. All other components are qualified for the 40 year life of the plant. This data will be input into the plant preventive maintenance program to ensure that this device does not exceed its qualified life.

4. JUSTIFICATION FOR INTERIM OPERATION

1. The postulated accident pressure environment is higher than the pressure for which this device has been tested by a margin of less than 1 psi. A 1 psi differential is not expected to affect this device's function. Therefore, this device is expected to perform its safety function as required.
2. This device is required to withstand an accident dose of 9×10^5 rads but has not been subjected to radiation testing. However, materials analysis (EDS Calculation No. 0630-001-013) indicates that the limiting material in this device is BUNA-N, having a radiation tolerance of 3×10^6 rads. Therefore, this device is expected to perform its safety function as required.

3. Extrapolation of the test data indicates that this device is capable of withstanding the postulated HELB temperature conditions for at least 33.6 hours (EDS Calculation No. 0630-001-018, Rev. 0). After this time, it will be exposed to only normal ambient temperature conditions. In addition, this device will be accessible for repair after an HELB and will not see a harsh environment, other than the radiation addressed, above after a LOCA. Therefore, this device is expected to remain operational for the required time of 1 day and not fail in a manner detrimental to plant safety for the duration of the accident (180 days).

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Pressure Switch
Manufacturer/Model: Barksdale/D2H
Equipment Specification: SH1-003
EQSS References: 3021

1. DESCRIPTION

The devices under evaluation are Barksdale Pressure Switches, Models D2H-M150SS, D2H-M18SS, D2H-M80SS. Examination of Barksdale technical manuals indicates that they are generic to each other and to the model D1T-M18SS tested because the differing digits in the model numbers denote features which would not affect environmental qualification, specifically, the number of settings, the class of switching element, and the setting range. In addition, all models have identical weathersealed housings.

2. CONCLUSION

These devices have been qualified by test for the postulated accident temperature and humidity conditions only. Therefore, they do not fully meet the requirements of NUREG-0588, Category II. However, use of this equipment for interim operation can be justified.

3. LIMITATIONS

1. The switch housing must be vented in order to alleviate a problem found during testing.
2. Materials analysis (EDS Calculation No. 0630-001-013 Rev. 0) indicates that the limiting part in this device, with respect to thermal aging, is the neoprene face gasket with a qualified life of 6 years. All other components are qualified for the 40 year life of the plant. This data will be input into the plant preventive maintenance program to ensure that this device does not exceed its qualified life.

4. JUSTIFICATION FOR INTERIM OPERATION

1. The postulated accident pressure environment is higher than the pressure for which this device has been tested by a margin of less than 1 psi. A 1 psi differential is not expected to affect this device's function. Therefore, this device is expected to perform its safety function as required.
2. This device is required to withstand an accident radiation dose of 9×10^5 rads but has not been subjected to radiation testing. However, materials analysis (EDS Calculation No. 0630-001-013, Rev. 0) indicates that the limiting material in this device is made of BUNA-N, having a radiation tolerance of 3×10^6 rads. Therefore, this device is expected to perform its safety function as required.
3. Extrapolation of the test data indicates that this device is capable of withstanding the postulated HELB temperature conditions for at least 48.6 hours (EDS Calculation No. 0630-001-014, Rev. 0). After this time, it will be exposed to only normal ambient temperature conditions. In addition, this device will be accessible for repair after an HELB and will not see a harsh environment, other than radiation addressed above, after a LOCA. Therefore, this device is expected to remain operational for the required time of 1 day and not fail in a manner detrimental to plant safety for the duration of the accident (180 days).

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Pressure Switch
Manufacturer/Model: Barksdale/PlH
Equipment Specification: SH1-003
EQSS References: 3025

1. DESCRIPTION

The devices under evaluation are Barksdale Pressure Switches, Model No. PlH-M34SS. According to Barksdale technical manuals, the basic model is the PlH, with all suffixes denoting options which have no effect on environmental qualification, such as switch electrical ratings. Therefore, qualification information for any PlH model is applicable to all.

2. CONCLUSION

These devices have been qualified by test for the postulated accident temperature and humidity conditions only. Therefore, they do not fully meet the requirements of NUREG-0588, Category II. However, use of this equipment for interim operation can be justified.

3. LIMITATIONS

Materials analysis (EDS Calculation No. 0630-001-023, Rev. 0) indicates that the limiting part in this device is the neoprene face gasket with a qualified life of 6 years. All other components are qualified for the 40 year life of the plant. This data will be input into the plant preventive maintenance program to ensure this device does not exceed its qualified life.

4. JUSTIFICATION FOR INTERIM OPERATION

1. The postulated accident pressure environment is higher than the pressure for which this device has been tested by a margin of less than 1 psi. A 1 psi differential is not expected to affect this device's function. Therefore, this device is expected to perform its safety function as required.
2. This device is required to withstand an accident dose of 1.7×10^6 rads but has not been subjected to radiation testing. However, materials analysis (EDS Calculation No. 0630-001-022, Rev. 0) indicates that the limiting material in this device is fish paper, having a radiation tolerance of 5×10^6 rads. Therefore, this device is expected to perform its safety function as required.

3. Extrapolation of the test data indicates that this device can withstand the postulated HELB temperature conditions for at least 33 hours (EDS Calculation No. 0630-001-023, Rev. 0). After this time, it will be exposed to only normal ambient temperature conditions. In addition, this device will be accessible for repair after an HELB and will not see a harsh environment, other than the radiation addressed above, after a LOCA. Therefore, this device is expected to remain operational for the required time of 7 days and not fail in a manner detrimental to plant safety for the duration of the accident (180 days).

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: ELECTRIC MOTOR OPERATED VALVE ACTUATOR

MANUFACTURER/MODEL: Beck 14-101-023645 (ES)

EQUIPMENT SPECIFICATION(S): SH1-310

EQSS REFERENCE(S): 310-01

QUALIFICATION SUMMARY:

A formal EQ test program was not completed; however, some testing was performed.

1. The test program did not include thermal aging or DBA testing; however, a thermal aging analysis was performed by the Wyle Laboratories
2. The motor capacitor failed a high potential test following the radiation test.
3. The radiation testing exceeded Shoreham's requirements for all components except the ESR board (electronic control board) which demonstrated operability after 1×10^7 RADS. This exceeds the requirements for all applicable Shoreham radiation zones except Zone K which required 1.27×10^8 RADS over 180 days.

RESOLUTION PROGRAM:

1. Replace the existing motor capacitors with ones more suited to the environment.
2. Test the valve actuator according to IEEE 382-194, IEEE 323-1974 and NUREG 0588 category 1 positions.

JUSTIFICATION FOR INTERIM OPERATION:

1. Existing motor capacitors are expected to be replaced.
2. Analysis to reduce the radiation dose requirement for the ESR boards in Zone K to less than 1×10^7 will be performed or the ESR boards will be shielded or relocated.
3. The peak accident temperature for which each actuator must be qualified is 178°F . The manufacturer's rating for the actuator is -40°F to 185°F at 99% relative humidity, which exceeds the accident temperature requirement. Additionally, the Wyle Laboratories thermal aging analysis on the component materials (except the ESR board) yields an expected life of greater than 120 years at 185°F . The ESR board is an electronic control board and, according to IEEE 650-1979, can be exempted from thermal aging provided it is subjected to a burn-in period to eliminate infant mortality.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: CHICO "A" and "X" SEALING COMPOUNDS

MANUFACTURER/MODEL: Crouse-Hinds

EQUIPMENT SPECIFICATION(S): SHI-159

EQSS REFERENCE(S): NONE

QUALIFICATION SUMMARY:

These sealing compounds are inert and not affected by gamma radiation at the 10^8 level. Aging is not a critical factor because the compounds are under a sealed conduit assembly. However, no qualification documentation has been found.

RESOLUTION PROGRAM:

The compounds are expected to be qualification tested in a Crouse-Hinds type EYS fitting in the Shoreham miscellaneous component test program by September 1982 or soon thereafter.

JUSTIFICATION FOR INTERIM OPERATION:

1. The sealing compounds are ceramic and, as determined by analysis, are not affected by the radiation levels applicable to Shoreham.
2. Additional material analysis will be performed by the testing laboratory prior to performing the qualification testing.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: DIFFERENTIAL PRESSURE SWITCH

MANUFACTURER/MODEL: Dwyer/1627

EQUIPMENT SPECIFICATION(S): SH1-319

EQSS REFERENCE(S): 319-01

QUALIFICATION SUMMARY:

The differential pressure switch was subjected to environmental qualification testing at a higher temperature than required for qualification. Thus, during final functional testing, the differential between the switch turn-on pressure (increasing) and turn-off (decreasing) exceeded the allowable limit. The differential was 0.4" H₂O while the allowable range is 0.07" to 0.27" H₂O.

RESOLUTION PROGRAM:

Retest the pressure switches to the applicable service conditions. The vendor has provided a proposal for retesting of this device. Qualification testing is expected to be completed by September 1982, or soon thereafter.

JUSTIFICATION FOR INTERIM OPERATION:

1. In the previous qualification test, the device was subjected to a 200°F environment which is more severe than is required for qualification (required maximum temperature: 158°F). Thus, retesting to a milder temperature requirement is being undertaken with a high level of confidence.
2. Should the switches exceed the allowable limit as in the final functional test, the following would occur: Since the pressure switch is required to start the spare RBSVS exhaust fan automatically if the running fan stops, the spare fan will start with the exceeded differential. The slight time delay (0.27" H₂O vs. 0.40" H₂O differential pressure) is considered insignificant, since the running fan differential pressure decreases very quickly.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: FLEXIBLE CONDUIT

MANUFACTURER/MODEL: Electro-Flex/CEA Sealtite

EQUIPMENT SPECIFICATION(S): SH1-159

EQSS REFERENCE(S): None

QUALIFICATION SUMMARY:

No qualification documentation has been found, despite inquiries to the conduit and jacket materials manufacturers and independent testing laboratories.

RESOLUTION PROGRAM

The flexible conduit is expected to be qualification tested in the Shoreham miscellaneous component test program to be completed by September 1982, or soon thereafter.

JUSTIFICATION FOR INTERIM OPERATION:

This flexible conduit is connected to the termination boxes of motors, instruments, etc., and is not used in the primary containment. Therefore, it must be qualified only for secondary containment service conditions. Zone 13 is the most severe accident temperature zone (218°F decreasing to 108°F after 11 hours), and Zone K is the most severe radiation zone (1.27x10⁸ rads gamma after 180 days). This conduit is considered as having a very high likelihood of passing the proposed qualification test due to the following:

1. During the initial period of the postulated accident when the conduit is exposed to a higher temperature and 100% steam environment, the radiation dose will not exceed 5.4x10⁵ rads gamma, which is within the radiation threshold (10⁵ to 10⁶ rads gamma) for polyurethane compounds (flexible conduit jacket material). When the total accident radiation dose is reached (180 days), the ambient conditions have returned to 104°F and 95% humidity. Thus, failure due to radiation should not occur during a harsh environment.
2. The conduit itself is composed of a tightly woven steel core which would limit the seepage of the steam environment into the cable terminations should the jacket of the conduit split or deteriorate during the postulated 100% humidity environment.
3. Cable, splices, switchboard wire, tape, and terminating devices are individually qualified.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: CHARCOAL FILTER TRAIN

MANUFACTURER/MODEL: Farr/N-240

EQUIPMENT SPECIFICATION(S): SH1-105

EQSS REFERENCE(S): None

QUALIFICATION SUMMARY:

The charcoal filter trains are composed of many devices integral to their operation. These devices can be grouped as follows:

- a. Devices with qualification data.
- b. Devices with limited or no qualification data available.
- c. Devices with data which demonstrate qualification may be in doubt, which are planned to be replaced.

RESOLUTION PROGRAM:

Qualification for the entire charcoal filter train will be provided under a proposal by ANCO Engineers, a subvendor to the manufacturer, with final qualification documentation expected to be available by September 1982, or soon thereafter.

JUSTIFICATION FOR INTERIM OPERATION:

Devices in groups b and c above, will be evaluated by ANCO to determine the effect that a failure of these components would have on safe operation and availability of the charcoal filter trains. In addition, qualified replacement devices will be identified. Replacement will be procured and installed, if failure of a specific device is determined to be detrimental to the performance of the filter train's safety function. This evaluation study is expected to be available by June 1982.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Temperature Switches
Manufacturer/Model: Fenwal 17002-40
Equipment Specification: SH1-003
EQSS References: 3040

1. DESCRIPTION

The devices under evaluation are Fenwal 17002-40 Temperature Switches.

2. CONCLUSION

These devices have been qualified by test for the postulated accident temperature and humidity conditions only. Testing also included exposure to a radiation environment. Therefore, they do not fully meet the requirements of NUREG-0588, Category II. However, use of this equipment for interim operation can be justified.

3. LIMITATIONS

Materials analysis (EDS Calculation No. 0630-001-024, Rev. 0) indicates that this device has a qualified life of at least 40 years.

4. JUSTIFICATION FOR INTERIM OPERATION

1. The postulated accident pressure environment is higher than the pressure for which this device has been tested by a margin of less than 8 psig. Since it will be exposed to this higher pressure for only approximately 4 seconds and is hermetically sealed, this pressure spike should not affect the device's function. Therefore, this device is expected to perform its safety function as required.
2. This device is required to withstand an accident dose of 5×10^5 rads, but has only been tested to 1.7×10^5 rads. Materials analysis (EDS Calculation No. 0630-001-024, Rev. 0) indicates that the limiting material is TAGT wire insulation containing teflon with a radiation tolerance of 2×10^4 rads. Since this type of insulation is also made up of asbestos and fiberglass braid (radiation tolerance of greater than 5×10^5 rads), it should retain its insulating capability despite possible failure of the teflon. All other materials have a radiation tolerance of greater than 5×10^5 rads. Therefore, this device is expected to perform its safety function as required.

3. The required operability time for these devices is currently under evaluation.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: LEVEL ELEMENTS

MANUFACTURER/MODEL: Gems XM-54854

EQUIPMENT SPECIFICATION(S): SH1-473

EQSS REFERENCE(S): NONE

QUALIFICATION SUMMARY:

No qualification documentation has been found to date.

RESOLUTION PROGRAM:

A Vendor test program to qualify the referenced Gems level elements to IEEE 323-1974 is in progress and scheduled for completion by August 1982. Testing is being performed according to Wyle laboratories Final Qualification Plan 45102-1. Review of the test plan indicated that the qualification will encompass Shoreham's service conditions and comply with IEEE 323-1974 and category I positions of NUREG 0588.

JUSTIFICATION FOR INTERIM OPERATION:

The vendor will submit an interim qualification report for the level elements by May 30, 1982. The interim report will include a summary of the results of the following tests, including functional testing after each step.

1. Radiation
2. Aging (Cycle, thermal, pressure)
3. Seismic
4. 30 day LOCA simulation

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Blower
Manufacturer/Model: General Electric Blower/2CH6-041-1U
Equipment Specification: SH1-003
EQSS References: 3903

1. DESCRIPTION

The device under evaluation is a General Electric Blower, Model 2CH6-041-1U.

2. CONCLUSION

This device has been qualified by test for all postulated plant accident conditions for which this equipment is required to operate (LOCA) except radiation. Therefore, this device is not fully qualified to the requirements of NUREG-0588, Category II. However, use of this device for interim operation can be justified.

3. LIMITATIONS

Analysis of the materials of construction (EDS Calculation No. 0630-001-026, Rev. 0) indicates the limiting material to be the neoprene wire insulation, with a qualified life of 6 years. All other materials are qualified for the 40 year life of the plant.

4. JUSTIFICATION FOR INTERIM OPERATION

This device is required to withstand an accident radiation dose of 4.14×10^6 rads but has not been subjected to radiation testing. However, materials analysis (EDS Calculation No. 0630-001-026, Rev. 0) indicates the limiting material in this device is polypropylene, with a radiation tolerance of 1×10^7 rads. Therefore, this device is expected to perform its safety function as required.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Electric Heater
Manufacturer/Model: General Electric/47D518673
Equipment Specification: SH1-003
EQSS References: 3902

1. DESCRIPTION

The device under evaluation is a General Electric Electric Heater, Model No. 47D518673.

2. CONCLUSION

This device has been qualified by test for the plant temperature, pressure, and humidity conditions only. Therefore, it does not fully meet the requirements of NUREG 0588, Category II. However, use of this device for interim operator can be justified.

3. LIMITATIONS

Materials analysis (EDS Calc. No. 0630-001-028, Rev. 0) indicates that this device has a qualified life of at least 40 years.

4. JUSTIFICATION FOR INTERIM OPERATION

This device is required to withstand an accident radiation dose of 3×10^6 rads but has not been subjected to radiation testing. However, materials analysis (EDS Calculation No. 0630-001-028, Rev. 0) indicates that the limiting material contained within this device is fiberglass, having a radiation tolerance of 1×10^{12} rads. Therefore, this device is expected to perform its safety function as required.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: 125 V DC MOTOR CONTROL CENTERS

MANUFACTURER/MODEL: General Electric/7700 Line

EQUIPMENT SPECIFICATION(S): SH1-168

EQSS REFERENCE(S): None

QUALIFICATION SUMMARY:

General Electric has provided data which indicates most components installed in the four MCC's have been irradiated to 1×10^6 rads gamma in a separate test program for another utility. Various reports for HFA and Agastat relays installed in the MCC's were also found.

RESOLUTION PROGRAM:

The need for additional qualification testing is under evaluation

JUSTIFICATION FOR INTERIM OPERATION:

1. Three of the 125V dc MCC's are installed in environmentally protected rooms or cubicles where they experience controlled humidity and temperature during all postulated accident conditions. The radiation environment for which these MCC's must function (180 day post-accident duration) is 3.1×10^5 rads gamma which is within GE's radiation test data.
2. The fourth MCC is located in the unprotected environment of the reactor building (secondary containment) and must function during a LOCA only: normal temperature, humidity and pressure with a radiation of 2.9×10^6 rads gamma. This level of radiation is only slightly higher than the radiation test data provided by GE. During a PBOC environment, the MCC will be subjected to a harsh temperature and humidity environment. However, the equipment fed from the MCC is not required to operate during or after a PBOC. Also this MCC is fed independently of the remaining 125V dc distribution system. In addition, conduit entries will be sealed to limit entry of steam inside the MCC enclosure.

Based on the required operation conditions the 125Vdc MCC's should function properly during and after all postulated accidents.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: CONTAINMENT ELECTRICAL PENETRATION

MANUFACTURER/MODEL: General Electric, series 100 Medium Voltage

EQUIPMENT SPECIFICATION(S): SH1-134

EQSS REFERENCE(S): 134-02

QUALIFICATION SUMMARY:

The containment electrical penetrations qualification documentation meets the requirement for radiation and cycle testing; however the following areas were not fully addressed

1. A qualified life was not established.
2. LOCA test duration was insufficient to directly demonstrate a post accident operability time of 180 days

RESOLUTION PROGRAM:

A purchase order is being placed with the manufacturer (G.E.) to perform a data search. The additional data is expected to be evaluated and analyzed with respect to the identified deficiencies by June 1982.

JUSTIFICATION FOR INTERIM OPERATION:

1. The qualification documentation addresses all phases of qualification except thermal aging. The effects of thermal aging are long term and will not significantly degrade the penetration in the time required to establish complete qualification. Additionally, the penetrations withstood a thermal cycle test of 120 cycles from 50°F to 150°F to simulate normal temperature excursions within the reactor building, over the life of the plant. The thermal cycle test provides evidence that the penetrations have a sufficient thermal life to justify interim operation.
2. The LOCA profile used in the test program exceeded the required profile for the first 10 days. For the remainder of the required 180 day profile the postulated temperature is 150°F which is the normal temperature for the required zones. Therefore, a failure after 10 days is unlikely because the penetrations will be operating in their normal environment.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: CONTAINMENT ELECTRICAL PENETRATION

MANUFACTURER/MODEL: General Electric, Series 200 Low Voltage

EQUIPMENT SPECIFICATION(S): SHI-134

EQSS REFERENCE(S): 134-01

QUALIFICATION SUMMARY:

The containment electrical penetration qualification documentation meets the requirement for radiation and cycling testing; however the following areas were not fully addressed.

1. A qualified life was not established.
2. LOCA test duration was insufficient to directly demonstrate a post accident operability time of 180 days.

RESOLUTION PROGRAM:

A purchase order is being placed with the manufacturer (G.E.) to perform a data search. The additional data is expected to be evaluated and analyzed with respect to the identified deficiencies by June 1982.

JUSTIFICATION FOR INTERIM OPERATION:

1. The qualification documentation addresses all phases of qualification except thermal aging. The effects of thermal aging are long term and will not significantly degrade the penetration in the time required to establish complete qualification. Additionally, the penetrations withstood a thermal cycle test of 120 cycles from 50°F to 150°F to simulate normal temperature excursions, within the reactor building, over the life of the plant. The thermal cycle test provides evidence that the penetrations have a sufficient thermal life to justify interim operation.
2. The LOCA profile used in the test program exceeded the required profile for the first 13 days. For the remainder of the required 180 days profile the postulated temperature is 150°F which is the normal temperature for the required zones. Therefore, a failure after 13 days is unlikely, because the penetrations will be operating in their normal environment.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: PUSH BUTTON STATIONS

MANUFACTURER/MODEL: General Electric/CR2940

EQUIPMENT SPECIFICATION(S): SH1-159

EQSS REFERENCE(S): None

QUALIFICATION SUMMARY:

Qualification documentation specific to these devices has not been found.

RESOLUTION PROGRAM:

The push button stations are expected to be qualification tested in the Shoreham miscellaneous component test program to be completed by September 1982, or soon thereafter.

JUSTIFICATION FOR INTERIM OPERATION:

1. Similar push button stations differ from these push button stations by having a metal mounting ring, rather than a plastic ring, and using compounds that are thoroughly traceable. However, GE has advised that the compounds in the two types of devices are very similar. The similar devices have been successfully irradiated to 1×10^6 rads gamma. Due to the similarity of the tested device to the Shoreham device, these data provide evidence of the radiation tolerance of the Shoreham devices, except for the plastic mounting ring.
2. The push button stations are operated only when the environment is not harsh; therefore, qualification requires that the devices withstand the accident environment without the occurrence of a spurious short or open circuit. Since these stations are installed in a metal enclosure with liquid seal-tite conduit fittings, the devices should not be effected by the accident environment.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: TERMINAL BLOCKS

MANUFACTURER/MODEL: General Electric/EB25, EB1, CR151

EQUIPMENT SPECIFICATION(S): SH1-159

EQSS REFERENCE(S): None

QUALIFICATION SUMMARY:

Qualification specific to these devices has not been found.

RESOLUTION PROGRAM:

The terminal blocks are expected to be qualification tested in the Shoreham miscellaneous component test program to be completed by September 1982, or soon thereafter.

JUSTIFICATION FOR INTERIM OPERATION:

1. Similar terminal blocks have been successfully irradiated to 1×10^5 rads gamma. Due to the similarity of the tested devices to the Shoreham device, these test data provide evidence of the radiation tolerance of the terminal blocks used at Shoreham.
2. The terminal blocks are installed in NEMA 12 enclosures which limit the entry of dust and other contaminating material.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Differential Pressure Indicating Switch
Manufacturer/Model: ITT Barton/288A; 289A
Equipment Specification: SH1-003
EQSS References: 3027

1. DESCRIPTION

The devices under evaluation are ITT Barton 288A and 289A Differential Pressure Indicating Switches (DPIS). Examination of ITT Barton technical manuals indicates that these two models are generic. Both DPIS's contain a dial indicator for local pressure measurements and a snap-action switch, which is actuated by a cam attached to the indicator movement, for sending a signal at the setpoint pressure.

2. CONCLUSION

These devices have been qualified by test for the postulated accident temperature and humidity conditions only. Testing also included exposure to a radiation environment. Therefore, they do not fully meet the requirements of NUREG-0588, Category II. However, use of this equipment for interim operation can be justified.

3. LIMITATIONS

Materials analysis (EDS Calculation No. 0630-001-010, Rev. 0) indicates that this device has a qualified life of 40 years.

4. JUSTIFICATION FOR INTERIM OPERATION

1. The postulated accident pressure environment is higher than the pressure for which this device has been tested by a margin of less than 1 psi. A 1 psi differential is not expected to affect this device's function. Therefore, this device is expected to perform its safety function as required.
2. This device is required to withstand an accident radiation dose of 4.14×10^6 rads but has only been tested to 3×10^6 rads (ITT Barton Test Report No. R3-288A-1). However, materials analysis (EDS Calculation No. 0630-001-010, Rev. 0) indicates the limiting materials in this device are Viton and PVC, both having a radiation tolerance level of 1×10^7 rads. Therefore, this device is expected to perform its safety function as required.

3. Extrapolation of the test data indicates that this device is capable of withstanding the postulated HELB temperature conditions for at least 48.6 hours (EDS Calculation No. 0630-001-009, Rev. 0). After this time, it will be exposed to only normal ambient temperature conditions. In addition, this device will be accessible for repair after an HELB and will not see a harsh environment, other than the radiation addressed above, after a LOCA. Therefore, this device is expected to remain operational for the required time of 180 days.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: MOTOR OPERATED DAMPER ACTUATOR

MANUFACTURER/MODEL: ITT General/NH-91

EQUIPMENT SPECIFICATION(S): SH1-319

EQSS REFERENCE(S): 319-01

QUALIFICATION SUMMARY:

Previous qualification testing of damper actuators resulted in certain malfunctions during testing (relief solenoid valve failed to open, valve disc became stuck to valve seat) and required corrective actions

RESOLUTION PROGRAM:

1. The manufacturer has advised that a requalification test program is currently being scheduled. It cannot be determined at this time when final qualification documentation will be available.
2. The actuators installed in the secondary containment are expected to be modified. (Install a filter screen and change valve seat material).

JUSTIFICATION FOR INTERIM OPERATION:

The damper actuators installed in the Shoreham plant will be modified in the same manner as was the test specimen. The previous test demonstrated that after these modifications were made, retesting for 200 hours to a 200^oF saturated steam environment did not result in any unsatisfactory performance and the actuator functioned as designed. This test provides evidence that the modified actuator is capable of operation in a harsh environment.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: MOTOR OPERATED VALVE ACTUATORS

MANUFACTURER/MODEL: Limitorque/SMB-2 SMB-3

EQUIPMENT SPECIFICATION(S): SH-003 (GE-NED)

EQSS REFERENCE(S): 003-01

QUALIFICATION SUMMARY:

Several MOV actuators were purchased prior to the issuing of IEEE standard 323-1971. These actuators have been tested according to Limitorque documents 600198 and 600376A and lack complete qualification documentation as required by this standard. The documentation was incomplete as follows:

1. Although the brakes supplied with the actuators are LOCA tested, they were not exposed to radiation.
2. The actuators were only cycled 150 times instead of 500 required per IEEE standard 382-1972.
3. The LOCA profile peaked at 239°F for one hour before decreasing thus not meeting the Shoreham primary containment accident conditions.

RESOLUTION PROGRAM:

Spare actuators are available at the plant for a requalification test program which is under consideration.

JUSTIFICATION FOR INTERIM OPERATION:

1. The materials used in the brake will be evaluated to determine if they are radiation sensitive. This evaluation is expected to be completed prior to June 1982.
2. Limitorque has been manufacturing actuators for many years with relatively minor manufacturing changes to the actuators and motors. Therefore, although the actuator tested was not cycled to the IEEE standard requirement, based on tests and operating experience to date, there is sufficient evidence to indicate that these actuators are capable of operation in accordance with the requirements of the IEEE standard.
3. The actuators have successfully passed a design basis accident test program. Although the temperature levels were slightly lower than those required for qualification, the 10°F or 15°F difference is relatively small. The existing reports demonstrate that the actuators are qualified for use in harsh environments.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: LEVEL SWITCHES

MANUFACTURER/MODEL: Magnetrol/291-MPG-X-M14DC

EQUIPMENT SPECIFICATION(S): SH1-407

EQSS REFERENCE(S): 407-1

QUALIFICATION SUMMARY:

Level switch test documentation did not include sufficient radiation exposure and a specific design basis event test with functional testing.

RESOLUTION PROGRAM:

Requalification testing by the manufacturer to the applicable service condition is scheduled for completion in December 1982.

JUSTIFICATION FOR INTERIM OPERATION:

1. The non-metallic parts of the Series 291 level switches are a phenolic terminal block and the Viton O-ring and seal. These non-metallic materials are used in other equipment which has been successfully qualified for the secondary containment environment where these level switches are installed. In addition, these materials were tested as documented in Magnetrol test report 43235-1, and functioned after radiation exposure to 4.4×10^6 rads gamma although this is less than the accident radiation requirements for these switches (4.2×10^6 rads gamma).
2. The switches were previously tested as follows: humidity levels between 95% and 100% were maintained at 300°F for 160 hours with cycle aging over 2000 cycles at rated load completed before high contact resistance was noted on one switch contact. This provides evidence of level switch operation when exposed to a harsh environment.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Level Switch
Manufacturer/Model: Magnetrol/3.5-751X-MPG-M14HY
Equipment Specification: SH1-003
EQSS References: 3143

1. DESCRIPTION

The devices under evaluation are Magnetrol level switches, Model No. 3.5-751-1X-MPG-M14HY. It has been determined by contact with the manufacturer that this model and the BCS-751 model tested are the same with respect to equipment qualification, differing only in the switching elements, the bellows size, and the drain size.

2. CONCLUSIONS

These devices have been qualified by test for the postulated accident temperature and humidity conditions only. Therefore, they do not fully meet the requirements of NUREG-0588, Category II. However, use of this equipment for interim operation can be justified.

3. LIMITATIONS

Materials analysis (EDS Calculation No. 0630-001-027, Rev. 0) indicates that this device has a qualified life of 6 years. This data will be input into the plant preventive maintenance program to ensure that this device does not surpass its qualified life.

4. JUSTIFICATION FOR INTERIM OPERATION

1. The postulated accident pressure environment is higher than the pressure for which this device has been tested by a margin of less than 1 psi. A 1 psi differential is not expected to affect this device's function. Therefore, this device is expected to perform its safety function as required.
2. This device is required to withstand an accident dose of 9×10^5 rads but has only been tested to 4.4×10^4 rads as an assembled unit. However, Table 1 of Wyle Laboratories test report No. 43235-1 indicates that each part of this device was irradiated separately to at least 1×10^6 rads without significant damage. Therefore, this device is expected to perform its safety function as required.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: SPLICING TAPE

MANUFACTURER/MODEL: Okonite/T35 & T95

EQUIPMENT SPECIFICATION(S): SH1-159

EQSS REFERENCE(S): 159-01

QUALIFICATION SUMMARY:

Although the Okonite splicing tapes were tested on Okonite/5 KV power cables and performed adequately, the cables used at Shoreham (EPR/Hypalon or EPR/Neoprene) were not included in the test. The concern is that due to the synergistic effects between the cable jacket and splicing tapes materials, the cable jackets may crack during design basis accident test and allow steam to penetrate into splices.

RESOLUTION PROGRAM:

Typical splices using Okonite tapes and Okonite power cables are expected to be qualification tested in the Shoreham miscellaneous component test program to be completed by September 1982, or soon thereafter.

JUSTIFICATION FOR INTERIM OPERATION:

Although cracks developed in the Okonite Hypalon or Neoprene power cable jackets** after the combination of thermal aging, radiation and LOCA chamber-chemical spray testing, the cracks were not evident prior to the LOCA chamber test. Therefore, the Okonite test results indicate that the splices and jacket material would not fail during an elevated temperature and radiation environment (design basis accident). Direct chemical or water spray testing is not applicable to these since they are installed in gasketed termination boxes.

** Per Okonite test report number NQRN-1

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Temperature Element
Manufacturer/Model: Pyco; California Alloy; NECI/145C3224
Equipment Specification: SH1-003
EQSS References: 3110

1. DESCRIPTION

The devices under evaluation are PYCO 102-9039-08, California Alloy 145C3224P001 & 145C3224P2, and NECI 145C3224P001 temperature elements. These items are considered generic as determined by review of their GE purchase part drawing (GE PPD 145C3224).

2. CONCLUSION

1. The following devices have been qualified by test for the postulated accident temperature, humidity, and radiation conditions only:

1E41*TE053 A, B
1E41*TE054 A, B
1E41*TE055 A, B
1E41*TE056 A, B
1G33*TE071 A Thru F

Therefore, these devices do not fully meet the requirements of NUREG-0588, Category II. However, use of this equipment for interim operation can be justified.

2. The following devices appear not to be qualified because their postulated pressure and temperature environment is more severe than that for which they have been tested to.

1B21*TE059 A thru D
1B21*TE043 AX, BX, CX, DX

Approaches to resolution are under evaluation.

3. LIMITATIONS

Analysis (EDS Calculation No. 0630-001-017, Rev. 0) indicates that this device has a qualified life of 28.9 years. This data will be input into the plant preventive maintenance program to ensure this device does not exceed its qualified life.

4. JUSTIFICATION FOR INTERIM OPERATION

The following justifications pertain to the equipment identified in Section 2.1 above.

1. The postulated accident pressure environment is higher than the pressure for which this device has been tested by a margin of less than 1 psi. A 1 psi differential is not expected to affect this device's function. Therefore this device is expected to perform its safety function as required.
2. Environmental testing indicates that this device can withstand the postulated HELB temperature conditions for 168 hours. After this time, the device will be exposed to only normal ambient temperature conditions. In addition, this device will be accessible for repair after an HELB and will not see a harsh environment, other than radiation, after a LOCA. Therefore, this device is expected to remain operational for the required time of 180 days.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: HEAT SHRINK TERMINATIONS

MANUFACTURER/MODEL: Raychem/WCSF-N

EQUIPMENT SPECIFICATION(S): SH1-159

EQSS REFERENCE(S): 159-05

QUALIFICATION SUMMARY:

Although the WCSF-N Raychem heat shrink terminations have been qualified they were not tested on the jacketed cables used at Shoreham (EPR Hypalon or EPR Neoprene jackets). The concern is that due to the synergistic effects between the jacket and the Raychem materials, the cable jackets may crack during a design basis accident test allowing steam to penetrate into the terminations.

RESOLUTION PROGRAM:

Typical Raychem terminations on Okonite power cables are expected to be qualification tested in the Shoreham miscellaneous component test program to be completed by September 1982, or soon thereafter.

JUSTIFICATION FOR INTERIM OPERATION:

Although the Okonite cable test reports show that cracks developed in the Hypalon and Neoprene power cable jackets** after the combination of thermal aging, radiation and LOCA chamber-chemical spray testing, the cracks were not evident prior to the LOCA chamber test. Therefore, the Okonite test results indicate that the Raychem terminations installed on Okonite cable jackets would not fail during an elevated temperature and radiation environment (design basis accident) only. Direct chemical and water spray testing is not applicable to these terminations since they are installed in gasketed termination boxes.

** Per Okonite test report number NQRN-1

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: MOTOR OPERATED DAMPER ACTUATOR

MANUFACTURER/MODEL: Raymond/MASR-9, 49

EQUIPMENT SPECIFICATION(S): SH1-319

EQSS REFERENCE(S): 319-01

QUALIFICATION SUMMARY:

The damper actuators were qualification tested; however, during the cycle aging test, the actuator froze after 400 cycles and oil leaked out of the actuator past the body and shaft. The failure was attributed to the misalignment of various metal parts. The actuator was returned to the manufacturer for machining of the spring clutch assembly but there was no evidence that it was included in the remaining portion of the test.

RESOLUTION PROGRAM:

1. Retest actuator with a reworked spring clutch assembly for applicable service conditions. The vendor has provided a proposal for retesting of this device. Qualification testing is expected to be completed by September 1982, or soon thereafter.
2. Actuators located in the field should have the spring clutch assemblies reworked. Instructions for the modifications are currently being requested from the manufacturer.

JUSTIFICATION FOR INTERIM OPERATION:

1. The Raymond actuators are used in the motor operated dampers which serve the standby ventilation system and the charcoal filter trains. During normal plant operation, two of three exhaust fans are running. During the postulated accident, only one of three exhaust fans must function so that a failure in all three associated dampers (1T46*MOD036A,B,C) and thus loss of all three fans is highly improbable. The other actuators (1T46*MOD031A,B, 047A,B, 048A,B) are in dampers that are tied to the operation of the charcoal filter trains and during an accident, only one filter is required to operate. These actuators are redundant and ducted such that one failure in each pair of actuators would not impair the operation of a charcoal filter train.
2. The actuator was tested to an environment of 180°F, 90% humidity for 1 day and 180 F, 50% humidity for 27 days prior to the cycle aging test. Therefore, there is evidence that the actuator is qualified for operation in a harsh environment.
3. A listing of materials used in the actuators will be evaluated to the required service conditions. This evaluation is expected by June 1982.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Differential Pressure Transmitter
Manufacturer/Model: Rosemount/1151
Equipment Specification: SH1-003
EQSS References: 3048

1. DESCRIPTION

The devices under evaluation are Rosemount Differential Pressure Transmitters, models 1151 AP, 1151 DP and 1151 GP. Analysis of Rosemount technical manuals indicates that these transmitters are all variations of the basic model 1151 transmitter, the only differences among them being the type of pressure they measure [i.e.; Atmospheric Pressure (AP), Differential Pressure (DP) and Gauge Pressure (GP)]. Therefore, for the purposes of environmental qualification, these transmitters are considered generic. In addition, Rosemount has stated that all test data for their 1152 transmitter, except for radiation, is applicable to the model 1151 (Rosemount Report No. 117415, Rev. A).

2. CONCLUSION

The following equipment has been qualified by test for all postulated plant accident environments:

1E41 * FT003	1B21*LT154A through D
1E51 * FT003	1B21*LT155B and D
1G33 * FT011	1B21*PT156 A through D
1G33 * FT012	1B21*PT158A through D
1G33 * FT013	1C71*PT007A through D
	1E11*PT165A through D

3. LIMITATIONS

1. The remaining Rosemount transmitters shown on the Equipment Qualification Summary Report (EQSR) have been qualified for a radiation dose of only 2×10^6 rads, but are required to withstand a postulated accident radiation dose of 4.14×10^6 . Therefore, this equipment does not fully meet the requirements of NUREG-0588, Category II.
2. Materials analysis indicates that the qualified life of these transmitters is 1.4 years. (Wyle Laboratories Report No. 17464-0902, July 29, 1981). This data will be input into the plant preventive maintenance program to ensure that this equipment would have a degraded condition detected if used beyond its qualified life.

4. JUSTIFICATION FOR INTERIM OPERATION

The postulated accident radiation dose of 4.14×10^6 rads for the devices discussed in section 3.1 above is a conservative determination based on the end of life fission product inventory in the core. However, the postulated accident dose may be expected to remain less than this conservatively calculated dose prior to the first refueling outage due to a smaller fission product inventory expected in the life of the first core. This expectation will be confirmed by analysis. Therefore, this device is expected to perform its required safety function at least until the first refueling outage.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION*

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/
JUSTIFICATION FOR INTERIM OPERATION

EQUIPMENT TYPE: 480 V AC MOTOR CONTROL CENTERS AND CIRCUIT BREAKER PANELS

MANUFACTURER/MODEL: Square D/Model 4

EQUIPMENT SPECIFICATION(S): SH1-115

EQSS REFERENCE(S): None

QUALIFICATION SUMMARY:

Qualification documentation for this equipment has not been found.

RESOLUTION PROGRAM:

A qualification proposal and test plan are in negotiation with the manufacturer.

JUSTIFICATION FOR INTERIM OPERATION:

1. Many of the MCC's and panels are installed in environmentally protected rooms or cubicles where they experience controlled humidity and temperature during all postulated accident conditions. The radiation environment for which these MCC's must function (180 day post-accident duration) is 3.1×10^5 rads gamma which is within the capability of most electrical equipment.
2. The remainder of the MCC's are located in the unprotected environment of the reactor building (secondary containment) and must function only during a LOCA: normal temperature, humidity and pressure with a radiation dose of 4.2×10^6 rads gamma. Since this level of radiation is within the capability of most electrical equipment, this equipment should function as required in this environment. During a PBOC environment, these MCC's will be subjected to a harsh temperature and humidity environment. However, the equipment fed from these MCC's are not required to operate during or after a "PBOC". Also these MCC's are fed independent of the remaining 480VAC distribution system. In addition, conduit entries will be sealed to limit entry of steam inside the enclosures.
3. A material analysis study for all MCC's and panels is expected to be available prior to testing. This study will determine the susceptibility of the materials to failure in a steam and radiation environment.

Based on the required operating conditions, the 480 V AC MCC's should function properly during and after all postulated accidents.

*Final complete documentation is not expected prior to fuel load.

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Pressure Switch
Manufacturer/Model: Static-O-Ring/5N, 6N Series
Equipment Specification: SH1-003
EQSS References: 3032

1. DESCRIPTION

The devices under evaluation are Static-O-Ring Series 5N & 6N Pressure Switches. The equipment serial numbers have been sent to the manufacturer. Static-O-Ring is in the process of providing the applicability of qualification documentation and the materials of construction.

2. CONCLUSION

(Later)

3. LIMITATIONS

(Later)

4. JUSTIFICATION FOR INTERIM OPERATION

(Later)

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Turbine
Manufacturer/Model: Terry Corporation/CCS
Equipment Specification: SH1-003
EQSS References: 3050

1. DESCRIPTION

The equipment under evaluation is the HPCI turbine, Terry Corporation model CCS, and accessory devices. A General Electric test program is currently in progress for this turbine and its accessories.

2. CONCLUSION

(Later)

3. LIMITATIONS

(Later)

4. JUSTIFICATION FOR INTERIM OPERATION

(Later)

EQUIPMENT WITH INCOMPLETE DOCUMENTATION

QUALIFICATION SUMMARY/RESOLUTION PROGRAM/JUSTIFICATION FOR INTERIM OPERATION

Equipment Type: Level Indicator
Manufacturer/Model: Yarway/4418C
Equipment Specification: SH1-003
EQSS References: 3037

1. DESCRIPTION

The devices under evaluation are Yarway remote level indicating switches, Model 4418C. Examination of Yarway test data indicates that all 4400 series level switches are generic.

2. CONCLUSION

These devices have been qualified by test for the postulated accident temperature and humidity conditions only. Therefore, they do not fully meet the requirements of NUREG-0588, Category II. However, use of this equipment for interim operation can be justified.

3. LIMITATIONS

Materials analysis (EDS Calculation No. 0630-001-016, Rev. 0) indicates that the limiting parts in this device, with respect to thermal aging, are the neoprene grommet and cover gasket and the cork and rubber control module casing gasket, all having a qualified life of 6 years. This data will be input to the plant preventive maintenance program to ensure that this device does not exceed its qualified life.

JUSTIFICATION FOR INTERIM OPERATION

1. The postulated accident pressure environment is higher than the pressure for which this device has been tested by a margin of less than 1 psi. A 1 psi differential is not expected to affect this device's function. Therefore, this device is expected to perform its safety function as required.

2. This device is required to withstand an accident radiation dose of 9×10^5 rads but has not been subjected to radiation testing. However, materials analysis (EDS Calculation No. 0630-001-016, Rev. 0) indicates that the limiting materials of this device are vinyl and diallyl phthalate, both having a radiation tolerance of 1×10^6 rads. Therefore, this device is expected to perform its safety function as required.

3. Extrapolation of the test data indicates that this device is capable of withstanding the postulated HELB temperature conditions for at least 16.6 hours (EDS Calculation No. 0630-001-015). After this time it will be exposed to only normal ambient temperature conditions. In addition, this device will be accessible for repair after an HELB and will not see a harsh environment, other than the radiation addressed above, after a LOCA. Therefore, this device is expected to remain operational for the required time of 1 day and not fail in a manner detrimental to plant safety for the duration of the accident (180 days).

APPENDIX H

LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE

APPENDIX H

LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE

A	Agitator
A/D	Analogue/Digital Converter
ABR	Auxiliary Boiler Room
ACC	Air-Cooled Condenser
ACH	Air Chamber
ACT	Actuator
ACU	Air-Conditioning Unit
AD	Air Dryer
ADS	Absorber
AE	Air Eliminator
AF	Air Filter
AO	Air Operator
AOD	Air-Operated Damper
AOV	Air-Operated Valve
APH	Air Preheater
ASS	Automatic Selector Switch
B	Boiler
B/A	Buffer Amplifier
BA	Battery
BC	Battery Charger
BIS	Switchgear Breaker Test Set
BLO	Blower
BPD	Bushing Potential Device
BRK	Breaker
C	Compressor
C/D	Carrier Demodulator
C/F	Signal Failure Alarm
C/M	Carrier Modulator
CC	Conductivity Controller
CCV	Conductivity Control Valve
CE	Conductivity Element
CI	Conductivity Indicator
CIS	Conductivity Indicating Switch
CIT	Conductivity Indicating Transmitter
CIV	Combined Intermediate Valve
CLC	Cooling Coil
CLR	Chlorine Recorder
CLZ	Chlorine Analyzer
CM	Conductivity Monitor
CNV	Conveyor, Feeder
CON	Continuous
CPD	Coupling Type Potential Device
CPG	Coupling
CR	Conductivity Recorder
CRN	Crane or Hoist
CRS	Conductivity Recorder Switch
CS	Conductivity Switch

LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE (CONT)

<u>ABBREVIATION</u>	<u>FULL TITLE</u>
CSK	Cask
CT	Conductivity Transmitter
CTR	Current Transformer
CV	Control Valve
CYL	Cylinder
D	Condensing Chambers
DA	Deaerator
DE	Demineralizer, Deionizer
DEM	Deminster
DG	Diesel Generator Building
DH	Desuperheater
DI	Ionization Fire Detector
DMP	Damper
DO	Door
DR	Density Recorder
DRY	Dryer
DT	Density Transmitter
DTC	Thermal Fire Detectors
E	Heat Exchanger
E/E	Voltage to Voltage Converter - Repeater
E/H	Voltage to Hydraulic Converter
E/I	Voltage to Current Converter
E/P	Voltage to Pneumatic Converter
E/S	Electric Power Supply
E/Y	Auctioneer
ECD	Electric Control Drive
EFV	Excess Flow Check Valve
EHC	Electro-Hydraulic Control
EI	Voltage Indicator
EJ	Ejector, Eductors
EL	Elevator
ELA	Laundry Equipment
EN	Elapsed Time Totalizer
ENC	Enclosure
ENG	Engine
EOL	End of Line
ER	Voltage Recorder
ET	Voltage Transmitter
EV	Explosive Valve
EXJ	Expansion Joint
FAN	Fan
FC	Flow Controller
FCD	Flow Control Damper
FCV	Flow Control Valve
FDI	Flow Differential Indicator

LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE (CONT)

<u>ABBREVIATION</u>	<u>FULL TITLE</u>
FDS	Flow Differential Switch
FE	Flow Element
FG	Flow Glass
FI	Flow Indicator
FIC	Flow Indicating Control
FIS	Flow Indicating Switch
FISL	Feedwater Isolation
FIT	Flow Indicating Transmitter
FK	Flow Square Root Extractor
FL	Filter
PLT	Filter Train
FN	Flow Totalizer
FNM	Flow Totalizing Meter
PNR	Flow Totalizing Recorder
FNT	Flow Totalizing Transmitter
FQ	Flow Integrator
FR	Flow Recorder
FRC	Flow Recorder Control
FS	Flow Switch
FT	Flow Transmitter
FUN	Funnel, Flush Funnel
G	Generator
GD	Gear Drive, Increase/Decrease
GN	Generator Neutral Equipment
GZ	Gas Analyzer
H	Heater
HC	Hand Control
HCC	Heating Coil, Reheat Coil
HCU	Hydraulic Control Unit
HCV	Hand Control Valve
HD	Hood
HDS	Disconnect Switch Bus
HFU	Heater Fan Unit
HIC	Hand Indicating Controller
HO	Hydraulic Operator
HOV	Hydraulic Operated Valve
HSG	Housing
HSS	Hand Selector Switch
HSV	Hand Selector Valve
HV	Hand Valve
HVU	Heating and Ventilation Unit
HZR	Frequency Recorder
HZT	Frequency Transmitter
HZE	Hydrogen Element
H2I	Hydrogen Indicator
H2R	Hydrogen Recorder

LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE (CONT)

<u>ABBREVIATION</u>	<u>FULL TITLE</u>
H2T	Hydrogen Transmitter
H2Z	Hydrogen Analyzer
I/E	Current to Voltage Converter
I/H	Current to Hydraulic Converter
I/I	Current Repeater
I/P	Current to Pneumatic Converter
I/S	Inverter Supply
IC	Current Controller
II	Current Indicator
INV	Inverter
IPB	Isolated Phase Bus
IR	Current Recorder
IRM	Intermediate Range Monitoring
IT	Current Transmitter
JB	Junction Box (Boxes for Terminations, etc, need not be numbered)
L/U	Logic Unit
LC	Level Controller
LCV	Level Control Valve
LDI	Level Differential Indicator
LDS	Level Differential Switch
LDT	Level Differential Transmitter
LE	Level Element
LG	Level Glass
LGT	Lights
LI	Level Indicator
LIC	Level Indicating Controller
LIS	Level Indicating Switch
LIT	Level Indicating Transmitter
LR	Level Recorder
LRS	Level Recording Switch
LS	Level Switch
LT	Level Transmitter
LTS	Level Transmitting Switch
M	Mixer
M/U	Manual Unit
MC	Moisture Controller
MCB	Main Control Board
MCC	Motor Control Center
MDS	Motor-Operated Switch Disconnect
ME	Moisture Element
MFD	Manifold
MG	Motor Generator
MGR	Motor Generator Room

LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE (CONT)

<u>ABBREVIATION</u>	<u>FULL TITLE</u>
MI	Moisture Indicator
MIC	Moisture Indicating Controller
MIT	Moisture Indicating Transmitter
MO	Motor Operator
MOD	Motor Operated Damper
MOT	Motor
MOV	Motor Operated Valve
MR	Moisture Recorder
MS	Magnetic Switch
MSH	Motor Space Heater (MSH for pumps, valves, elec PNL, etc, shall not be identified with separate numbers)
MST	Magnetic Starter
MSV	Main Steam Stop Valve
MSW	Moisture Switch
MT	Moisture Transmitter
MT	Test Motor
NAI	Sodium Indicator
NAZ	Sodium Analyzer
NNE	Eccentricity Element
NNI	Eccentricity Indicator
NNR	Eccentricity Recorder
NNS	Eccentricity Switch
NNT	Eccentricity Transmitter
NPB	Nonsegregated Phase Bus
NRV	Non Return Valve
NSA	Neutron Source Critical
NXE	Expansion Element
NXI	Expansion Indicator
NXR	Expansion Recorder
NXS	Expansion Switch
NXT	Expansion Transmitter
O2R	Oxygen Recorder
O2Z	Oxygen Analyzer
P	Pump
P/C	Potentiometric Transducer Conditioning Module
P/D	Proportional Delay Unit
P/E	Pneumatic-Electrical Converter
P/I	Pneumatic to Current Converter
P/U	Pneumatic Unit
PBM	Piggyback Motor
PC	Pressure Controller
PCD	Pressure Control Damper
PCV	Pressure Control Valve
PD	Photoelectric Detector

LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE (CONT)

<u>ABBREVIATION</u>	<u>FULL TITLE</u>
PDC	Pressure Differential Controller
PDI	Pressure Differential Indicator
PDR	Pressure Differential Recorder
PDS	Pressure Differential Switch
PDT	Pressure Differential Transmitter
PDV	Pressure Differential Valve
PHE	pH Element
PHI	pH Indicator
PHR	pH Switch
PHT	pH Transmitter
PI	Pressure Indicator
PIC	Pressure Indicating Controller
PIS	Pressure Indicating Switch
PNE	Position Element
PNI	Position Indicator
PNL	Panel
PNR	Position Recorder
PNS	Position Switch (PNS for AOV/MOV do not have to be assigned)
PNT	Position Transmitter
PR	Pressure Recorder
PS	Pressure Switch
PSA	Pipe Support Restraint
PSB	Portable Steam Boiler
PSG	Pipe Support Guide
PSRH	Pipe Support Rod Hanger
PSS	Pipe Support Sliding
PSSH	Pipe Support Spring Support
PSSP	Pipe Support Snubber/Suppressor
PSST	Pipe Support Strut
PT	Pressure Transmitter
PUR	Purifier
PWR	Pipe Whip Restraints
R/E	Resistance to Voltage Converter
R/I	Resistance to Current Converter
RA	Resistor Assembly
RAK	Rack or Storage Stand
RB	Radial Beams
RC	Recombiner
RCL	Ultrasonic Resin Cleaner
RCO	Restricting Control Orifice
RD	Rupture Disc
RE	Radiation Element
REC	Rectifier
REF	Refrigeration Unit
RFP	Retractable Fill Pipe
RI	Radiation Indicator

LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE (CONT)

<u>ABBREVIATION</u>	<u>FULL TITLE</u>
RIS	Radiation Indicating Switch
RK	Instrument Rack
RO	Restriction Orifices
RP	Pneumatic Relay
RR	Radiation Recorder
RS	Radiation Switch
RT	Radiation Transmitter
RTS	Radiation Transmitter Switch
RV	Relief Valve
S	Permanent Strainer
S/A	Summing Amplifier
S/C	Signal Characterizer
S/G	Signal Generator
SC	Speed Controller
SCT	Signal Conditioner - Temporary
SDF	Seal Drywell Floor
SE	Seal
SH	Shield
SHE	Shop Equipment
SI	Speed Indicator
SIC	Speed Indicating Controller
SIL	Silencer
SIR	Speed Recorder
SIR	Speed Recorder
SIX	Speed Demand Indicator
SK	Skimmer
SL	Speed Limiter
SLG	Sling
SLU	Seal Oil Unit
SOV	Solenoid Operated Valve
SP	Sparger
SPPB	Suppression Pool Pump Back
SR	Separator
SRM	Source Range Monitor
ST	Speed Transmitter
STE	Special Test Instrument
STT	Temporary Strainer
STU	Sewage Treatment Unit
SUP	Support Equipment
SV	Safety Valve
SW	Service Water Wells Isolation Gates
SWC	Screenwell
SWE	Shield Wall Extension
SWG	Switchgear
T	Transformer
TBE	Tubes, Condenser

LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE (CONT)

<u>ABBREVIATION</u>	<u>FULL TITLE</u>
TC	Temperature Controller
TCV	Temperature Control Valve
TDI	Temperature Differential Indicator
TDR	Temperature Differential Recorder
TDS	Temperature Differential Switch
TDT	Temperature Differential Transmitter
TE	Temperature Element
TG	Turning Gear
TI	Temperature Indicator
TIC	Temperature Indicating Controller
TIP	Transversing Incore Probe
TIS	Temperature Indicating Switch
TIT	Temperature Indicating Transmitter
TK	Tank, Sump, Shipping Container, Reservoir
TL	Liner
TM	Temperature Monitor
TO	Tool
TP	Potential Transformer
TR	Temperature Recorder
TRK	Trash Rack
TRP	Trap
TRS	Temperature Recording Switch
TRV	Temperature Relief Valve
TS	Temperature Switch
TSC	Traveling Water Screen
TT	Temperature Transmitter
TU	Turbine
TUE	Turbidity Element
TUI	Turbidity Indicator
TUR	Turbidity Recorder
TUT	Turbidity Transmitter
TVC	Television Camera
TVM	Television Monitor
TX	Transceiver, Base Station
UBI	Ultrasonic Equipment Cleaner
UC	Unit Cooler
UEC	Ultrasonic Cleaning Transducer
UH	Unit Heater
UT	Unit Trip
VBA	Vibration Alarm
VBE	Vibration Element
VBI	Vibration Indicator
VBM	Vibration Monitor
VBR	Vibration Recorder
VBS	Vibration Switch
VBT	Vibration Transmitter

LIST OF ABBREVIATIONS FOR EQUIPMENT TYPE (CONT)

<u>ABBREVIATION</u>	<u>FULL TITLE</u>
VBX	Vibration Test Point
VCH	Valve Chest
VH	Vehicle
VM	Vibrating Motor
VR	Viscosity Recorder
VT	Viscosity Transmitter
VU	Ventilator Unit
WB	Baler (Solid Waste)
WC	Water Chiller
WDW	Window-Includes Leaded Glass
WHS	Warehouse
WI	Watt Indicator
WR	Watt Recorder
WX	Watt Counter
XL	Lighting Transformer
XXX	Downcomer
Z	Penetration
ZIU	Zone Indicating Unit
ZN	Zone Module