

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

82 JAN 11 AM 11:20

January 8, 1982



Mr. James F. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE  
REPORT BFRO-50-259/81085

The enclosed report provides details concerning high-pressure coolant  
injection suppression chamber high level switches which were discovered  
to be set 8 inches above normal level. This report is submitted in  
accordance with Browns Ferry unit 1 Technical Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
H. J. Green  
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Records Center  
Institute of Nuclear Power Operations  
1820 Water Place  
Atlanta, Georgia 30339

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

8201290344 820108  
PDR ADOCK 05000259  
S PDR

OFFICIAL COPY

IE 22

S/11