


1. APPLICANT'S USE		a. DATE OF APPLICATION 1/7/82		b. APPLICANT'S REFERENCE MACPJ 3075KY		2. NRC USE		a. LICENSE NO. XSNM-1909		b. DOCKET NO. 11002721							
3. APPLICANT'S NAME AND ADDRESS						RIS		4. SUPPLIER'S NAME AND ADDRESS (Complete if applicant is not supplier of material)				RIS					
a. NAME NISSHO IWAI AMERICAN CORPORATION																	
b. STREET ADDRESS 1211 AVENUE OF THE AMERICAS						a. NAME 1032 JAN 11 AM 9 23 DEPARTMENT OF ENERGY OAK RIDGE OPERATIONS											
c. CITY NEW YORK				STATE NY		ZIP CODE 10036		b. STREET ADDRESS P.O. BOX E EXPORT/IMPORT									
d. TELEPHONE NUMBER (Area Code - Number - Extension) 212-730-2255						c. CITY OAK RIDGE				INTERNATIONAL SFGRS		STATE TN		ZIP CODE 37830			
5. FIRST SHIPMENT SCHEDULED OCTOBER, 1983			6. FINAL SHIPMENT SCHEDULED APRIL, 1984			7. APPLICANT'S CONTRACTUAL DELIVERY DATE SAME AS ITEMS 5 & 6			8. PROPOSED LICENSE EXPIRATION DATE SEPTEMBER, 1985			9. U.S. DEPARTMENT OF ENERGY CONTRACT NO. (If Known)					
10. ULTIMATE CONSIGNEE						RIS		11. ULTIMATE END USE (Include plant or facility name) 56.058 kg U for the fuel of the Japan Materials Testing Reactor (JMTR) in Oarai Research Establishment									
a. NAME JAPAN ATOMIC ENERGY RESEARCH INSTITUTE																	
b. STREET ADDRESS 2-2, Uchisaiwai-cho 2-chome, Chiyoda-ku																	
c. CITY - STATE - COUNTRY Tokyo 100, Japan						11a. EST. DATE OF FIRST USE September, 1984											
12. INTERMEDIATE CONSIGNEE						RIS		13. INTERMEDIATE END USE Fabrication of enriched uranium metal into fuel elements									
a. NAME NUCLEAR FUEL INDUSTRIES, LTD.																	
b. STREET ADDRESS 23-5, Nishishinbashi 3-chome, Minato-ku																	
c. CITY - STATE - COUNTRY Tokyo 105, Japan						13a. EST. DATE OF FIRST USE December, 1983											
14. INTERMEDIATE CONSIGNEE						RIS		15. INTERMEDIATE END USE									
a. NAME																	
b. STREET ADDRESS																	
c. CITY - STATE - COUNTRY						15a. EST. DATE OF FIRST USE											
16. NRC USE		17. DESCRIPTION (Include chemical and physical form of nuclear material; give dollar value of nuclear equipment and components) Uranium Metal								18. MAX. ELEMENT WEIGHT 56.058		19. MAX. WT. % 93.30		20. MAX. ISOTOPE WT. 52.302		21. UNIT kg	
22. COUNTRY OF ORIGIN - SOURCE MATERIAL U.S.A.						23. COUNTRY OF ORIGIN - SNM WHERE ENRICHED OR PRODUCED U.S.A.						24. COUNTRIES WHICH ATTACH SAFEGUARDS (If Known) U.S.A.					
25. ADDITIONAL INFORMATION (Use separate sheet if necessary) 8202020016 820107 PDR XPORT XSNM-1909 PDR																	
26. The applicant certifies that this application is prepared in conformity with Title 10, Code of Federal Regulations, and that all information in this application is correct to the best of his/her knowledge.																	
27. AUTHORIZED OFFICIAL				a. SIGNATURE 				b. TITLE Manager, Nuclear Energy & Equipment									



Japan Atomic Energy Research Institute

2-2, Uchisaiwai-cho, 2-chome, Chiyoda, Tokyo 100

Telephone: (03) 503-6111

Telex: J24596

Cable: JAERINIPPON TOKYO

To whom it may concern :

1982 JAN 11 11:09 28

END USE STATEMENT

EXPORT/IMPORT
AND
INTERNATIONAL SFORDS

The undersigners certify that a quantity of

56.058 kgs of uranium (93.30 % U-235 enriched)

in form of uranium metal containing 52.302 kgs of U-235 which will be furnished to us under the Adjustable Fixed Commitment Enrichment Contract and a metal-conversion contract with USDOE will be used by us for fuel elements of the Japan Materials Testing Reactor (JMTR) in our Oarai Research Establishment, Oarai, Ibaraki, Japan.

The enriched uranium metal shall be fabricated into fuel elements by Nuclear Fuel Industries Ltd., 23-5, Nishishinbashi 3-chome, Minato-ku, Tokyo 105, Japan.

We authorize Nissho-Iwai American Corp., 1211 Avenue of the Americas, New York, U.S.A. and/or Transnuclear, Inc., 5205 Leesburg Pike, Falls Church, Virginia, U.S.A. to apply for the export license.

JAPAN ATOMIC ENERGY RESEARCH
INSTITUTE

Shoichi Takahashi
Shoichi Takahashi

Head, Division of Contracts

JMTR.

CHECKLIST FOR USE IN REVIEW OF REQUESTS FOR
ENRICHED URANIUM TO DETERMINE
TECHNICAL AND ECONOMIC JUSTIFICATION

Date November 30, 1981

1. Name of Facility: Japan Materials Testing Reactor (JMTR)
2. Quantity of Uranium Requested (Kgs): 56.058 Kgs U in form of Uranium Metal
3. Enrichment in the Isotope U-235 (%): 93 %
4. Sale or Toll Enriching: Toll enriching
5. Current Core Loading (Kgs of U-235): Approx. 7 Kgs U-235
6. Current Power Level (MWth): 50 MWth
Criticality and Full Operating Power Dates and Power Rating (If request involves new facility): Criticality : December, 1969 50 MWth: January, 1970
8. Name of Converter and Fabricator of Fuel: Converter: USDOE
Fabricator: Nuclear Fuel Industries, Ltd., in Japan
9. Breakdown of Fuel Inventory (Kgs of U-235):
 - a. Amount of U-235 in Fabrication outside USA Including Scrap Allowances:
(including the amount of U Metal on the way of transportation from U.S.A. to Japan)
Approx. 40 Kgs U-235
 - b. Amount of U-235 in Storage in Completed, Unirradiated Fuel Elements:
Approx. 16.9 Kgs U-235
 - c. Amount of U-235 in Core: Approx. 7 Kgs U-235
 - d. Amount of U-235 in Spent Fuel Storage within the Community Including Chemical Reprocessing Plants, and the Reprocessing Schedule for Such Material:
Approx. 49.8 kgs U-235 in Spent Fuel Storage,
Approx. 33.9 kgs U-235 in the USDOE Savannah River Plant, and
Approx. 15.6 kgs U-235 on the way of transportation from Japan to USDOE SPP
 - e. Amount of U-235 Lost and/or Consumed During Operation of Above Facility:
Approx. 7 Kgs U-235/year
 - f. Amount of U-235 per Fuel Element: Standard Fuel Element: 0.279 Kgs U-235
Fuel Element: 0.195 Kgs U-235
 - g. Average Core Life: 4 weeks
 - h. Average Lead Time for Conversion and Fuel Fabrication if Conversion and Fabrication is to be Done Abroad:
Approx. 2 years

JMTR

JMTR

RESEARCH, TRAINING, AND TEST REACTOR DIRECTORY

1. GENERAL

1.1 Reactor Name (Acronym)	Japan Materials Testing Reactor(JMTR)
1.2 License Number	
1.3 NRC Docket Number	
1.4 Reactor Address	Narita-cho, Oarai-machi, Higashi-Ibaraki-gun, Ibaraki-ken 311-13, Japan
1.5 Reactor Telephone	02926-7-4111
1.6 Reactor Owner	Japan Atomic Energy Research Institute
1.7 Reactor Operator	as above
1.8 Reactor Administrators	as above
1.9 Reactor Facility Staff	
a. Scientific/Technical	40
b. Operations	20
c. Support	20
d. Normal Number of Personnel in Reactor Containment/Confinement	30
1.10 Reactor Architect/Engineer	Japan Atomic Energy Research Institute, and NAIG, Hitachi, MAPI, Sumitomo and Dai-ichi groups
1.11 Reactor Constructor	NAIG, Hitachi, MAPI, Sumitomo and Dai-ichi groups
1.12 Organization/Country Supplying Nuclear Technology	Not applicable
1.13 Reactor Setting	Mar. 1965 (start of construction)
1.14 Reactor Operating Status	
a. Initial Criticality Date	Mar. 28, 1968

JMTR

b. Full Power Date	Jan. 12, 1970 (50 MW)
c. Operating Cycle	about one month/operation cycle
	5 operation cycles/year
d. Full Power Hours/Year	2800 hours
e. Pulses/Year, Average Energy	Not applicable
1.15 Reactor Facility Cost	12,000 million yen (including Hot Lab. and irradiation facilities)
1.16 Annual Operating Budget	2,000 million yen (excluding personnel expenses)
2. REACTOR	
2.1 Reactor Type	Tank type, highly enriched uranium (93%), light water moderated and cooled
2.2 Reactor Vessel	
a. Configuration	See Fig. 1
b. Overall Dimensions	9500 mm high
	2600 mm diameter
c. Material	stainless steel
d. Normal Operating Pressure	14 kg/cm ² -G (Inlet)
e. Normal Operating Temperature	42°C (Inlet)
2.3 Core	
a. Volume	102 l
b. Overall Dimensions	540 x 386 x 750 (mm) (Including in-core irradiation space)
c. Lattice Configuration	square pitch 77.2 mm
d. Number of Elements	22
1. Standard	5
2. Control	
e. Maximum Number of Grid Locations That can be used for Fuel	37
f. Normal Core ²³⁵ U Content	Approx. 6.6 kg
g. Subdivided Core	
1. Number of Subdivisions	None
2. Subdivision Differentiating Characteristics	None

JMTR

3. Number of Elements per Subdivision		None
2.4	Containment	
	a. Type	Domed building
	b. Volume	$4 \times 10^4 \text{ m}^3$
	c. Material	Reinforced concrete, steel roof
2.5	Moderator	Light water
2.6	Blanket Gas	None
2.7	Reflectors	Beryllium
2.8	Thermal Shield	None
2.9	Biological Shield	Light water, concrete
	a. External Radiation Levels	0.1 mR/hr
2.10	Power Level	
	a. Normal Steady State	50 MW
	b. Pulsing	Not applicable
2.11	Normal Average Thermal Power Density	
	a. Volumetric (2.10.a/2.3.a)	490 KW/l
	b. Linear (2.10.a/(Number of Plates/ Pins x Plate/Pin Length))	1.46 KW/cm
2.12	Normal Specific Power (2.10.a/2.3.f)	7.58 KW/g
2.13	Reactor Control	
	a. Safety Rods	
	1. Number	4
	2. Shape and Dimensions	63.5 mm square x 800 mm
	3. Material and Loading	Hafnium, 10.7kg/element
	4. Normal Withdrawal/Insertion Speed	200 mm/min. or 40 mm/min.
	5. Scram Insertion Speed	800 mm/250 m.sec
	6. Total Reactivity	17.3 $\Delta k/k$

7. Average Reactivity Addition Rate	$1.08 \times 10^{-2} \Delta k/k/mm/2rods$
8. Scram Mechanism	Scram initiated by release of magnetic actuated spring actuator energized from core of driving mechanism casing
b. Regulating Rods	
1. Number	1
2. Shape and Dimensions	63.5 mm square x 800 mm
3. Material and Loading	Hafnium 10.7 kg/element
4. Normal Withdrawal/Insertion Speed	Variable 0 ~ 2000 mm/min.
5. Total Reactivity	$0.5 \Delta k/k$ (automatic control range)
6. Average Reactivity Addition Rate	$5 \times 10^{-3} \Delta k/k/mm$
c. Chemical Shim Control	
1. Chemical	Not applicable
2. Loading	Not applicable
3. Control Mechanism	N.t applicable
4. Total Reactivity	Not applicable
d. Burnable Poison	
1. Isotopes Utilized	Not applicable
2. Location	Not applicable
3. Loading	Not applicable
4. Total Reactivity	Not applicable
3. <u>FUEL</u>	
3.1 Standard Fuel Element	
a. Configuration	Modified ETR type
b. Element Dimensions	77.04 square at pad portion
c. Overall Plate/Pin Dimensions	1200 mm length
	778 mm length
	1.27 mm thickness

JNTR

d. Number of Plates/Pins per Element	19 plates
e. Distance Between Plate/Pin Centerlines	3.94 ~ 4.29
f. Active Portion of Fuel Plate/Pin	750 mm length, 61.6 mm width
1. Dimensions	0.51 mm thickness
2. Composition	U-Al alloy
3. ^{235}U Enrichment	93 %
4. Fissile Material Density	0.62 g/cm ³
g. Reflector Portion of Fuel Plate/Pin	None
1. Composition	
2. Dimensions	None
h. Clad	
1. Composition	Aluminum
2. Thickness	0.38 mm
i. Structural Material	Aluminum
3.2 Control Rod Fuel Element	
a. Specify Differences from Standard Fuel Elements	Element dimension: 63.64 square x 890 (mm) Number of fuel plate: 16 plates U-235 content: 12.19 g/plate
3.3. Fuel Cycle	
a. Criteria for Refueling	Reactivity and burn up
b. Frequency of Refueling	2/cycle
c. Normal Element Lifetime	1 cycle
d. Burnup	
1. Average ^{235}U Burnup	20 %
2. Peak ^{235}U Burnup	34 %
3. Maximum Allowed ^{235}U Burnup	40 %
e. Number of Elements Replaced During Typical Refueling	25 elements/cycle
f. Spent Fuel	
1. Minimum Cooling Time	120 days
2. Maximum Amount in Storage	Approx. 2250 elements

JMTR

g. Disposition of Spent Fuel	Spent fuel storage rack
h. Spent Fuel Shipping Cask	JMTR W5200 (cylindrical type, lead shielding dry cask)
i. Spent Fuel Handling	Double hook handling tool, under water
j. Fuel Failure Detection	During operation: 1. Detection of delayed neutron and γ ray included in primary coolant with BF_3 and NaI 2. Detection of γ ray included off gas with NaI - Other; Wet sipping method with NaI
3.4 Fuel Inventory	
a. Current Fissile Material Inventory Status	As of November 30, 1981
1. New Fuel In-Process	43.6 kgs U (NFI in Japan, and on the way transportation from USA to Japan)
2. New Fuel On Hand	62 elements
3. Fuel In-Core	27 elements
4. Spent Fuel In Storage	220 elements
5. Spent Fuel Being Reprocessed	56 kgs U (in USDOE SRP, and on the way of transportation from Japan to USDOE SRP)
6. Non-Fuel Special Nuclear Material	None
b. Fissile Material Inventory Needed to Assure Continuity of Operations	
1. New Fuel In-Process	125 elements
2. New Fuel On Hand	50 elements
3. Fuel In-Core	27 elements
3.5 Fuel Source	
a. Fuel Fabricator	Nuclear Fuel Industries Ltd.(NFI). Japan
b. Fuel Supplier	USA
c. Fissile Material Origin	USA
d. Enrichment Supplier	USA
e. Method of Fabrication	1) U-Al alloy 2) Covered with Al plates by the picture frame method 3) Fuel element; the roll-swaging method

Fuel Element Cost

9.500 thousand yen/element/75 element

4. HEAT TRANSFER DATA

4.1	Fuel Element Heat Transfer Area (No. of Plates/Pins x Active Plate/ Pin Surface in Contact with Coolant)	1.76 m ²
4.2	Fuel Element Flow Area	3.75 x 10 ⁻³ m ²
4.3	Fuel Element Wetted Perimeter	2.63 m
4.4	Fuel Heat Thermal Resistivity	3.584 cm·sec·°C/cal
4.5	Clad-Coolant Heat Transfer Coefficient (at Hot Spot)	1.62 x 10 ⁻³ cal/cm ² ·sec·°C
4.6	Heat Flux at Plate Surface	
	a. Normal Average Heat Flux	9.89 x 10 ⁵ Kcal/hr·m ²
	b. Peak Heat Flux	
	1. Without Hot Channel Factors	3.78 x 10 ⁶ Kcal/hr·m ²
	2. With Hot Channel Factors	4.05 x 10 ⁶ Kcal/hr·m ²
	c. Axial Peaking Factor in Hot Channel (from Axial Fission Rate Distribution)	
	1. Without Hot Channel Factors	1.52
	2. With Hot Channel Factors	1.63
	d. Hot Spot Location	Lattice position ; H-8 (see Fig. 2)
4.7	Peak Operating Fuel Plate/Pin Temperature	
	a. At Plate/Pin Surface	
	1. Without Hot Channel Factors	141°C
	2. With Hot Channel Factors	188°C
	b. Inside Fuel Meat	
	1. Without Hot Channel Factors	150°C
	2. With Hot Channel Factors	197°C
4.8	Primary Coolant	Light water
4.9	Coolant Flow	
	a. Flow Direction	Down flow
	b. Flow Induced by	Centrifugal pump x 3
	c. Normal flow Rate	6000 m ³ /hr

JMTR

d. Maximum Flow rate	6000 m ³ /hr
e. Mean Core Flow Velocity	10 m/sec
f. Normal Core Inlet Temperature	42 °C
g. Normal Core Temperature Rise (ΔT)	7.2 °C
h. Peak Coolant Temperature Rise (ΔT) at Hot Spot	
1. Without Hot Channel Factors	38 °C
2. With hot Channel factors	52 °C
i. Coolant Pressure at Core Outlet (Absolute)	11.7 kg/cm ²
j. Coolant Pressure at Hot Spot (Absolute)	
1. Without Hot Channel Factors	
2. With Hot Channel Factors	12.6 kg/cm ²
4.10 Hot Channel Factors (Including Only effects Other than Nuclear Peaking; Specify Breakdowns)	
a. For Coolant Temperature Rise	1.35
b. For Film Temperature Rise	1.70
c. Others	None
4.11 Core Heat Dissipation System	Primary coolant → Heat Exchanger → Secondary coolant → cooling tower (with cooling fan showering)
4.12 Shutdown Heat Removal System	Operating primary cooling system for about 5 hours
2. Worst Case Elapsed Time from Shutdown to Coolant Independence Without Fuel Distortion	
4.13 Emergency Core Cooling System	Emergency pump (500 m ³ /hr) driven by Diesel generator

5. NUCLEAR DATA5.1 Fuel Loading

- | | |
|---|-----------------------------|
| a. Minimum Critical Mass | Approx. 5 kg U-235 |
| b. Normal Core Loading
(Beginning of Cycle at Rated Power) | Approx. 6.6 kg U-235 |
| c. Maximum k excess Components | |
| 1. Temperature | 0.3 % $\Delta k/k$ |
| 2. Equilibrium Xenon | 4.1 % $\Delta k/k$ |
| 3. Equilibrium Samarium | |
| 4. Xenon Override | |
| 5. Burnup (Including Burnable Poison) | 5.3 % $\Delta k/k$ |
| 6. Experimental Sample | |
| 7. Others | 0.5 % $\Delta k/k$ |
| 8. Total | 10.2 % $\Delta k/k$ (limit) |
| d. Shutdown Margin | 0.81 (limit; 0.9) |

5.2 Reactivity Coefficients

- | | |
|---------------------|---|
| a. Temperature | |
| 1. Moderator | -3.1×10^{-2} % $\Delta k/k/^\circ C$ |
| 2. Doppler | |
| 3. Fuel Expansion | |
| 4. Burnable Poisons | |
| b. Void | -2×10^{-1} % $\Delta k/k/\%$ void |

5.3 Neutron Flux Densities

- | | |
|---------------------------------|--|
| a. Steady State Average Thermal | 2.6×10^{14} n/cm ² ·sec (in fuel region) |
| b. Steady State Peak Thermal | 3.6×10^{14} " " |
| c. Steady State Average Fast | 1.8×10^{14} " " |
| d. Steady State Peak Fast | 2.6×10^{14} " " |
| e. Peak Pulsing Power | Not applicable |
| f. Pulse Integrated Power | Not applicable |

5.4 Pulsing Characteristics

- | | |
|-----------------|----------------|
| a. Pulse Period | Not applicable |
|-----------------|----------------|

JMTR

b. Full Width at Half Maximum	Not applicable
c. Maximum Frequency of Pulses	Not applicable
5.5 Fission Density	
a. Normal Average	2.0×10^{15} fission/element
b. Peak	7.8×10^{15} fission/element
c. Axial Peak/Average Ratio for Typical Element	1.52
5.6 Maximum Fission Product Inventory	3.7×10^7 Ci/core
6. OPERATING EXPERIENCE	
6.1 Forced Outages per 100 Full Power Operating Hours Since Criticality	
a. Equipment Malfunction	0.199
b. Personnel Error	4.6×10^{-3}
c. Total	0.26
7. SAFEGUARDS	
7.1 Agency Responsible for Regulatory Jurisdiction	Nuclear Safety bureau, Science and Technology Agency
8. PAST MODIFICATIONS AND FUTURE PLANS	
8.1 Past Major Modifications	
a. Power Increase	None
b. Fuel Conversion	209 g U-235/element $\rightarrow$ 279 g U-235/element
c. Other	None
d. Date	Oct., 1971
8.2 Future Major Modifications	
a. Power Increase	None
b. Fuel Conversion	Increasing uranium content of fuel element
c. Decommissioning	None
d. Other	None
e. Date	After
8.3 Future Reactors	
a. Type	High Flux Material Testing Reactor
b. Date	After ten years

JMTR

Irradiation Facilities	Description	Dimensions (Sample max.) (in mm)	Neutron Flux (n/cm/sec)		Gamma Flux (Rad/hr)
			Thermal	Fast	
Beamports	None				
Converter Blocks	None				
Irradiation Racks	None				
Pneumatic Tubes					
Neutron Source	None				
Reactor Core	Water Loop x 2	118 ϕ x 750 1	0.3 ~ 1 x 10 ¹⁴	1 ~ 2 x 10 ¹³	
	Gas Loop	3.2 ϕ x 750 1	"	"	
	Neutron Control Facility	32 ϕ x 270 1	0.1 ~ 1 x 10 ¹⁴	0.3 ~ 3 x 10 ¹⁴	
	Hydraulic Rabbit x 2	26 ϕ x 120 1	1 x 10 ¹⁴	2 x 10 ¹³	
	Irradiation Holes	36 ϕ x 750 1	0.1 ~ 3 x 10 ¹⁴	0.1 x 20 x 10 ¹³	
Reactor Pool	None				
Thermal Column	None				

JMTR

9.1 REACTOR, LABORATORY, AND EXPERIMENTAL FACILITIES (Cont.d)

<u>Laboratory Facilities</u>	<u>Description</u>
<u>Accelerator</u>	<u>None</u>
<u>Critical Assemblies</u>	<u>Securing the operation of JMTR and making the core configuration to perform accurate irradiations in JMTR</u>
<u>Gamma Sources</u>	<u>Not applicable</u>
<u>Hot Cells</u>	<u>The hot laboratory of JMTR consists of a concrete hot cave line and a lead cell line. They are mainly used for dismounting irradi- ated capsules and for post-irradiation exami- nation of fuels and materials</u>
<u>Neutron Activation Analysis</u>	<u>None</u>
<u>Neutron Generator</u>	<u>None</u>
<u>Neutron Radiograph</u>	<u>None</u>
<u>Neutron Spectrometer</u>	<u>None</u>
<u>Radioisotope Laboratories</u>	<u>None</u>

RESEARCH AND TECHNICAL PROGRAM AND REACTOR UTILIZATION SUMMARY

10.1 Research, Technical, and Training Program

- 1) Water reactor safety research
- 2) Research and development of the Very High Temperature Reactor
- 3) Fuel and material irradiation for Fast Breeder Reactor and Advanced Thermal Reactor
- 4) Materials irradiation for reactor materials
- 5) R & D on materials for fusion reactor
- 6) Basic research on material science

10.2 Principal Isotopes Produced

JMTR produces many kinds of Radioisotope and supplies them for industrial and medical used in Japan. The major nuclides of Radioisotope are P-32, S-35, Cd-58, Ir-192, C-14, Mo-99, Tm-170, Cr-51, etc. Antimony is also irradiated to produce neutron sources for reactor start-up in various domestic nuclear plants.

JMTR

11. COMPUTER CODES UTILIZED IN DESIGN

11.1 Neutronics

PDQ, UGMG, THERMOS

11.2 Structural Design

a. Reactor Vessel

b. Fuel

c. Containment

11.3 Heat Transfer

12 DECOMMISSIONED FACILITY DATA

12.1 Facility Structural Condition

None

12.2 Maintenance and Surveillance Program

12.3 Types and Quantity of Contamination
Present

12.4 Types and Quantity of Stored Wastes
Present

12.5 Facility Radionuclide Inventory

12.6 Planned Interim Disposition of
Facility

12.7 Planned Ultimate Disposition of
Facility

12.8 Estimate Volume of Radioactive Waste
Generated by Decommissioning

13 FACILITY DESIGN AND OPERATION
REFERENCE DOCUMENTS

JAERI 1056 ; Conceptual Design of the Japan Materials Testing
Reactor




Fig. 1 JMTR Reactor Vessel




Fig. 2 JMTR Core Cross Section (Top View)