Mr. R. C. Haynes, Director
Office of Inspection & Enforcement, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

No. 3-81-22/3L

RECEIVED FEB 1 1982 U.S. NUCLEAR REGULATORY COMMISSION REGIONAL MAILROOM

Dear Mr. Haynes:

This LER deals with two out of calibration level switches determined during surveillance testing.

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 PAPBS3 (2) 00-0000000 (3) 4 1111 (4) (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — 57 CAT 58

CON'T
01 REPORT SOURCE (6) 05000-0278 (7) 122181 (8) 012082 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While at power, during surveillance testing, torus high level switches
03 3-23-91-A & B were determined to be out of calibration by one half inch. These
04 instruments are Robertshaw type 83035-A2. Safety significance is
05 minimal as instruments remained functional and were recalibrated immediately.
06 Applicable Tech Spec. is Table 3.2.B.
07
08

09 SYSTEM CODE SF (11) CAUSE CODE E (12) CAUSE SUBCODE B (13) COMPONENT CODE INSTRU (14) COMP. SUBCODE S (15) VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 — SEQUENTIAL REPORT NO. 022 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN E (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS C 000 (22) ATTACHMENT SUBMITTED N (23) NPRD-4 FORM SUB. Y (24) PRIME COMP. SUPPLIER A (25) COMPONENT MANUFACTURER R290 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause of the event was setpoint drift. These instruments were
11 recalibrated and returned to service within 30 minutes.
12
13
14

8202020359 820120
PDR ADOCK 05000278
S PDR

15 FACILITY STATUS E (28) % POWER 099 (29) OTHER STATUS (30) N/A — METHOD OF DISCOVERY B (31) DISCOVERY DESCRIPTION (32) Surveillance Test

16 ACTIVITY RELEASED Z (33) CONTENT OF RELEASE Z (34) AMOUNT OF ACTIVITY (35) N/A — LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES NUMBER 000 (37) TYPE Z (38) DESCRIPTION (39) N/A

18 PERSONNEL INJURIES NUMBER 000 (40) DESCRIPTION (41) N/A

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION (43) N/A

20 PUBLICITY ISSUED N (44) DESCRIPTION (45) N/A — NRC USE ONLY

NAME OF PREPARER: [signature] PHONE:

IE22