

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	J	O	C	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5	
LICENSEE CODE														LICENSE NUMBER						LICENSE TYPE					CAT 58			

0	1	L	6	0	5	0	0	0	2	1	9	7	1	2	3	0	8	1	8	0	1	2	6	8	2	9
REPORT SOURCE												DOCKET NUMBER					EVENT DATE					REPORT DATE				

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During surveillance testing Core Spray High Drywell Pressure Switches

0 3 | RV-46A, RV-46B and RV-46D were found to trip at 2.15, 2.30 and 2.20 psig

0 4 | respectively. These values are greater than the limit of 2.0 psig given

0 5 | in the Tech. Specs. Table 3.1.1 Item D.2. Safety significance was min-

C 6 | imized due to proper operation of switch RV-46C.

C 7 |

0 8 |

0	9	S	F	11	X	12	Z	13	I	N	S	T	R	U	14	S	15	Z	16
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE					
17	LER NO	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.									
33	18	8	1	0	6	9	0	3	L	0									
ACTION TAKEN		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER					
34	19	Z	20	Z	21	0	0	0	Y	23	Y	24	A	25	I	2	0	4	26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause was attributed to instrument repeatability. The switches

1 1 | were reset to trip within the 2.0 psig Technical Specification limit.

1 2 | Switch setpoint has subsequently been changed to reflect inherent

1 3 | design error. These switches will be replaced in a future refueling

1 4 | outage with an improved design.

5	G	28	0	0	0	29	NA	30	B	31	Surveillance Test	32
FACILITY STATUS		% POWER				OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		
6	Z	33	Z	34	NA	35	NA	36				
ACTIVITY CONTENT RELEASED		AMOUNT OF ACTIVITY		LOCATION OF RELEASE								
PERSONNEL EXPOSURES		DESCRIPTION		NA								
PERSONNEL INJURIES		DESCRIPTION		NA								
LOSS OF OR DAMAGE TO FACILITY		DESCRIPTION		NA								
PUBLICITY ISSUED		DESCRIPTION		NA								

8202040318 820126
PDR ADOCK 05000219
S PDR

NRC USE ONLY

Michael J. Fitzgerald

609-693-6038