

APPENDIX A

NOTICE OF VIOLATION

Georgia Power Company  
Vogtle 1 and 2

Docket Nos. 50-424 & 50-425  
License Nos. CPPR-108 & CPPR-109

As a result of the inspection conducted on November 17-19, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violation was identified.

10 CFR 50, Appendix B, Criterion V and the accepted quality assurance program (PSAR 17.1.5) require that activities affecting quality be accomplished in accordance with procedures. Procedure QA-04-12 requires the recipient of procedural changes to transmit a Statement of Receipt to corporate QA to verify receipt and filing of procedural changes thereby assuring that all controlled copy manual holders have the latest information.

Contrary to the above, corporate QA had no Statement of Receipt from controlled procedure manual holders No. 5, 6 and 7 for procedure changes to their QA Department Procedures Manual transmitted by amendment 20 dated 5/13/81. In addition, procedure manual No. 5 had not been updated since amendment 15.

This is a Severity Level VI Violation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

DEC 17 1981

Date: \_\_\_\_\_