

JANUARY 08 1982

Docket Nos. 50-259
50-260
50-296

Mr. Hugh G. Parris
Manager of Power
Tennessee Valley Authority
500A Chestnut Street, Tower II
Chattanooga, TN 37401

Dear Mr. Parris:

RE: STATUS OF NUREG-0737 ITEM II.F.1.3 AT BROWNS FERRY UNIT NOS. 1, 2 AND 3

NUREG-0737 Item II.F.1.3 states that high range radiation monitors, capable of functioning in an accident environment, shall be installed in each containment. Since a post-implementation review is planned, we are presently reviewing only deviations to the stated positions of NUREG-0737.

Based on our review of your submittals, no technical deviations from our stated positions were requested. If this understanding is not correct, we request formal notification of such within 30 days of receipt of this letter.

In the meeting with your staff on September 30, 1981 and in your letters of October 28, 1981, November 3, 1981 and November 20, 1981, you presented a schedule for completion of all NRC requested modifications. According to these schedules, the containment high range radiation monitors are scheduled to be installed in Units 1, 2 and 3 during the spring 1983, spring 1984, and fall 1983 refueling outages, respectively. As we have advised you in previous correspondence, the Commission is reviewing all requests by you and other licensees for delayed implementation of NUREG-0737 items. We will inform you as soon as we can of the decisions on schedule revisions.

Sincerely,

Original signed by
Thomas A. Ippolito, Chief
Operating Reactors Branch #2
Division of Licensing

8202080100 820108
PDR ADCK 05000259
P PDR

cc: See next page

Distribution:

Docket File	OELD	TERA
NRC PDR	IE (3)	ACRS (10)
Local PDR	R. Clark	Gray File
ORB#2 Reading	S. Norris	D. Verrelli
D. Eisenhower	NSIC	M. Fairtile

OFFICE	ORB#2	ORB#2	ORB#4	ORB#2		
SURNAME	SNorris	RClark:pbe	MFairtile	Tippolito		
DATE	12/28/81	12/28/81	12/28/81	12/28/81		



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 8, 1982

Docket Nos. 50-259
50-260
50-296

Mr. Hugh G. Parris
Manager of Power
Tennessee Valley Authority
500A Chestnut Street, Tower II
Chattanooga, TN 37401

Dear Mr. Parris:


RE: STATUS OF NUREG-0737 ITEM II.F.1.3 AT BROWNS FERRY UNIT NOS. 1, 2 AND 3

NUREG-0737 Item II.F.1.3 states that high range radiation monitors, capable of functioning in an accident environment, shall be installed in each containment. Since a post-implementation review is planned, we are presently reviewing only deviations to the stated positions of NUREG-0737.

Based on our review of your submittals, no technical deviations from our stated positions were requested. If this understanding is not correct, we request formal notification of such within 30 days of receipt of this letter.

In the meeting with your staff on September 30, 1981 and in your letters of October 28, 1981, November 3, 1981 and November 20, 1981, you presented a schedule for completion of all NRC requested modifications. According to these schedules, the containment high range radiation monitors are scheduled to be installed in Units 1, 2 and 3 during the spring 1983, spring 1984, and fall 1983 refueling outages, respectively. As we have advised you in previous correspondence, the Commission is reviewing all requests by you and other licensees for delayed implementation of NUREG-0737 items. We will inform you as soon as we can of the decisions on schedule revisions.

Sincerely,


Thomas A. Ippolito, Chief
Operating Reactors Branch #2
Division of Licensing

cc: See next page

Mr. Hugh G. Parris

cc:

H. S. Sanger, Jr., Esquire
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 33 C
Knoxville, Tennessee 37902

Mr. Ron Rogers
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Mr. H. N. Culver
249A HBD
400 Commerce Avenue
Tennessee Valley Authority
Knoxville, Tennessee 37902

Robert F. Sullivan
U. S. Nuclear Regulatory Commission
Route 2, Box 311
Athens, Alabama 35611

Athens Public Library
South and Forrest
Athens, Alabama 35611

Mr. John F. Cox
Tennessee Valley Authority
W9-D 207C
400 Commerce Avenue
Knoxville, Tennessee 37902

Mr. Herbert Abercrombie
Tennessee Valley Authority
P. O. Box 2000
Decatur, Alabama 35602