





Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 STA 3 UNIT 82 YEAR 1 NO.

PART 1 TITLE OF DEVIATION OCCURRED 1-3-82 0330 DATE TIME

Failure of the Seal on the Vacuum Breaker 3-1601-32B

SYSTEM AFFECTED 1600 PLANT STATUS AT TIME OF EVENT TESTING Pressure Suppression MODE Shutdown, PWR(MWT) 0, LOAD(MWE) 0 YES NO

DESCRIPTION OF EVENT The outside seal of the vacuum breakers positioning arm was found leaking during the local leak rate test of Vacuum Breaker 3-1601-32B. Leakage was 31.70 SCFH. Tech Spec limit is 29.38 SCFH.

EQUIPMENT FAILURE 17886 WORK REQUEST NO. RESPONSIBLE SUPERVISOR Ed Rowley DATE 1-5-81

PART 2 OPERATING ENGINEER'S COMMENTS The unit was in cold shutdown during the discovery of the excessive leakage. The seal will be repaired and retested prior to startup from refueling.

EVENT OF PUBLIC INTEREST, TECH. SPEC. VIOLATION, NON REPORTABLE OCCURRENCE, 14 DAY REPORTABLE/T.S., 30 DAY REPORTABLE/T.S. 6.6.B.2.d, ANNUAL/SPECL REPORT REQ'D, 24-HOUR NRC NOTIFICATION REQ'D, TELEPH Mike Jordan (courtesy) 1-5-82 1400, TELEGM/TELECOPY REGION III, CECO CORPORATE NOTIFICATION MADE, 5-DAY WRITTEN REPORT REQ'D PER 10CFR21, TELEPH F. A. Palmer 1-5-82 1512

PRELIMINARY REPORT COMPLETED AND REVIEWED Michael Wright 1-5-82 OPERATING ENGINEER DATE

INVESTIGATED REPORT & RESOLUTION ACCEPTED BY STATION REVIEW Jack D. Brunner 1/29/82 Michael Wright 2-1-82

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION Douglas Scott 2/1/82 STATION SUPERINTENDENT DATE