NRC FORM 366 (7.77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

	CONTROL BLOCK: []]] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	MI PA 11 200 0 - 0 0 0 - 0 3 4 1 1 1 1 4 57 CAT 58 5
CON'T	SOURCE L 6 0 5 0 0 2 5 5 7 0 1 0 5 8 2 8 0 2 0 3 8 2 9 9 9 9 9 9 9 9 9
0 2	When transferring electrical power from startup power to station power,
0 3	the closing spring charging motor for breaker 152-105 (station power trans-
0 4	former supply to 1C bus) failed to charge. The breaker was tripped open
0 5	and removed from its cubicle in order to permit repairs; as a result, the
0 6	station power transformer was inoperable with respect to supplying power
0 7	to bus 1C. Event reportable per TS 3.7.2a and 6.9.2.b(2). Both diesels
0 8	were operable. No freat to public health or safety.
<u>0</u> 9	CODE SUBCODE S
	TO REPORT VEAR REPORT NO. SEQUENTIAL REPORT NO. SODE TYPE NUMBER 21 22 23 24 26 27 28 29 30 31 32
	ACTION FUTURE COMPONENT NETHOD HOURS 22 ATTACHMENT SUBMITTED FORM SUB SUPPLIER MANUFACTURER AT 19 2 2 36 36 37 40 41 23 42 43 43
110	The breaker closing spring linkage was dirty, and required cleaning and
	lubrication. Concrete dust resulting from construction activities (seismic
1 2	anchorage of electrical equipment) is the suspected source.
1 3	
7 8	9 80 METHOD OF 80
1 5	F 28 10 14 7 29 Power Ascension A 30 Observation 32
	CONTINITY CONTENT ELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36 NA NA 44 45
1 7	PERSONNEL EXPOSURES NUMBER OF TYPE DESCRIPTION (39) NA
1 8	PERSONNEL INJURIES 13 NUMBER DESCRIPTION 4
7 8	9 11 12 LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION 43
7 8	Z 42 NA
20	PUBLICITY DESCRIPTION 45 NRC USE ONLY ISSUED DESCRIPTION 45 NRC USE ONLY 15SUED DESCRIPTION 65 NRC USE ONLY 15SUED DESCRIPTION 65 NRC USE ONLY 15SUED DESCRIPTION 65 NRC USE ONLY