

LICENSEE EVENT REPORT

CONTROL BLOCK: [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0][1] [N][J][S][G][S][1] [2] [0][0]-[0][0][0][0][0][0]-[0][0] [3] [4] [1][1][1][1] [4] [] [] [5]
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
[0][1] REPORT SOURCE [L] [6] [0][5][0][0][] [2][7][2] [7] [0][1][0][9][8][2] [8] [0][2][0][3][8][2] [9]
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0][2] On January 8, 1982 at 1500 hours, the No. 13 Charging Pump was declared inoperable
[0][3] due to the Component Cooling Water System being tagged out for planned maintenance.
[0][4] With Nos. 11 and 12 Charging Pumps being previously tagged out for planned
[0][5] maintenance, Action Statements 3.1.2.1 and 3.1.2.3 were entered. At 0110 hours,
[0][6] January 9, a sample of the primary coolant indicated a boron concentration of
[0][7] 1991 PPM. This change in boron concentration constituted a positive reactivity
[0][8] change. At 0110 hours, January 9, Action Statement 3.0.3 was entered.
7 8 9 80

[0][9] SYSTEM CODE [S][F] [11] CAUSE CODE [X] [12] CAUSE SUBCODE [Z] [13] COMPONENT CODE [P][U][M][P][X][X] [14] COMP. SUBCODE [E] [15] VALVE SUBCODE [Z] [16]
7 8 9 10 11 12 13 18 19 20
[17] LER NO REPORT NUMBER [8][2] [] [] [0][0][4] [] [0][3] [L] [] [0]
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN [X] [18] FUTURE ACTION [Z] [19] EFFECT ON PLANT [Z] [20] SHUTDOWN METHOD [Z] [21] HOURS [0][0][0][0] [22] ATTACHMENT SUBMITTED [Y] [23] NPD-4 FORM SUB. [N] [24] PRIME COMP. SUPPLIER [N] [25] COMPONENT MANUFACTURER [U][0][5][5] [26]
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1][0] Upon detection of the addition of positive reactivity, the operators initiated
[1][1] rapid boration of the Reactor Coolant System by temporarily operating the No. 13
[1][2] Charging Pump. A temporary hose connection was made to the No. 11 Component
[1][3] Cooling Water (CCW) Heat Exchanger to provide cooling water to the motor cooler
[1][4] on the No. 13 Charging Pump. At 2240 hours, January 9, Action Statements 3.1.2.1,
7 8 9 3.1.2.3 and 3.0.3 were terminated.
80

[1][5] FACILITY STATUS [H] [28] % POWER [0][0][0] [29] OTHER STATUS [N/A] [30] METHOD OF DISCOVERY [Z] [31] N/A DISCOVERY DESCRIPTION [] [32]
7 8 9 10 17 13 44 45 46 80

[1][6] ACTIVITY CONTENT RELEASED OF RELEASE [Z] [33] [Z] [34] AMOUNT OF ACTIVITY [N/A] [35] LOCATION OF RELEASE [N/A] [36]
7 8 9 10 11 44 45 80

[1][7] PERSONNEL EXPOSURES NUMBER [0][0][0] [37] TYPE [Z] [38] DESCRIPTION [N/A] [39]
7 8 9 11 12 13 80

[1][8] PERSONNEL INJURIES NUMBER [0][0][0] [40] DESCRIPTION [N/A] [41]
7 8 9 11 12 80

[1][9] LOSS OF OR DAMAGE TO FACILITY TYPE [Z] [42] DESCRIPTION [N/A] [43] 8202160244 820203 PDR ADOCK 05000272 S PDR
7 8 9 10 80

[2][0] PUBLICITY ISSUED [N] [44] DESCRIPTION [N/A] [45] NRC USE ONLY
7 8 9 10 68 69 80

NAME OF PREPARER Frank Dickey

PHONE 609-935-0998