

APPENDIX A

NOTICE OF VIOLATION

Georgia Power Company
A. W. Vogtle 1 & 2

Docket Nos. 50-424 & 50-425
License Nos. CPPR-108 & 109

As a result of the inspection conducted on November 5 - December 11, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violation was identified.

As required by 10 CFR 50 Appendix B, Criterion XIII and implemented by Georgia Power Company PSAR Section 17, which states in part, "measures shall be established to control the handling, storage, shipping, cleaning and preservation of material and equipment in accordance with work and inspection instructions to prevent damage or deterioration."

Contrary to the above, activities affecting quality were not accomplished in accordance with established procedures in that on December 7, 1981 an inspection disclosed that 14 of 22 items of equipment were installed or stored in the unit 1 and 2 auxiliary building without the required protection maintained for the prevention of damage or deterioration.

This is a Severity Level V Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Date: DEC 28 1981