

Harry Tauber  
Vice President  
Engineering and Construction

Detroit  
Edison

2000 Second Avenue  
Detroit, Michigan 48226  
(313) 237-8000

January 22, 1982  
EF2 - 56,332

Mr. L. L. Kintner  
U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Division of Licensing  
Washington, D. C. 20555



Dear Mr. Kintner:

- References:
1. Enrico Fermi Atomic Power Plant, Unit 2  
NRC Docket No. 50-341
  2. Diesel Engine Lubrication, EF2-54,624,  
August 31, 1981

Subject: Diesel Engine Lubrication Modifications

Detroit Edison provided a Colt Industries Engineering Report as part of Reference 2. This report was specific to Alabama Power, but it is applicable to Fermi 2. The modifications to the Fermi 2 EDGs are functionally identical to those described for Alabama Power. However, the heater and pump are powered with 480 Volts at Fermi 2, while Alabama Power uses 208 Volts. Also, the 480 Volt power and the specific model numbers for the electrical components used for Fermi 2 are different than those for Alabama Power.

Should you have any further questions, please contact L. E. Schuerman, (313) 649-7562.

Sincerely,

A handwritten signature in cursive script that reads "Harry Tauber".

cc: Mr. B. Little

Boo'  
s/  
1/0